

-DRAFT-

PROJECT STATUS MEMORANDUM

NO. 05-08

TO: Pamela Tames, USEPA

FROM: Mark M. Goldberg, P.E.
Tunde H. Komuves-Sandor

DATE: July 18, 2008

PROJECT: Rowe Industries Superfund Site
Ground-Water Recovery and Treatment System
May 2008 Status Report
Sag Harbor, New York

LBG Engineering Services, P.C. (LBG) commenced operation of the ground-water remediation system at the above-referenced site on December 17, 2002. This status report presents a summary of system performance, operation and maintenance, and monitoring activities for the site from May 1, 2008 through May 31, 2008. The report includes a summary of system performance parameters, system operation parameters, and analytical results for ground water, system effluent samples, and air quality results.

SUMMARY OF SYSTEM PERFORMANCE AND OPERATION

(May 1, 2008 through May 31, 2008)

- | | |
|---|----------------------------------|
| 1. Hours of operation during the reporting period: | 663 hours (89%) |
| 2. Alarm conditions during the reporting period: | See Table 1 |
| 3. Was the SPDES VOC discharge permit criteria achieved: | yes, (Table 2) |
| 4. Total volume of water pumped during the reporting period: | 11,847,967 gal. |
| 5. Was the system effluent flow below the SPDES limit of 1,023,000 gpd: yes, (Graph 1) | |
| 6. Mass of VOCs recovered during the reporting period: | 0.5 pounds |
| 7. Cumulative mass of VOCs recovered since startup on 12/17/02:
(calculations can be provided upon request) | 210.7 pounds |
| 8. Effluent VOC vapor concentration for the reporting period: | 0.08 mg/m ³ (Table 3) |
| 9. Was the effluent VOC vapor emission rate below 0.022 lbs/hr.:
(calculations can be provided upon request) | yes (0.00071 lbs/hr) |

GROUND-WATER RECOVERY SYSTEM STATUS SUMMARY

The following table summarizes select recovery well parameters for the reporting period. Table 4 presents a summary of the quality results for water samples collected from recovery wells. Graph 2 presents PCE concentrations for each recovery well. For wells with water quality that meets or is approaching remedial criteria, Graph 3 presents PCE concentrations at an expanded scale in order to compare them to the PCE aquifer restoration concentration of 5 ug/L. Laboratory analytical reports are included as Appendix I.

Well	Volume pumped (gal)	Average Flow (gpm)	Lowest Measured Flow (gpm) ¹	Total VOC Concentration (µg/L)	VOC Recovery (lbs)
RW-2	1,155,831	27	13	4.7	0.05
RW-3 ³	5,519	35	10	0	0
RW-4	12,318	11 ⁴	10	11.2	0.001
RW-5	2,311,648	50	50	0	0
RW-6	527,747	15	15	23.5	0.1
RW-7	2,311,550	70	69	11.2	0.22
RW-8	2,121,973	54	41	2.5	0.04
RW-9 ²	2,985,345	75	16	0	0

¹Lowest measured flows are based on the lowest average 24-hour pumping rates for each well recorded to date.

²On May 24, 2008 the RW-9 flow meter totalizer malfunctioned, the average flow and the hours of operation were used to calculate the volume pumped.

³ RW-3 was restarted on May 27, 2008 at 1:32 PM for sampling purposes and was shut down on May 27, 2008 at 5:47 PM.

⁴ RW-4 was temporarily shut down on May 1, 2008 due to very low and variable flow caused by iron fouling and shall be restarted following well rehabilitation, which is scheduled for the beginning of June.

Based on the results of the updated ground-water model for the site, the plume is not migrating beyond the influence of the FSP&T system if the recovery well pumps operate at or above the “Lowest Measured Flows”. Although RW-4 was not operating, it is anticipated that contaminants near RW-4 would be captured and recovered by the downgradient recovery wells based on capture zone maps from the semi-annual ground-water elevation monitoring and supported by the updated ground-water model discussed in the 2006 Annual Report for the site. All other wells were at or above their lowest measured flow when they were operating.

BAG FILTER STATUS

The following table presents an operational summary of the bag filter usage and configuration for the reporting period.

Dates	Bank 1	Bank 2	Bank 3
May1 to 31	7 of 8 housings used with 400 micron bag filters	7 of 8 housings used with 400 micron bag filters	Not active

No modifications were made to the filter bank configuration or operation during this reporting period.

OTHER O&M ACTIVITIES AND FUTURE O&M ACTIVITIES

Other O&M activities conducted in May 2008 include:

- On May 1, 2008, measure RW-4 was shutdown as a preventative to avoid damaging the pump and motor due to very low and inconsistent flow most likely caused by iron fouling. RW-4 will be restarted following well rehabilitation which is scheduled for June 2008.

Future O&M activities scheduled for the summer of 2008 include:

- Continue to evaluate the effect on contaminant concentrations in RW-2 when RW-3 is not operating; and
- Conduct recovery well rehabilitation and FSP&T system maintenance.

MMG:nv

Attachments

cc: Jeff Srulovitz - Kraft Foods Global, Inc. - .pdf
Lisa Krogman, Environ – .pdf
Jeff Trad, NYSDEC – .pdf
Chief-Operation Maintenance and Support Section, NYSDEC – .pdf
William Spitz, RWM, R-1, NYSDEC
Garrett W. Swensen Jr., Esq., Town of Southampton

TABLES

TABLE 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

MAINTENANCE LOG
(May 1, 2008 through May 31, 2008)

Date	Time	System Changes/Modifications	Personnel
5/1/2008	2:01 PM	Booster blower failure alarm likely caused by power fluctuations, system shut down.	
	5:45 PM	Reset motor starter, acknowledged alarms and restarted system.	JF
5/6/2008		Changed multi-bag filter bags (400 mm) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	SH
5/15/2008		Changed multi-bag filter bags (400 mm) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	SH
5/16/2008	11:26 AM	System communication failure, system shut down.	
	4:10 PM	Rebooted computer, reset alarms and restarted system.	JF
5/20/2008		Changed multi-bag filter bags (400 mm) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	SH
5/24/2008	1:31 PM	Booster blower failure alarm likely caused by power fluctuations, system shut down.	
5/27/2008		Changed multi-bag filter bags (400 mm) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	SH
	1:32 PM	Reset motor starter, acknowledged alarms and restarted system.	SH

TABLE 2

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

EFFLUENT WATER QUALITY RESULTS

Date Sampled ^{2/}	pH ^{1/}	TDS (mg/l)	PCE (ug/l)	1,1,1-TCA (ug/l)	TCE (ug/l)	1,1-DCA (ug/l)	1,1-DCE (ug/l)	1,2-DCE (ug/l)	Xylene (ug/l)	Bromoform (ug/l)	Dibromo- chloromethane (ug/l)	Methylene Chloride (ug/l)	Freon 113 (ug/l)	Acetone (ug/l)	Chloroform (ug/l)	MTBE (ug/l)	Total Iron (mg/l)	Dissolved Iron (mg/l)
SPDES Limits	5.0 to 8.5	---	5	5	5	5	5	5	5	---	---	5	---	50	7	---	---	---
6-May-08	6.39	112	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	0.085	0.106
15-May-08	6.51	108	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	1.09	0.100
20-May-08	5.55	108	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	0.985	0.090
27-May-08	6.61	108	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	1.63	0.147

SPDES: State Pollutant Discharge Elimination System

mg/l: Milligrams per liter

ug/l: Micrograms per liter

---: Not established

J: Analyte detected below quantitation limits

NM: Not Measured

TDS: Total dissolved solids

PCE: Tetrachloroethylene

TCE: Trichloroethylene

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

1,2-DCE: 1,2-Dichloroethene

MTBE: Methyl tert-butyl ether

Notes:

1. Based on the new SPDES criteria from an NY SDEC letter dated on May 11, 2006, the new allowable pH range for the Rowe Site is between 5.0 and 8.5.

The pH was measured with a calibrated electronic pH meter. Influent pH values from recovery wells typically range between 5 and 7.

2. "Effluent" samples were collected from sample port labeled NP2-10 unless otherwise noted.

TABLE 3

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

CARBON UNIT SYSTEM AIR QUALITY RESULTS

Precarbon			Parameters (mg/m3)																				TOTAL VOCs		
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CE	CT	DCP	
AQ050107:1100NP4-1	5/12/2007	11:00	0.13	0.0065	0.082	0.0033	0.017	ND	0.0020	0.00088	ND	ND	ND	0.0055	0.0021	0.003	0.0046	ND	ND	ND	ND	ND	ND	ND	ND
AQ060707:1030NP4-1	6/7/2007	10:30	0.1	0.0048	0.046	ND	0.0075	ND	0.0023	ND	ND	ND	ND	0.0045	0.0012	0.0018	0.0064	ND	ND	ND	ND	ND	ND	ND	ND
AQ070507:1100NP4-1	7/5/2007	11:00	0.18	0.0067	0.044	0.0021	0.0094	ND	0.0027	ND	ND	ND	ND	0.0046	0.0019	0.0064	0.0064	ND	ND	ND	ND	ND	ND	ND	ND
AQ080807:1100NP4-1	8/8/2007	11:00	0.0028 ^B	0.0072	ND	ND	ND	ND	0.0027	0.0029	ND	ND	ND	ND	0.0028 ^B	0.0025	0.021	ND	ND	ND	ND	ND	ND	ND	ND
AQ091207:1100NP4-1	9/12/2007	11:00	0.370	0.0031	0.027	ND	0.0077	ND	0.11	ND	ND	ND	ND	0.0047	0.0031	0.002	0.11	ND	ND	ND	0.0015 ^B	ND	ND	ND	ND
AQ100307:900NP4-1	10/3/2007	9:00	0.200	0.0080	0.05	0.004	0.016	ND	0.0026	0.0012	ND	ND	ND	0.0061	ND	0.0074	0.0074	ND	ND	ND	ND	ND	ND	ND	ND
AQ112807:900NP4-1	11/28/2007	9:00	0.110	0.0046	0.034	0.0037	0.013	0.0023	0.0022	0.001	ND	ND	ND	0.0062	0.0018 ^B	0.002	0.0061	ND	ND	ND	ND	ND	ND	ND	ND
AQ121207:900NP4-1	12/12/2007	9:00	0.090	0.0047	0.040	0.0021	0.015	ND	0.0023	ND	ND	ND	ND	0.0058	0.0011	ND	0.0022	ND	ND	ND	ND	ND	ND	ND	ND
AQ11608:900NP4-1	1/16/2008	9:00	0.032	ND	0.022	ND	0.0079	ND	ND	ND	ND	ND	ND	0.0025	0.04	ND	0.0013	ND	ND	ND	ND	ND	ND	ND	ND
AQ021308:1100NP4-1	2/13/2008	11:00	0.063	0.0037	0.025	0.0022	0.012	ND	0.0027	ND	ND	ND	ND	0.0047	0.0021 ^B	0.0025	0.0034	ND	ND	ND	ND	ND	ND	ND	ND
AQ032708:1220NP4-1	3/27/2008	12:20	0.069	0.0039	0.042	0.0031	0.018	ND	0.0022	ND	ND	ND	ND	0.0073	0.0032	0.002	0.002	ND	ND	ND	ND	ND	ND	ND	ND
AQ042208:1030NP4-1	4/22/2008	10:30	0.110	0.0055	0.027	0.0024	0.012	0.0023	0.0034	0.0013	ND	ND	ND	0.0053	0.0052 ^B	0.0031	0.0028	ND	ND	ND	ND	ND	ND	ND	ND
AQ052708:1700NP4-1	5/27/2008	17:00	0.077	0.0045	0.028	0.0027	0.010	ND	0.0012	ND	ND	ND	ND	0.0062	0.0030 ^B	0.0034	0.0079	ND	ND	ND	ND	ND	ND	ND	ND
Midcarbon			Parameters (mg/m3)																				TOTAL VOCs		
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CE	CT	DCP	
AQ050107:1105NP4-2	5/12/2007	11:05	0.0036	0.001	0.083	0.0030	0.013	0.003	0.0017	ND	ND	ND	ND	0.0047	0.002 ^B	0.0027	0.0036	ND	ND	ND	ND	ND	ND	ND	ND
AQ060707:1055NP4-2	6/7/2007	10:55	0.0052	0.002	0.058	ND	0.0096	ND	0.0023	ND	0.0013	ND	ND	0.004	0.0014	ND	0.006	ND	ND	ND	ND	ND	ND	ND	ND
AQ070507:1105NP4-2	7/5/2007	11:05	0.0018	0.001	0.066	ND	0.0084	ND	0.0018	ND	ND	ND	ND	0.0038	0.0019 ^B	ND	0.0071	ND	ND	ND	ND	ND	ND	ND	ND
AQ080807:1105NP4-2	8/8/2007	11:05	1.3 ^B	0.120	0.33	0.0053	0.035	0.0068	0.0092	0.0049	0.0028	ND	ND	0.016	0.0026 ^B	0.0018	0.02	ND	ND	ND	ND	ND	0.0028	0.0012	0.56
AQ091207:1105NP4-2	9/12/2007	11:05	1.8	0.051	0.100	0.0040	0.020	ND	0.029	0.0035	ND	ND	ND	0.0075	0.0042	0.0029	0.025	ND	ND	ND	0.0011	ND	ND	ND	2.05
AQ100307:905NP4-2	10/3/2007	9:05	0.220	0.018	0.054	0.0017	0.015	ND	0.0014	0.00093	ND	ND	ND	0.0053	0.0014	ND	0.01	ND	ND	ND	0.0012 ^B	ND	ND	ND	0.33
AQ112807:905NP4-2	11/28/2007	9:05	0.086	0.011	0.072	0.0038	0.015	ND	0.0014	ND	ND	ND	ND	0.0056	0.0019 ^B	0.0051	0.0051	ND	ND	ND	ND	ND	ND	ND	0.20
AQ121207:905NP4-2	12/12/2007	9:05	0.250	0.025	0.086	0.0023	0.017	ND	0.010	0.00095	ND	ND	ND	0.0064	0.0014	ND	0.0024	ND	ND	ND	ND	ND	ND	ND	0.40
AQ11608:905NP4-2	1/16/2008	9:05	0.210	0.007	0.079	ND	0.015	ND	ND	ND	ND	ND	ND	0.0066	ND	ND	0.0024	ND	ND	ND	ND	ND	ND	ND	0.32
AQ021308:1105NP4-2	2/13/2008	11:05	0.029	0.004	0.066	0.0026	0.017	0.0014	0.002	ND	ND	ND	ND	0.0059	0.0032 ^B	0.0044	0.0035	ND	ND	ND	ND	ND	ND	ND	0.14
AQ032708:1225NP4-2	3/27/2008	12:25	0.240	0.007	0.039	0.0032	0.014	ND	0.0033	ND	ND	ND	ND	0.006	0.0046	0.0034	0.0021	ND	ND	ND	ND	ND	ND	ND	0.32
AQ042208:1035NP4-2	4/22/2008	10:35	0.025	0.052	0.040	0.0033	0.015	ND	0.0036	0.00120	0.0042	ND	ND	0.0057	0.0061 ^B	0.0030	0.0047	ND	ND	ND	ND	ND	ND	ND	0.16
AQ052707:1705NP4-2	5/27/2008	17:05	0.044	0.008	0.081	0.0042	0.021	ND	0.0010	ND	ND	ND	ND	0.0098	0.0054 ^B	0.0024	0.0081	ND	ND	ND	ND	ND	ND	ND	0.18
Postcarbon			Parameters (mg/m3)																				TOTAL VOCs		
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CE	CT	DCP	
AQ050107:1110NP4-3	5/12/2007	11:10	ND	ND	0.12	0.0026	0.0078	0.007	0.0089	ND	ND	ND	ND	0.0047	0.005 ^B	0.003	0.0038	ND	ND	ND	ND	ND	ND	ND	ND
AQ060707:1100NP4-3	6/7/2007	11:00	ND	0.067	0.067	0.0020	0.0092	0.0045	0.002	ND	0.0023	ND	ND	0.0035	0.0011	ND	0.0052	ND	ND	ND	ND	ND	ND	ND	0.16
AQ070507:1100NP4-3	7/5/2007	11:10	ND	ND	0.110	0.0033	0.015	0.0064	0.0016	ND	ND	ND	ND	0.006	0.0019 ^B	ND	0.0062	ND	ND	ND	ND	ND	ND	ND	0.10
AQ080807:1100NP4-3	8/8/2007	11:10	0.013 ^B	0.0015	0.190	0.0063	0.029	0.011	0.41	0.0018	ND	ND	ND	0.011	0.0047 ^B	0.0037	0.019	ND	ND	ND	ND	ND	ND	ND	0.15
AQ091207:1100NP4-3	9/12/2007	11:10	ND	ND	0.033	ND	0.0061	0.0028	0.0028	ND	ND	ND	ND	0.0028	0.0013	ND	0.0099	ND	ND	ND	0.00092	ND	ND	ND	0.06
AQ100307:910NP4-3	10/3/2007	9:10	ND	ND	0.044	ND	0.0076	0.0021	0.0033	ND	ND	ND	ND	0.003	0.0012	ND	0.008	ND	ND	ND	ND	ND	ND	ND	0.07
AQ112807:910NP4-3	11/28/2007	9:10	ND	ND	0.11	0.0030	0.014	0.0022	0.0015	ND	ND	ND	ND	0.0045	0.0018 ^B	0.0061	0.0061	ND	ND	ND	ND	ND	ND	ND	0.14
AQ121207:910NP4-3	12/12/2007	9:10	ND	ND	0.16	0.0033	0.025	0.003	0.0012	ND	ND	ND	ND	0.007	ND	ND	0.0028	ND	ND	ND	ND	ND	ND	ND	0.20
AQ11608:910NP4-3	1/16/2008	9:10	ND	ND	0.14	0.0025	0.022	ND	0.0032	ND	ND	ND	ND	0.0082	ND	ND	0.0034	ND	ND	ND	0.0011	ND	ND	ND	0.18
AQ021308:1100NP4-3	2/13/2008	11:10	ND	ND	0.12	0.0029	0.018	0.0019	0.0022	ND	ND	ND	ND	0.007	0.0023	0.0025	0.0038	ND	ND	ND	ND	ND	ND	ND	0.16
AQ032708:1230NP4-3	3/27/2008	12:30	ND	ND	0.063	0.0036	0.014	ND	0.0019	ND	ND	ND	ND	0.006	0.0029	0.0026	0.0023	ND	ND	ND	ND	ND	ND	ND	0.10
AQ042208:1040NP4-3	4/22/2008	10:40	ND	ND	0.030	0.0020	0.0073	0.0035	0.0025	0.00099	ND	ND	ND	0.0034	0.0055 ^B	0.0024	0.0036	ND	ND	ND	ND	ND	ND	ND	0.05
AQ052707:1708NP4-3	5/27/2008	17:08	ND	ND	0.045	0.0039	0.013	0.0014	0.0025	ND	ND	ND	ND	0.0057	0.0088 ^B	0.0027	0.0046	ND	ND	ND	ND	ND	ND	ND	0.08

Note: B Method blank contamination. The associated method blank contains the target analyte at a reportable level.

PCE - Tetrachloroethane
 TCE - Trichloroethane
 TCA - 1,1,1-Trichloroethane
 CE - Chloroethane
 DCE - 1,1-Dichloroethane
 DCA - 1,1-Dichloroethane
 cis-DCE - cis-1,2-Dichloroethane
 CT - Carbon Tetrachloride
 CF - Chloroform
 MC - Methylene Chloride
 CM - Chloromethane
 CD - Carbon Disulfide
 BM - Bromomethane
 CB - Chlorobenzene
 EB - Ethylbenzene
 VC - Vinyl Chloride
 DCP - 1,2-Dichloropropane

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloroethane (ug/L)	cis-1,2-Dichloroethene (ug/L)	1,1-Dichloroethene (ug/L)	Methylene Chloride (ug/L) ^{1/}	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L) ^{1/}	
RW-1	15-Sep-04	ND<1	ND<1	5	NE	2.8	NE	300	ND<0.02	ND<1	5	ND<1	5	NE	NE	ND<2	ND<1	ND<1	NE	
	7-Oct-04	ND<1	ND<1	ND<1	ND<1	7	ND<1	0.0865	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	3-Nov-04	ND<1	ND<1	ND<1	ND<1	2.0	2.0	0.0133	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	15-Dec-04	ND<1	ND<1	ND<1	ND<1	9.8	2.0	0.0475	0.0229	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	13-Jan-05	ND<1	ND<1	ND<1	ND<1	1.5	2.1	0.0703	0.0326	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	8-Feb-05	ND<1	ND<1	ND<1	ND<1	4.6	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	15-Mar-05	ND<1	ND<1	ND<1	ND<1	2.5	ND<1	0.0285	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	19-Apr-05	ND<1	ND<1	ND<1	ND<1	1.5	ND<1	0.0357	0.0217	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	2-May-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	16-Jun-05	ND<1	ND<1	ND<1	ND<1	4.0	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	14-Jul-05	ND<1	ND<1	ND<1	ND<1	2.1	ND<1	0.0289	ND<0.02	ND<1	ND<1	ND<1	8.4 ^{1/}	ND<1	ND<1	3.3	1.3	1	6.9 ^{1/}	
	7-Mar-06	ND<1	ND<1	ND<1	ND<1	5.2	ND<1	0.1650	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	19-Sep-06	ND<1	ND<1	ND<1	ND<1	1.7	ND<1	NA	NA	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	7-Mar-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	NA	NA	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	3-Oct-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	NA	NA	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	13-Mar-08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	NA	NA	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
RW-2	17-May-06	19.0	5.1	ND<1	ND<1	ND<1	ND<1	5.95	0.063	ND<1	14.0	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	21-Jun-06	13.0	3.0	25	ND<1	ND<1	ND<1	3.57	0.093	ND<1	5.0	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	20-Jul-06	8.0	3.4	60	ND<1	ND<1	ND<1	4.49	0.177	ND<1	7.5	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	24-Aug-06	11.0	1.1	25	ND<1	ND<1	ND<1	4.14	0.0172	ND<1	5.7	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	19-Sep-06	2.8	ND<1	200	ND<1	ND<1	ND<1	13.7	0.0184	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	24-Oct-06	5.0	1.6	160	ND<1	ND<1	ND<1	3.6	0.00756	ND<1	3.6	0.91	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	29-Nov-06	6.0	1.8	36	ND<1	ND<1	ND<1	14.1	0.0148	ND<1	3	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	20-Dec-06	2.2	ND<1	110	ND<1	ND<1	ND<1	11.8	0.0197	ND<1	2.8	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	10-Jan-07	4.2	2.7	68	ND<1	ND<1	ND<1	2.77	0.458	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	8-Feb-07	3.4	2.4	62	ND<1	ND<1	ND<1	8.72	0.00829	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	7-Mar-07	ND<1	ND<1	31	ND<1	ND<1	ND<1	4.28	0.107	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	18-Apr-07	3	1.7	23	ND<1	ND<1	ND<1	3.81	0.32	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	10-May-07	ND<1	ND<1	26	ND<1	ND<1	ND<1	3.04	0.00589	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	15-Jun-07	1.1	1.2	ND<1	ND<1	ND<1	ND<1	2.7	0.0392	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	18-Jul-07	1.2	0.78	17	ND<1	ND<1	ND<1	2.26	0.198	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	16-Aug-07	0.75	ND<1	10	ND<1	ND<1	ND<1	3.92	0.157	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	12-Sep-07	1.6	ND<1	1.2	ND<1	ND<1	ND<1	1.76	0.232	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	3-Oct-07	1.4	ND<1	1.2	ND<1	ND<1	ND<1	1.9	1.28	ND<1	0.65	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	19-Nov-07	5.6	ND<1	ND<1	ND<1	ND<1	ND<1	2.18	0.0132	ND<1	1.6	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	12-Dec-07	2.2	0.86	8.3	ND<1	ND<1	ND<1	5.55	0.0186	ND<1	0.61	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	16-Jan-08	2	ND<1	5.9	ND<1	ND<1	ND<1	3.09	0.185	0.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	13-Feb-08	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	10-Mar-08	1.9	ND<1	5.6	ND<1	ND<1	ND<1	2.74	0.0592	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	17-Apr-08	1.6	ND<1	4.1	ND<1	ND<1	ND<1	2.83	0.252	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	27-May-08	1.8	ND<1	2.9	ND<1	ND<1	ND<1	3.00	0.838	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L) ^{1/}	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L) ^{1/}
RW-3	ARAR's	5	5	5	NE	7	NE	300	300	5	5	5	5	NE	NE	ND-2	ND-1	ND-1	NE
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.06	0.353	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	21-June-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Jul-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Aug-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Sep-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Oct-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	29-Nov-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Dec-06	6.4	ND<1	4.4	ND<1	ND<1	ND<1	2.36	0.053	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-Jan-07	1.2	ND<1	3.5	ND<1	ND<1	ND<1	1.87	1.63	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-07	ND<1	3.2	ND<1	ND<1	ND<1	ND<1	ND<0.02	2.16	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.09	1.65	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	18-Apr-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.24	0.761	ND<1	ND<1	ND<1	6.1*	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-May-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.89	1.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Jun-07	0.91	8.5	ND<1	ND<1	ND<1	ND<1	2.48	0.19	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-Jul-07	ND<1	2.8	1.2	ND<1	ND<1	ND<1	2.36	0.0414	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Aug-07	ND<1	1.2	0.72	ND<1	ND<1	ND<1	2.95	1.16	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Sep-07	ND<1	1.6	ND<1	ND<1	ND<1	ND<1	2.20	1.49	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Oct-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.46	2.16	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Nov-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.70	0.971	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Dec-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jan-08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.73	0.229	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-Feb-08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.88	1.09	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-Mar-08	ND<1	2.2	0.8	ND<1	ND<1	ND<1	2.23	2.08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	17-Apr-08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	4.27	1.94	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	27-May-08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.08	1.61	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-4	17-May-06	26	ND<1	ND<1	ND<1	ND<1	ND<1	3.15	0.109	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	21-Jun-06	23	ND<1	8.4	ND<1	ND<1	ND<1	9.23	0.086	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Jul-06	14	ND<1	9.4	ND<1	ND<1	ND<1	4.10	0.155	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Aug-06	23	ND<1	ND<1	ND<1	ND<1	ND<1	8.60	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Sep-06	9	ND<1	7.5	ND<1	ND<1	ND<1	5.95	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Oct-06	11	ND<1	5.6	ND<1	ND<1	ND<1	7.17	0.0178	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	29-Nov-06	14	ND<1	ND<1	ND<1	ND<1	ND<1	2.82	0.00708	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Dec-06	6.4	ND<1	4.4	ND<1	ND<1	ND<1	17.30	0.0112	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-Jan-07	12	ND<1	4.6	ND<1	ND<1	ND<1	3.17	0.0794	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	4.2	ND<1
	8-Feb-07	13	ND<1	3.3	ND<1	ND<1	ND<1	3.64	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-07	7.3	ND<1	2.1	ND<1	ND<1	ND<1	3.85	0.0767	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	18-Apr-07	10	ND<1	ND<1	ND<1	ND<1	ND<1	4.46	0.251	ND<1	ND<1	ND<1	7.2*	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-May-07	11	ND<1	ND<1	ND<1	ND<1	ND<1	3.67	0.0422	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Jun-07	5.3	ND<1	0.89	ND<1	ND<1	ND<1	3.73	0.048	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Jul-07	6.9	ND<1	3.3	ND<1	ND<1	ND<1	6.58	3.37	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Aug-07	5.8	ND<1	5.0	ND<1	ND<1	ND<1	4.44	0.213	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Sep-07	7	ND<1	6.3	ND<1	ND<1	ND<1	4.02	1.73	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Oct-07	9.4	1.1	10.0	ND<1	ND<1	ND<1	5.04	3.1	0.68	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Nov-07	15	1.3	8.2	ND<1	ND<1	ND<1	3.73	0.0317	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Dec-07	7.7	ND<1	4.6	ND<1	ND<1	ND<1	4.47	2.34	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jan-08	7.9	ND<1	4.2	ND<1	ND<1	ND<1	4.67	0.954	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-Feb-08	2.1	ND<1	ND<1	ND<1	ND<1	ND<1	8.28	0.371	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-Mar-08	6.5	0.57	3.0	ND<1	ND<1	ND<1	4.96	1.94	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	17-Apr-08	6.1	ND<1	2.6	ND<1	ND<1	ND<1	5.86	0.96	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	27-May-08	9.9	1.3	ND<1	ND<1	ND<1	ND<1	6.13	4.14	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (ug/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L) ^{1/}	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L) ^{1/}
RW5	17-May-06 ARAR's	5	5	5	NE	7	NE	300	300	5	5	5	5	NE	NE	NE	NE	NE	NE
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.016	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	21-Jun-06	2.4	ND<1	2.6	ND<1	ND<1	ND<1	0.195	0.012	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Jul-06	1.3	ND<1	3.1	ND<1	ND<1	ND<1	0.184	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Aug-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.09	0.0116	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Sep-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.194	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Oct-06	1.1	ND<1	1.3	ND<1	ND<1	ND<1	0.0683	0.00684	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	29-Nov-06	6	ND<1	1.3	ND<1	ND<1	ND<1	0.136	0.0195	ND<1	ND<1	ND<1	ND<1	0.96	ND<1	ND<2	ND<1	ND<1	ND<1
	29-Dec-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.508	0.0113	ND<1	ND<1	ND<1	ND<1	2.8	ND<1	ND<2	ND<1	ND<1	ND<1
	10-Jan-07	1.2	ND<1	ND<1	ND<1	ND<1	1.2	0.0608	0.0128	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	12	ND<1	3.9	ND<1
	8-Feb-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.327	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0655	0.00722	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Apr-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.973	0.0106	ND<1	ND<1	ND<1	8.1*	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-May-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0763	0.00469	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Jun-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.118	0.00747	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Jul-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.395	0.0889	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Aug-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0450	0.008	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Sep-07	ND<1	ND<1	ND<1	ND<1	0.6	ND<1	0.0460	0.008	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	3-Oct-07	ND<1	ND<1	ND<1	ND<1	0.81	0.7	0.0600	0.350	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Nov-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.1330	0.022	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Dec-07	ND<1	ND<1	0.61	ND<1	0.65	ND<1	0.0366	0.014	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jan-08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0732	0.0441	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	13-Feb-08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.3680	0.0121	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-Mar-08	ND<1	ND<1	ND<1	ND<1	0.67	ND<1	0.0491	0.0236	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
RW6	17-Apr-08	ND<1	ND<1	3.1	ND<1	ND<1	ND<1	0.1090	0.0735	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	27-May-08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0522	0.0113	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	17-May-06	86	ND<1	18	ND<1	ND<1	ND<1	0.17	0.019	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	21-Jun-06	83	ND<1	20	ND<1	ND<1	ND<1	0.075	0.025	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Jul-06	45	1.5	24	ND<1	ND<1	ND<1	1.01	0.0169	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Aug-06	30	ND<1	22	ND<1	ND<1	ND<1	5.36	0.0563	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Sep-06	46	ND<1	27	ND<1	ND<1	ND<1	0.916	0.0078	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Oct-06	45	1.2	15	ND<1	ND<1	ND<1	1.84	0.007	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	29-Nov-06	36	1.0	14	ND<1	ND<1	ND<1	0.399	0.137	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Dec-06	31	ND<1	13	ND<1	ND<1	ND<1	2.43	0.00877	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-Jan-07	46	0.96	16	ND<1	ND<1	ND<1	0.0348	ND<0.02	ND<1	ND<1	ND<1	ND<1	2.2	ND<1	11	3.3	3.2	ND<1
	8-Feb-07	42	ND<1	13	ND<1	ND<1	ND<1	0.0928	0.00453	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-07	29	ND<1	8.4	ND<1	ND<1	ND<1	0.153	0.0108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Apr-07	28	ND<1	8.3	ND<1	ND<1	ND<1	0.554	0.0316	ND<1	ND<1	ND<1	7.2*	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-May-07	31	ND<1	7.7	ND<1	ND<1	ND<1	0.206	0.00708	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Jun-07	19	ND<1	6.6	ND<1	ND<1	ND<1	0.127	0.0139	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Jul-07	20	ND<1	6.8	ND<1	ND<1	ND<1	0.595	0.597	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Aug-07	19	ND<1	6.7	ND<1	ND<1	ND<1	0.0610	0.0200	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Sep-07	21	ND<1	7.0	ND<1	ND<1	ND<1	0.1990	0.0330	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	3-Oct-07	14	ND<1	11.0	ND<1	ND<1	ND<1	0.1650	0.0860	0.92	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Nov-07	20	ND<1	12.0	ND<1	ND<1	ND<1	0.2620	0.0317	1.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Dec-07	25	ND<1	7.5	ND<1	ND<1	ND<1	0.0567	0.0282	0.66	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jan-08	22	ND<1	6.9	ND<1	ND<1	ND<1	0.0815	0.0453	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	13-Feb-08	19	ND<1	6.4	ND<1	ND<1	ND<1	0.1710	0.0188	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-Mar-08	17	ND<1	6.1	ND<1	ND<1	ND<1	0.1520	0.0282	0.61	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	17-Apr-08	17	ND<1	5.2	ND<1	ND<1	ND<1	1.3200	0.0465	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	27-May-08	17	ND<1	6.5	ND<1	ND<1	ND<1	0.1240	0.0646	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L) ^{1/}	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L) ^{1/}
RW-7	ARAR's	5	5	5	NE	7	NE	300	300	5	5	5	5	NE	NE	NE	NE	NE	NE
	17-Jun-06	99	ND<1	ND<1	ND<1	ND<1	ND<1	0.126	0.026	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	21-Jun-06	44	ND<1	4.6	ND<1	ND<1	ND<1	0.081	0.013	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Jul-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	24-Aug-06	39	ND<1	7.9	ND<1	ND<1	ND<1	0.307	0.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Sep-06	36	ND<1	7.5	ND<1	ND<1	ND<1	0.116	0.0046	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Oct-06	26	ND<1	3.5	ND<1	ND<1	ND<1	0.0692	0.00846	2.4	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	9-Nov-06	33	ND<1	4.1	ND<1	ND<1	ND<1	0.1910	0.04990	1.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Dec-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	10-Jan-07	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	8-Feb-07	43	ND<1	4.4	ND<1	ND<1	ND<1	0.131	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-07	23	ND<1	2.7	ND<1	ND<1	ND<1	0.0492	0.0221	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Apr-07	34	ND<1	ND<1	ND<1	ND<1	ND<1	0.138	0.0438	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-May-07	22	ND<1	2.3	ND<1	ND<1	ND<1	0.111	0.0271	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Jun-07	14	ND<1	1.7	ND<1	ND<1	ND<1	0.136	0.0165	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Jul-07	17	ND<1	2	ND<1	ND<1	ND<1	0.434	0.0548	1.2	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Aug-07	14	ND<1	1.6	ND<1	ND<1	ND<1	0.239	0.0250	1.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Sep-07	24	ND<1	2	ND<1	ND<1	ND<1	0.17	0.0800	0.68	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	3-Oct-07	25	0.73	2.8	ND<1	ND<1	ND<1	0.164	0.2090	0.96	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Nov-07	11	ND<1	1.1	ND<1	ND<1	ND<1	0.163	0.0259	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Dec-07	12	ND<1	1.4	ND<1	ND<1	ND<1	0.172	0.0538	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jan-08	8.4	ND<1	0.73	ND<1	ND<1	ND<1	0.125	0.0499	0.82	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	13-Feb-08	11	ND<1	ND<1	ND<1	ND<1	ND<1	0.0982	0.0381	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-Mar-08	11	ND<1	1.1	ND<1	ND<1	ND<1	0.0793	0.0488	0.97	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	17-Apr-08	11	ND<1	ND<1	ND<1	ND<1	ND<1	0.488	0.0711	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	27-May-08	10	ND<1	1.2	ND<1	ND<1	ND<1	0.127	0.0399	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
RW-8	17-May-08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.03	0.066	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	21-Jun-06	ND<1	ND<1	2.8	ND<1	ND<1	ND<1	8.40	0.897	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Jul-06	1.0	ND<1	4.0	ND<1	ND<1	ND<1	10.80	0.175	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Aug-06	ND<1	ND<1	3.2	ND<1	ND<1	ND<1	5.98	1.860	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Sep-06	ND<1	ND<1	3.0	ND<1	ND<1	ND<1	7.44	0.009	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Oct-06	0.9	ND<1	3.1	ND<1	ND<1	ND<1	8.32	0.0605	2.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	29-Nov-06	1.0	ND<1	3.4	ND<1	ND<1	ND<1	3.87	0.0091	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Dec-06	ND<1	ND<1	3.5	ND<1	ND<1	ND<1	62.80	0.0346	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-Jan-07	1.3	ND<1	3.5	ND<1	ND<1	ND<1	6.57	0.8100	ND<1	ND<1	ND<1	ND<1	1.9	ND<1	ND<2	2.8	2.7	ND<1
	8-Feb-07	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	7-Mar-07	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	18-Apr-07	ND<1	ND<1	2.2	ND<1	ND<1	ND<1	9.13	0.3820	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-May-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	24.70	0.0129	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Jun-07	ND<1	ND<1	1.7	ND<1	ND<1	ND<1	6.67	0.0341	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Jul-07	ND<1	ND<1	1.5	ND<1	ND<1	ND<1	8.16	0.0505	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Aug-07	ND<1	ND<1	1.2	ND<1	ND<1	ND<1	26.7	0.4350	1.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Sep-07	ND<1	ND<1	1.5	ND<1	ND<1	ND<1	8.7	0.3860	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	3-Oct-07	ND<1	ND<1	2.0	ND<1	ND<1	ND<1	7.5	5.43	1.2	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Nov-07	0.6	ND<1	ND<1	ND<1	ND<1	ND<1	11.2	0.0442	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Dec-07	ND<1	ND<1	1.3	ND<1	ND<1	ND<1	7.87	3.02	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jan-08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	7.19	1.00	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	13-Feb-08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	7.14	0.0771	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-Mar-08	ND<1	ND<1	1.2	ND<1	ND<1	ND<1	6.08	1.81	1.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	17-Apr-08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	10.20	0.08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	27-May-08	1.4	ND<1	1.1	ND<1	ND<1	ND<1	5.26	2.24	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L)
	ARAR's	5	5	5	NE	7	NE	300	300	5	5	5	5	NE	NE	NE	NE	NE	NE
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.64	0.054	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	21-June-06	NM	NM	NM	NM	ND<1	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	20-Jul-06	ND<1	ND<1	2.2	ND<1	ND<1	ND<1	3.5	0.695	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Aug-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.97	0.0165	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Sep-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	5.16	ND<0.02	ND<1	ND<1	ND<1	18*	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Oct-06	ND<1	ND<1	1.5	ND<1	ND<1	ND<1	6.96	0.00719	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	29-Nov-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.99	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Dec-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	6.54	0.0119	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-Jan-07	ND<1	ND<1	1.4	ND<1	ND<1	ND<1	5.08	0.0855	ND<1	ND<1	ND<1	ND<1	1.4	ND<1	7	2	2.1	ND<1
	8-Feb-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.96	0.0076	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	8.03	0.399	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Apr-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.77	0.232	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-May-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.6	0.0366	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	25-Jun-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.888	0.04	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Jul-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.59	0.0227	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Aug-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	4.39	0.0250	ND<1	ND<1	ND<1	13*	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Sep-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	4.33	0.4040	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	3-Oct-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.18	0.180	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Nov-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.704	0.066	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Dec-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.2	1.92	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jan-08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.85	1.46	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	13-Feb-08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.94	0.176	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-Mar-08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.01	0.363	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	17-Apr-08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.99	1.330	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	27-May-08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	9.68	0.579	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1

ND: Not detected
 <4: Less than method detection limit
 ug/L: Micrograms per liter
 -: Not analyzed
 ARAR's are chemical specific aquifer restoration goals for ground water at the Former Rowe Industries Superfund Site.
 Bold values indicate an exceedance of the ARAR standard established for the site


NE indicates that the ARAR goal was not established for this compound by the EP.
 * Concentrations with an asterisk following them are due to laboratory contamination.
 1/ RW-3 is currently non operational waiting for the reprogramming of the drive for the new 4 amp pump.
 2/ RW-9 was being rehabilitated during this sampling event, thus no water sample was collected.

GRAPHS


GRAPH 1

GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK


EFFLUENT FLOW DATA
(May 1, 2008 through May 31, 2008)



GRAPH 2 GROUND-WATER REMEDIAL ACTION ROWE INDUSTRIES SUPERFUND SITE SAG HARBOR, NEW YORK



GRAPH 3
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK



APPENDIX I
MAY 2008 LABORATORY ANALYTICAL REPORTS

Wednesday, May 14, 2008

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe

Order No.: 0805114

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 5/9/2008 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The results reported herein relate only to the samples received by the laboratory. This report may not be reproduced, except in full, without the approval of American Analytical Laboratories, LLC and is not considered complete without a cover page and chain of custody documentation. The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report. This package has been reviewed by American Analytical Laboratories' QA Department/Laboratory Director to comply with NELAC standards prior to report submittal.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 14-May-08

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe
Lab Order: 0805114

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0805114-01A	WQ050608:1100NP2-6		5/6/2008 11:00:00 AM	5/9/2008
0805114-01B	WQ050608:1100NP2-6		5/6/2008 11:00:00 AM	5/9/2008
0805114-01C	WQ050608:1100NP2-6		5/6/2008 11:00:00 AM	5/9/2008
0805114-02A	WQ050608:1105NP2-7		5/6/2008 11:05:00 AM	5/9/2008
0805114-02B	WQ050608:1105NP2-7		5/6/2008 11:05:00 AM	5/9/2008
0805114-02C	WQ050608:1105NP2-7		5/6/2008 11:05:00 AM	5/9/2008
0805114-03A	WQ050608:1110NP2-10		5/6/2008 11:10:00 AM	5/9/2008
0805114-03B	WQ050608:1110NP2-10		5/6/2008 11:10:00 AM	5/9/2008
0805114-03C	WQ050608:1110NP2-10		5/6/2008 11:10:00 AM	5/9/2008

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value.
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of the method allowable holding time.

American Analytical Laboratories, LLC.

Date: 14-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805114
Project: Rowe
Lab ID: 0805114-01A

Client Sample ID: WQ050608:1100NP2-6
Tag Number:
Collection Date: 5/6/2008 11:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
1,1,1-Trichloroethane	1.9	1.0		µg/L	1	5/10/2008 9:27:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
2-Butanone	U	3.0		µg/L	1	5/10/2008 9:27:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
2-Hexanone	U	2.0		µg/L	1	5/10/2008 9:27:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	5/10/2008 9:27:00 AM
Acetone	U	2.0		µg/L	1	5/10/2008 9:27:00 AM
Benzene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
Bromobenzene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
Bromochloromethane	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
Bromodichloromethane	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
Bromoform	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
Bromomethane	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
Carbon disulfide	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
Chlorobenzene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 14-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805114
Project: Rowe
Lab ID: 0805114-01A

Client Sample ID: WQ050608:1100NP2-6
Tag Number:
Collection Date: 5/6/2008 11:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
Chloroform	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
Chloromethane	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
Dibromochloromethane	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
Dibromomethane	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
Ethylbenzene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
Isopropylbenzene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
m,p-Xylene	U	2.0		µg/L	1	5/10/2008 9:27:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
Methylene chloride	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
Naphthalene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
n-Butylbenzene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
n-Propylbenzene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
o-Xylene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
Styrene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
Tetrachloroethene	3.1	1.0		µg/L	1	5/10/2008 9:27:00 AM
Toluene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
Trichloroethene	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
Vinyl acetate	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
Vinyl chloride	U	1.0		µg/L	1	5/10/2008 9:27:00 AM
Surr: 4-Bromofluorobenzene	102	54-134		%REC	1	5/10/2008 9:27:00 AM
Surr: Dibromofluoromethane	97.7	52-132		%REC	1	5/10/2008 9:27:00 AM
Surr: Toluene-d8	97.6	51-127		%REC	1	5/10/2008 9:27:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 14-May-08

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ050608:1100NP2-6**Lab Order:** 0805114**Tag Number:****Project:** Rowe**Collection Date:** 5/6/2008 11:00:00 AM**Lab ID:** 0805114-01B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	2.46	0.0200		mg/L	1	5/13/2008 10:35:47 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 14-May-08**CLIENT:** Leggette Brashears & Graham Inc.**Client Sample ID:** WQ050608:1100NP2-6**Lab Order:** 0805114**Tag Number:****Project:** Rowe**Collection Date:** 5/6/2008 11:00:00 AM**Lab ID:** 0805114-01C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3010A		Analyst: JP
Iron	0.0558	0.0200		mg/L	1	5/13/2008 10:33:43 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 14-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805114
Project: Rowe
Lab ID: 0805114-02A

Client Sample ID: WQ050608:1105NP2-7
Tag Number:
Collection Date: 5/6/2008 11:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
2-Butanone	U	3.0		µg/L	1	5/10/2008 9:58:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
2-Hexanone	U	2.0		µg/L	1	5/10/2008 9:58:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	5/10/2008 9:58:00 AM
Acetone	U	2.0		µg/L	1	5/10/2008 9:58:00 AM
Benzene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
Bromobenzene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
Bromochloromethane	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
Bromodichloromethane	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
Bromoform	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
Bromomethane	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
Carbon disulfide	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
Chlorobenzene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detecte	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 14-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805114
Project: Rowe
Lab ID: 0805114-02A

Client Sample ID: WQ050608:1105NP2-7
Tag Number:
Collection Date: 5/6/2008 11:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
Chloroform	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
Chloromethane	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
Dibromochloromethane	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
Dibromomethane	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
Ethylbenzene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
Isopropylbenzene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
m,p-Xylene	U	2.0		µg/L	1	5/10/2008 9:58:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
Methylene chloride	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
Naphthalene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
n-Butylbenzene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
n-Propylbenzene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
o-Xylene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
Styrene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
Tetrachloroethene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
Toluene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
Trichloroethene	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
Vinyl acetate	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
Vinyl chloride	U	1.0		µg/L	1	5/10/2008 9:58:00 AM
Surr: 4-Bromofluorobenzene	102	54-134		%REC	1	5/10/2008 9:58:00 AM
Surr: Dibromofluoromethane	95.3	52-132		%REC	1	5/10/2008 9:58:00 AM
Surr: Toluene-d8	99.9	51-127		%REC	1	5/10/2008 9:58:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 14-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805114
Project: Rowe
Lab ID: 0805114-02B

Client Sample ID: WQ050608:1105NP2-7
Tag Number:
Collection Date: 5/6/2008 11:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.46	0.0200		mg/L	1	5/13/2008 10:43:52 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 14-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805114
Project: Rowe
Lab ID: 0805114-02C

Client Sample ID: WQ050608:1105NP2-7
Tag Number:
Collection Date: 5/6/2008 11:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3010A		Analyst: JP
Iron	0.0960	0.0200		mg/L	1	5/13/2008 10:37:50 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 14-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805114
Project: Rowe
Lab ID: 0805114-03A

Client Sample ID: WQ050608:1110NP2-10
Tag Number:
Collection Date: 5/6/2008 11:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
2-Butanone	U	3.0		µg/L	1	5/10/2008 10:28:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
2-Hexanone	U	2.0		µg/L	1	5/10/2008 10:28:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	5/10/2008 10:28:00 AM
Acetone	U	2.0		µg/L	1	5/10/2008 10:28:00 AM
Benzene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
Bromobenzene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
Bromochloromethane	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
Bromodichloromethane	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
Bromoform	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
Bromomethane	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
Carbon disulfide	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
Chlorobenzene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 14-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805114
Project: Rowe
Lab ID: 0805114-03A

Client Sample ID: WQ050608:1110NP2-10
Tag Number:
Collection Date: 5/6/2008 11:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
Chloroform	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
Chloromethane	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
Dibromochloromethane	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
Dibromomethane	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
Ethylbenzene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
Isopropylbenzene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
m,p-Xylene	U	2.0		µg/L	1	5/10/2008 10:28:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
Methylene chloride	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
Naphthalene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
n-Butylbenzene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
n-Propylbenzene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
o-Xylene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
Styrene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
Tetrachloroethene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
Toluene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
Trichloroethene	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
Vinyl acetate	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
Vinyl chloride	U	1.0		µg/L	1	5/10/2008 10:28:00 AM
Surr: 4-Bromofluorobenzene	97.6	54-134		%REC	1	5/10/2008 10:28:00 AM
Surr: Dibromofluoromethane	101	52-132		%REC	1	5/10/2008 10:28:00 AM
Surr: Toluene-d8	97.2	51-127		%REC	1	5/10/2008 10:28:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 14-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805114
Project: Rowe
Lab ID: 0805114-03B

Client Sample ID: WQ050608:1110NP2-10
Tag Number:
Collection Date: 5/6/2008 11:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	0.0851	0.0200		mg/L	1	5/13/2008 10:59:05 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 14-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805114
Project: Rowe
Lab ID: 0805114-03C

Client Sample ID: WQ050608:1110NP2-10
Tag Number:
Collection Date: 5/6/2008 11:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3010A		Analyst: JP
Iron	0.106	0.0200		mg/L	1	5/13/2008 10:57:01 AM
TOTAL DISSOLVED SOLIDS		M2540C				Analyst: AS
Total Dissolved Solids (Residue, Filterable)	112	1.00		mg/L	1	5/12/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Tuesday, May 27, 2008

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555

FAX (203) 926-9140

RE: Rowe

Order No.: 0805179

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 5/20/2008 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The results reported herein relate only to the items tested or to the samples as received by the laboratory. This report may not be reproduced, except in full, without the approval of American Analytical Laboratories, LLC and is not considered complete without a cover page and chain of custody documentation. The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report. This package has been reviewed by American Analytical Laboratories' QA Department/Laboratory Director to comply with NELAC standards prior to report submittal.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 27-May-08

CLIENT: Leggette Brashears & Graham Inc.**Project:** Rowe**Lab Order:** 0805179**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0805179-01A	WQ051508:1000NP2-6		5/15/2008 10:00:00 AM	5/20/2008
0805179-01B	WQ051508:1000NP2-6		5/20/2008 10:02:25 AM	5/20/2008
0805179-01C	WQ051508:1000NP2-6		5/20/2008 10:02:25 AM	5/20/2008
0805179-02A	WQ051508:1005NP2-7		5/15/2008 10:05:00 AM	5/20/2008
0805179-02B	WQ051508:1005NP2-7		5/15/2008 10:05:00 AM	5/20/2008
0805179-02C	WQ051508:1005NP2-7		5/15/2008 10:05:00 AM	5/20/2008
0805179-03A	WQ051508:1010NP2-10		5/15/2008 10:10:00 AM	5/20/2008
0805179-03B	WQ051508:1010NP2-10		5/15/2008 10:10:00 AM	5/20/2008
0805179-03C	WQ051508:1010NP2-10		5/15/2008 10:10:00 AM	5/20/2008

56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
(631) 454-6100 • FAX (631) 454-8027

TAG # / COC

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 27-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805179
Project: Rowe
Lab ID: 0805179-01A

Client Sample ID: WQ051508:1000NP2-6
Tag Number:
Collection Date: 5/15/2008 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
1,1,1-Trichloroethane	2.0	1.0		µg/L	1	5/20/2008 4:24:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
2-Butanone	U	3.0		µg/L	1	5/20/2008 4:24:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
2-Hexanone	U	2.0		µg/L	1	5/20/2008 4:24:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	5/20/2008 4:24:00 PM
Acetone	U	2.0		µg/L	1	5/20/2008 4:24:00 PM
Benzene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
Bromobenzene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
Bromochloromethane	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
Bromodichloromethane	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
Bromoform	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
Bromomethane	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
Carbon disulfide	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
Chlorobenzene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805179
Project: Rowe
Lab ID: 0805179-01A

Client Sample ID: WQ051508:1000NP2-6
Tag Number:
Collection Date: 5/15/2008 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
Chloroform	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
Chloromethane	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
Dibromochloromethane	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
Dibromomethane	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
Ethylbenzene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
Isopropylbenzene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
m,p-Xylene	U	2.0		µg/L	1	5/20/2008 4:24:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
Methylene chloride	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
Naphthalene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
n-Butylbenzene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
n-Propylbenzene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
o-Xylene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
Styrene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
Tetrachloroethene	2.4	1.0		µg/L	1	5/20/2008 4:24:00 PM
Toluene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
Trichloroethene	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
Vinyl acetate	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
Vinyl chloride	U	1.0		µg/L	1	5/20/2008 4:24:00 PM
Surr: 4-Bromofluorobenzene	106	54-134		%REC	1	5/20/2008 4:24:00 PM
Surr: Dibromofluoromethane	106	52-132		%REC	1	5/20/2008 4:24:00 PM
Surr: Toluene-d8	91.5	51-127		%REC	1	5/20/2008 4:24:00 PM

Qualifiers:
 B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits
 X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805179
Project: Rowe
Lab ID: 0805179-01B

Client Sample ID: WQ051508:1000NP2-6
Tag Number:
Collection Date: 5/20/2008 10:02:25 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.63	0.0200		mg/L	1	5/20/2008 12:33:44 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805179
Project: Rowe
Lab ID: 0805179-01C

Client Sample ID: WQ051508:1000NP2-6
Tag Number:
Collection Date: 5/20/2008 10:02:25 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0420	0.0200		mg/L	1	5/20/2008 12:31:41 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-May-08

CLIENT: Leggett Brashears & Graham Inc.
Lab Order: 0805179
Project: Rowe
Lab ID: 0805179-02A

Client Sample ID: WQ051508:1005NP2-7
Tag Number:
Collection Date: 5/15/2008 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
2-Butanone	U	3.0		µg/L	1	5/20/2008 4:54:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
2-Hexanone	U	2.0		µg/L	1	5/20/2008 4:54:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
4-isopropyltoluene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	5/20/2008 4:54:00 PM
Acetone	U	2.0		µg/L	1	5/20/2008 4:54:00 PM
Benzene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
Bromobenzene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
Bromochloromethane	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
Bromodichloromethane	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
Bromoform	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
Bromomethane	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
Carbon disulfide	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
Chlorobenzene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805179
Project: Rowe
Lab ID: 0805179-02A

Client Sample ID: WQ051508:1005NP2-7
Tag Number:
Collection Date: 5/15/2008 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
Chloroform	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
Chloromethane	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
Dibromochloromethane	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
Dibromomethane	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
Ethylbenzene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
Isopropylbenzene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
m,p-Xylene	U	2.0		µg/L	1	5/20/2008 4:54:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
Methylene chloride	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
Naphthalene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
n-Butylbenzene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
n-Propylbenzene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
o-Xylene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
Styrene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
Tetrachloroethene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
Toluene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
Trichloroethene	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
Vinyl acetate	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
Vinyl chloride	U	1.0		µg/L	1	5/20/2008 4:54:00 PM
Surr: 4-Bromofluorobenzene	95.8	54-134		%REC	1	5/20/2008 4:54:00 PM
Surr: Dibromofluoromethane	105	52-132		%REC	1	5/20/2008 4:54:00 PM
Surr: Toluene-d8	96.5	51-127		%REC	1	5/20/2008 4:54:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805179
Project: Rowe
Lab ID: 0805179-02B

Client Sample ID: WQ051508:1005NP2-7
Tag Number:
Collection Date: 5/15/2008 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.39	0.0200		mg/L	1	5/20/2008 12:37:50 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805179
Project: Rowe
Lab ID: 0805179-02C

Client Sample ID: WQ051508:1005NP2-7
Tag Number:
Collection Date: 5/15/2008 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0870	0.0200		mg/L	1	5/20/2008 12:35:47 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805179
Project: Rowe
Lab ID: 0805179-03A

Client Sample ID: WQ051508:1010NP2-10
Tag Number:
Collection Date: 5/15/2008 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
2-Butanone	U	3.0		µg/L	1	5/21/2008 6:48:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
2-Hexanone	U	2.0		µg/L	1	5/21/2008 6:48:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	5/21/2008 6:48:00 AM
Acetone	U	2.0		µg/L	1	5/21/2008 6:48:00 AM
Benzene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
Bromobenzene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
Bromochloromethane	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
Bromodichloromethane	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
Bromoform	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
Bromomethane	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
Carbon disulfide	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
Chlorobenzene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805179
Project: Rowe
Lab ID: 0805179-03A

Client Sample ID: WQ051508:1010NP2-10
Tag Number:
Collection Date: 5/15/2008 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
Chloroform	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
Chloromethane	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
Dibromochloromethane	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
Dibromomethane	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
Ethylbenzene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
Isopropylbenzene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
m,p-Xylene	U	2.0		µg/L	1	5/21/2008 6:48:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
Methylene chloride	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
Naphthalene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
n-Butylbenzene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
n-Propylbenzene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
o-Xylene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
Styrene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
Tetrachloroethene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
Toluene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
Trichloroethene	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
Vinyl acetate	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
Vinyl chloride	U	1.0		µg/L	1	5/21/2008 6:48:00 AM
Surr: 4-Bromofluorobenzene	101	54-134		%REC	1	5/21/2008 6:48:00 AM
Surr: Dibromofluoromethane	105	52-132		%REC	1	5/21/2008 6:48:00 AM
Surr: Toluene-d8	96.8	51-127		%REC	1	5/21/2008 6:48:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-May-08

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ051508:1010NP2-10**Lab Order:** 0805179**Tag Number:****Project:** Rowe**Collection Date:** 5/15/2008 10:10:00 AM**Lab ID:** 0805179-03B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.09	0.0200		mg/L	1	5/20/2008 12:41:55 PM

Qualifiers:


B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 27-May-08**CLIENT:** Leggette Brashears & Graham Inc.**Client Sample ID:** WQ051508:1010NP2-10**Lab Order:** 0805179**Tag Number:****Project:** Rowe**Collection Date:** 5/15/2008 10:10:00 AM**Lab ID:** 0805179-03C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.100	0.0200		mg/L	1	5/20/2008 12:39:52 PM
TOTAL DISSOLVED SOLIDS		M2540C				Analyst: AS
Total Dissolved Solids (Residue, Filterable)	108	1.00		mg/L	1	5/22/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Wednesday, May 28, 2008

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe

Order No.: 0805203

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 5/22/2008 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The results reported herein relate only to the items tested or to the samples as received by the laboratory. This report may not be reproduced, except in full, without the approval of American Analytical Laboratories, LLC and is not considered complete without a cover page and chain of custody documentation. The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report. This package has been reviewed by American Analytical Laboratories' QA Department/Laboratory Director to comply with NELAC standards prior to report submittal.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 28-May-08

CLIENT: Leggette Brashears & Graham Inc.**Project:** Rowe**Lab Order:** 0805203**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0805203-01A	WQ052008:1100NP2-6		5/20/2008 11:00:00 AM	5/22/2008
0805203-01B	WQ052008:1100NP2-6		5/20/2008 11:00:00 AM	5/22/2008
0805203-01C	WQ052008:1100NP2-6		5/20/2008 11:00:00 AM	5/22/2008
0805203-02A	WQ052008:1105NP2-7		5/20/2008 11:05:00 AM	5/22/2008
0805203-02B	WQ052008:1105NP2-7		5/20/2008 11:05:00 AM	5/22/2008
0805203-02C	WQ052008:1105NP2-7		5/20/2008 11:05:00 AM	5/22/2008
0805203-03A	WQ052008:1110NP2-10		5/20/2008 11:10:00 AM	5/22/2008
0805203-03B	WQ052008:1110NP2-10		5/20/2008 11:10:00 AM	5/22/2008
0805203-03C	WQ052008:1110NP2-10		5/20/2008 11:10:00 AM	5/22/2008

TAG # / COC

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100

FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 28-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805203
Project: Rowe
Lab ID: 0805203-01A

Client Sample ID: WQ052008:1100NP2-6
Tag Number:
Collection Date: 5/20/2008 11:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
1,1,1-Trichloroethane	2.9	1.0		µg/L	1	5/23/2008 1:49:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
2-Butanone	U	3.0		µg/L	1	5/23/2008 1:49:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
2-Hexanone	U	2.0		µg/L	1	5/23/2008 1:49:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	5/23/2008 1:49:00 AM
Acetone	U	2.0		µg/L	1	5/23/2008 1:49:00 AM
Benzene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
Bromobenzene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
Bromochloromethane	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
Bromodichloromethane	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
Bromoform	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
Bromomethane	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
Carbon disulfide	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
Chlorobenzene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 28-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805203
Project: Rowe
Lab ID: 0805203-01A

Client Sample ID: WQ052008:1100NP2-6
Tag Number:
Collection Date: 5/20/2008 11:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
Chloroform	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
Chloromethane	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
Dibromochloromethane	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
Dibromomethane	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
Ethylbenzene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
Isopropylbenzene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
m,p-Xylene	U	2.0		µg/L	1	5/23/2008 1:49:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
Methylene chloride	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
Naphthalene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
n-Butylbenzene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
n-Propylbenzene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
o-Xylene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
Styrene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
Tetrachloroethene	4.1	1.0		µg/L	1	5/23/2008 1:49:00 AM
Toluene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
Trichloroethene	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
Vinyl acetate	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
Vinyl chloride	U	1.0		µg/L	1	5/23/2008 1:49:00 AM
Surr: 4-Bromofluorobenzene	99.0	54-134		%REC	1	5/23/2008 1:49:00 AM
Surr: Dibromofluoromethane	106	52-132		%REC	1	5/23/2008 1:49:00 AM
Surr: Toluene-d8	96.1	51-127		%REC	1	5/23/2008 1:49:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 28-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805203
Project: Rowe
Lab ID: 0805203-01B

Client Sample ID: WQ052008:1100NP2-6
Tag Number:
Collection Date: 5/20/2008 11:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.62	0.0200		mg/L	1	5/27/2008 11:17:06 AM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 28-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805203
Project: Rowe
Lab ID: 0805203-01C

Client Sample ID: WQ052008:1100NP2-6
Tag Number:
Collection Date: 5/20/2008 11:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0510	0.0200		mg/L	1	5/27/2008 11:15:02 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 28-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805203
Project: Rowe
Lab ID: 0805203-02A

Client Sample ID: WQ052008:1105NP2-7
Tag Number:
Collection Date: 5/20/2008 11:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
2-Butanone	U	3.0		µg/L	1	5/23/2008 2:24:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
2-Hexanone	U	2.0		µg/L	1	5/23/2008 2:24:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	5/23/2008 2:24:00 AM
Acetone	U	2.0		µg/L	1	5/23/2008 2:24:00 AM
Benzene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
Bromobenzene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
Bromochloromethane	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
Bromodichloromethane	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
Bromoform	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
Bromomethane	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
Carbon disulfide	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
Chlorobenzene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 28-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805203
Project: Rowe
Lab ID: 0805203-02A

Client Sample ID: WQ052008:1105NP2-7
Tag Number:
Collection Date: 5/20/2008 11:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
Chloroform	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
Chloromethane	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
Dibromochloromethane	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
Dibromomethane	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
Ethylbenzene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
Isopropylbenzene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
m,p-Xylene	U	2.0		µg/L	1	5/23/2008 2:24:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
Methylene chloride	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
Naphthalene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
n-Butylbenzene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
n-Propylbenzene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
o-Xylene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
Styrene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
Tetrachloroethene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
Toluene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
Trichloroethene	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
Vinyl acetate	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
Vinyl chloride	U	1.0		µg/L	1	5/23/2008 2:24:00 AM
Surr: 4-Bromofluorobenzene	99.8	54-134		%REC	1	5/23/2008 2:24:00 AM
Surr: Dibromofluoromethane	105	52-132		%REC	1	5/23/2008 2:24:00 AM
Surr: Toluene-d8	97.6	51-127		%REC	1	5/23/2008 2:24:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 28-May-08

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ052008:1105NP2-7**Lab Order:** 0805203**Tag Number:****Project:** Rowe**Collection Date:** 5/20/2008 11:05:00 AM**Lab ID:** 0805203-02B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.19	0.0200		mg/L	1	5/27/2008 11:21:13 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 28-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805203
Project: Rowe
Lab ID: 0805203-02C

Client Sample ID: WQ052008:1105NP2-7
Tag Number:
Collection Date: 5/20/2008 11:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.104	0.0200		mg/L	1	5/27/2008 11:19:09 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 28-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805203
Project: Rowe
Lab ID: 0805203-03A

Client Sample ID: WQ052008:1110NP2-10
Tag Number:
Collection Date: 5/20/2008 11:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
2-Butanone	U	3.0		µg/L	1	5/23/2008 2:59:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
2-Hexanone	U	2.0		µg/L	1	5/23/2008 2:59:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	5/23/2008 2:59:00 AM
Acetone	U	2.0		µg/L	1	5/23/2008 2:59:00 AM
Benzene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
Bromobenzene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
Bromochloromethane	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
Bromodichloromethane	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
Bromoform	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
Bromomethane	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
Carbon disulfide	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
Chlorobenzene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 28-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805203
Project: Rowe
Lab ID: 0805203-03A

Client Sample ID: WQ052008:1110NP2-10
Tag Number:
Collection Date: 5/20/2008 11:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
Chloroform	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
Chloromethane	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
Dibromochloromethane	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
Dibromomethane	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
Ethylbenzene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
Isopropylbenzene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
m,p-Xylene	U	2.0		µg/L	1	5/23/2008 2:59:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
Methylene chloride	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
Naphthalene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
n-Butylbenzene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
n-Propylbenzene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
o-Xylene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
Styrene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
Tetrachloroethene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
Toluene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
Trichloroethene	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
Vinyl acetate	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
Vinyl chloride	U	1.0		µg/L	1	5/23/2008 2:59:00 AM
Surr: 4-Bromofluorobenzene	101	54-134		%REC	1	5/23/2008 2:59:00 AM
Surr: Dibromofluoromethane	107	52-132		%REC	1	5/23/2008 2:59:00 AM
Surr: Toluene-d8	99.3	51-127		%REC	1	5/23/2008 2:59:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 28-May-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805203
Project: Rowe
Lab ID: 0805203-03B

Client Sample ID: WQ052008:1110NP2-10
Tag Number:
Collection Date: 5/20/2008 11:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	0.985	0.0200		mg/L	1	5/27/2008 11:51:33 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 28-May-08

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ052008:1110NP2-10**Lab Order:** 0805203**Tag Number:****Project:** Rowe**Collection Date:** 5/20/2008 11:10:00 AM**Lab ID:** 0805203-03C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0900	0.0200		mg/L	1	5/27/2008 11:49:29 AM
TOTAL DISSOLVED SOLIDS		M2540C				Analyst: AS
Total Dissolved Solids (Residue, Filterable)	108	1.00		mg/L	1	5/23/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

Thursday, June 05, 2008

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555

FAX (203) 926-9140

RE: Rowe

Order No.: 0805243

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 5/29/2008 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The results reported herein relate only to the items tested or to the samples as received by the laboratory. This report may not be reproduced, except in full, without the approval of American Analytical Laboratories, LLC and is not considered complete without a cover page and chain of custody documentation. The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report. This package has been reviewed by American Analytical Laboratories' QA Department/Laboratory Director to comply with NELAC standards prior to report submittal.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,



Lori Beyer
Lab Director

American Analytical Laboratories, LLC.**Date:** 05-Jun-08**CLIENT:** Leggette Brashears & Graham Inc.**Project:** Rowe**Lab Order:** 0805243**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0805243-01A	WQ052708:1500NP2-6		5/27/2008 3:00:00 PM	5/29/2008
0805243-01B	WQ052708:1500NP2-6		5/27/2008 3:00:00 PM	5/29/2008
0805243-01C	WQ052708:1500NP2-6		5/27/2008 3:00:00 PM	5/29/2008
0805243-02A	WQ052708:1505NP2-7		5/27/2008 3:05:00 PM	5/29/2008
0805243-02B	WQ052708:1505NP2-7		5/27/2008 3:05:00 PM	5/29/2008
0805243-02C	WQ052708:1505NP2-7		5/27/2008 3:05:00 PM	5/29/2008
0805243-03A	WQ052708:1510NP2-10		5/27/2008 3:10:00 PM	5/29/2008
0805243-03B	WQ052708:1510NP2-10		5/27/2008 3:10:00 PM	5/29/2008
0805243-03C	WQ052708:1510NP2-10		5/27/2008 3:10:00 PM	5/29/2008

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value.
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of the method allowable holding time.

American Analytical Laboratories, LLC.**Date:** 05-Jun-08**CLIENT:** Leggette Brashears & Graham Inc.**Project:** Rowe**Lab Order:** 0805243**CASE NARRATIVE**

Samples were analyzed using the methods outlined in the following references:

Test Methods for Evaluating Solid Waste, Physical/Chemical Methods, SW846, 3rd Edition

All method blanks, laboratory spikes, and/or matrix spikes met quality assurance objectives.

No analytical problems were encountered.

American Analytical Laboratories, LLC.

Date: 05-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805243
Project: Rowe
Lab ID: 0805243-01A

Client Sample ID: WQ052708:1500NP2-6
Tag Number:
Collection Date: 5/27/2008 3:00:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
1,1,1-Trichloroethane	0.95	1.0	J	µg/L	1	5/29/2008 7:27:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
2-Butanone	U	3.0		µg/L	1	5/29/2008 7:27:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
2-Hexanone	U	2.0		µg/L	1	5/29/2008 7:27:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	5/29/2008 7:27:00 PM
Acetone	U	2.0		µg/L	1	5/29/2008 7:27:00 PM
Benzene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
Bromobenzene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
Bromochloromethane	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
Bromodichloromethane	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
Bromoform	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
Bromomethane	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
Carbon disulfide	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
Chlorobenzene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 05-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805243
Project: Rowe
Lab ID: 0805243-01A

Client Sample ID: WQ052708:1500NP2-6
Tag Number:
Collection Date: 5/27/2008 3:00:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
Chloroform	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
Chloromethane	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
Dibromochloromethane	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
Dibromomethane	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
Ethylbenzene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
Isopropylbenzene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
m,p-Xylene	U	2.0		µg/L	1	5/29/2008 7:27:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
Methylene chloride	6.8	1.0		µg/L	1	5/29/2008 7:27:00 PM
Naphthalene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
n-Butylbenzene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
n-Propylbenzene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
o-Xylene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
Styrene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
Tetrachloroethene	3.1	1.0		µg/L	1	5/29/2008 7:27:00 PM
Toluene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
Trichloroethene	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
Vinyl acetate	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
Vinyl chloride	U	1.0		µg/L	1	5/29/2008 7:27:00 PM
Surr: 4-Bromofluorobenzene	109	54-134		%REC	1	5/29/2008 7:27:00 PM
Surr: Dibromofluoromethane	116	52-132		%REC	1	5/29/2008 7:27:00 PM
Surr: Toluene-d8	94.5	51-127		%REC	1	5/29/2008 7:27:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 05-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805243
Project: Rowe
Lab ID: 0805243-01B

Client Sample ID: WQ052708:1500NP2-6
Tag Number:
Collection Date: 5/27/2008 3:00:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	2.58	0.0200		mg/L	1	5/30/2008 10:37:30 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 05-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805243
Project: Rowe
Lab ID: 0805243-01C

Client Sample ID: WQ052708:1500NP2-6
Tag Number:
Collection Date: 5/27/2008 3:00:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0619	0.0200		mg/L	1	5/30/2008 10:35:27 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 05-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805243
Project: Rowe
Lab ID: 0805243-02A

Client Sample ID: WQ052708:1505NP2-7
Tag Number:
Collection Date: 5/27/2008 3:05:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
2-Butanone	U	3.0		µg/L	1	5/29/2008 7:49:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
2-Hexanone	U	2.0		µg/L	1	5/29/2008 7:49:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	5/29/2008 7:49:00 PM
Acetone	U	2.0		µg/L	1	5/29/2008 7:49:00 PM
Benzene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
Bromobenzene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
Bromochloromethane	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
Bromodichloromethane	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
Bromoform	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
Bromomethane	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
Carbon disulfide	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
Chlorobenzene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 05-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805243
Project: Rowe
Lab ID: 0805243-02A

Client Sample ID: WQ052708:1505NP2-7
Tag Number:
Collection Date: 5/27/2008 3:05:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
Chloroform	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
Chloromethane	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
Dibromochloromethane	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
Dibromomethane	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
Ethylbenzene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
Isopropylbenzene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
m,p-Xylene	U	2.0		µg/L	1	5/29/2008 7:49:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
Methylene chloride	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
Naphthalene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
n-Butylbenzene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
n-Propylbenzene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
o-Xylene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
Styrene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
Tetrachloroethene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
Toluene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
Trichloroethene	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
Vinyl acetate	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
Vinyl chloride	U	1.0		µg/L	1	5/29/2008 7:49:00 PM
Surr: 4-Bromofluorobenzene	104	54-134		%REC	1	5/29/2008 7:49:00 PM
Surr: Dibromofluoromethane	119	52-132		%REC	1	5/29/2008 7:49:00 PM
Surr: Toluene-d8	97.8	51-127		%REC	1	5/29/2008 7:49:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 05-Jun-08

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ052708:1505NP2-7**Lab Order:** 0805243**Tag Number:****Project:** Rowe**Collection Date:** 5/27/2008 3:05:00 PM**Lab ID:** 0805243-02B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.97	0.0200		mg/L	1	5/30/2008 10:54:50 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 05-Jun-08

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ052708:1505NP2-7**Lab Order:** 0805243**Tag Number:****Project:** Rowe**Collection Date:** 5/27/2008 3:05:00 PM**Lab ID:** 0805243-02C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.119	0.0200		mg/L	1	5/30/2008 10:52:46 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 05-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805243
Project: Rowe
Lab ID: 0805243-03A

Client Sample ID: WQ052708:1510NP2-10
Tag Number:
Collection Date: 5/27/2008 3:10:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
2-Butanone	U	3.0		µg/L	1	5/29/2008 8:12:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
2-Hexanone	U	2.0		µg/L	1	5/29/2008 8:12:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	5/29/2008 8:12:00 PM
Acetone	U	2.0		µg/L	1	5/29/2008 8:12:00 PM
Benzene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
Bromobenzene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
Bromochloromethane	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
Bromodichloromethane	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
Bromoform	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
Bromomethane	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
Carbon disulfide	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
Chlorobenzene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 05-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805243
Project: Rowe
Lab ID: 0805243-03A

Client Sample ID: WQ052708:1510NP2-10
Tag Number:
Collection Date: 5/27/2008 3:10:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
Chloroform	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
Chloromethane	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
Dibromochloromethane	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
Dibromomethane	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
Ethylbenzene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
Isopropylbenzene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
m,p-Xylene	U	2.0		µg/L	1	5/29/2008 8:12:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
Methylene chloride	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
Naphthalene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
n-Butylbenzene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
n-Propylbenzene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
o-Xylene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
Styrene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
Tetrachloroethene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
Toluene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
Trichloroethene	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
Vinyl acetate	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
Vinyl chloride	U	1.0		µg/L	1	5/29/2008 8:12:00 PM
Surr: 4-Bromofluorobenzene	97.6	54-134		%REC	1	5/29/2008 8:12:00 PM
Surr: Dibromofluoromethane	113	52-132		%REC	1	5/29/2008 8:12:00 PM
Surr: Toluene-d8	93.6	51-127		%REC	1	5/29/2008 8:12:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 05-Jun-08**CLIENT:** Leggette Brashears & Graham Inc.**Client Sample ID:** WQ052708:1510NP2-10**Lab Order:** 0805243**Tag Number:****Project:** Rowe**Collection Date:** 5/27/2008 3:10:00 PM**Lab ID:** 0805243-03B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.63	0.0200		mg/L	1	5/30/2008 11:03:02 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 05-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805243
Project: Rowe
Lab ID: 0805243-03C

Client Sample ID: WQ052708:1510NP2-10
Tag Number:
Collection Date: 5/27/2008 3:10:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.147	0.0200		mg/L	1	5/30/2008 10:56:53 AM
TOTAL DISSOLVED SOLIDS		M2540C				Analyst: AS
Total Dissolved Solids (Residue, Filterable)	108	1.00		mg/L	1	6/3/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 05-Jun-08

CLIENT: Leggett Brashears & Graham Inc.
 Work Order: 0805243
 Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

Sample ID	V624LCS-052908Y	SampType: LCS	TestCode: 8260MTBE11	Units: µg/L	Prep Date:	RunNo: 35683					
Client ID:	LCSW	Batch ID: R35683	TestNo: SW8260B		Analysis Date: 5/29/2008	SeqNo: 458668					
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
1,1,1-Trichloroethane	48	1.0	50.00	0	95.7	52	137				
1,1,2,2-Tetrachloroethane	46	1.0	50.00	0	91.8	53	133				
1,1,2-Trichloroethane	41	1.0	50.00	0	83.0	51	130				
1,1-Dichloroethane	51	1.0	50.00	0	101	51	133				
1,1-Dichloroethene	60	1.0	50.00	0	120	42	133				
1,2-Dichlorobenzene	42	1.0	50.00	0	83.7	48	129				
1,2-Dichloroethane	48	1.0	50.00	0	96.7	51	130				
1,2-Dichloropropane	46	1.0	50.00	0	92.6	52	136				
1,3-Dichlorobenzene	45	1.0	50.00	0	89.5	53	132				
1,4-Dichlorobenzene	44	1.0	50.00	0	87.7	53	135				
2-Chloroethyl vinyl ether	43	1.0	50.00	0	85.8	43	125				
Benzene	47	1.0	50.00	0	93.7	44	133				
Bromodichloromethane	41	1.0	50.00	0	82.3	52	137				
Bromoform	42	1.0	50.00	0	84.9	43	123				
Bromomethane	58	1.0	50.00	0	116	36	126				
Carbon tetrachloride	49	1.0	50.00	0	98.5	48	128				
Chlorobenzene	46	1.0	50.00	0	91.8	57	135				
Chloroethane	58	1.0	50.00	0	116	53	147				
Chloroform	52	1.0	50.00	0	104	42	122				
Chloromethane	49	1.0	50.00	0	98.5	52	144				
cis-1,3-Dichloropropene	42	1.0	50.00	0	84.3	48	127				
Dibromochloromethane	42	1.0	50.00	0	84.0	47	125				
Ethylbenzene	45	1.0	50.00	0	90.8	53	136				
Tetrachloroethene	41	1.0	50.00	0	82.9	44	137				
Toluene	41	1.0	50.00	0	81.2	43	134				
trans-1,2-Dichloroethene	51	1.0	50.00	0	102	53	130				
trans-1,3-Dichloropropene	40	1.0	50.00	0	79.8	46	129				
Trichloroethene	46	1.0	50.00	0	92.2	43	138				
Trichlorofluoromethane	47	1.0	50.00	0	94.0	55	135				
Vinyl chloride	53	1.0	50.00	0	106	46	146				

Qualifiers:	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation li
	ND	Not Detected at the Reporting Limit	R	RPD outside accepted recovery limits	S	Spike Recovery outside accepted reco
	U	Indicates the compound was analyzed for but not detecte				

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 0805243
Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

Sample ID	V624LCS-052908Y	Sample Type:	LCS	TestCode:	8260MTBE11	Units:	µg/L	Prep Date:		RunNo:	35683
Client ID:	LCSW	Batch ID:	R35683	TestNo:	SW8260B			Analysis Date:	5/29/2008	SeqNo:	458668
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Surr: 4-Bromofluorobenzene	45		50.00		90.5	54	134				
Surr: Dibromofluoromethane	53		50.00		106	52	132				
Surr: Toluene-d8	50		50.00		100	51	127				

Sample ID	VBLK-052908Y	Sample Type:	MBLK	TestCode:	8260MTBE11	Units:	µg/L	Prep Date:		RunNo:	35683
Client ID:	PBW	Batch ID:	R35683	TestNo:	SW8260B			Analysis Date:	5/29/2008	SeqNo:	458669
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

1,1,1,2-Tetrachloroethane	U	1.0									
1,1,1-Trichloroethane	U	1.0									
1,1,2,2-Tetrachloroethane	U	1.0									
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0									
1,1,2-Trichloroethane	U	1.0									
1,1-Dichloroethane	U	1.0									
1,1-Dichloroethene	U	1.0									
1,1-Dichloropropene	U	1.0									
1,2,3-Trichlorobenzene	U	1.0									
1,2,3-Trichloropropane	U	1.0									
1,2,4-Trichlorobenzene	U	1.0									
1,2,4-Trimethylbenzene	U	1.0									
1,2-Dibromo-3-chloropropane	U	1.0									
1,2-Dibromoethane	U	1.0									
1,2-Dichlorobenzene	U	1.0									
1,2-Dichloroethane	U	1.0									
1,2-Dichloropropane	U	1.0									
1,3,5-Trimethylbenzene	U	1.0									
1,3-Dichlorobenzene	U	1.0									
1,3-dichloropropane	U	1.0									
1,4-Dichlorobenzene	U	1.0									
2,2-Dichloropropane	U	1.0									
2-Butanone	U	3.0									

Qualifiers:	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation l
	ND	Not Detected at the Reporting Limit	R	RPD outside accepted recovery limits	S	Spike Recovery outside accepted recs
	U	Indicates the compound was analyzed for but not detecte				

CLIENT: Leggette Brashears & Graham Inc.
 Work Order: 0805243
 Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

Sample ID	VBLK-052908Y	SampType: MBLK	TestCode: 8260MTBE11	Units: µg/L	Prep Date:	RunNo: 35683						
Client ID:	PBW	Batch ID: R35683	TestNo: SW8260B		Analysis Date: 5/29/2008	SeqNo: 458669						
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
2-Chloroethyl vinyl ether		U	1.0									
2-Chlorotoluene		U	1.0									
2-Hexanone		U	2.0									
4-Chlorotoluene		U	1.0									
4-Isopropyltoluene		U	1.0									
4-Methyl-2-pentanone		U	2.0									
Acetone		U	2.0									
Benzene		U	1.0									
Bromobenzene		U	1.0									
Bromochloromethane		U	1.0									
Bromodichloromethane		U	1.0									
Bromoform		U	1.0									
Bromomethane		U	1.0									
Carbon disulfide		U	1.0									
Carbon tetrachloride		U	1.0									
Chlorobenzene		U	1.0									
Chloroethane		U	1.0									
Chloroform		U	1.0									
Chloromethane		U	1.0									
cis-1,2-Dichloroethene		U	1.0									
cis-1,3-Dichloropropene		U	1.0									
Dibromochloromethane		U	1.0									
Dibromomethane		U	1.0									
Dichlorodifluoromethane		U	1.0									
Ethylbenzene		U	1.0									
Hexachlorobutadiene		U	1.0									
Isopropylbenzene		U	1.0									
m,p-Xylene		U	2.0									
Methyl tert-butyl ether		U	1.0									
Methylene chloride		U	1.0									
Naphthalene		U	1.0									

Qualifiers:	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation l
	ND	Not Detected at the Reporting Limit	R	RPD outside accepted recovery limits	S	Spike Recovery outside accepted reco
	U	Indicates the compound was analyzed for but not detecte				

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 0805243
Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

Sample ID	VBLK-052908Y	SampleType: MBLK	TestCode: 8260MTBE11	Units: µg/L	Prep Date:	RunNo: 35683					
Client ID:	PBW	Batch ID: R35683	TestNo: SW8260B		Analysis Date: 5/29/2008	SeqNo: 458669					
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

n-Butylbenzene	U	1.0									
n-Propylbenzene	U	1.0									
o-Xylene	U	1.0									
sec-Butylbenzene	U	1.0									
Styrene	U	1.0									
tert-Butylbenzene	U	1.0									
Tetrachloroethene	U	1.0									
Toluene	U	1.0									
trans-1,2-Dichloroethene	U	1.0									
trans-1,3-Dichloropropene	U	1.0									
Trichloroethene	U	1.0									
Trichlorofluoromethane	U	1.0									
Vinyl acetate	U	1.0									
Vinyl chloride	U	1.0									

Surr: 4-Bromofluorobenzene	46		50.00		92.6	54	134				
Surr: Dibromofluoromethane	54		50.00		108	52	132				
Surr: Toluene-d8	44		50.00		87.4	51	127				

Sample ID	V624LCS-052908Y	SampleType: LCS	TestCode: 8260MTBE11	Units: µg/L	Prep Date:	RunNo: 35683					
Client ID:	LCSW	Batch ID: R35683a	TestNo: SW8260B		Analysis Date: 5/29/2008	SeqNo: 458672					
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

1,1,1-Trichloroethane	44	1.0	50.00	0	88.7	52	137				
1,1,2,2-Tetrachloroethane	54	1.0	50.00	0	107	53	133				
1,1,2-Trichloroethane	49	1.0	50.00	0	97.6	51	130				
1,1-Dichloroethane	52	1.0	50.00	0	103	51	133				
1,1-Dichloroethene	49	1.0	50.00	0	98.1	42	133				
1,2-Dichlorobenzene	41	1.0	50.00	0	82.0	48	129				
1,2-Dichloroethane	44	1.0	50.00	0	87.7	51	130				
1,2-Dichloropropane	41	1.0	50.00	0	82.6	52	136				
1,3-Dichlorobenzene	45	1.0	50.00	0	90.3	53	132				

Qualifiers: E Value above quantitation range
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

J Analyte detected below quantitation limit
 S Spike Recovery outside accepted range

CLIENT: Leggett Brashears & Graham Inc.
Work Order: 0805243
Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

Sample ID	V624LCS-052908Y	SampleType: LCS	TestCode: 8260MTBE11	Units: µg/L	Prep Date:	RunNo: 35683					
Client ID:	LCSW	Batch ID: R35683a	TestNo: SW8260B		Analysis Date: 5/29/2008	SeqNo: 458672					
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

1,4-Dichlorobenzene	47	1.0	50.00	0	93.3	53	135				
2-Chloroethyl vinyl ether	43	1.0	50.00	0	86.6	43	125				
Benzene	50	1.0	50.00	0	100	44	133				
Bromodichloromethane	44	1.0	50.00	0	87.8	52	137				
Bromoform	46	1.0	50.00	0	91.2	43	123				
Bromomethane	42	1.0	50.00	0	84.2	36	126				
Carbon tetrachloride	46	1.0	50.00	0	92.7	48	128				
Chlorobenzene	43	1.0	50.00	0	85.9	57	135				
Chloroethane	42	1.0	50.00	0	84.9	53	147				
Chloroform	47	1.0	50.00	0	94.8	42	122				
Chloromethane	50	1.0	50.00	0	100	52	144				
cis-1,3-Dichloropropene	45	1.0	50.00	0	89.9	48	127				
Dibromochloromethane	40	1.0	50.00	0	80.5	47	125				
Ethylbenzene	41	1.0	50.00	0	82.1	53	136				
Tetrachloroethene	40	1.0	50.00	0	80.3	44	137				
Toluene	44	1.0	50.00	0	89.0	43	134				
trans-1,2-Dichloroethene	48	1.0	50.00	0	95.2	53	130				
trans-1,3-Dichloropropene	43	1.0	50.00	0	86.3	46	129				
Trichloroethene	46	1.0	50.00	0	92.4	43	138				
Trichlorofluoromethane	48	1.0	50.00	0	95.8	55	135				
Vinyl chloride	50	1.0	50.00	0	101	46	146				
Surr: 4-Bromofluorobenzene	49		50.00		98.8	54	134				
Surr: Dibromofluoromethane	53		50.00		106	52	132				
Surr: Toluene-d8	52		50.00		105	51	127				

Sample ID	VBLK-052908Y	Sample Type: MBLK	TestCode: 8260MTBE11	Units: µg/L	Prep Date:	RunNo: 35683						
Client ID:	PBW	Batch ID: R35683a	TestNo: SW8260B		Analysis Date: 5/29/2008	SeqNo: 458673						
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

1,1,1,2-Tetrachloroethane	U	1.0									
1,1,1-Trichloroethane	U	1.0									

Qualifiers: E Value above quantitation range
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

H Holding times for preparation or analysis exceeded
R RPD outside accepted recovery limits
J Analyte detected below quantitation limit
S Spike Recovery outside accepted recovery

CLIENT: Leggett Brashears & Graham Inc.
Work Order: 0805243
Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

Sample ID	VBLK-052908Y	SampleType: MBLK	TestCode: 8260MTBE11	Units: µg/L	Prep Date:	RunNo: 35683						
Client ID:	PBW	Batch ID: R35683a	TestNo: SW8260B		Analysis Date: 5/29/2008	SeqNo: 458673						
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
1,1,2,2-Tetrachloroethane		U	1.0									
1,1,2-Trichloro-1,2,2-trifluoroethane		U	1.0									
1,1,2-Trichloroethane		U	1.0									
1,1-Dichloroethane		U	1.0									
1,1-Dichloroethene		U	1.0									
1,1-Dichloropropene		U	1.0									
1,2,3-Trichlorobenzene		U	1.0									
1,2,3-Trichloropropane		U	1.0									
1,2,4-Trichlorobenzene		U	1.0									
1,2,4-Trimethylbenzene		U	1.0									
1,2-Dibromo-3-chloropropane		U	1.0									
1,2-Dibromoethane		U	1.0									
1,2-Dichlorobenzene		U	1.0									
1,2-Dichloroethane		U	1.0									
1,2-Dichloropropane		U	1.0									
1,3,5-Trimethylbenzene		U	1.0									
1,3-Dichlorobenzene		U	1.0									
1,3-dichloropropane		U	1.0									
1,4-Dichlorobenzene		U	1.0									
2,2-Dichloropropane		U	1.0									
2-Butanone		U	3.0									
2-Chloroethyl vinyl ether		U	1.0									
2-Chlorotoluene		U	1.0									
2-Hexanone		U	2.0									
4-Chlorotoluene		U	1.0									
4-Isopropyltoluene		U	1.0									
4-Methyl-2-pentanone		U	2.0									
Acetone		U	2.0									
Benzene		U	1.0									
Bromobenzene		U	1.0									
Bromochloromethane		U	1.0									

Qualifiers:	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation l
	ND	Not Detected at the Reporting Limit	R	RPD outside accepted recovery limits	S	Spike Recovery outside accepted rec
	U	Indicates the compound was analyzed for but not detecte				

CLIENT: Leggett Brashears & Graham Inc.
Work Order: 0805243
Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

Sample ID	VBLK-052908Y	SampType: MBLK	TestCode: 8260MTBE11	Units: µg/L	Prep Date:	RunNo: 35683					
Client ID:	PBW	Batch ID: R35683a	TestNo: SW8260B		Analysis Date: 5/29/2008	SeqNo: 458673					
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Bromodichloromethane	U	1.0									
Bromoform	U	1.0									
Bromomethane	U	1.0									
Carbon disulfide	U	1.0									
Carbon tetrachloride	U	1.0									
Chlorobenzene	U	1.0									
Chloroethane	U	1.0									
Chloroform	U	1.0									
Chloromethane	U	1.0									
cis-1,2-Dichloroethene	U	1.0									
cis-1,3-Dichloropropene	U	1.0									
Dibromochloromethane	U	1.0									
Dibromomethane	U	1.0									
Dichlorodifluoromethane	U	1.0									
Ethylbenzene	U	1.0									
Hexachlorobutadiene	U	1.0									
Isopropylbenzene	U	1.0									
m,p-Xylene	U	2.0									
Methyl tert-butyl ether	U	1.0									
Methylene chloride	U	1.0									
Naphthalene	U	1.0									
n-Butylbenzene	U	1.0									
n-Propylbenzene	U	1.0									
o-Xylene	U	1.0									
sec-Butylbenzene	U	1.0									
Styrene	U	1.0									
tert-Butylbenzene	U	1.0									
Tetrachloroethene	U	1.0									
Toluene	U	1.0									
trans-1,2-Dichloroethene	U	1.0									
trans-1,3-Dichloropropene	U	1.0									

Qualifiers:	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limit
	ND	Not Detected at the Reporting Limit	R	RPD outside accepted recovery limits	S	Spike Recovery outside accepted recovery
	U	Indicates the compound was analyzed for but not detected				

CLIENT: Leggett Brashears & Graham Inc.
Work Order: 0805243
Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

Sample ID	VBLK-052908Y	SampType: MBLK	TestCode: 8260MTBE11	Units: µg/L	Prep Date:	RunNo: 35683					
Client ID:	PBW	Batch ID: R35683a	TestNo: SW8260B		Analysis Date: 5/29/2008	SeqNo: 458673					
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Trichloroethene	U	1.0									
Trichlorofluoromethane	U	1.0									
Vinyl acetate	U	1.0									
Vinyl chloride	U	1.0									
Surr: 4-Bromofluorobenzene	50		50.00		100	54	134				
Surr: Dibromofluoromethane	52		50.00		105	52	132				
Surr: Toluene-d8	48		50.00		96.1	51	127				

Qualifiers:	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation l:
	ND	Not Detected at the Reporting Limit	R	RPD outside accepted recovery limits	S	Spike Recovery outside accepted reco
	U	Indicates the compound was analyzed for but not detecte				

CLIENT: Leggette Brashears & Graham Inc.
 Work Order: 0805243
 Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: FE_D

Sample ID	0805243-03C-MS	SampType: MS	TestCode: FE_D	Units: mg/L	Prep Date: 5/29/2008	RunNo: 35691					
Client ID:	WQ052708:1510NP2	Batch ID: 21529	TestNo: E200.7	SW3005A	Analysis Date: 5/30/2008	SeqNo: 458807					
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Iron	1.15	0.0200	1.000	0.1468	100	68	122				

Sample ID	0805243-03C-MSD	SampType: MSD	TestCode: FE_D	Units: mg/L	Prep Date: 5/29/2008	RunNo: 35691					
Client ID:	WQ052708:1510NP2	Batch ID: 21529	TestNo: E200.7	SW3005A	Analysis Date: 5/30/2008	SeqNo: 458808					
Analyte	Result	PQL	SPK value	SPK RefVal	%REC	LowLimit	HighLimit	RPD RefVal	%RPD	RPDLimit	Qual
Iron	1.15	0.0200	1.000	0.1468	101	68	122	1.150	0.247		20

Sample ID	PBW-052908B	SampType: MBLK	TestCode: FE_D	Units: mg/L	Prep Date: 5/29/2008	RunNo: 35691					
Client ID:	PBW	Batch ID: 21529	TestNo: E200.7	SW3005A	Analysis Date: 5/30/2008	SeqNo: 458812					
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Iron	U	0.0200									

Sample ID	LCSW-052908B	SampType: LCS	TestCode: FE_D	Units: mg/L	Prep Date: 5/29/2008	RunNo: 35691					
Client ID:	LCSW	Batch ID: 21529	TestNo: E200.7	SW3005A	Analysis Date: 5/30/2008	SeqNo: 458813					
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Iron	2.02	0.0200	2.000	0	101	68	122				

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limit
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery
 U Indicates the compound was analyzed for but not detected

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 0805243
Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: FE_T

Sample ID	PBW-052908B	SampleType: MBLK	TestCode: FE_T	Units: mg/L	Prep Date:	RunNo: 35691					
Client ID:	PBW	Batch ID: 21530	TestNo: E200.7	SW3010A	Analysis Date: 5/30/2008	SeqNo: 458748					
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Iron		U	0.0200								

Sample ID	LCSW-052908B	SampleType: LCS	TestCode: FE_T	Units: mg/L	Prep Date:	RunNo: 35691					
Client ID:	LCSW	Batch ID: 21530	TestNo: E200.7	SW3010A	Analysis Date: 5/30/2008	SeqNo: 458749					
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Iron	2.02	0.0200	2.000	0	101	68	122				

Sample ID	0805243-03B-MSD	SampleType: MSD	TestCode: FE_T	Units: mg/L	Prep Date: 5/29/2008	RunNo: 35691					
Client ID:	WQ052708:1510NP2	Batch ID: 21530	TestNo: E200.7	SW3010A	Analysis Date: 5/30/2008	SeqNo: 458778					
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Iron	2.61	0.0200	1.000	1.633	97.2	68	122				

Sample ID	0805243-03B-MSD	SampleType: MSD	TestCode: FE_T	Units: mg/L	Prep Date: 5/29/2008	RunNo: 35691					
Client ID:	WQ052708:1510NP2	Batch ID: 21530	TestNo: E200.7	SW3010A	Analysis Date: 5/30/2008	SeqNo: 458779					
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Iron	2.60	0.0200	1.000	1.633	96.4	68	122				

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation I:
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted rec
 U Indicates the compound was analyzed for but not detect

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 0805243
Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: TDS_W

Sample ID	MB-R35801	SampType: MBLK	TestCode: TDS_W	Units: mg/L	Prep Date:	RunNo: 35801						
Client ID:	PBW	Batch ID: R35801	TestNo: M2540C		Analysis Date: 6/3/2008	SeqNo: 462042						
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Total Dissolved Solids (Residue, Filtera) U 1.00

Qualifiers:	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation l
	ND	Not Detected at the Reporting Limit	R	RPD outside accepted recovery limits	S	Spike Recovery outside accepted reco
	U	Indicates the compound was analyzed for but not detecte				

Monday, June 02, 2008

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe

Order No.: 0805242

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 8 sample(s) on 5/29/2008 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The results reported herein relate only to the items tested or to the samples as received by the laboratory. This report may not be reproduced, except in full, without the approval of American Analytical Laboratories, LLC and is not considered complete without a cover page and chain of custody documentation. The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report. This package has been reviewed by American Analytical Laboratories' QA Department/Laboratory Director to comply with NELAC standards prior to report submittal.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 02-Jun-08

CLIENT: Leggette Brashears & Graham Inc.**Project:** Rowe**Lab Order:** 0805242**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0805242-01A	GWQ052708:1345NP1-1-2		5/27/2008 1:45:00 PM	5/29/2008
0805242-01B	GWQ052708:1345NP1-1-2		5/27/2008 1:45:00 PM	5/29/2008
0805242-01C	GWQ052708:1345NP1-1-2		5/27/2008 1:45:00 PM	5/29/2008
0805242-02A	GWQ052708:1350NP1-1-3		5/27/2008 1:50:00 PM	5/29/2008
0805242-02B	GWQ052708:1350NP1-1-3		5/27/2008 1:50:00 PM	5/29/2008
0805242-02C	GWQ052708:1350NP1-1-3		5/27/2008 1:50:00 PM	5/29/2008
0805242-03A	GWQ052708:1355NP1-1-4		5/27/2008 1:55:00 PM	5/29/2008
0805242-03B	GWQ052708:1355NP1-1-4		5/27/2008 1:55:00 PM	5/29/2008
0805242-03C	GWQ052708:1355NP1-1-4		5/27/2008 1:55:00 PM	5/29/2008
0805242-04A	GWQ052708:1400NP1-1-5		5/27/2008 2:00:00 PM	5/29/2008
0805242-04B	GWQ052708:1400NP1-1-5		5/27/2008 2:00:00 PM	5/29/2008
0805242-04C	GWQ052708:1400NP1-1-5		5/27/2008 2:00:00 PM	5/29/2008
0805242-05A	GWQ052708:1405NP1-1-6		5/27/2008 2:05:00 PM	5/29/2008
0805242-05B	GWQ052708:1405NP1-1-6		5/27/2008 2:05:00 PM	5/29/2008
0805242-05C	GWQ052708:1405NP1-1-6		5/27/2008 2:05:00 PM	5/29/2008
0805242-06A	GWQ052708:1410NP1-1-7		5/27/2008 2:10:00 PM	5/29/2008
0805242-06B	GWQ052708:1410NP1-1-7		5/27/2008 2:10:00 PM	5/29/2008
0805242-06C	GWQ052708:1410NP1-1-7		5/27/2008 2:10:00 PM	5/29/2008
0805242-07A	GWQ052708:1415NP1-1-8		5/27/2008 2:15:00 PM	5/29/2008
0805242-07B	GWQ052708:1415NP1-1-8		5/27/2008 2:15:00 PM	5/29/2008
0805242-07C	GWQ052708:1415NP1-1-8		5/27/2008 2:15:00 PM	5/29/2008
0805242-08A	GWQ052708:1420NP1-1-9		5/27/2008 2:20:00 PM	5/29/2008
0805242-08B	GWQ052708:1420NP1-1-9		5/27/2008 2:20:00 PM	5/29/2008
0805242-08C	GWQ052708:1420NP1-1-9		5/27/2008 2:20:00 PM	5/29/2008

TAG # / COC

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value.
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of the method allowable holding time.

American Analytical Laboratories, LLC.

Date: 02-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805242
Project: Rowe
Lab ID: 0805242-01A

Client Sample ID: GWQ052708:1345NP1-1-2
Tag Number:
Collection Date: 5/27/2008 1:45:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
1,1,1-Trichloroethane	2.9	1.0		µg/L	1	5/29/2008 4:26:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
2-Butanone	U	3.0		µg/L	1	5/29/2008 4:26:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
2-Hexanone	U	2.0		µg/L	1	5/29/2008 4:26:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	5/29/2008 4:26:00 PM
Acetone	U	2.0		µg/L	1	5/29/2008 4:26:00 PM
Benzene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
Bromobenzene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
Bromochloromethane	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
Bromodichloromethane	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
Bromoform	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
Bromomethane	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
Carbon disulfide	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
Chlorobenzene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805242
Project: Rowe
Lab ID: 0805242-01A

Client Sample ID: GWQ052708:1345NP1-1-2
Tag Number:
Collection Date: 5/27/2008 1:45:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
Chloroform	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
Chloromethane	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
Dibromochloromethane	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
Dibromomethane	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
Ethylbenzene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
Isopropylbenzene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
m,p-Xylene	U	2.0		µg/L	1	5/29/2008 4:26:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
Methylene chloride	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
Naphthalene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
n-Butylbenzene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
n-Propylbenzene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
o-Xylene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
Styrene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
Tetrachloroethene	1.8	1.0		µg/L	1	5/29/2008 4:26:00 PM
Toluene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
Trichloroethene	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
Vinyl acetate	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
Vinyl chloride	U	1.0		µg/L	1	5/29/2008 4:26:00 PM
Surr: 4-Bromofluorobenzene	110	54-134		%REC	1	5/29/2008 4:26:00 PM
Surr: Dibromofluoromethane	108	52-132		%REC	1	5/29/2008 4:26:00 PM
Surr: Toluene-d8	97.4	51-127		%REC	1	5/29/2008 4:26:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Jun-08

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** GWQ052708:1345NP1-1-2**Lab Order:** 0805242**Tag Number:****Project:** Rowe**Collection Date:** 5/27/2008 1:45:00 PM**Lab ID:** 0805242-01B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	3.00	0.0200		mg/L	1	5/30/2008 9:57:02 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 02-Jun-08**CLIENT:** Leggette Brashears & Graham Inc.**Client Sample ID:** GWQ052708:1345NP1-1-2**Lab Order:** 0805242**Tag Number:****Project:** Rowe**Collection Date:** 5/27/2008 1:45:00 PM**Lab ID:** 0805242-01C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.838	0.0200		mg/L	1	5/30/2008 9:54:59 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805242
Project: Rowe
Lab ID: 0805242-02A

Client Sample ID: GWQ052708:1350NP1-1-3
Tag Number:
Collection Date: 5/27/2008 1:50:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
2-Butanone	U	3.0		µg/L	1	5/29/2008 4:49:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
2-Hexanone	U	2.0		µg/L	1	5/29/2008 4:49:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	5/29/2008 4:49:00 PM
Acetone	U	2.0		µg/L	1	5/29/2008 4:49:00 PM
Benzene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
Bromobenzene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
Bromochloromethane	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
Bromodichloromethane	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
Bromoform	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
Bromomethane	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
Carbon disulfide	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
Chlorobenzene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805242
Project: Rowe
Lab ID: 0805242-02A

Client Sample ID: GWQ052708:1350NP1-1-3
Tag Number:
Collection Date: 5/27/2008 1:50:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
Chloroform	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
Chloromethane	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
Dibromochloromethane	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
Dibromomethane	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
Ethylbenzene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
Isopropylbenzene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
m,p-Xylene	U	2.0		µg/L	1	5/29/2008 4:49:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
Methylene chloride	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
Naphthalene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
n-Butylbenzene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
n-Propylbenzene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
o-Xylene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
Styrene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
Tetrachloroethene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
Toluene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
Trichloroethene	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
Vinyl acetate	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
Vinyl chloride	U	1.0		µg/L	1	5/29/2008 4:49:00 PM
Surr: 4-Bromofluorobenzene	98.2	54-134		%REC	1	5/29/2008 4:49:00 PM
Surr: Dibromofluoromethane	114	52-132		%REC	1	5/29/2008 4:49:00 PM
Surr: Toluene-d8	92.7	51-127		%REC	1	5/29/2008 4:49:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 02-Jun-08**CLIENT:** Leggette Brashears & Graham Inc.**Client Sample ID:** GWQ052708:1350NP1-1-3**Lab Order:** 0805242**Tag Number:****Project:** Rowe**Collection Date:** 5/27/2008 1:50:00 PM**Lab ID:** 0805242-02B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	2.08	0.0200		mg/L	1	5/30/2008 10:01:07 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 02-Jun-08**CLIENT:** Leggette Brashears & Graham Inc.**Client Sample ID:** GWQ052708:1350NP1-1-3**Lab Order:** 0805242**Tag Number:****Project:** Rowe**Collection Date:** 5/27/2008 1:50:00 PM**Lab ID:** 0805242-02C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	1.61	0.0200		mg/L	1	5/30/2008 9:59:05 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805242
Project: Rowe
Lab ID: 0805242-03A

Client Sample ID: GWQ052708:1355NP1-1-4
Tag Number:
Collection Date: 5/27/2008 1:55:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
2-Butanone	U	3.0		µg/L	1	5/29/2008 5:12:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
2-Hexanone	U	2.0		µg/L	1	5/29/2008 5:12:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	5/29/2008 5:12:00 PM
Acetone	U	2.0		µg/L	1	5/29/2008 5:12:00 PM
Benzene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
Bromobenzene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
Bromochloromethane	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
Bromodichloromethane	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
Bromoform	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
Bromomethane	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
Carbon disulfide	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
Chlorobenzene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805242
Project: Rowe
Lab ID: 0805242-03A

Client Sample ID: GWQ052708:1355NP1-1-4
Tag Number:
Collection Date: 5/27/2008 1:55:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
Chloroform	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
Chloromethane	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
Dibromochloromethane	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
Dibromomethane	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
Ethylbenzene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
Isopropylbenzene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
m,p-Xylene	U	2.0		µg/L	1	5/29/2008 5:12:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
Methylene chloride	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
Naphthalene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
n-Butylbenzene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
n-Propylbenzene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
o-Xylene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
Styrene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
Tetrachloroethene	9.9	1.0		µg/L	1	5/29/2008 5:12:00 PM
Toluene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
Trichloroethene	1.3	1.0		µg/L	1	5/29/2008 5:12:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
Vinyl acetate	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
Vinyl chloride	U	1.0		µg/L	1	5/29/2008 5:12:00 PM
Surr: 4-Bromofluorobenzene	91.8	54-134		%REC	1	5/29/2008 5:12:00 PM
Surr: Dibromofluoromethane	114	52-132		%REC	1	5/29/2008 5:12:00 PM
Surr: Toluene-d8	99.6	51-127		%REC	1	5/29/2008 5:12:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805242
Project: Rowe
Lab ID: 0805242-03B

Client Sample ID: GWQ052708:1355NP1-1-4
Tag Number:
Collection Date: 5/27/2008 1:55:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	6.13	0.0200		mg/L	1	5/30/2008 10:05:12 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 02-Jun-08**CLIENT:** Leggette Brashears & Graham Inc.**Client Sample ID:** GWQ052708:1355NP1-1-4**Lab Order:** 0805242**Tag Number:****Project:** Rowe**Collection Date:** 5/27/2008 1:55:00 PM**Lab ID:** 0805242-03C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	4.14	0.0200		mg/L	1	5/30/2008 10:03:09 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805242
Project: Rowe
Lab ID: 0805242-04A

Client Sample ID: GWQ052708:1400NP1-1-5
Tag Number:
Collection Date: 5/27/2008 2:00:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
2-Butanone	U	3.0		µg/L	1	5/29/2008 5:34:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
2-Hexanone	U	2.0		µg/L	1	5/29/2008 5:34:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	5/29/2008 5:34:00 PM
Acetone	U	2.0		µg/L	1	5/29/2008 5:34:00 PM
Benzene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
Bromobenzene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
Bromochloromethane	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
Bromodichloromethane	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
Bromoform	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
Bromomethane	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
Carbon disulfide	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
Chlorobenzene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 02-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805242
Project: Rowe
Lab ID: 0805242-04A

Client Sample ID: GWQ052708:1400NP1-1-5
Tag Number:
Collection Date: 5/27/2008 2:00:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
Chloroform	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
Chloromethane	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
Dibromochloromethane	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
Dibromomethane	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
Ethylbenzene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
Isopropylbenzene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
m,p-Xylene	U	2.0		µg/L	1	5/29/2008 5:34:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
Methylene chloride	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
Naphthalene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
n-Butylbenzene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
n-Propylbenzene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
o-Xylene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
Styrene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
Tetrachloroethene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
Toluene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
Trichloroethene	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
Vinyl acetate	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
Vinyl chloride	U	1.0		µg/L	1	5/29/2008 5:34:00 PM
Surr: 4-Bromofluorobenzene	97.1	54-134		%REC	1	5/29/2008 5:34:00 PM
Surr: Dibromofluoromethane	110	52-132		%REC	1	5/29/2008 5:34:00 PM
Surr: Toluene-d8	93.1	51-127		%REC	1	5/29/2008 5:34:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 02-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805242
Project: Rowe
Lab ID: 0805242-04B

Client Sample ID: GWQ052708:1400NP1-1-5
Tag Number:
Collection Date: 5/27/2008 2:00:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	0.0522	0.0200		mg/L	1	5/30/2008 10:09:19 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 02-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805242
Project: Rowe
Lab ID: 0805242-04C

Client Sample ID: GWQ052708:1400NP1-1-5
Tag Number:
Collection Date: 5/27/2008 2:00:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0113	0.0200	J	mg/L	1	5/30/2008 10:07:16 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805242
Project: Rowe
Lab ID: 0805242-05A

Client Sample ID: GWQ052708:1405NP1-1-6
Tag Number:
Collection Date: 5/27/2008 2:05:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
1,1,1-Trichloroethane	6.5	1.0		µg/L	1	5/29/2008 5:56:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
2-Butanone	U	3.0		µg/L	1	5/29/2008 5:56:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
2-Hexanone	U	2.0		µg/L	1	5/29/2008 5:56:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	5/29/2008 5:56:00 PM
Acetone	U	2.0		µg/L	1	5/29/2008 5:56:00 PM
Benzene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
Bromobenzene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
Bromochloromethane	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
Bromodichloromethane	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
Bromoform	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
Bromomethane	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
Carbon disulfide	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
Chlorobenzene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805242
Project: Rowe
Lab ID: 0805242-05A

Client Sample ID: GWQ052708:1405NP1-1-6
Tag Number:
Collection Date: 5/27/2008 2:05:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
Chloroform	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
Chloromethane	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
Dibromochloromethane	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
Dibromomethane	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
Ethylbenzene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
Isopropylbenzene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
m,p-Xylene	U	2.0		µg/L	1	5/29/2008 5:56:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
Methylene chloride	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
Naphthalene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
n-Butylbenzene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
n-Propylbenzene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
o-Xylene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
Styrene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
Tetrachloroethene	17	1.0		µg/L	1	5/29/2008 5:56:00 PM
Toluene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
Trichloroethene	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
Vinyl acetate	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
Vinyl chloride	U	1.0		µg/L	1	5/29/2008 5:56:00 PM
Surr: 4-Bromofluorobenzene	105	54-134		%REC	1	5/29/2008 5:56:00 PM
Surr: Dibromofluoromethane	112	52-132		%REC	1	5/29/2008 5:56:00 PM
Surr: Toluene-d8	101	51-127		%REC	1	5/29/2008 5:56:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 02-Jun-08**CLIENT:** Leggette Brashears & Graham Inc.**Client Sample ID:** GWQ052708:1405NP1-1-6**Lab Order:** 0805242**Tag Number:****Project:** Rowe**Collection Date:** 5/27/2008 2:05:00 PM**Lab ID:** 0805242-05B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	0.124	0.0200		mg/L	1	5/30/2008 10:21:08 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 02-Jun-08**CLIENT:** Leggette Brashears & Graham Inc.**Client Sample ID:** GWQ052708:1405NP1-1-6**Lab Order:** 0805242**Tag Number:****Project:** Rowe**Collection Date:** 5/27/2008 2:05:00 PM**Lab ID:** 0805242-05C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0646	0.0200		mg/L	1	5/30/2008 10:19:04 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805242
Project: Rowe
Lab ID: 0805242-06A

Client Sample ID: GWQ052708:1410NP1-1-7
Tag Number:
Collection Date: 5/27/2008 2:10:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
1,1,1-Trichloroethane	1.2	1.0		µg/L	1	5/29/2008 6:19:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
2-Butanone	U	3.0		µg/L	1	5/29/2008 6:19:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
2-Hexanone	U	2.0		µg/L	1	5/29/2008 6:19:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	5/29/2008 6:19:00 PM
Acetone	U	2.0		µg/L	1	5/29/2008 6:19:00 PM
Benzene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
Bromobenzene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
Bromochloromethane	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
Bromodichloromethane	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
Bromoform	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
Bromomethane	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
Carbon disulfide	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
Chlorobenzene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805242
Project: Rowe
Lab ID: 0805242-06A

Client Sample ID: GWQ052708:1410NP1-1-7
Tag Number:
Collection Date: 5/27/2008 2:10:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
Chloroform	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
Chloromethane	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
Dibromochloromethane	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
Dibromomethane	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
Ethylbenzene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
Isopropylbenzene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
m,p-Xylene	U	2.0		µg/L	1	5/29/2008 6:19:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
Methylene chloride	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
Naphthalene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
n-Butylbenzene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
n-Propylbenzene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
o-Xylene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
Styrene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
Tetrachloroethene	10	1.0		µg/L	1	5/29/2008 6:19:00 PM
Toluene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
Trichloroethene	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
Vinyl acetate	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
Vinyl chloride	U	1.0		µg/L	1	5/29/2008 6:19:00 PM
Surr: 4-Bromofluorobenzene	109	54-134		%REC	1	5/29/2008 6:19:00 PM
Surr: Dibromofluoromethane	112	52-132		%REC	1	5/29/2008 6:19:00 PM
Surr: Toluene-d8	96.6	51-127		%REC	1	5/29/2008 6:19:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 02-Jun-08**CLIENT:** Leggette Brashears & Graham Inc.**Client Sample ID:** GWQ052708:1410NP1-1-7**Lab Order:** 0805242**Tag Number:****Project:** Rowe**Collection Date:** 5/27/2008 2:10:00 PM**Lab ID:** 0805242-06B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	0.127	0.0200		mg/L	1	5/30/2008 10:25:14 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 02-Jun-08**CLIENT:** Leggette Brashears & Graham Inc.**Client Sample ID:** GWQ052708:1410NP1-1-7**Lab Order:** 0805242**Tag Number:****Project:** Rowe**Collection Date:** 5/27/2008 2:10:00 PM**Lab ID:** 0805242-06C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0399	0.0200		mg/L	1	5/30/2008 10:23:11 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805242
Project: Rowe
Lab ID: 0805242-07A

Client Sample ID: GWQ052708:1415NP1-1-8
Tag Number:
Collection Date: 5/27/2008 2:15:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
1,1,1-Trichloroethane	1.1	1.0		µg/L	1	5/29/2008 6:41:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
2-Butanone	U	3.0		µg/L	1	5/29/2008 6:41:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
2-Hexanone	U	2.0		µg/L	1	5/29/2008 6:41:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	5/29/2008 6:41:00 PM
Acetone	U	2.0		µg/L	1	5/29/2008 6:41:00 PM
Benzene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
Bromobenzene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
Bromochloromethane	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
Bromodichloromethane	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
Bromoform	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
Bromomethane	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
Carbon disulfide	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
Chlorobenzene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805242
Project: Rowe
Lab ID: 0805242-07A

Client Sample ID: GWQ052708:1415NP1-1-8
Tag Number:
Collection Date: 5/27/2008 2:15:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
Chloroform	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
Chloromethane	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
Dibromochloromethane	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
Dibromomethane	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
Ethylbenzene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
Isopropylbenzene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
m,p-Xylene	U	2.0		µg/L	1	5/29/2008 6:41:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
Methylene chloride	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
Naphthalene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
n-Butylbenzene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
n-Propylbenzene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
o-Xylene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
Styrene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
Tetrachloroethene	1.4	1.0		µg/L	1	5/29/2008 6:41:00 PM
Toluene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
Trichloroethene	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
Vinyl acetate	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
Vinyl chloride	U	1.0		µg/L	1	5/29/2008 6:41:00 PM
Surr: 4-Bromofluorobenzene	103	54-134		%REC	1	5/29/2008 6:41:00 PM
Surr: Dibromofluoromethane	121	52-132		%REC	1	5/29/2008 6:41:00 PM
Surr: Toluene-d8	110	51-127		%REC	1	5/29/2008 6:41:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Jun-08

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** GWQ052708:1415NP1-1-8**Lab Order:** 0805242**Tag Number:****Project:** Rowe**Collection Date:** 5/27/2008 2:15:00 PM**Lab ID:** 0805242-07B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	5.26	0.0200		mg/L	1	5/30/2008 10:29:19 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 02-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805242
Project: Rowe
Lab ID: 0805242-07C

Client Sample ID: GWQ052708:1415NP1-1-8
Tag Number:
Collection Date: 5/27/2008 2:15:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	2.42	0.0200		mg/L	1	5/30/2008 10:27:17 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805242
Project: Rowe
Lab ID: 0805242-08A

Client Sample ID: GWQ052708:1420NP1-1-9
Tag Number:
Collection Date: 5/27/2008 2:20:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
2-Butanone	U	3.0		µg/L	1	5/29/2008 7:04:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
2-Hexanone	U	2.0		µg/L	1	5/29/2008 7:04:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	5/29/2008 7:04:00 PM
Acetone	U	2.0		µg/L	1	5/29/2008 7:04:00 PM
Benzene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
Bromobenzene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
Bromochloromethane	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
Bromodichloromethane	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
Bromoform	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
Bromomethane	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
Carbon disulfide	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
Chlorobenzene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805242
Project: Rowe
Lab ID: 0805242-08A

Client Sample ID: GWQ052708:1420NP1-1-9
Tag Number:
Collection Date: 5/27/2008 2:20:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
Chloroform	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
Chloromethane	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
Dibromochloromethane	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
Dibromomethane	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
Ethylbenzene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
Isopropylbenzene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
m,p-Xylene	U	2.0		µg/L	1	5/29/2008 7:04:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
Methylene chloride	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
Naphthalene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
n-Butylbenzene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
n-Propylbenzene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
o-Xylene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
Styrene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
Tetrachloroethene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
Toluene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
Trichloroethene	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
Vinyl acetate	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
Vinyl chloride	U	1.0		µg/L	1	5/29/2008 7:04:00 PM
Surr: 4-Bromofluorobenzene	97.8	54-134		%REC	1	5/29/2008 7:04:00 PM
Surr: Dibromofluoromethane	114	52-132		%REC	1	5/29/2008 7:04:00 PM
Surr: Toluene-d8	94.5	51-127		%REC	1	5/29/2008 7:04:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Jun-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0805242
Project: Rowe
Lab ID: 0805242-08B

Client Sample ID: GWQ052708:1420NP1-1-9
Tag Number:
Collection Date: 5/27/2008 2:20:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	9.68	0.0200		mg/L	1	5/30/2008 10:33:24 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 02-Jun-08**CLIENT:** Leggette Brashears & Graham Inc.**Client Sample ID:** GWQ052708:1420NP1-1-9**Lab Order:** 0805242**Tag Number:****Project:** Rowe**Collection Date:** 5/27/2008 2:20:00 PM**Lab ID:** 0805242-08C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.579	0.0200		mg/L	1	5/30/2008 10:31:21 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

H8E290110 Analytical Report	1
Sample Receipt Documentation	15
Total Number of Pages	17

ANALYTICAL REPORT


Rowe-NABSAG 0401

Lot #: H8E290110

Mark Goldberg

Leggette, Brashears & Graham,
4 Research Drive
Suite #301
Shelton, CT 06484

TESTAMERICA LABORATORIES, INC.



Jamie A. McKinney
Project Manager

May 30, 2008

ANALYTICAL METHODS SUMMARY

H8E290110

<u>PARAMETER</u>	<u>ANALYTICAL METHOD</u>
Volatile Organics by TO15	EPA-2 TO-15

References:

EPA-2 "Compendium of Methods for the Determination of Toxic
Organic Compounds in Ambient Air", EPA-625/R-96/010b,
January 1999.

SAMPLE SUMMARY

H8E290110

<u>WO #</u>	<u>SAMPLE#</u>	<u>CLIENT SAMPLE ID</u>	<u>SAMPLED DATE</u>	<u>SAMP TIME</u>
KN14X	001	AQ052708:1700NP4-1	05/27/08	17:00
KN147	002	AQ052708:1705NP4-2	05/27/08	17:05
KN148	003	AQ052708:1710NP4-3	05/27/08	17:10

NOTE(S) :

- The analytical results of the samples listed above are presented on the following pages.
- All calculations are performed before rounding to avoid round-off errors in calculated results.
- Results noted as "ND" were not detected at or above the stated limit.
- This report must not be reproduced, except in full, without the written approval of the laboratory.
- Results for the following parameters are never reported on a dry weight basis: color, corrosivity, density, flashpoint, ignitability, layers, odor, paint filter test, pH, porosity pressure, reactivity, redox potential, specific gravity, spot tests, solids, solubility, temperature, viscosity, and weight.

PROJECT NARRATIVE

H8E290110

The results reported herein are applicable to the samples submitted for analysis only.

This report shall not be reproduced except in full, without the written approval of the laboratory.

The original chain of custody documentation is included with this report.

Sample Receipt

The "Relinquished by" field on the chain of custody documentation did not contain a signature.

Quality Control and Data Interpretation

Unless otherwise noted, all holding times and QC criteria were met and the test results shown in this report meet all applicable NELAC requirements.

The samples were received on 5/29/08 in Tedlar bags and analyzed within 72 hours of sampling.

The EPA method requires that all target analytes in the continuing calibration verification standard be within 30% difference from the initial calibration. The laboratory standard operating procedure allows up to four analytes in the calibration verification to be $\leq 40\%$ difference from the initial calibration. The calibration verification analyzed on 5/29/08 (LCS for batch 8151053) exhibited a %difference of $>30\%$ but $\leq 40\%$ for chloromethane, carbon disulfide and vinyl chloride.

TestAmerica Knoxville maintains the following certifications, approvals and accreditations: Arkansas DEQ Cert. #05-043-0, California DHS ELAP Cert. #2423, Colorado DPHE, Connecticut DPH Cert. #PH-0223, Florida DOH Cert. #E87177, Georgia DNR Cert. #906, Hawaii DOH, Illinois EPA Cert. #000687, Indiana DOH Cert. #C-TN-02, Iowa DNR Cert. #375, Kansas DHE Cert. #E-10349, Kentucky DEP Lab ID #90101, Louisiana DEQ Cert. #03079, Louisiana DOHH Cert. #LA030024, Maryland DHMH Cert. #277, Massachusetts DEP Cert. #M-TN009, Michigan DEQ Lab ID #9933, New Jersey DEP Cert. #TN001, New York DOH Lab #10781, North Carolina DPH Lab ID #21705, North Carolina DEHNR Cert. #64, Ohio EPA VAP Cert. #CL0059, Oklahoma DEQ ID #9415, Pennsylvania DEP Cert. #68-00576, South Carolina DHEC Lab ID #84001001, Tennessee DOH Lab ID #02014, Utah DOH Cert. #QUAN3, Virginia DGS Lab ID #00165, Washington DOE Lab #C120, West Virginia DEP Cert. #345, Wisconsin DNR Lab ID #998044300, Naval Facilities Engineering Service Center and USDA Soil Permit #S-46424. This list of approvals is subject to change and does not imply that laboratory certification is available for all parameters reported in this environmental sample data report.

Sample Data Summary

Leggette, Brashears & Graham, Inc.

Client Sample ID: AQ052708:1700NP4-1

GC/MS Volatiles

Lot-Sample # H8E290110 - 001

Work Order # KN14X1AA

Matrix.....: AIR

Date Sampled...: 05/27/2008

Date Received...: 05/29/2008

Prep Date.....: 05/29/2008

Analysis Date...: 05/29/2008

Prep Batch #.....: 8151053

Dilution Factor.: 5

Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	1.0	ND	3.2
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
Carbon disulfide	2.5	2.5	7.9	7.8
Carbon tetrachloride	ND	1.0	ND	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	ND	1.0	ND	2.6
Chloroform	1.3	1.0	6.2	4.9
Chloromethane	1.6	2.5	3.4	5.2
1,1-Dichloroethane	2.5	1.0	10	4.0
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	ND	1.0	ND	4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
1,1-Dichloroethene	0.67	1.0	2.7	4.0
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
Methylene chloride	0.87	2.5	3.0	8.7
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
Tetrachloroethene	11	1.0	77	6.8
Toluene	0.32	1.0	1.2	3.8
1,1,1-Trichloroethane	5.1	1.0	28	5.5
1,1,2-Trichloroethane	ND	1.0	ND	5.5
Trichloroethene	0.84	1.0	4.5	5.4
Vinyl chloride	ND	1.0	ND	2.6
m-Xylene & p-Xylene	ND	1.0	ND	4.3
o-Xylene	ND	1.0	ND	4.3

SURROGATE

PERCENT
RECOVERYLABORATORY
CONTROL
LIMITS (%)

1,2-Dichloroethane-d4
Toluene-d8
4-Bromofluorobenzene

112
100
99

70 - 130
70 - 130
70 - 130

Leggette, Brashears & Graham, Inc.

Client Sample ID: AQ052708:1700NP4-1

GC/MS Volatiles

Lot-Sample # H8E290110 - 001

Work Order # KN14X1AA

Matrix.....: AIR

Qualifiers

B Method blank contamination. The associated method blank contains the target analyte at a reportable level.

J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.
 Client Sample ID: AQ052708:1705NP4-2
 GC/MS Volatiles

Lot-Sample # H8E290110 - 002 Work Order # KN1471AA Matrix.....: AIR

Date Sampled...: 05/27/2008 Date Received...: 05/29/2008
 Prep Date.....: 05/29/2008 Analysis Date...: 05/29/2008
 Prep Batch #.....: 8151053
 Dilution Factor.: 5 Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	1.0	ND	3.2
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
Carbon disulfide	2.6	2.5	8.1	7.8
Carbon tetrachloride	ND	1.0	ND	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	ND	1.0	ND	2.6
Chloroform	2.0	1.0	9.8	4.9
Chloromethane	1.2	2.5	2.4 J	5.2
1,1-Dichloroethane	5.1	1.0	21	4.0
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	ND	1.0	ND	4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
1,1-Dichloroethene	1.0	1.0	4.2	4.0
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
Methylene chloride	1.6	2.5	5.4 J B	8.7
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
Tetrachloroethene	6.5	1.0	44	6.8
Toluene	0.27	1.0	1.0 J	3.8
1,1,1-Trichloroethane	15	1.0	81	5.5
1,1,2-Trichloroethane	ND	1.0	ND	5.5
Trichloroethene	1.4	1.0	7.5	5.4
Vinyl chloride	ND	1.0	ND	2.6
m-Xylene & p-Xylene	ND	1.0	ND	4.3
o-Xylene	ND	1.0	ND	4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	112	70 - 130
Toluene-d8	102	70 - 130
4-Bromofluorobenzene	100	70 - 130

Leggette, Brashears & Graham, Inc.

Client Sample ID: AQ052708:1705NP4-2

GC/MS Volatiles

Lot-Sample # H8E290110 - 002

Work Order # KN1471AA

Matrix.....: AIR

Qualifiers

B Method blank contamination. The associated method blank contains the target analyte at a reportable level.

J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.
 Client Sample ID: AQ052708:1710NP4-3
 GC/MS Volatiles

Lot-Sample # H8E290110 - 003 Work Order # KN1481AA Matrix.....: AIR

Date Sampled...: 05/27/2008 Date Received...: 05/29/2008
 Prep Date.....: 05/29/2008 Analysis Date...: 05/29/2008
 Prep Batch #.....: 8151053
 Dilution Factor.: 5 Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	1.0	ND	3.2
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
Carbon disulfide	1.5	2.5	4.6 J	7.8
Carbon tetrachloride	ND	1.0	ND	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	ND	1.0	ND	2.6
Chloroform	1.2	1.0	5.7	4.9
Chloromethane	1.3	2.5	2.7 J	5.2
1,1-Dichloroethane	3.3	1.0	13	4.0
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	0.35	1.0	1.4 J	4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
1,1-Dichloroethene	0.99	1.0	3.9 J	4.0
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
Methylene chloride	2.5	2.5	8.8 B	8.7
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
Tetrachloroethene	ND	1.0	ND	6.8
Toluene	0.66	1.0	2.5 J	3.8
1,1,1-Trichloroethane	8.2	1.0	45	5.5
1,1,2-Trichloroethane	ND	1.0	ND	5.5
Trichloroethene	ND	1.0	ND	5.4
Vinyl chloride	ND	1.0	ND	2.6
m-Xylene & p-Xylene	ND	1.0	ND	4.3
o-Xylene	ND	1.0	ND	4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	113	70 - 130
Toluene-d8	99	70 - 130
4-Bromofluorobenzene	101	70 - 130

Leggette, Brashears & Graham, Inc.

Client Sample ID: AQ052708:1710NP4-3

GC/MS Volatiles

Lot-Sample # H8E290110 - 003 Work Order # KN1481AA Matrix.....: AIR

Qualifiers

B Method blank contamination. The associated method blank contains the target analyte at a reportable level.
J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting
Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.
 Client Sample ID: INTRA-LAB BLANK
 GC/MS Volatiles

Lot-Sample # H8E300000 - 053B Work Order # KN3641AA Matrix.....: AIR

Prep Date.....: 05/21/2008 Date Received...: 05/27/2008
 Prep Date.....: 05/29/2008 Analysis Date...: 05/29/2008
 Prep Batch #.....: 8151053
 Dilution Factor.: 1 Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	0.20	ND	0.64
Bromodichloromethane	ND	0.20	ND	1.3
Bromoform	ND	0.20	ND	2.1
Bromomethane	ND	0.20	ND	0.78
Carbon disulfide	ND	0.50	ND	1.6
Carbon tetrachloride	ND	0.20	ND	1.3
Chlorobenzene	ND	0.20	ND	0.92
Dibromochloromethane	ND	0.20	ND	1.7
Chloroethane	ND	0.20	ND	0.53
Chloroform	ND	0.20	ND	0.98
Chloromethane	ND	0.50	ND	1.0
1,1-Dichloroethane	ND	0.20	ND	0.81
1,2-Dichloroethane	ND	0.20	ND	0.81
cis-1,2-Dichloroethene	ND	0.20	ND	0.79
trans-1,2-Dichloroethene	ND	0.20	ND	0.79
1,1-Dichloroethene	ND	0.20	ND	0.79
1,2-Dichloropropane	ND	0.20	ND	0.92
cis-1,3-Dichloropropene	ND	0.20	ND	0.91
trans-1,3-Dichloropropene	ND	0.20	ND	0.91
Ethylbenzene	ND	0.20	ND	0.87
Methylene chloride	0.10	0.50	0.36 J	1.7
Styrene	ND	0.20	ND	0.85
1,1,2,2-Tetrachloroethane	ND	0.20	ND	1.4
Tetrachloroethene	ND	0.20	ND	1.4
Toluene	ND	0.20	ND	0.75
1,1,1-Trichloroethane	ND	0.20	ND	1.1
1,1,2-Trichloroethane	ND	0.20	ND	1.1
Trichloroethene	ND	0.20	ND	1.1
Vinyl chloride	ND	0.20	ND	0.51
m-Xylene & p-Xylene	ND	0.20	ND	0.87
o-Xylene	ND	0.20	ND	0.87

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	119	70 - 130
Toluene-d8	96	70 - 130
4-Bromofluorobenzene	104	70 - 130

Leggette, Brashears & Graham, Inc.
Client Sample ID: INTRA-LAB BLANK
GC/MS Volatiles

Lot-Sample # H8E300000 - 053B Work Order # KN3641AA Matrix.....: AIR

Qualifiers

J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.
 Client Sample ID: CHECK SAMPLE
 GC/MS Volatiles

Lot-Sample # H8E300000 - 053C Work Order # KN3641AC Matrix.....: AIR

Prep Date.....: 05/21/2008 Date Received...: 05/27/2008
 Prep Date.....: 05/29/2008 Analysis Date...: 05/29/2008
 Prep Batch #.....: 8151053
 Dilution Factor.: 1 Method.....: TO-15

PARAMETER	SPIKE AMOUNT (ppb(v/v))	MEASURED AMOUNT (ppb(v/v))	SPIKE AMOUNT (ug/m3)	MEASURED AMOUNT (ug/m3)	PERCENT RECOVERY	RECOVERY LIMITS
Benzene	6.25	6.08	20	19	97	70 - 130
Chlorobenzene	6.25	5.52	29	25	88	70 - 130
1,1-Dichloroethene	6.25	8.05	25	32	129	70 - 130
Toluene	6.25	5.74	24	22	92	70 - 130
Trichloroethene	6.25	6.42	34	35	103	70 - 130

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	108	70 - 130
Toluene-d8	108	70 - 130
4-Bromofluorobenzene	108	70 - 130

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting
 Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Sample Receipt Documentation

STL Knoxville

5815 Middlebrook Pike • Knoxville, TN 37921-5947
Phone: (865) 291-3000 • Fax: (865) 584-4315
Receiving: (865) 291-3031

ANALYSIS REQUEST AND CHAIN OF CUSTODY RECORD*

HSE-240110

Reference Document No.

Page 1 of 1

Bill to: 5

Project Name/No. 1 Rowe
Sample Team Members 2 STH
Profit Center No. 3
Project Manager 4 M. Goldberg
Purchase Order No. 6 NAB3AG-
Required Report Date 11

Samples Shipment Date 7 5/22/08
Lab Destination 8 STL
Lab Contact 9 S. McKinney
Project Contact / Phone 12
Carrier / Waybill No. 13

Report to: 10 M. Goldberg
LBG
4 Research Dr.
Shelton, CT 06484

ONE CONTAINER PER LINE

Sample 14 Number	Sample 15 Type	Date/Time 16 Collected	Container 17 Type	Sample 18 Volume	Pre- 19 servative	Requested Testing 20 Program	Condition on Receipt 21 Lab use only
AQ052708:1700NP4-1	Air	5/22/08 1700	Taylor Bag	1 liter	None	TO IS	Custody seals intact ☒ N NA
AQ052708:1705NP4-2		5/22/08 1705				TO IS	Temperature received at <u>AMBIENT</u>
AQ052708:1710NP4-3		5/22/08 1710				TO IS	Received by <u>NAB</u> Date <u>5-22-08</u>
							Number of packages <u>1 CD 14R</u>
							Tracking # <u>79894973 7673</u>

Special Instructions: 23

Possible Hazard Identification: 24

Non-Hazard ☒ Flammable ☐ Skin Irritant ☐ Poison B ☐ Unknown ☐ Sample Disposal: 25
Return to Client ☐ Disposal by Lab ☒ Archive (mos.)

Turnaround Time Required: 26

Normal ☒ Rush ☐

QC Level: 27

I. ☐ II. ☐ III. ☐

Project Specific (specify):

1. Relinquished by 28

(Signature / Affiliation)

Date:

Time:

1. Received by 28

(Signature / Affiliation)

Date:

Time:

1. Relinquished by

(Signature / Affiliation)

Date:

Time:

1. Received by

(Signature / Affiliation)

Date:

Time:

Comments: 29

TESTAMERICA KNOXVILLE SAMPLE RECEIPT/CONDITION UPON RECEIPT ANOMALY CHECKLIST

Client: BS6

Project: RONF

Lot Number: H8E290110

Review Items	Yes	No	NA	If No, what was the problem?	Comments/Actions Taken
1. Do sample container labels match COC? (IDs, Dates, Times)	☒			☐ 1a Do not match COC ☐ 1b Incomplete information ☐ 1c Marking smeared ☐ 1d Label torn ☐ 1e No label ☐ 1f COC not received ☐ 1g Other:	<u>14A</u>
2. Is the cooler temperature within limits? (> freezing temp. of water to 6°C; NC, 1668, 1613B: 0-4°C; VOST: 10°C; MA: 2-6°C)			☒	☐ 2a Temp Blank = _____ ☐ 2b Cooler Temp = _____	
3. Were samples received with correct chemical preservative (excluding Encore)?			☒	☐ 3a Sample preservative = _____	
4. Were custody seals present/intact on cooler and/or containers?	☒			☐ 4a Not present ☐ 4b Not intact ☐ 4c Other:	
5. Were all of the samples listed on the COC received?	☒			☐ 5a Samples received-not on COC ☐ 5b Samples not received-on COC	
6. Were all of the sample containers received intact?	☒			☐ 6a Leaking ☐ 6b Broken	
7. Were VOA samples received without headspace?	☒			☐ 7a Headspace (VOA only)	
8. Were samples received in appropriate containers?	☒			☐ 8a Improper container	
9. Did you check for residual chlorine, if necessary?				☐ 9a Could not be determined due to matrix interference	
10. Were samples received within holding time?	☒			☐ 10a Holding time expired	
11. For rad samples, was sample activity info. provided?				☒ Incomplete information	
12. For SOG water samples (1613B, 1668A, 8290, LR PAHs), do samples have visible solids present?				If yes & appears to be > 1%, was SOG notified?	
13. Are the shipping containers intact?	☒			☐ 13a Leaking ☐ 13b Other:	
14. Was COC relinquished? (Signed/Dated/Timed)	☒			☒ 14a Not relinquished	
15. Are tests/parameters listed for each sample?	☒			☐ 15a Incomplete information	
16. Is the matrix of the samples noted?	☒			☐ 15a Incomplete information	
17. Is the date/time of sample collection noted?	☒			☐ 15a Incomplete information	
18. Is the client and project name/# identified?	☒			☐ 15a Incomplete information	
19. Was the sampler identified on the COC?	☒			☐ 15a Incomplete information	
Quote #: <u>69610</u>				PM Instructions:	

Sample Receiving Associate: Dwight Danner Date: 5-26-08

QA026R19.doc, 080707