

National Heatset Printing Site - 1 Adams Boulevard, Farmingdale, NY - Site
 Project: Management
 Contractors: EA Engineering and Preferred Environmental Services

EA Engineering Job No: 1447429
 Site No: 152140
 EA Project Manager: James Hayward

DAILY REPORT

Day:

S	M	T	W	TH	F	S
---	---	---	---	----	---	---

 Date: 10-May-12
 REPORT No. _____
 PAGE No. 1
 PREPARED BY: Rob Peterson TITLE: Geologist

WEATHER	Bright Sun	Partly Cloudy	Overcast	Rain	Snow
TEMP	To 32	32-50	50-70	70-85	85 and up
WIND	Light	Moderate	High		
HUMIDITY	Dry	Moderate	Humid		
WIND DIR	NE	NW	SE	SW	
	N	S	E	W	

AVERAGE FIELD FORCE

Name of Contractor	Title	Hours Worked	Remarks
Rob Peterson	Geologist	10:11 - 11:00	EA Engineering

VISITORS

Name	Time (From - To)	Representing	Remarks
None	NA	NA	NA

EQUIPMENT AT THE SITE

I = Idle W = Working

1. Camera - W	3. Pressure Gauges - W	5. Vacuum Pump - W
2. PID - W	4. Velocity & Temperature Meter - W	

OPERATION & MAINTENANCE ACTIVITIES

EA/Preferred Site Representative: Rob Peterson - EA

DESCRIPTION OF WORK PERFORMED AND OBSERVED

On May 9, 2012 Verizon installed a phone line to Treatment System #1 and Gray Electric installed an additional relay in System #1 control box. The relay was installed in order for the auto-dialer (Sensaphone) to monitor system power supply. The phone line was connected to the Sensaphone mounted on the control panel inside Treatment System #1. The Sensaphone was installed by Gray Electric on April 30, 2012. The Sensaphone was programmed by EA with the following parameters: Date & Time, zones (Temp. & System Power Supply), alarm limits, voice messages (zones & site ID), and dial out telephone numbers. Currently the dial out number is set for Rob Peterson (EA). The Sensaphone telephone number is 631-752-5404 and the alarm acknowledgment code is 555. Once the Sensaphone was programmed, EA simulated a power loss alarm and the Sensaphone dialed out and performed correctly.

10:11 - Rob Peterson (EA) on-site. System #1 and System #2 operating upon arrival.

10:15 - Start System #2 O&M. NOTE: VOC monitoring of influent and effluent was collected in parts per billion (ppb) to achieve greater definition in concentration data (see page 5 for concentrations).

10:33 - System #2 O&M complete. System performing satisfactorily.

10:36 - Start System #1 O&M. NOTE: VOC monitoring of influent and effluent was collected in parts per billion (ppb) to achieve greater definition in concentration data (see page 3 for concentrations).

10:55 - System #1 O&M complete. System performing satisfactorily.

11:00 - O&M for both systems complete. EA locked both systems and all parties off-site.

☒ - Designates report is continued on additional pages

EA/Preferred Site Representative: Rob Peterson (EA)

Project Manager: James Hayward

Page 1 of 5

EA Engineering

6712 Brooklawn Parkway, Suite 104, Syracuse, New York 13211

National Heatset Printing Site, Farmingdale, NY

Contract No. D004441, Site No. 152140

Monitoring Table May 10, 2012

DATE: 05/10/2012

DAY: Thursday

TECHNICIAN: Rob Peterson

Weather: 65F, Partly Cloudy

TCE Groundwater Treatment System #1 STATUS: ON OFF

I: System Data Collection

Total Run Time Meter Reading: 11,160.3 hours

System Running at: 30.0 Hz

Temperature Monitoring					
Time	Location	TI-ID	Temperature deg. C	Temperature deg. F	Comments
10:38	Extracted From Well	TI-01	16.0	60.8	DDC-1
10:38	Extracted From Well	TI-02	17.0	62.6	DDC-2
10:40	Pre-Heater Outlet	TI-03	25.0	77.0	Post Shell and Tubing
10:39	Pre-Heater Input	TI-04	18.0	64.4	Before Shell and Tubing
10:38	After Cooler Outlet	TI-05	24.0	75.2	Post Cooler Reading
10:39	After Cooler Input	TI-06	36.0	96.8	Before Cooler Reading
10:39	Blower Outlet	TI-07	47.0	116.6	Going to Pre-heater
10:40	Between GAC Units	TI-08	24.0	75.2	After GAC #1
10:40	GAC Unit Output	TI-09	24.0	75.2	After GAC #2

Pressure/Vacuum Monitoring				
Time	Location	PI/VI-ID	Pressure	Comments
10:37	Discharge to Well	PI-01	2.3 PSI	DDC-1
10:37	Discharge to Well	PI-02	2.4 PSI	DDC-2
10:39	Drum	PI-03	-29.0 in. H2O	Vacuum Reading Going to Blower

Flow Readings			
Time	IF-ID	Location	Flow (SCFM)
10:37	FI-01	Extracted From DDC-1	---
10:37	FI-02	Extracted From DDC-2	190

Comments:

1) Flow meter F0-1 not functioning. Air flow visually inspected at DDC-1 well head. Determined that DDC-1 aerating sufficiently. Replacement flow meter is currently on back order and is expected to be installed May 2012.

DATE: 05/10/2012DAY: ThursdayTECHNICIAN: Rob PetersonWeather: 65F, Partly Cloudy**TCE Groundwater Treatment System #1****GAC Unit Information****Influent Port**

TIME	PID VOC ppb	Temp Deg. F
10:42	4,001	77

Comments: Measurements collected in parts per billion (ppb) to achieve greater definition for concentration data. Conversion: 4.0 ppm.

Between GAC Unit #1 and GAC Unit #2

TIME	PID VOC ppb	Temp Deg. F
10:45	2,757	75.2

Comments: Measurements collected in parts per billion (ppb) to achieve greater definition for concentration data. Conversion: 2.7 ppm.

Effluent Port

TIME	PID VOC ppb	Temp Deg. F
10:48	905	75.2

Comments: Measurements collected in parts per billion (ppb) to achieve greater definition for concentration data. Conversion: 0.9 ppm.

II: System Maintenance and Observations**Inspection of Water Column in DDC Wells**

Well#	Comments
DDC-1	Bubbling in well sufficient.
DDC-2	Bubbling in well sufficient.

Inspection of Sumps Associated with DDC Wells

Well#	Comments
DDC-1	No sump associated with this well.
DDC-2	1.0-inch of water detected within sump. Sump pump non-operational

Liquid Levels in Knock-Out Tanks

Comments: No water detected in K/O tanks.

Oil Level on Blower

Comments: Oil quality and levels satisfactory. Oil was changed on 19 April 2012 with Omega SB-220 oil.

Additional Comments:

DDC-2 sump pump is currently on back order and will be installed May 2012. Water will be removed weekly via whale pump until pump is replaced.

Knock Out Tank #1 pump is non-operational. Pump is currently on back order and will be replaced May 2012. Water will be drained manually if accumulation occurs.

Flow meter F0-1 not functioning. Air flow visually inspected at DDC-1 well head. Determined that DDC-1 bubbling sufficiently. Replacement flow meter is currently on back order and is expected to be installed May 2012.

On May 9, 2012 Verizon installed a phone line to Treatment System #1 and Gray Electric installed an additional relay in System #1 control box. The relay was installed in order for the auto-dialer (Sensaphone) to monitor system power supply. The phone line was connected to the Sensaphone mounted on the control panel inside Treatment System #1. The Sensaphone was installed by Gray Electric on April 30, 2012. The Sensaphone was programmed by EA with the following parameters: Date & Time, zones (Temp. & System Power Supply), alarm limits, voice messages (zones & site ID), and dial out telephone numbers. Currently the dial out number is set for Rob Peterson (EA). The Sensaphone telephone number is 631-752-5404 and the alarm acknowledgment code is 555.

III: System Evaluation

☒ System is operating satisfactorily
☐ EA recommends / implements the following....

IV: Sampling / Lab Data

N/A

DATE: 05/10/2012

DAY: Thursday

TECHNICIAN: Rob Peterson

Weather: 65F, Partly Cloudy

TCE Groundwater Treatment System #2 STATUS: ON OFF

I: System Data Collection

Total Run Time Meter Reading: 13,858.9 hours.

System Running at 41.0 Hz.

Temperature Monitoring					
Time	Location	TI-ID	Temperature deg. C	Temperature deg. F	Comments
10:16	Carbon Unit Inlet	CA01	25.0	77.0	Carbon Unit #1
10:17	Pre-Heater	PHA01	32.2	90.0	After Shell and Tubing
10:18	Blower Panel	B01	72.0	161.6	Exiting Blower
10:16	After Cooler Outlet	AC01	35.0	95.0	Post Cooler Piping
10:17	Pre-Heater	PHB01	60.0	140.0	Before Shell and Tubing

Flow Readings			
Time	TI-ID	Location	Flow (CFM)
10:15	WD01	Injected Air to DDC-3	150
10:15	WD02	Injected Air to DDC-4	150

Comments: None

Pressure/Vacuum Monitoring				
Time	Location	TI-ID	Pressure	Comments
10:15	Knock-Out Tank	T01	0.0 in. Hg	Vacuum gauge on knock-out tank
10:16	Carbon-Unit #1 Outlet	CA1	-5.0 in. Hg	Vacuum exiting GAC #1
10:15	Discharge to Wells	WD2	2.3 PSI	Pressure reading on piping prior to splicing off to both wells
10:18	Blower Panel	BP01	-1.5 in. Hg	Vacuum coming off of blower
10:16	Carbon Unit #2 Outlet	CA2	-4.2 in. Hg	Vacuum exiting GAC #2
10:30	DDC-3	N/A	0.0 PSI	Pressure gauge on well head
10:33	DDC-4	N/A	0.0 PSI	Pressure gauge on well head

DATE: 05/10/2012DAY: ThursdayTECHNICIAN: Rob PetersonWeather: 65F, Partly Cloudy**TCE Groundwater Treatment System #2****GAC Unit Information****Influent Port GAC#1**

TIME	PID VOC ppb	Temp Deg. F
10:19	1,090	71.4

Comments: Measurements collected in parts per billion (ppb) to achieve greater definition for concentration data. Conversion: 1.0 ppm.

Influent Port GAC#2

TIME	PID VOC ppb	Temp Deg. F
10:23	501	72.7

Comments: Measurements collected in parts per billion (ppb) to achieve greater definition for concentration data. Conversion: 0.5 ppm.

Effluent

TIME	PID VOC ppb	Temp Deg. F
10:26	703	72.3

Comments: Measurements collected in parts per billion (ppb) to achieve greater definition for concentration data. Conversion: 0.7 ppm.

II: System Maintenance and Observations**Inspection of Water Column in DDC Wells**

Well#	Comments
DDC-3	Bubbling was sufficient.
DDC-4	Bubbling was sufficient.

Inspection of Sumps Associated with DDC Wells

Well#	Comments
DDC-3	0.5-inch of water detected in sump. Sump pump operating satisfactorily.
DDC-4	0.5-inch of water detected in sump. Sump pump operating satisfactorily.

Additional Comments:	Sensaphone operational and performing correctly
----------------------	---

Liquid Levels in Knock-Out Tanks

Comments: No water was detected within site-glass.

Oil Level on Blower

Comments: Oil quality and levels satisfactory. Oil was changed on 19 April 2012 with Omega SB-220 oil.

III: System Evaluation

☒ System is operating satisfactorily
☐ EA recommends / implements the following....

--

IV: Sampling / Lab Data

N/A

National Heatset On-site DDC O&M Photolog
10 May 2012



System #1 additional relay and associated connections.



View of Treatment System #1 control panel (interior).