

Project: National Heatsheet Printing Site - Off-Site - Site Management
 Contractors: AECOM and Preferred Environmental Services
 AECOM Job No: 60135649
 Site No: 1-52-140
 AECOM Project Manager: Walt Howard

AECOM
 40 British American Boulevard
 Airport Park
 Latham, NY 12110
 Telephone: 518.7951.2242

DAILY REPORT

Day:

S	M	T	W	TH	F	S
---	---	---	----------	----	---	---

 Date: 5-Dec-12
 REPORT No. _____
 PAGE No. 1
 PREPARED BY: Thomas Fitzpatrick TITLE: Site Rep.

WEATHER	Bright Sun	Partly Cloudy	Overcast	Rain	Clear
TEMP	To 32	32-50	50-70	70-85	85 and up
WIND	Light	Moderate	High		
HUMIDITY	Dry	Moderate	Humid		
WIND DIR	NE	NW	SE	SW	
	N	S	E	W	

AVERAGE FIELD FORCE

Name of Contractor	Title	Hours Worked	Remarks
Thomas Fitzpatrick	Technician	8:25 - 11:15	Preferred
Dan Prisco-Buxbaum	Technician	10:05 - 10:40	Preferred

VISITORS

Name	Time (From - To)	Representing	Remarks
NA	NA	NA	NA

EQUIPMENT AT THE SITE

I = Idle W = Working

1. Camera - W	3. Pressure Gauges - W	5. Vacuum Pump - W	7. VelociCalc - TSI 9555/9 -W
2. PID - W	4. Interface Probe - W	6. Four Gas Meter - W	

OPERATION & MAINTENANCE ACTIVITIES

AECOM/Preferred Site Representative: Thomas Fitzpatrick - Preferred	
DESCRIPTION OF WORK PERFORMED AND OBSERVED	
8:25	- Preferred arrived on-site. Both systems are up with seven (7) alarms triggered: 11/07/12 21:08 W12: Well DDC-7 Low Differential Pressure 11/03/12 11:29 W5 B-501 low vacuum 11/03/12 11:29 W6 B-502 low vacuum 11/10/12 8:52 W9:Well DDC-10 Low Differential Pressure 11/25/12 14:25 W8: Well DDC-5 Low Differential Pressure 11/21/12 23:13 W11: Well DDC-8 Low Differential Pressure 11/26/12 12:10 W13: Well DDC-6 Low Differential Pressure
8:30	- Weekly O&M started.
9:45	- DDC-5 & DDC-6 condensate drainage valves were drained for 15 minutes.
10:05	- Dan Prisco-Buxbaum on-site to assist in the gauging of the DDC wells located along Benjoe Drive.
10:40	- Dan Prisco-Buxbaum off-site.
10:45	- O&M completed.
10:50	- Preferred confirms shallow and deep monitoring well locations.
11:15	- Preferred locked both sheds and all parties off-site. All alarms were reset, with blowers B-501 & B-502 up upon departure.

- Designates report is continued on additional pages

AECOM/Preferred Site Representative: Thomas Fitzpatrick (Preferred) Project Manager: W. Howard

O&M DATA SHEET - NATIONAL HEATSET - OFF-SITE SYSTEM

Date: 12/5/2012

Time: 8:30

Weather: 52° F - Partly Cloudy -Slight Humidity

B-501 Status on Arrival: **Up** / Down / Off

B-502 Status on Arrival: **Up** / Down / Off

Alarm Light Status on Arrival: **ON** / OFF

Alarm Light Reset on Arrival: YES / **NO**

SYSTEM OPERATING DATA

ID	B-501	TP-211	B-502	TP-212	B-503	TP-213	Time
Hours	3,926.2	0.1	4,199.1	0.3	0	0	@ 8:33
Hz	31	Hz	31		Separator ID	Water Level (IN)	Drained
PI-511	5.0	PI-512	6.5		ST-201	0	YES / NO
TSH-511	110	TSH-512	150		ST-202	0	YES / NO
VI-201	-2.0	IWC	VI-202		-2.0	IWC	
TI-201	62	°F	TI-202	65	°F		
DPT-201	0.57	IWC (6" Pipe)	DPT-202	0.59	IWC (6" Pipe)		
V-DLH5-6	Open / Closed		V-DLH5-6	Open / Closed			
VI-401	-4.0	IWC	VI-402	-5.0	IWC		
TI-401	62	°F	TI-402	63	°F		
VI-401B	-6.0	IWC	VI-402A	-22	IWC		
SP-401B	0.0	ppb / <u>ppm</u>	SP-402A	0.0	ppb / <u>ppm</u>		
VI-401A	-24	IWC	VI-402B	-8.0	IWC		
SP-401A	0.0	ppb / ppm	SP-402B	0.3	ppb / <u>ppm</u>		
VI-403B	-16	IWC	VI-403A	-16	IWC		
SP-403B	0.0	ppb / <u>ppm</u>	SP-403A	0.0	ppb / <u>ppm</u>		
VI-501	-31	IWC	VI-502	-30	IWC		
SP-501	0.0	ppb / <u>ppm</u>	SP-502	0.0	ppb / <u>ppm</u>		
TI-501	64	°F	TI-502	66	°F		
VI-501A	-32	IWC	VI-502A	-32	IWC		
DPT-301	0.44	IWC (6" Pipe)	DPT-302	0.38	IWC (6" Pipe)		
PI-301	5.5	PSI	PI-302	6.4	PSI		
TI-301	100	°F	TI-302	110	°F		
FM-601	82.7 gal	Electric Meter Reading:		3,679 kW/h @	8:51 AM		

B-501 Status on Departure: **UP** / DOWN / OFF

B-502 Status on Departure: **UP** / DOWN / OFF

Alarm Light Status on Departure: ON / **OFF**

Alarm Light Reset on Departure: **YES** / NO

O&M DATA SHEET - NATIONAL HEATSET - OFF-SITE SYSTEM

 Date: 12/05/12

 Time: 9:15

Weather: _____

52° F - Partly Cloudy

INJECTION & EXTRACTION MANIFOLD OPERATING DATA

Well ID	4" - INJECTION			6" - EXTRACTION			
	Δ Pressure (IWC)	Temp (°F)	Pressure (PSI)	Vacuum (IWC)	Temp (°F)	Velocity (ft/min)	VOCs (ppb or ppm)
DDC-05	0.18	90	4.0	1.084	63	685	0.0
DDC-10	0.13	90	4.0	0.939	65	697	0.0
DDC-09	0.36	88	4.8	0.980	64	979	0.0
DDC-08	0.32	90	4.0	1.702	64	945	0.9
DDC-07	0.11	88	4.3	1.714	64	646	0.0
DDC-06	0.20	93	4.5	1.757	62	750	0.0

DDC WELLHEAD OPERATING DATA

WELL ID	PZ SHALLOW (FT)	PZ DEEP (FT)	Air Space (FT)	COMMENTS	MW ID	DTW (FT)
DDC-05	11.23	16.19	5.0'	Drained Condensate Valve	NA	NA
DDC-10	10.89	14.80	2.0'	---	NA	NA
DDC-09	10.63	15.88	1.5'	---	NA	NA
DDC-08	10.15	15.18	1.5'	---	NA	NA
DDC-07	10.55	12.76	2.0'	---	NA	NA
DDC-06	10.27	10.43	4.5'	Drained Condensate Valve	NA	NA

AIR SAMPLING DATA

B-501			B-502		
Sample Port Position	SAMPLE PORT ID	VOC Reading (ppb / ppm)	Sample Port Position	SAMPLE PORT ID	VOC Reading (ppb / ppm)
Influent	SP-401B	0.0	Influent	SP-402B	0.3
Intermediate #1	SP-403B	0.0	Intermediate #1	SP-403A	0.0
Intermediate #2	SP-401A	0.0	Intermediate #2	SP-402A	0.0
Effluent	SP-501	0.0	Effluent	SP-502	0.0

CHILLER	TECHNICIAN COMMENTS/NOTES:
Set Temp. (°F)	75
Actual Temp. (°F)	72
Pump Pressure (PSI)	25
Freon High Pres. (PSI)	152
Freon Low Pres. (PSI)	110

PHOTOGRAPHIC LOG

Date: 12-05-12

AECOM Job No.

National Heatset Printing Site - Off-Site

PHOTO	DATE	TIME	DESCRIPTION	COMMENTS
Picture 367	12/5/2012	9:45	DDC-5 & DDC-6 condensate drainage valves were drained for 15 minutes.	
Picture 368	12/5/2012	11:10	An interface probe was utilized for the gauging of the DDC peizometer wells.	

Photos (12.05.12)



Picture 367- DDC-5 & DDC-6 condensate drainage valves were drained for 15 minutes.



Picture 368- An interface probe was utilized for the gauging of the DDC peizometer wells.