

AECOM  
40 British American Boulevard  
Airport Park  
Latham, NY 12110  
Telephone: 518.951.2200

Project Manager: W. Howard

# O&M DATA SHEET - NATIONAL HEATSET - OFF-SITE SYSTEM

Date: 12/27/2012

Time: 9:00

Weather: 43° F - Rain - Humid

B-501 Status on Arrival: Up / Down / Off

B-502 Status on Arrival: Up / Down / Off

Alarm Light Status on Arrival: ON / OFF

Alarm Light Reset on Arrival: YES / NO

## SYSTEM OPERATING DATA

ID	B-501	TP-211	B-502	TP-212	B-503	TP-213	Time
Hours	4,454.3	0.1	4,727.2	0.3	0	0	@ 8:42
Hz	32	Hz	31		Separator ID	Water Level (IN)	Drained
PI-511	5.3	PI-512	6.9				
TSH-511	100	TSH-512	140		ST-201	0	YES / <u>NO</u>
					ST-202	0	YES / <u>NO</u>
VI-201	-2.5	IWC	VI-202	-2.0	IWC		
TI-201	54	°F	TI-202	56	°F		
DPT-201	0.57	IWC (6" Pipe)	DPT-202	0.56	IWC (6" Pipe)		
V-DLH5-6	<u>Open</u> / Closed		V-DLH5-6	<u>Open</u> / Closed			
VI-401	-4.0	IWC	VI-402	-5.0	IWC		
TI-401	54	°F	TI-402	54	°F		
VI-401B	-6.0	IWC	VI-402A	-22	IWC		
SP-401B	0.1	ppb / <u>ppm</u>	SP-402A	0.1	ppb / <u>ppm</u>		
VI-401A	-24	IWC	VI-402B	-8.0	IWC		
SP-401A	0.0	ppb / ppm	SP-402B	0.8	ppb / <u>ppm</u>		
VI-403B	-16	IWC	VI-403A	-16	IWC		
SP-403B	0.0	ppb / <u>ppm</u>	SP-403A	0.3	ppb / <u>ppm</u>		
VI-501	-30	IWC	VI-502	-30	IWC		
SP-501	0.0	ppb / <u>ppm</u>	SP-502	0.0	ppb / <u>ppm</u>		
TI-501	58	°F	TI-502	60	°F		
VI-501A	-31	IWC	VI-502A	-32	IWC		
DPT-301	0.41	IWC (6" Pipe)	DPT-302	0.36	IWC (6" Pipe)		
PI-301	5.9	PSI	PI-302	6.5	PSI		
TI-301	100	°F	TI-302	105	°F		
FM-601	82.7 gal	Electric Meter Reading:		4,185 kW/h @	11:58 AM		

B-501 Status on Departure: UP / DOWN / OFF

B-502 Status on Departure: UP / DOWN / OFF

Alarm Light Status on Departure: ON / OFF

Alarm Light Reset on Departure: YES / NO

# O&M DATA SHEET - NATIONAL HEATSET - OFF-SITE SYSTEM

 Date: 12/27/12

 Time: 10:30

 Weather: 

45° F - Bright Sun

## INJECTION & EXTRACTION MANIFOLD OPERATING DATA

Well ID	4" - INJECTION			6" - EXTRACTION			
	Δ Pressure (IWC)	Temp (°F)	Pressure (PSI)	Vacuum (IWC)	Temp (°F)	Velocity (ft/min)	VOCs (ppb or ppm)
DDC-05	0.12	80	4.2	0.932	56	655	0.0
DDC-10	0.16	80	4.4	0.937	58	705	0.0
DDC-09	0.33	75	5.0	1.169	58	930	0.2
DDC-08	0.30	80	4.1	1.770	56	970	1.8
DDC-07	0.24	75	4.5	1.826	58	540	0.0
DDC-06	0.21	85	4.6	1.774	56	705	0.0

## DDC WELLHEAD OPERATING DATA

WELL ID	PZ SHALLOW (FT)	PZ DEEP (FT)	Air Space (FT)	COMMENTS	MW ID	DTW (FT)
DDC-05	10.69	15.77	5.0'	(1) Drained condensate valve	NA	NA
DDC-10	10.34	14.13	1.5'	---	NA	NA
DDC-09	9.99	15.18	1.5'	---	NA	NA
DDC-08	9.45	14.41	1.0'	---	NA	NA
DDC-07	9.52	11.97	1.5'	4.5-inches of pooled water within vault	NA	NA
DDC-06	9.61	9.75	4.5'	(2) Drained condensate valve	NA	NA

## AIR SAMPLING DATA

B-501			B-502		
Sample Port Position	SAMPLE PORT ID	VOC Reading (ppb / ppm)	Sample Port Position	SAMPLE PORT ID	VOC Reading (ppb / ppm)
Influent	SP-401B	0.1	Influent	SP-402B	0.8
Intermediate #1	SP-403B	0.0	Intermediate #1	SP-403A	0.3
Intermediate #2	SP-401A	0.0	Intermediate #2	SP-402A	0.1
Effluent	SP-501	0.0	Effluent	SP-502	0.0

## CHILLER

## TECHNICIAN COMMENTS/NOTES:

Set Temp. (°F)	75	1 - DDC-5's condensate valve was drained for 5 minutes, from which less than a half of a gal. of water was produced.
Actual Temp. (°F)	78	
Pump Pressure (PSI)	25	2 - DDC-6's condensate valve was drained for 1 minute, from which a less than a quarter gallon of water was produced. DDC-6 produced mostly air from the initial release of the valve.
Freon High Pres. (PSI)	200	
Freon Low Pres. (PSI)	74	

**PHOTOGRAPHIC LOG**  
**Date: 12-27-12**  
**AECOM Job No.**  
**National Heatset Printing Site - Off-Site**

PHOTO	DATE	TIME	DESCRIPTION	COMMENTS
Picture 348	12/27/2012	8:42	Both blowers were up and two (2) alarms were triggered upon arrival.	
Picture 353	12/27/2012	9:00	Water drained from DDC-6 condensate valve..	

## Photos (12.27.12)



**Picture 348-** Both blowers were up and two (2) alarms were triggered upon arrival.



**Picture 353-** Water drained from DDC-6 condensate valve.