

Project: National Heatset Printing Site - Off-Site - Site Management  
Contractors: AECOM and Preferred Environmental Services  
AECOM Job No: 60135649  
Site No: 1-52-140  
AECOM Project Manager: Walt Howard

AECOM  
40 British American Boulevard  
Airport Park  
Latham, NY 12110  
Telephone: 518.7951.2242

### DAILY REPORT

Day: 

S	M	T	W	TH	F	S
---	---	---	---	----	---	---

  
Date: 2-Jan-13  
REPORT No. \_\_\_\_\_  
PAGE No. 1  
PREPARED BY: Thomas Fitzpatrick TITLE: Site Rep.

WEATHER	Bright Sun	Partly Cloudy	Overcast	Rain	Clear
TEMP	To 32	32-50	50-70	70-85	85 and up
WIND	Light	Moderate	High		
HUMIDITY	Dry	Moderate	Humid		
WIND DIR	NE	NW	SE	SW	
	N	S	E	W	

### AVERAGE FIELD FORCE

Name of Contractor	Title	Hours Worked	Remarks
Thomas Fitzpatrick	Technician	8:10 - 10:40	Preferred
Daniel Prisco-Buxbaum	Technician	9:35 - 10:08	Preferred

### VISITORS

Name	Time (From - To)	Representing	Remarks
NA	NA	NA	NA

### EQUIPMENT AT THE SITE

I = Idle W = Working

1. Camera - W	3. Pressure Gauges - W	5. Vacuum Pump - W	7. VelociCalc - TSI 9555/9 - W
2. PID - W	4. Interface Probe - W	6. Four Gas Meter - W	

### OPERATION & MAINTENANCE ACTIVITIES

AECOM/Preferred Site Representative: Thomas Fitzpatrick - Preferred	
DESCRIPTION OF WORK PERFORMED AND OBSERVED	
8:10- Preferred arrived on-site. Both systems are up with two (2) alarms triggered:	
12/29/12 10:18 W13: Well DDC-6 Low Differential Pressure	
12/30/12 2:44 W8: Well DDC-5 Low Differential Pressure	
8:15 - Weekly O&M started.	
9:35 - Daniel Prisco-Buxbaum assisted in the gauging of the DDC wells located along Benjoe Drive.	
10:08 - Daniel Prisco-Buxbaum off-site.	
10:20 - DDC-5 & DDC-6 condensate drainage valves were drained in 5 gallon buckets.	
10:35 - O&M completed.	
10:40 - Preferred locked both sheds and all parties off-site. All alarms were reset, with blowers B-501 & B-502 up upon departure.	

☒ - Designates report is continued on additional pages

AECOM/Preferred Site Representative: Thomas Fitzpatrick (Preferred)

Project Manager: W. Howard

# O&M DATA SHEET - NATIONAL HEATSET - OFF-SITE SYSTEM

Date: 1/2/2013

Time: 8:15

Weather: 30° F - Bright Sun - Dry

B-501 Status on Arrival: Up / Down / Off

B-502 Status on Arrival: Up / Down / Off

Alarm Light Status on Arrival: ON / OFF

Alarm Light Reset on Arrival: YES / NO

## SYSTEM OPERATING DATA

ID	B-501	TP-211	B-502	TP-212	B-503	TP-213	Time
Hours	4,598.0	0.1	4,870.9	0.3	0	0	@ 8:24
Hz	31	Hz	31		Separator ID	Water Level (IN)	Drained
PI-511	5.4	PI-512	7.1				
TSH-511	90	TSH-512	135		ST-201	0	YES / <u>NO</u>
					ST-202	0	YES / <u>NO</u>
VI-201	-3.0	IWC	VI-202	-2.0	IWC		
TI-201	52	°F	TI-202	55	°F		
DPT-201	0.58	IWC (6" Pipe)	DPT-202	0.56	IWC (6" Pipe)		
V-DLH5-6	<u>Open</u> / Closed		V-DLH5-6	<u>Open</u> / Closed			
VI-401	-4.0	IWC	VI-402	-5.0	IWC		
TI-401	52	°F	TI-402	52	°F		
VI-401B	-6.0	IWC	VI-402A	-22	IWC		
SP-401B	0.2	ppb / <u>ppm</u>	SP-402A	0.1	ppb / <u>ppm</u>		
VI-401A	-24	IWC	VI-402B	-8.0	IWC		
SP-401A	0.0	ppb / ppm	SP-402B	0.8	ppb / <u>ppm</u>		
VI-403B	-16	IWC	VI-403A	-16	IWC		
SP-403B	0.0	ppb / <u>ppm</u>	SP-403A	0.3	ppb / <u>ppm</u>		
VI-501	-31	IWC	VI-502	-30	IWC		
SP-501	0.0	ppb / <u>ppm</u>	SP-502	0.0	ppb / <u>ppm</u>		
TI-501	56	°F	TI-502	56	°F		
VI-501A	-32	IWC	VI-502A	-32	IWC		
DPT-301	0.42	IWC (6" Pipe)	DPT-302	0.38	IWC (6" Pipe)		
PI-301	6.0	PSI	PI-302	6.8	PSI		
TI-301	100	°F	TI-302	105	°F		
FM-601	82.7 gal	Electric Meter Reading:		4,326 kW/h @	8:58 AM		

B-501 Status on Departure: UP / DOWN / OFF

B-502 Status on Departure: UP / DOWN / OFF

Alarm Light Status on Departure: ON / OFF

Alarm Light Reset on Departure: YES / NO

# O&M DATA SHEET - NATIONAL HEATSET - OFF-SITE SYSTEM

 Date: 01/02/13

 Time: 9:00

 Weather: 30° F - Bright Sun

## INJECTION& EXTRACTION MANIFOLD OPERATING DATA

Well ID	4" - INJECTION			6" - EXTRACTION			
	Δ Pressure (IWC)	Temp (°F)	Pressure (PSI)	Vacuum (IWC)	Temp (°F)	Velocity (ft/min)	VOCs (ppb or ppm)
DDC-05	0.26	80	4.4	1.008	55	640	0.0
DDC-10	0.15	80	4.5	1.148	56	625	0.0
DDC-09	0.33	75	5.1	1.014	56	915	0.2
DDC-08	0.29	80	4.4	1.858	56	800	2.0
DDC-07	0.18	75	5.0	1.899	57	488	0.0
DDC-06	0.19	85	4.9	1.919	56	615	0.0

## DDC WELLHEAD OPERATING DATA

WELL ID	PZ SHALLOW (FT)	PZ DEEP (FT)	Air Space (FT)	COMMENTS	MW ID	DTW (FT)
DDC-05	10.17	15.54	5.0'	(1) Drained condensate valve	NA	NA
DDC-10	9.82	9.90	1.5'	---	NA	NA
DDC-09	9.55	14.83	1.5'	3-inches of pooled water within vault	NA	NA
DDC-08	9.10	14.08	1.0'	2.5-inches of pooled water within vault	NA	NA
DDC-07	9.32	11.50	1.0'	---	NA	NA
DDC-06	9.24	9.42	4.0'	(2) Drained condensate valve	NA	NA

## AIR SAMPLING DATA

B-501			B-502		
Sample Port Position	SAMPLE PORT ID	VOC Reading (ppb / ppm)	Sample Port Position	SAMPLE PORT ID	VOC Reading (ppb / ppm)
Influent	SP-401B	0.2	Influent	SP-402B	0.8
Intermediate #1	SP-403B	0.0	Intermediate #1	SP-403A	0.3
Intermediate #2	SP-401A	0.0	Intermediate #2	SP-402A	0.1
Effluent	SP-501	0.0	Effluent	SP-502	0.0

## CHILLER

Set Temp. (°F)	75	1 - DDC-5's condensate valve was drained for 5 minutes, from which less than a half of a gal. of water was produced. 2 - DDC-6's condensate valve was drained for 1 minute, from which a less than a quarter gallon of water was produced. DDC-6 produced mostly air from the initial release of the valve.
Actual Temp. (°F)	73	
Pump Pressure (PSI)	25	
Freon High Pres. (PSI)	100	
Freon Low Pres. (PSI)	100	

## TECHNICIAN COMMENTS/NOTES:

**PHOTOGRAPHIC LOG**

**Date: 1-2-13**

**AECOM Job No.**

**National Heatset Printing Site - Off-Site**

<b>PHOTO</b>	<b>DATE</b>	<b>TIME</b>	<b>DESCRIPTION</b>	<b>COMMENTS</b>
Picture 333	1/2/2013	10:35	All alarms were reset, with blowers B-501 & B-502 up upon departure.	
Picture 336	1/2/2013	8:30	No water was observed within the ST-201 separator's site glass.	

## Photos (1.2.13)



**Picture 333-** All alarms were reset, with blowers B-501 & B-502 up upon departure.



**Picture 336-** No water was observed within the ST-201 separator's site glass.