

Project: National Heatset Printing Site - 1 Adams Boulevard, Farmingdale, NY - Site Management  
Contractors: AECOM and Preferred Environmental Services  
AECOM Job No: 60135649  
Site No: 152140  
AECOM Project Manager: Walt Howard

AECOM  
40 British American Boulevard  
Airport Park  
Latham, NY 12110  
Telephone: 518.7951.2242

### DAILY REPORT

Day: 

S	M	T	W	TH	F	S
---	---	---	---	----	---	---

  
Date: 3-Apr-13  
REPORT No.                       
PAGE No. 1  
PREPARED BY: Thomas Fitzpatrick TITLE: Site Rep.

WEATHER	Bright Sun	Partly Cloudy	Overcast	Rain	Clear
TEMP	To 32	32-50	50-70	70-85	85 and up
WIND	Light	Moderate	High		
HUMIDITY	Dry	Moderate	Humid		
WIND DIR	NE	NW	SE	SW	
	N	S	E	W	

### AVERAGE FIELD FORCE

Name of Contractor	Title	Hours Worked	Remarks
Thomas Fitzpatrick	Technician	8:00 - 9:40	Preferred

### VISITORS

Name	Time (From - To)	Representing	Remarks
Dan Prisco-Buxbaum	8:00 - 11:50	Preferred	Quarterly groundwater sampling

### EQUIPMENT AT THE SITE

I = Idle                      W = Working

1. Camera - W	3. Pressure Gauges - W	5. Vacuum Pump - W
2. PID - W	4. Velocity & Temperature Meter - W	

### OPERATION & MAINTENANCE ACTIVITIES

AECOM/Preferred Site Representative: <u>Thomas Fitzpatrick - Preferred</u>
DESCRIPTION OF WORK PERFORMED AND OBSERVED
8:00 - Preferred on-site. Both systems were running upon arrival.
8:30 - O&M started on System #2.
9:13 - O&M started on System #1.
9:35 - Weekly O&M completed.
9:40 - Preferred locked both systems and quarterly groundwater sampling activities resume. Both systems running upon departure.

☒ - Designates report is continued on additional pages

AECOM/Preferred Site Representative: Thomas Fitzpatrick (Preferred)

Project Manager: W. Howard Page 1 of 7

# AECOM

40 British American Boulevard, Airport Park, Latham, NY 12110 tel: (518) 782-4500 fax: (518) 786-3810



**PREFERRED ENVIRONMENTAL SERVICES**

323 Merrick Avenue - North Merrick, New York 11566 Tel: (516) 546-1100 Fax : (516) 213-8156

**National Heatset Printing Site, Farmingdale, NY**

**Contract No. , Site No. 152140**

**Monitoring Table April 03, 2013**

DATE: 4/03/13

DAY: Wednesday

TECHNICIAN: Thomas Fitzpatrick

Weather: 36 Deg. F Partly Cloudy

**TCE Groundwater Treatment System #1 STATUS: ON OFF**

## **I: System Data Collection**

Run Time Meter Reading : 494.4 hours

Total Run Time Meter Reading: 14,904.0 hours @ 14:44

System Running at 30.0 Hz.

Temperature Monitoring					
Time	Location	TI-ID	Temperature deg. C	Temperature deg. F	Comments
9:17	Extracted From Well	TI-01	18.0	64.4	DDC-1
9:17	Extracted From Well	TI-02	14.0	57.2	DDC-2
9:18	Pre-Heater Outlet	TI-03	26.0	78.8	Post Shell and Tubing
9:18	Pre-Heater Input	TI-04	16.0	60.8	Before Shell and Tubing
9:17	After Cooler Outlet	TI-05	31.0	87.8	Post Cooler Reading
9:18	After Cooler Input	TI-06	40.0	104.0	Before Cooler Reading
9:18	Blower Outlet	TI-07	50.0	122.0	Going to Pre-heater
9:19	Between GAC Units	TI-08	26.0	78.8	After GAC #1
9:19	GAC Unit Output	TI-09	25.0	77.0	After GAC #2

Flow Readings			
Time	IF-ID	Location	Flow (SCFM)
9:15	FI-01	Extracted From DDC-1	90
9:15	FI-02	Extracted From DDC-2	325

Comments: Flow meters are set on return pipes to wells. FI-01 in non-functioning and needs to be replaced.

Pressure/Vacuum Monitoring				
Time	Location	PI/VI-ID	Pressure	Comments
9:15	Discharge to Well	PI-01	3.3 PSI	DDC-1
9:15	Discharge to Well	PI-02	2.6 PSI	DDC-2
9:15	Drum	PI-03	-26.0 in. H2O	Vacuum Reading Going to Blower

DATE: 4/03/13

DAY: Wednesday

TECHNICIAN: Thomas Fitzpatrick

Weather: 36 Deg. F Partly Cloudy

## TCE Groundwater Treatment System #1

### GAC Unit Information

#### Influent Port

TIME	PID VOC ppm	Temp Deg. F
9:20	1.9	83.5

Comments:

#### Between GAC Unit #1 and GAC Unit #2

TIME	PID VOC ppm	Temp Deg. F
9:27	0.1	75.1

Comments:

#### Effluent Port

TIME	PID VOC ppm	Temp Deg. F
9:24	0.0	66.1

Comments:

## II: System Maintenance and Observations

### Inspection of Water Column in DDC Wells

Well#	Comments
DDC-1	Bubbling in well is not sufficient.
DDC-2	Bubbling in well is sufficient.

### Inspection of Sumps Associated with DDC Wells

Well#	Comments
DDC-1	No sump associated with this well.
DDC-2	1-inch of water was observed in this sump.

### Liquid Levels in Knock-Out Tanks

Comments: No liquid found in either knock-out tank.

### Oil Level on Blower

Comments: Oil levels were good. Oil was Changed n 4/19/12 with Omega SB-220 oil.

Addition Comments:

*Flow Gauge, FI-01, is non-functioning and needs to be replaced.*

## III: System Evaluation



System is operating satisfactorily

AECOM recommends / implements the following....

## IV: Sampling / Lab Data

N/A

DATE: 4/03/13

DAY: Wednesday

TECHNICIAN: Thomas Fitzpatrick

Weather: 36 Deg. F Partly Cloudy

GWTT EQUIPMENT INFORMATION

**TCE Groundwater Treatment System #2**      **STATUS: ON    OFF**

**I: System Data Collection**

Total Run Time Meter Reading: 17,648.5 hours @ 11:47

System Running at 40.0 Hz.

Temperature Monitoring					
Time	Location	TI-ID	Temperature deg. C	Temperature deg. F	Comments
8:34	Carbon Unit Inlet	CA01	16.0	60.8	Carbon Unit #1
8:33	Pre-Heater	PHA01	24.4	76	After Shell and Tubing
8:33	Blower Panel	B01	54.4	130	Exiting Blower
8:32	After Cooler Outlet	AC01	32.2	90	Post Cooler Piping
8:33	Pre-Heater	PHB01	48.9	120	Before Shell and Tubing

Flow Readings			
Time	TI-ID	Location	Flow (CFM)
10:57	WD01	Injected Air to DDC-3	147
10:57	WD02	Injected Air to DDC-4	189

Comments:

Pressure/Vacuum Monitoring				
Time	Location	TI-ID	Pressure	Comments
8:32	Knock-Out Tank	T01	0.0 in. Hg	Vacuum gauge on knock-out tank
8:34	Carbon-Unit #1 Outlet	CA1	-3.6 in. Hg	Vacuum exiting GAC #1
8:32	Discharge to Wells	WD2	2.5 PSI	Pressure reading on piping prior to splicing off to both wells
8:33	Blower Panel	BP01	-0.0 in. Hg	Vacuum coming off of blower
8:34	Carbon Unit #2 Outlet	CA2	-3.2 in. Hg	Vacuum exiting GAC #2
8:52	DDC-3	N/A	0.4 PSI	Pressure gauge on well head
8:57	DDC-4	N/A	0.4 PSI	Pressure gauge on well head

DATE: 4/03/13DAY: WednesdayTECHNICIAN: Thomas FitzpatrickWeather: 36 Deg. F Partly Cloudy**TCE Groundwater Treatment System #2****GAC Unit Information****Influent Port GAC#1**

TIME	PID VOC ppm	Temp Deg. F
8:40	0.7	51.6

Comments:

**Influent Port GAC#2**

TIME	PID VOC ppm	Temp Deg. F
8:44	0.6	53.7

Comments:

**Effluent**

TIME	PID VOC ppm	Temp Deg. F
8:47	0.1	57.7

Comments:

**II: System Maintenance and Observations****Inspection of Water Column in DDC Wells**

Well#	Comments
DDC-3	Bubbling is sufficient in well.
DDC-4	Bubbling is sufficient in well.

**Inspection of Sumps Associated with DDC Wells**

Well#	Comments
DDC-3	One (1)-inch of water was detected. Sump was observed to be non-functioning on 3-27-13. Pump was pulled and water within the sump was drained via a whale pump.
DDC-4	One (1)-inch of water was detected.

**Liquid Levels in Knock-Out Tanks:**

Comments: No water detected.

**Oil Level on Blower**

Comments: Oil levels were good. Oil was changed on 4/19/12 with Omega SB-220 oil.

Addition Comments:

***Vacuum gauge, BP01, is non-functioning and needs to be replaced.*****III: System Evaluation**☒ System is operating satisfactorily☐ AECOM recommends / implements the following....**IV: Sampling / Lab Data**

N/A

**PHOTOGRAPHIC LOG**  
**Date: 4-03-13**  
**AECOM Job No.**  
**National Headset Printing Site**

PHOTO	DATE	TIME	DESCRIPTION	COMMENTS
Picture 0013	4/3/2013	12:59	Quarterly groundwater sampling activities were performed on 4/2/13 & 4/3/13	
Picture 0019	4/3/2013	13:10	No water was observed in the site glasses of the knock-out tanks associated with System #1.	

## Photos (04.03.13)



**Picture 0013** - Quarterly groundwater sampling activities were performed on 4/2/13 & 4/3/13



**Picture 0019** - No water was observed in the site glasses of the knock-out tanks associated with System #1.