

Project: National Heatsheet Printing Site - Off-Site - Site Management
 Contractors: AECOM and Preferred Environmental Services
 AECOM Job No: 1-52-140
 Site No: 60135649
 AECOM Project Manager: Walt Howard

AECOM
 40 British American Boulevard
 Airport Park
 Latham, NY 12110
 Telephone: 518.7951.2242

DAILY REPORT

Day:

S	M	T	W	TH	F	S
---	---	---	---	----	---	---

 Date: 4-Apr-13
 REPORT No. _____
 PAGE No. 1
 PREPARED BY: Thomas Fitzpatrick TITLE: Site Rep.

WEATHER	Bright Sun	Partly Cloudy	Overcast	Rain	Clear
TEMP	To 32	32-50	50-70	70-85	85 and up
WIND	Light	Moderate	High		
HUMIDITY	Dry	Moderate	Humid		
WIND DIR	NE	NW	SE	SW	
	N	S	E	W	

AVERAGE FIELD FORCE

Name of Contractor	Title	Hours Worked	Remarks
Thomas Fitzpatrick	Technician	8:00 - 10:20	Preferred
Marc Morgenstern	Technician	8:00 - 10:20	Preferred

VISITORS

Name	Time (From - To)	Representing	Remarks
Robert Peterson	8:00 - 14:30	EA	NA

EQUIPMENT AT THE SITE

I = Idle W = Working

1. Camera - W	3. Pressure Gauges - W	5. Vacuum Pump - W	7. VelociCalc - TSI 9555/9 - W
2. PID - W	4. Interface Probe - W	6. Four Gas Meter - W	

OPERATION & MAINTENANCE ACTIVITIES

AECOM/Preferred Site Representative: Thomas Fitzpatrick - Preferred	
DESCRIPTION OF WORK PERFORMED AND OBSERVED	
8:00 - Preferred arrived on-site. Both systems are up with five (5) alarms triggered:	
4/03/2013 14:35 W4: Switch in Hand Position	
4/03/2013 15:38 W13: Well DDC-6 Low Differential Pressure	
4/03/2013 14:36 W12: Well DDC-7 Low Differential Pressure	
3/30/2013 14:54 W6:B-502 Low Vacuum (VT202)	
3/30/2013 14:54 W5:B-501 Low Vacuum (VT201)	
8:05 - Weekly O&M started.	
Weekly gauging of the piezometer wells were performed during the quarterly groundwater sampling event.	
10:20 - O&M completed.	
10:25 - Preferred locked both sheds and groundwater sample activities continued. All alarms were reset, with blowers B-501 & B-502 up upon departure.	

☒ - Designates report is continued on additional pages

AECOM/Preferred Site Representative: Thomas Fitzpatrick (Preferred) Project Manager: W. Howard

O&M DATA SHEET - NATIONAL HEATSET - OFF-SITE SYSTEM

Date: 4/4/2013

Time: 8:05

Weather: 43° F - Bright Sun- Mod. Humidity

B-501 Status on Arrival: Up / Down / Off

B-502 Status on Arrival: Up / Down / Off

Alarm Light Status on Arrival: ON / OFF

Alarm Light Reset on Arrival: YES / NO

SYSTEM OPERATING DATA

ID	B-501	TP-211	B-502	TP-212	B-503	TP-213	Time
Hours	6,694.4	0.1	6,970.3	0.3	0	0	@ 8:45
Hz	27	Hz	27		Separator ID	Water Level (IN)	Drained
PI-511	6.0	PI-512	7.2				
TSH-511	100	TSH-512	140		ST-201	0	YES / <u>NO</u>
					ST-202	0	YES / <u>NO</u>
VI-201	-2.0	IWC	VI-202	-2.0	IWC		
TI-201	54	°F	TI-202	56	°F		
DPT-201	0.43	IWC (6" Pipe)	DPT-202	0.43	IWC (6" Pipe)		
V-DLH5-6	<u>Open</u> / Closed		V-DLH5-6	<u>Open</u> / Closed			
VI-401	-4.0	IWC	VI-402	-4.0	IWC		
TI-401	54	°F	TI-402	54	°F		
VI-401B	-5.0	IWC	VI-402A	-18	IWC		
SP-401B	0.3	ppb / <u>ppm</u>	SP-402A	0.2	ppb / <u>ppm</u>		
VI-401A	-19	IWC	VI-402B	-7.0	IWC		
SP-401A	0.0	ppb / ppm	SP-402B	1.8	ppb / <u>ppm</u>		
VI-403B	-13	IWC	VI-403A	-13	IWC		
SP-403B	0.0	ppb / <u>ppm</u>	SP-403A	0.5	ppb / <u>ppm</u>		
VI-501	-24	IWC	VI-502	-23	IWC		
SP-501	0.0	ppb / <u>ppm</u>	SP-502	0.1	ppb / <u>ppm</u>		
TI-501	60	°F	TI-502	60	°F		
VI-501A	-25	IWC	VI-502A	-25	IWC		
DPT-301	0.33	IWC (6" Pipe)	DPT-302	0.34	IWC (6" Pipe)		
PI-301	6.1	PSI	PI-302	6.6	PSI		
TI-301	100	°F	TI-302	105	°F		
FM-601	82.7 gal	Electric Meter Reading:		6,361 kW/h @	8:57 AM		

B-501 Status on Departure: UP / DOWN / OFF

B-502 Status on Departure: UP / DOWN / OFF

Alarm Light Status on Departure: ON / OFF

Alarm Light Reset on Departure: YES / NO

O&M DATA SHEET - NATIONAL HEATSET - OFF-SITE SYSTEM

Date: 04/04/13 Time: 9:00 Weather: 43° F - Bright Sun

INJECTION& EXTRACTION MANIFOLD OPERATING DATA

Well ID	4" - INJECTION			6" - EXTRACTION			
	Δ Pressure (IWC)	Temp (°F)	Pressure (PSI)	Vacuum (IWC)	Temp (°F)	Velocity (ft/min)	VOCs (ppb or ppm)
DDC-05	0.18	90	4.5	1.124	55	793	0.0
DDC-10	1.05	90	5.0	1.159	56	606	0.4
DDC-09	0.18	88	5.6	1.131	56	781	0.0
DDC-08	0.26	90	4.9	1.533	56	812	3.6
DDC-07	-0.05	88	5.5	1.650	56	584	0.3
DDC-06	0.08	90	5.3	1.318	55	693	0.1

DDC WELLHEAD OPERATING DATA

WELL ID	PZ SHALLOW (FT)	PZ DEEP (FT)	Air Space (FT)	COMMENTS	MW ID	DTW (FT)
DDC-05	8.79	14.48	5.0'	---	MW-1D	8.14
DDC-10	9.01	12.42	1.0'	---	MW-1S	7.35
DDC-09	8.60	13.68	1.5'	1-foot of pooled water within vault	MW-2D	11.80
DDC-08	8.01	12.83	0.5'	1.5-feet of pooled water within vault *	MW-2S	11.68
DDC-07	8.31	10.40	1.5'	---	MW-3D	8.39
DDC-06	8.10	8.25	2.5'	(1) Drained condensate valve	MW-3S	8.26

AIR SAMPLING DATA

B-501			B-502		
Sample Port Position	SAMPLE PORT ID	VOC Reading (ppb / ppm)	Sample Port Position	SAMPLE PORT ID	VOC Reading (ppb / ppm)
Influent	SP-401B	0.3	Influent	SP-402B	1.8
Intermediate #1	SP-403B	0.0	Intermediate #1	SP-403A	0.5
Intermediate #2	SP-401A	0.0	Intermediate #2	SP-402A	0.2
Effluent	SP-501	0.0	Effluent	SP-502	0.1

CHILLER

TECHNICIAN COMMENTS/NOTES:

Set Temp. (°F)	75	* - Water observed leaking from DDC drum head
Actual Temp. (°F)	72	
Pump Pressure (PSI)	25	1 - DDC-6's condensate valve was drained for 1 minute, from which a less than a quarter gallon of water was produced. DDC-6 produced mostly air from the initial release of the valve.
Freon High Pres. (PSI)	121	
Freon Low Pres. (PSI)	115	

PHOTOGRAPHIC LOG
Date: 4-04-13
AECOM Job No.
National Heatset Printing Site - Off-Site

PHOTO	DATE	TIME	DESCRIPTION	COMMENTS
Picture 024	4/4/2013	10:30	Quarterly groundwater sample activities were performed during the O&M visit on 4-4-13.	
Picture 015	4/4/2013	14:00	The wood pallets previously staged between the two (2) treatments sheds were disposed of at Omni Recycling of Babylon.	

Photos (4.04.13)



Picture 024- Quarterly groundwater sample activities were performed during the O&M visit on 4-4-13.



Picture 015- The wood pallets previously staged between the two (2) treatments sheds were disposed of at Omni Recycling of Babylon.