

Project: National Heatset Printing Site - Off-Site - Site Management  
 Contractors: EA Engineering, P.C. and Preferred Environmental Services  
 AECOM Job No: \_\_\_\_\_  
 Site No: \_\_\_\_\_  
 AECOM Project Manager: James Hayward

EA Engineering, P.C.  
 6712 Brooklawn Parkway, Suite 104  
 Syracuse, NY 13211-2158  
 Phone: 315-431-4610,  
 Fax: 315-431-4280

## DAILY REPORT

Day: 

S	M	T	W	TH	F	S
---	---	---	---	----	---	---

  
 Date: 14-May-13  
 REPORT No. \_\_\_\_\_  
 PAGE No. 1

PREPARED BY: Thomas Fitzpatrick TITLE: Site Rep.

WEATHER	Bright Sun	Partly Cloudy	Overcast	Rain	Clear
TEMP	To 32	32-50	50-70	70-85	85 and up
WIND	Light	Moderate	High		
HUMIDITY	Dry	Moderate	Humid		
WIND DIR	NE	NW	SE	SW	
	N	S	E	W	

### AVERAGE FIELD FORCE

Name of Contractor	Title	Hours Worked	Remarks
Thomas Fitzpatrick	Technician	10:25 - 12:20	Preferred

### VISITORS

Name	Time (From - To)	Representing	Remarks
Robert Peterson	10:25 - 12:20	EA	NA

### EQUIPMENT AT THE SITE

I = Idle      W = Working

1. Camera - W	3. Pressure Gauges - W	5. Vacuum Pump - W	7. VelociCalc - TSI 9555/9 -W
2. PID - W	4. Interface Probe - W	6. Four Gas Meter - W	

### OPERATION & MAINTENANCE ACTIVITIES

<b>AECOM/Preferred Site Representative:</b> Thomas Fitzpatrick - Preferred
<b>DESCRIPTION OF WORK PERFORMED AND OBSERVED</b>
<b>10:25</b> - Preferred and EA representative arrived on-site. Both systems are up with five (5) alarms triggered:
5/13/2013 11:59 W12: WELL DDC7 LOF DIFF. PRESSURE
5/13/2013 11:59 W9: WELL DDC10 LOW DIFF. PRESSURE
5/13/2013 11:59 W8: WELL DDC5 LOW DIFF. PRESSURE
5/13/2013 11:59 W6: B-502 Low Vacuum (VT202)
5/13/2013 11:59 A1: Emergency Stop. This was done manually at the site in order to test/verify the newly configured remote communication system was working properly.
<b>10:35</b> - Weekly O&M started.
<b>11:24</b> - Gauged piezometer wells along Benjoe Avenue.
<b>12:10</b> - O&M completed.
<b>12:20</b> - Preferred locked both sheds and all parties off-site. All alarms were reset, with blowers B-501 & B-502 up upon departure.

x
---

 - Designates report is continued on additional pages

EA Engineering/Preferred Site Representative: Thomas Fitzpatrick (Preferred)

Project Manager: J. Hayward

# O&M DATA SHEET - NATIONAL HEATSET - OFF-SITE SYSTEM

Date: 5/14/2013

Time: 10:26

Weather: 55° F - Bright Sun- Low Humidity

B-501 Status on Arrival: Up / Down / Off

B-502 Status on Arrival: Up / Down / Off

Alarm Light Status on Arrival: ON / OFF

Alarm Light Reset on Arrival: YES / NO

## SYSTEM OPERATING DATA

ID	B-501	TP-211	B-502	TP-212	B-503	TP-213	Time
Hours	7,656.2	0.1	7,115.0	0.3	0	0	@10:36
Hz	27	Hz	27		Separator ID	Water Level (IN)	Drained
PI-511	5.9	PI-512	7.1				
TSH-511	115	TSH-512	160		ST-201	0	YES / <u>NO</u>
					ST-202	0	YES / <u>NO</u>
VI-201	-2.0	IWC	VI-202	-2.0	IWC		
TI-201	70	°F	TI-202	71	°F		
DPT-201	0.40	IWC (6" Pipe)	DPT-202	0.44	IWC (6" Pipe)		
V-DLH5-6	<u>Open</u> / Closed		V-DLH5-6	<u>Open</u> / Closed			
VI-401	-4.0	IWC	VI-402	-4.0	IWC		
TI-401	65	°F	TI-402	68	°F		
VI-401B	-5.0	IWC	VI-402A	-17	IWC		
SP-401B	0.1	ppb / <u>ppm</u>	SP-402A	0.1	ppb / <u>ppm</u>		
VI-401A	-19	IWC	VI-402B	-7.0	IWC		
SP-401A	0.0	ppb / ppm	SP-402B	1.5	ppb / <u>ppm</u>		
VI-403B	-13	IWC	VI-403A	-12	IWC		
SP-403B	0.0	ppb / <u>ppm</u>	SP-403A	0.2	ppb / <u>ppm</u>		
VI-501	-24	IWC	VI-502	-22	IWC		
SP-501	0.0	ppb / <u>ppm</u>	SP-502	0.0	ppb / <u>ppm</u>		
TI-501	70	°F	TI-502	72	°F		
VI-501A	-25	IWC	VI-502A	-22	IWC		
DPT-301	0.33	IWC (6" Pipe)	DPT-302	0.28	IWC (6" Pipe)		
PI-301	6.0	PSI	PI-302	6.4	PSI		
TI-301	100	°F	TI-302	115	°F		
FM-601	82.7 gal	Electric Meter Reading:		7,158 kW/h @	10:49 AM		

B-501 Status on Departure: UP / DOWN / OFF

B-502 Status on Departure: UP / DOWN / OFF

Alarm Light Status on Departure: ON / OFF

Alarm Light Reset on Departure: YES / NO

## O&M DATA SHEET - NATIONAL HEATSET - OFF-SITE SYSTEM

Date: 05/14/13      Time: 11:00      Weather: 55° F - Bright Sun

### INJECTION& EXTRACTION MANIFOLD OPERATING DATA

Well ID	4" - INJECTION			6" - EXTRACTION			
	Δ Pressure (IWC)	Temp (°F)	Pressure (PSI)	Vacuum (IWC)	Temp (°F)	Velocity (ft/min)	VOCs (ppb or ppm)
DDC-05	-0.07	95	4.3	1.241	69	668	0.0
DDC-10	-0.02	95	4.5	1.435	71	709	0.0
DDC-09	0.28	95	5.1	0.903	71	778	0.4
DDC-08	0.27	100	4.5	1.293	71	980	2.4
DDC-07	-0.05	95	5.1	1.270	70	660	0.1
DDC-06	0.43	100	5.2	1.455	69	688	0.0

### DDC WELLHEAD OPERATING DATA

WELL ID	PZ SHALLOW (FT)	PZ DEEP (FT)	Air Space (FT)	COMMENTS	MW ID	DTW (FT)
DDC-05	9.45	14.94	5.0'	---	MW-1D	N/A
DDC-10	9.47	13.74	1.5'	Dry	MW-1S	N/A
DDC-09	9.08	14.14	2.0'	7-Inches of pooled water within vault	MW-2D	N/A
DDC-08	8.47	13.32	1.0'	7-Inches of pooled water within vault	MW-2S	N/A
DDC-07	8.91	10.94	1.5'	Dry	MW-3D	N/A
DDC-06	8.70	8.87	4.0'	(1) Drained condensate valve	MW-3S	N/A

### AIR SAMPLING DATA

B-501			B-502		
Sample Port Position	SAMPLE PORT ID	VOC Reading (ppb / ppm)	Sample Port Position	SAMPLE PORT ID	VOC Reading (ppb / ppm)
Influent	SP-401B	0.1	Influent	SP-402B	1.0
Intermediate #1	SP-403B	0.0	Intermediate #1	SP-403A	0.3
Intermediate #2	SP-401A	0.0	Intermediate #2	SP-402A	0.1
Effluent	SP-501	0.0	Effluent	SP-502	0.0

### CHILLER

### TECHNICIAN COMMENTS/NOTES:

Set Temp. (°F)	75	
Actual Temp. (°F)	73	
Pump Pressure (PSI)	25	1 - DDC-6's condensate valve was drained for 1 minute, from which a less
Freon High Pres. (PSI)	149	than a quarter gallon of water was produced. DDC-6 produced mostly air
Freon Low Pres. (PSI)	115	from the initial release of the valve.

Lawn Cut by EA at 10:43

**PHOTOGRAPHIC LOG**  
**Date: 5-14-13**  
**EA Engineering, P.C. Job No.**  
**National Heatset Printing Site - Off-Site**

PHOTO	DATE	TIME	DESCRIPTION	COMMENTS
Picture 0074	5/14/2013	12:34	Five (5) alarms were triggered on the control panel upon arrival.	
Picture 0081	5/14/2013	13:04	An Interface probe was utilized in the gauging of the on and off-site piezometer wells.	

## Photos (5.14.13)



**Picture 0074-** Five (5) alarms were triggered on the control panel upon arrival.



**Picture 0081-** An Interface probe was utilized in the gauging of the on and off-site piezometer wells.