

Inactive Hazardous Waste Site Operations and Maintenance Review Report

Form Date 96.10.01

Site Name: NOW Corporation Class: 2 Number: 3-14-008  
O&M Funding Source: ☒ State Superfund ☐ Federal Superfund ☐ Municipal ☐ Responsible Party  
O&M Information: O&M Start: 4/1/99 End: Annual Cost: \$ ☐ Estimated

Interim Remedial Measures/Operable Units in O&M Phase:

☐ Drum Removal ☒ Soil Removal ☐ Tank Removal  
☐ Cap/Cover ☐ Containment Structure ☐ Fence/Security  
☒ Groundwater Recovery/Treatment ☐ Leachate Collection/Treatment ☐ Vapor Extraction/Treatment  
☒ Air Sparging/Stripper System ☐ Treatment/Filtration Plant/System ☐ Potable Water  
Supply/System  
☒ Other: GAC Filters on 2 Adjacent Homeowners

Institutional Controls: ☐ Deed Restriction ☒ Discharge Permit ☐ Department of Health Sampling  
☐ Other:

O&M Review Information:

Reports: Yes

Inspection: Yes

Sampling: Sampling

Other:

Conclusions:

Remedy Effective? ☒ Yes ☐ No:

ROD Compliance? ☒ Yes ☐ No:

Consent Order Compliance? ☐ Yes ☐ No: Not Applicable

Other:

Recommendations:

Gave OK to remove the twin GAC cylinders from the airstripper vapor - the reconnection system, 2 wells, other work on 1 well

ROD/Consent Order Modifications? ☐ No ☐ Yes (per above) Reclassify the Site? ☐ No ☐ Yes → Class:

Comments: There were several SPDES violations for zinc during the summer

Project Manager:

Signature: [Signature] Date: 03/24/00  
Name: Terry Hulse Region or Bureau: C.O.S.T. 518-457-7224 Telephone:

Reviewer:

Signature: \_\_\_\_\_ Date: \_\_\_\_\_  
Name: \_\_\_\_\_ Region or Bureau: \_\_\_\_\_ Telephone: \_\_\_\_\_

Which reports also when DEC? also when DEC?

?