

NEW YORK STATE DEPARTMENT OF ENVIRONMENTAL CONSERVATION
Division of Environmental Remediation
Inactive Hazardous Waste Site Operations and Maintenance Review Report

Form Date 98.10.01

Site Name: NOV CORPORATION Class: 4 Number: 314008

O&M Funding Source: ☐ State Superfund ☐ Federal Superfund ☐ Municipal ☐ Responsible Party

O&M Information: O&M Start: _____ End: _____ Annual Cost: \$ _____ ☐ Estimated

Interim Remedial Measures/Operable Units in O&M Phase:

☐ Drum Removal	☐ Soil Removal	☐ Tank Removal
☐ Cap/Cover	☐ Containment Structure	☐ Fence/Security
☒ Groundwater Recovery/Treatment	☐ Leachate Collection/Treatment	☒ Vapor Extraction/Treatment
☐ Air Sparging/Stripper System	☐ Treatment/Filtration Plant/System	☐ Potable Water

Supply/System: ☒ Other: NA

Institutional Controls: ☐ Deed Restriction ☐ Discharge Permit ☒ Department of Health Sampling

☒ Other: NYS DOH / NYSDER SAMPLING OF PRIVATE WELLS

O&M Review Information:

Reports: MONTHLY REPORTS AND A ANNUAL REPORT

Inspection: 05/10/02 WITH GEORGE MAMBERGER

Sampling: GW QUALITY (15 MONITORING WELLS) ANNUAL + REST MONTHLY

Other: RESIDENTIAL DRINKING WATER WELLS MONITORED BY THE NYS DOH

Conclusions:

Remedy Effective? ☒ Yes ☐ No

ROD Compliance? ☒ Yes ☐ No

Consent Order Compliance? ☒ Yes ☐ No

Other: CO & ROD NOT AVAILABLE FROM NYS ATTORNEY ??

Recommendations: NONE AT THIS TIME

NOTE:
THE SYSTEM IS OPERATING AT THIS TIME ON MINIMUM FLOW TREATMENT UNTIL NECESSARY REPAIRS ARE CARRIED OUT. SPOKE TO TECHNIC WILF. LINDBERGH AND STEVE OF EARTH TECH AND FILED OF B & R SPECIALITIES

ROD/Consent Order Modifications? ☐ No ☐ Yes (per above) Reclassify the Site? ☐ No ☐ Yes → Class: _____

Comments: VISITED THE WELL FIELD. INSPECTED THE TWO (2) RECOVERY SCAVENGER WELLS AND THE TWO (2) INJECTION WELLS THAT ARE GRAVITY FED. THE FOLLOWING SAMPLE TYPE, LOCATION, MATRIX WERE NOTED. IN THE TREATMENT BUILDING, THE AIR STRIPPER (INFLUENT, EFFLUENT) WATER MATRIX; THE AIR STRIPPER (EXHAUST) AIR MATRIX; GW RECOVERY WELLS (TW-1, TW-2A, TW-3) WATER MATRIX; VAPOR EXT. POINTS (TW-1, TW-2A, VE-1, VE-2) AIR MATRIX; COMBINED SVE (INFLUENT) AIR MATRIX; SVE EXHAUST (CAC UNITS) AIR MATRIX; I IDENTIFIED THE MWs (MW-1 TO MW-11) FOR THE WATER MATRIX

Project Manager: S-E-MAHAMOOD 05/15/02 Date

Signature: S-E-MAHAMOOD +? 845-258-3147

Name: _____ Region or Bureau: _____ Telephone: _____

Reviewer: R. [Signature] 10/16/02

Signature: R. [Signature] 10/16/02

Name: _____ Region or Bureau: _____ Telephone: _____