

**Operation, Maintenance and Monitoring Report
December 2007**

**NOW Corporation
Site 3-14-008**

**Work Assignment No.
D004445-4**

Prepared for:



**SUPERFUND STANDBY PROGRAM
New York State
Department of Environmental Conservation
625 Broadway
Albany, New York 12233**

Prepared by:

**Earth Tech Northeast, Inc.
40 British American Boulevard
Latham, New York 12110**

March 6, 2008

Mr. Carl Hoffman, P.E.
NYSDEC Division of Environmental Remediation
625 Broadway, 12th Floor
Albany, New York 12233-7013

Re: NOW Corporation - Site #3-14-008
Monthly Summary Report – “December” 2007

Dear Mr. Hoffman:

This monthly summary report describes the operation, monitoring and maintenance (OM&M) of the remedial system at the NOW Corporation site in the Town of Clinton, New York, for a 28-day period (**November 15, 2007 – December 13, 2007**).

With the exceptions noted below (if any), the P&T system was online and operational throughout the reporting period. Approximately 404,600 gallons of water were treated during the period. Discharge from the treatment system averaged approximately 14,450 gallons per day (gpd). During the prior reporting period, the average discharge was 7,000 gpd.

As of the last day of the reporting period, a total of 60,506,000 gallons of groundwater had been recovered and treated by the system since it became operational in February 1998.

Table 1 summarizes influent and effluent analytical data for water samples collected on December 13, 2007. **There were no exceedences of effluent limitations.** A copy of the laboratory data report is included in this letter report. Table 2 summarizes selected operational data recorded on the last day of the reporting period.

Earth Tech made two site visits during the reporting period to conduct the required system inspection, perform scheduled and/or unscheduled maintenance, and to collect water samples. The November 15th service visit was described in the previous report. Details for the current period follow:

December 7th – Tech, who was in the area, briefly stopped by to increase the flow rate on TW-3. Water levels had been high in this well since November 28th.

December 13th – Monthly system inspection and sampling. Daily remote monitoring on the 11th showed that the system went down just after midnight due to high water in the final settling tank. Tech relaced effluent pump with clean spare. Restarted system. On a later date, the failed pump was delivered to Pump Service & Supply (Troy, NY) for inspection.

Please feel free to contact me at (518) 951-2262 if you have any questions regarding this report or the operation of the treatment system.

Sincerely,
Earth Tech Northeast



Stephen R. Choiniere
Project Manager

Attachments

Table 1
Summary of Influent and Effluent Data
Sampling Date: December 13, 2007
NOW Corporation Site
Town of Clinton, New York

Analytes/ Parameters	Total Influent	Effluent	Recovery Wells			Effluent Limitations	
			TW-1	TW-2A	TW-3	(units)	
Quantity treated, per day		14,450				Monitor	gpd
pH	7.4	6.8	NA	NA	NA	6.5 to 8.5	standard units
Oil and Grease	<5.0	<5.0	NA	NA	NA	15	mg/L
Total Cyanide	<10	<10	NA	NA	NA	10	ug/L
TDS	350	300	NA	NA	NA	1000	mg/L
TSS	<10	<10	NA	NA	NA	50	mg/L
Aluminum, Total	<200	<200	NA	NA	NA	2000	ug/L
Arsenic, Total	32	26	NA	NA	NA	50	ug/L
Barium, Total	<200	<200	NA	NA	NA	2000	ug/L
Chromium	<20	<20	NA	NA	NA	100	ug/L
Copper	<25	<25	NA	NA	NA	24	ug/L
Iron	240	230	NA	NA	NA	600	ug/L
Mercury	<0.20	<0.20	NA	NA	NA	0.8	ug/L
Manganese	140	89	NA	NA	NA	600	ug/L
Nickel	<50	<50	NA	NA	NA	200	ug/L
Zinc	<50	<50	NA	NA	NA	150	ug/L
1,1,1-Trichloroethane	560	<0.50	14	1300	15	5	ug/L
1,1,2-Trichloroethane	<25	<0.50	<2.5	<25	<0.50	1.2	ug/L
1,1-Dichloroethane	130	<0.50	68	260	21	5	ug/L
1,1-Dichloroethene	16 J	<0.50	9.9	30	2.1	0.5	ug/L
1,2-Dichloroethane	<25	<0.50	<2.5	<25	<0.50	1.6	ug/L
Benzene	<25	<0.50	<2.5	<25	<0.50	0.8	ug/L
Chlorobenzene	<25	<0.50	<2.5	<25	<0.50	5	ug/L
Chloroethane	<25	<0.50	1.1 J	<25	<0.50	5	ug/L
cis-1,2-Dichloroethene	12 J	<0.50	4.7	19 J	0.26 J	5	ug/L
Ethylbenzene	<25	<0.50	<2.5	<25	<0.50	5	ug/L
Methyl tert-butyl ether	<25	<0.50	<2.5	<25	<0.50	5	ug/L
o-Xylene	<25	<0.50	<2.5	<25	<0.50	5	ug/L
p&m-Xylene	<25	<0.50	<2.5	<25	<0.50	10	ug/L
Tetrachloroethene	<25	<0.50	<2.5	<25	<0.50	1.4	ug/L
Toluene	<25	<0.50	<2.5	<25	<0.50	5	ug/L
trans-1,2-Dichloroethene	<25	<0.50	<2.5	<25	<0.50	5	ug/L
Trichloroethene	300	<0.50	70	630	11	5	ug/L
Vinyl Chloride	<25	<0.50	<2.5	<25	<0.50	0.6	ug/L

Notes:

- 1) Detected concentrations are presented in **bold** typeface, and are expressed in the units shown in far right column.
- 2) Effluent concentration boxed in **bold** denotes exceedance of effluent limitations.
- 3) NA indicates not analyzed.
- 4) "J" indicates an estimated concentration below the method detection limit.
- 5) "D" denotes analytical result for a diluted sample.

Table 2
Summary of December 2007 O&M Data

NOW Corporation Site
Town of Clinton, New York

Instrumentation/Readings:		12/13/07	Units
<i>TW-1</i>			
	Pumping Rate	4	GPM
	Water Level Above Transducer	27.64	feet
	Flow Meter Reading	4,282,400	gallons
	Pump Pressure	70	psi
<i>TW-2A</i>			
	Pumping Rate	9	GPM
	Water Level Above Transducer	59.97	feet
	Flow Meter Reading	3,560,500	gallons
	Pump Pressure	44	psi
<i>TW-3</i>			
	Pumping Rate	4	GPM
	Water Level Above Transducer	28.98	feet
	Flow Meter Reading	4,702,200	gallons
	Pump Pressure	64	psi
<i>Air Stripper</i>			
	Stripper Blower Pressure	18	inches H ₂ O
	Air Temperature in Stripper	46	°F
	Pressure Gauge - Left Leg	0.9	inches H ₂ O
	Pressure Gauge - Right Leg	0.4	inches H ₂ O
<i>Effluent Flow</i>			
	Effluent Flow this period (calculated)	404,600	gallons
	Total Effluent Flow (calculated)	60,506,300	gallons

**INFLUENT & EFFLUENT WATER
ANALYTICAL REPORT**

Client: Earth Tech

Client Project: NOW Corp, 94017.02, 12/07

Lab Work Order: F1865

Date samples received: 12/14/07

Project Narrative

This data report includes the analysis results for six (6) aqueous samples that were received from Earth Tech on December 14, 2007. Analyses were performed per specification in the Chain of Custody form. For reference, a copy of the Mitkem Sample Log-In form is included for cross-referencing the client sample ID and laboratory sample ID.

Surrogate recoveries were within the QC limits for volatile organic analyses. Percent recoveries in laboratory control samples were within the QC limits. Due to elevated concentrations of target analytes, the following samples were initially analyzed at dilution: INF-121307 (50X), TW-1 (5X) and TW-2A (50X).

Spike recoveries were within the QC limits in the laboratory control samples for metals, total dissolved solids, total suspended solids, cyanide and oil & grease analyses.

No other unusual occurrences were noted during sample analysis.

All pages in this report have been numbered consecutively, starting with the title page and ending with a page saying only "Last Page of Data Report".

This data report has been reviewed and is authorized for release as evidenced by the signature below.



Edward A. Lawler
Laboratory Operations Manager

Mitkem Laboratories

Date: 31-Dec-07

Client: Earth Tech
Client Sample ID: EFF 121307
Lab ID: F1865-01

Project: NOW Corp. Site
Collection Date: 12/13/07 11:35

Analyses	Result	Qual	RL	Units	DF	Date Analyzed	Batch ID
VOC by GC-MS (25 mL Purge)			SW8260B_25_W				
Vinyl chloride	ND		0.50	µg/L	1	12/24/2007 18:57	34006
Chloroethane	ND		0.50	µg/L	1	12/24/2007 18:57	34006
1,1-Dichloroethene	ND		0.50	µg/L	1	12/24/2007 18:57	34006
trans-1,2-Dichloroethene	ND		0.50	µg/L	1	12/24/2007 18:57	34006
Methyl tert-butyl ether	ND		0.50	µg/L	1	12/24/2007 18:57	34006
1,1-Dichloroethane	ND		0.50	µg/L	1	12/24/2007 18:57	34006
cis-1,2-Dichloroethene	ND		0.50	µg/L	1	12/24/2007 18:57	34006
1,1,1-Trichloroethane	ND		0.50	µg/L	1	12/24/2007 18:57	34006
1,2-Dichloroethane	ND		0.50	µg/L	1	12/24/2007 18:57	34006
Benzene	ND		0.50	µg/L	1	12/24/2007 18:57	34006
Trichloroethene	ND		0.50	µg/L	1	12/24/2007 18:57	34006
Toluene	ND		0.50	µg/L	1	12/24/2007 18:57	34006
1,1,2-Trichloroethane	ND		0.50	µg/L	1	12/24/2007 18:57	34006
Tetrachloroethene	ND		0.50	µg/L	1	12/24/2007 18:57	34006
Chlorobenzene	ND		0.50	µg/L	1	12/24/2007 18:57	34006
Ethylbenzene	ND		0.50	µg/L	1	12/24/2007 18:57	34006
m,p-Xylene	ND		0.50	µg/L	1	12/24/2007 18:57	34006
o-Xylene	ND		0.50	µg/L	1	12/24/2007 18:57	34006
Surr: Dibromofluoromethane	100		88-124	%REC	1	12/24/2007 18:57	34006
Surr: 1,2-Dichloroethane-d4	99.2		79-115	%REC	1	12/24/2007 18:57	34006
Surr: Toluene-d8	97.1		80-114	%REC	1	12/24/2007 18:57	34006
Surr: Bromofluorobenzene	94.7		60-123	%REC	1	12/24/2007 18:57	34006

Qualifiers: ND - Not Detected at the Reporting Limit
J - Analyte detected below quantitation limits
B - Analyte detected in the associated Method Blank
DF - Dilution Factor

S - Spike Recovery outside accepted recovery limits
R - RPD outside accepted recovery limits
E - Value above quantitation range
RL - Reporting Limit

0000

Mitkem Laboratories

Date: 31-Dec-07

Client: Earth Tech
Client Sample ID: INF 121307
Lab ID: F1865-02

Project: NOW Corp. Site
Collection Date: 12/13/07 11:20

Analyses	Result	Qual	RL	Units	DF	Date Analyzed	Batch ID
VOC by GC-MS (25 mL Purge)			SW8260B_25_W				
Vinyl chloride	ND		25	µg/L	50	12/24/2007 20:00	34006
Chloroethane	ND		25	µg/L	50	12/24/2007 20:00	34006
1,1-Dichloroethene	16	J	25	µg/L	50	12/24/2007 20:00	34006
trans-1,2-Dichloroethene	ND		25	µg/L	50	12/24/2007 20:00	34006
Methyl tert-butyl ether	ND		25	µg/L	50	12/24/2007 20:00	34006
1,1-Dichloroethane	130		25	µg/L	50	12/24/2007 20:00	34006
cis-1,2-Dichloroethene	12	J	25	µg/L	50	12/24/2007 20:00	34006
1,1,1-Trichloroethane	560		25	µg/L	50	12/24/2007 20:00	34006
1,2-Dichloroethane	ND		25	µg/L	50	12/24/2007 20:00	34006
Benzene	ND		25	µg/L	50	12/24/2007 20:00	34006
Trichloroethene	300		25	µg/L	50	12/24/2007 20:00	34006
Toluene	ND		25	µg/L	50	12/24/2007 20:00	34006
1,1,2-Trichloroethane	ND		25	µg/L	50	12/24/2007 20:00	34006
Tetrachloroethene	ND		25	µg/L	50	12/24/2007 20:00	34006
Chlorobenzene	ND		25	µg/L	50	12/24/2007 20:00	34006
Ethylbenzene	ND		25	µg/L	50	12/24/2007 20:00	34006
m,p-Xylene	ND		25	µg/L	50	12/24/2007 20:00	34006
o-Xylene	ND		25	µg/L	50	12/24/2007 20:00	34006
Surr: Dibromofluoromethane	107		88-124	%REC	50	12/24/2007 20:00	34006
Surr: 1,2-Dichloroethane-d4	107		79-115	%REC	50	12/24/2007 20:00	34006
Surr: Toluene-d8	98.7		80-114	%REC	50	12/24/2007 20:00	34006
Surr: Bromofluorobenzene	92.4		60-123	%REC	50	12/24/2007 20:00	34006

Qualifiers: ND - Not Detected at the Reporting Limit
J - Analyte detected below quantitation limits
B - Analyte detected in the associated Method Blank
DF - Dilution Factor

S - Spike Recovery outside accepted recovery limits
R - RPD outside accepted recovery limits
E - Value above quantitation range
RL - Reporting Limit

Mitkem Laboratories

Date: 31-Dec-07

Client: Earth Tech

Client Sample ID: TW-1

Lab ID: F1865-03

Project: NOW Corp. Site

Collection Date: 12/13/07 11:40

Analyses	Result	Qual	RL	Units	DF	Date Analyzed	Batch ID
VOC by GC-MS (25 mL Purge)			SW8260B_25_W				
Vinyl chloride	ND		2.5	µg/L	5	12/24/2007 20:31	34006
Chloroethane	1.1	J	2.5	µg/L	5	12/24/2007 20:31	34006
1,1-Dichloroethene	9.9		2.5	µg/L	5	12/24/2007 20:31	34006
trans-1,2-Dichloroethene	ND		2.5	µg/L	5	12/24/2007 20:31	34006
Methyl tert-butyl ether	ND		2.5	µg/L	5	12/24/2007 20:31	34006
1,1-Dichloroethane	68		2.5	µg/L	5	12/24/2007 20:31	34006
cis-1,2-Dichloroethene	4.7		2.5	µg/L	5	12/24/2007 20:31	34006
1,1,1-Trichloroethane	14		2.5	µg/L	5	12/24/2007 20:31	34006
1,2-Dichloroethane	ND		2.5	µg/L	5	12/24/2007 20:31	34006
Benzene	ND		2.5	µg/L	5	12/24/2007 20:31	34006
Trichloroethene	70		2.5	µg/L	5	12/24/2007 20:31	34006
Toluene	ND		2.5	µg/L	5	12/24/2007 20:31	34006
1,1,2-Trichloroethane	ND		2.5	µg/L	5	12/24/2007 20:31	34006
Tetrachloroethene	ND		2.5	µg/L	5	12/24/2007 20:31	34006
Chlorobenzene	ND		2.5	µg/L	5	12/24/2007 20:31	34006
Ethylbenzene	ND		2.5	µg/L	5	12/24/2007 20:31	34006
m,p-Xylene	ND		2.5	µg/L	5	12/24/2007 20:31	34006
o-Xylene	ND		2.5	µg/L	5	12/24/2007 20:31	34006
Surr: Dibromofluoromethane	105		88-124	%REC	5	12/24/2007 20:31	34006
Surr: 1,2-Dichloroethane-d4	97.5		79-115	%REC	5	12/24/2007 20:31	34006
Surr: Toluene-d8	96.8		80-114	%REC	5	12/24/2007 20:31	34006
Surr: Bromofluorobenzene	95.1		60-123	%REC	5	12/24/2007 20:31	34006

Qualifiers: ND - Not Detected at the Reporting Limit
J - Analyte detected below quantitation limits
B - Analyte detected in the associated Method Blank
DF - Dilution Factor

S - Spike Recovery outside accepted recovery limits
R - RPD outside accepted recovery limits
E - Value above quantitation range
RL - Reporting Limit

0005

Mitkem Laboratories

Date: 31-Dec-07

Client: Earth Tech

Client Sample ID: TW-2A

Lab ID: F1865-04

Project: NOW Corp. Site

Collection Date: 12/13/07 11:45

Analyses	Result	Qual	RL	Units	DF	Date Analyzed	Batch ID
VOC by GC-MS (25 mL Purge)			SW8260B_25_W				
Vinyl chloride	ND		25	µg/L	50	12/24/2007 21:02	34006
Chloroethane	ND		25	µg/L	50	12/24/2007 21:02	34006
1,1-Dichloroethene	30		25	µg/L	50	12/24/2007 21:02	34006
trans-1,2-Dichloroethene	ND		25	µg/L	50	12/24/2007 21:02	34006
Methyl tert-butyl ether	ND		25	µg/L	50	12/24/2007 21:02	34006
1,1-Dichloroethane	260		25	µg/L	50	12/24/2007 21:02	34006
cis-1,2-Dichloroethene	19	J	25	µg/L	50	12/24/2007 21:02	34006
1,1,1-Trichloroethane	1300		25	µg/L	50	12/24/2007 21:02	34006
1,2-Dichloroethane	ND		25	µg/L	50	12/24/2007 21:02	34006
Benzene	ND		25	µg/L	50	12/24/2007 21:02	34006
Trichloroethene	630		25	µg/L	50	12/24/2007 21:02	34006
Toluene	ND		25	µg/L	50	12/24/2007 21:02	34006
1,1,2-Trichloroethane	ND		25	µg/L	50	12/24/2007 21:02	34006
Tetrachloroethene	ND		25	µg/L	50	12/24/2007 21:02	34006
Chlorobenzene	ND		25	µg/L	50	12/24/2007 21:02	34006
Ethylbenzene	ND		25	µg/L	50	12/24/2007 21:02	34006
m,p-Xylene	ND		25	µg/L	50	12/24/2007 21:02	34006
o-Xylene	ND		25	µg/L	50	12/24/2007 21:02	34006
Surr: Dibromofluoromethane	105		88-124	%REC	50	12/24/2007 21:02	34006
Surr: 1,2-Dichloroethane-d4	93.2		79-115	%REC	50	12/24/2007 21:02	34006
Surr: Toluene-d8	101		80-114	%REC	50	12/24/2007 21:02	34006
Surr: Bromofluorobenzene	95.3		60-123	%REC	50	12/24/2007 21:02	34006

Qualifiers: ND - Not Detected at the Reporting Limit
J - Analyte detected below quantitation limits
B - Analyte detected in the associated Method Blank
DF - Dilution Factor

S - Spike Recovery outside accepted recovery limits
R - RPD outside accepted recovery limits
E - Value above quantitation range
RL - Reporting Limit

0006

Mitkem Laboratories

Date: 31-Dec-07

Client: Earth Tech

Client Sample ID: TW-3

Lab ID: F1865-05

Project: NOW Corp. Site

Collection Date: 12/13/07 11:50

Analyses	Result	Qual	RL	Units	DF	Date Analyzed	Batch ID
VOC by GC-MS (25 mL Purge)		SW8260B_25_W					
Vinyl chloride	ND		0.50	µg/L	1	12/24/2007 19:28	34006
Chloroethane	ND		0.50	µg/L	1	12/24/2007 19:28	34006
1,1-Dichloroethene	2.1		0.50	µg/L	1	12/24/2007 19:28	34006
trans-1,2-Dichloroethene	ND		0.50	µg/L	1	12/24/2007 19:28	34006
Methyl tert-butyl ether	ND		0.50	µg/L	1	12/24/2007 19:28	34006
1,1-Dichloroethane	21		0.50	µg/L	1	12/24/2007 19:28	34006
cis-1,2-Dichloroethene	0.26	J	0.50	µg/L	1	12/24/2007 19:28	34006
1,1,1-Trichloroethane	15		0.50	µg/L	1	12/24/2007 19:28	34006
1,2-Dichloroethane	ND		0.50	µg/L	1	12/24/2007 19:28	34006
Benzene	ND		0.50	µg/L	1	12/24/2007 19:28	34006
Trichloroethene	11		0.50	µg/L	1	12/24/2007 19:28	34006
Toluene	ND		0.50	µg/L	1	12/24/2007 19:28	34006
1,1,2-Trichloroethane	ND		0.50	µg/L	1	12/24/2007 19:28	34006
Tetrachloroethene	ND		0.50	µg/L	1	12/24/2007 19:28	34006
Chlorobenzene	ND		0.50	µg/L	1	12/24/2007 19:28	34006
Ethylbenzene	ND		0.50	µg/L	1	12/24/2007 19:28	34006
m,p-Xylene	ND		0.50	µg/L	1	12/24/2007 19:28	34006
o-Xylene	ND		0.50	µg/L	1	12/24/2007 19:28	34006
Surr: Dibromofluoromethane	103		88-124	%REC	1	12/24/2007 19:28	34006
Surr: 1,2-Dichloroethane-d4	103		79-115	%REC	1	12/24/2007 19:28	34006
Surr: Toluene-d8	101		80-114	%REC	1	12/24/2007 19:28	34006
Surr: Bromofluorobenzene	93.3		60-123	%REC	1	12/24/2007 19:28	34006

Qualifiers: ND - Not Detected at the Reporting Limit
J - Analyte detected below quantitation limits
B - Analyte detected in the associated Method Blank
DF - Dilution Factor

S - Spike Recovery outside accepted recovery limits
R - RPD outside accepted recovery limits
E - Value above quantitation range
RL - Reporting Limit

0007

Mitkem Laboratories

Date: 31-Dec-07

Client: Earth Tech

Client Sample ID: TRIP BLANK

Lab ID: F1865-06

Project: NOW Corp. Site

Collection Date: 12/13/07 0:00

Analyses	Result	Qual	RL	Units	DF	Date Analyzed	Batch ID
VOC by GC-MS (25 mL Purge)			SW8260B_25_W				
Vinyl chloride	ND		0.50	µg/L	1	12/24/2007 18:25	34006
Chloroethane	ND		0.50	µg/L	1	12/24/2007 18:25	34006
1,1-Dichloroethene	ND		0.50	µg/L	1	12/24/2007 18:25	34006
trans-1,2-Dichloroethene	ND		0.50	µg/L	1	12/24/2007 18:25	34006
Methyl tert-butyl ether	ND		0.50	µg/L	1	12/24/2007 18:25	34006
1,1-Dichloroethane	ND		0.50	µg/L	1	12/24/2007 18:25	34006
cis-1,2-Dichloroethene	ND		0.50	µg/L	1	12/24/2007 18:25	34006
1,1,1-Trichloroethane	ND		0.50	µg/L	1	12/24/2007 18:25	34006
1,2-Dichloroethane	ND		0.50	µg/L	1	12/24/2007 18:25	34006
Benzene	ND		0.50	µg/L	1	12/24/2007 18:25	34006
Trichloroethene	ND		0.50	µg/L	1	12/24/2007 18:25	34006
Toluene	ND		0.50	µg/L	1	12/24/2007 18:25	34006
1,1,2-Trichloroethane	ND		0.50	µg/L	1	12/24/2007 18:25	34006
Tetrachloroethene	ND		0.50	µg/L	1	12/24/2007 18:25	34006
Chlorobenzene	ND		0.50	µg/L	1	12/24/2007 18:25	34006
Ethylbenzene	ND		0.50	µg/L	1	12/24/2007 18:25	34006
m,p-Xylene	ND		0.50	µg/L	1	12/24/2007 18:25	34006
o-Xylene	ND		0.50	µg/L	1	12/24/2007 18:25	34006
Surr: Dibromofluoromethane	103		88-124	%REC	1	12/24/2007 18:25	34006
Surr: 1,2-Dichloroethane-d4	93.5		79-115	%REC	1	12/24/2007 18:25	34006
Surr: Toluene-d8	99.4		80-114	%REC	1	12/24/2007 18:25	34006
Surr: Bromofluorobenzene	94.0		60-123	%REC	1	12/24/2007 18:25	34006

Qualifiers: ND - Not Detected at the Reporting Limit
J - Analyte detected below quantitation limits
B - Analyte detected in the associated Method Blank
DF - Dilution Factor

S - Spike Recovery outside accepted recovery limits
R - RPD outside accepted recovery limits
E - Value above quantitation range
RL - Reporting Limit

0000

CLIENT: Earth Tech
Work Order: F1865
Project: NOW Corp. Site

TestCode: SW8260B_25_W

ANALYTICAL QC SUMMARY REPORT

Sample ID: MB-34006	SampType: MBLK	TestCode: SW8260B_25_W	Prep Date: 12/24/2007	Run ID: V2_071224A							
Client ID: MB-34006	Batch ID: 34006	Units: µg/L	Analysis Date: 12/24/2007	SeqNo: 741567							
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Vinyl chloride	ND	0.50									
Chloroethane	ND	0.50									
1,1-Dichloroethene	ND	0.50									
trans-1,2-Dichloroethene	ND	0.50									
Methyl tert-butyl ether	ND	0.50									
1,1-Dichloroethane	ND	0.50									
cis-1,2-Dichloroethene	ND	0.50									
1,1,1-Trichloroethane	ND	0.50									
1,2-Dichloroethane	ND	0.50									
Benzene	ND	0.50									
Trichloroethene	ND	0.50									
Toluene	ND	0.50									
1,1,2-Trichloroethane	ND	0.50									
Tetrachloroethene	ND	0.50									
Chlorobenzene	ND	0.50									
Ethylbenzene	ND	0.50									
m,p-Xylene	ND	0.50									
o-Xylene	ND	0.50									
Surr: Dibromofluoromethane	5.009	0.50	5.000	0	100	88	124			0	
Surr: 1,2-Dichloroethane-d4	4.286	0.50	5.000	0	85.7	79	115			0	
Surr: Toluene-d8	5.210	0.50	5.000	0	104	80	114			0	
Surr: Bromofluorobenzene	4.792	0.50	5.000	0	95.8	60	123			0	

0000

Qualifiers: ND - Not Detected at the Reporting Limit
J - Analyte detected below quantitation limits

S - Spike Recovery outside accepted recovery limits
R - RPD outside accepted recovery limits

B - Analyte detected in the associated Method Blank

Sample ID: LCS-34006	Samp Type: LCS	TestCode: SW8260B_25_W	Prep Date: 12/24/2007	Run ID: V2_071224A							
Client ID: LCS-34006	Batch ID: 34006	Units: µg/L	Analysis Date: 12/24/2007	SeqNo: 741568							
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Vinyl chloride	9.113	0.50	10.00	0	91.1	77	120	0			
Chloroethane	9.442	0.50	10.00	0	94.4	75	135	0			
1,1-Dichloroethene	8.938	0.50	10.00	0	89.4	81	125	0			
trans-1,2-Dichloroethene	9.974	0.50	10.00	0	99.7	60	137	0			
Methyl tert-butyl ether	10.25	0.50	10.00	0	103	61	134	0			
1,1-Dichloroethane	9.870	0.50	10.00	0	98.7	82	120	0			
cis-1,2-Dichloroethene	9.959	0.50	10.00	0	99.6	84	116	0			
1,1,1-Trichloroethane	9.943	0.50	10.00	0	99.4	80	124	0			
1,2-Dichloroethane	9.982	0.50	10.00	0	99.8	86	117	0			
Benzene	10.13	0.50	10.00	0	101	81	121	0			
Trichloroethene	8.836	0.50	10.00	0	88.4	74	123	0			
Toluene	9.989	0.50	10.00	0	99.9	88	117	0			
1,1,2-Trichloroethane	10.48	0.50	10.00	0	105	83	121	0			
Tetrachloroethene	9.739	0.50	10.00	0	97.4	74	115	0			
Chlorobenzene	10.03	0.50	10.00	0	100	83	112	0			
Ethylbenzene	10.05	0.50	10.00	0	101	87	110	0			
m,p-Xylene	20.29	0.50	20.00	0	101	87	114	0			
o-Xylene	10.24	0.50	10.00	0	102	84	114	0			
Surr: Dibromofluoromethane	5.213	0.50	5.000	0	104	88	124	0			
Surr: 1,2-Dichloroethane-d4	5.433	0.50	5.000	0	109	79	115	0			
Surr: Toluene-d8	4.926	0.50	5.000	0	98.5	80	114	0			
Surr: Bromofluorobenzene	5.230	0.50	5.000	0	105	60	123	0			

0010

Sample ID: LCSD-34006	SampType: LCSD	TestCode: SW8260B_25_W	Prep Date: 12/24/2007	Run ID: V2_071224A							
Client ID: LCSD-34006	Batch ID: 34006	Units: µg/L	Analysis Date: 12/24/2007	SeqNo: 741569							
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Vinyl chloride	9.617	0.50	10.00	0	96.2	77	120	9.113	5.38	40	
Chloroethane	10.09	0.50	10.00	0	101	75	135	9.442	6.64	40	
1,1-Dichloroethene	10.01	0.50	10.00	0	100	81	125	8.938	11.4	40	
trans-1,2-Dichloroethene	11.02	0.50	10.00	0	110	60	137	9.974	9.98	40	
Methyl tert-butyl ether	11.15	0.50	10.00	0	112	61	134	10.25	8.4	40	
1,1-Dichloroethane	11.07	0.50	10.00	0	111	82	120	9.870	11.5	40	
cis-1,2-Dichloroethene	10.82	0.50	10.00	0	108	84	116	9.959	8.3	40	
1,1,1-Trichloroethane	10.71	0.50	10.00	0	107	80	124	9.943	7.4	40	
1,2-Dichloroethane	11.31	0.50	10.00	0	113	86	117	9.982	12.5	40	
Benzene	11.01	0.50	10.00	0	110	81	121	10.13	8.33	40	
Trichloroethene	9.600	0.50	10.00	0	96.0	74	123	8.836	8.29	40	
Toluene	10.98	0.50	10.00	0	110	88	117	9.989	9.43	40	
1,1,2-Trichloroethane	11.84	0.50	10.00	0	118	83	121	10.48	12.2	40	
Tetrachloroethene	10.71	0.50	10.00	0	107	74	115	9.739	9.49	40	
Chlorobenzene	10.78	0.50	10.00	0	108	83	112	10.03	7.18	40	
Ethylbenzene	10.74	0.50	10.00	0	107	87	110	10.05	6.63	40	
m,p-Xylene	21.64	0.50	20.00	0	108	87	114	20.29	6.44	40	
o-Xylene	10.94	0.50	10.00	0	109	84	114	10.24	6.61	40	
Surr: Dibromofluoromethane	5.292	0.50	5.000	0	106	88	124	0	0	40	
Surr: 1,2-Dichloroethane-d4	5.357	0.50	5.000	0	107	79	115	0	0	40	
Surr: Toluene-d8	4.790	0.50	5.000	0	95.8	80	114	0	0	40	
Surr: Bromofluorobenzene	4.914	0.50	5.000	0	98.3	60	123	0	0	40	

Mitkem Laboratories

Date: 24-Dec-07

Client: Earth Tech
Client Sample ID: EFF 121307
Lab ID: F1865-01

Project: NOW Corp. Site
Collection Date: 12/13/07 11:35

Analyses	Result	Qual	RL	Units	DF	Date Analyzed	Batch ID
Oil & Grease, HEM							
Oil & Grease, Total Recoverable	ND		5.0	mg/L	1	12/23/2007 0:00	33925

Qualifiers: ND - Not Detected at the Reporting Limit
J - Analyte detected below quantitation limits
B - Analyte detected in the associated Method Blank
DF - Dilution Factor

S - Spike Recovery outside accepted recovery limits
R - RPD outside accepted recovery limits
E - Value above quantitation range
RL - Reporting Limit

Mitkem Laboratories

Date: 24-Dec-07

Client: Earth Tech
Client Sample ID: INF 121307
Lab ID: F1865-02

Project: NOW Corp. Site
Collection Date: 12/13/07 11:20

Analyses	Result	Qual	RL	Units	DF	Date Analyzed	Batch ID
Oil & Grease, HEM				E1664			
Oil & Grease, Total Recoverable	ND		5.0	mg/L	1	12/23/2007 0:00	33925

Qualifiers: ND - Not Detected at the Reporting Limit
J - Analyte detected below quantitation limits
B - Analyte detected in the associated Method Blank
DF - Dilution Factor

S - Spike Recovery outside accepted recovery limits
R - RPD outside accepted recovery limits
E - Value above quantitation range
RL - Reporting Limit

ANALYTICAL QC SUMMARY REPORT

CLIENT: Earth Tech
 Work Order: F1865
 Project: NOW Corp. Site

TestCode: E1664

Sample ID: MB-33925	SampType: MBLK	TestCode: E1664	Prep Date: 12/20/2007	Run ID: MANUAL_071223A	
Client ID: MB-33925	Batch ID: 33925	Units: mg/L	Analysis Date: 12/23/2007	SeqNo: 740155	
Analyte		Result	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Oil & Grease, Total Recoverable		ND			5.0

Sample ID: LCS-33925	SampType: LCS	TestCode: E1664	Prep Date: 12/20/2007	Run ID: MANUAL_071223A	
Client ID: LCS-33925	Batch ID: 33925	Units: mg/L	Analysis Date: 12/23/2007	SeqNo: 740153	
Analyte		Result	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Oil & Grease, Total Recoverable		34.60	40.00	0	86.5 78 114 0

Sample ID: LCSD-33925	SampType: LCSD	TestCode: E1664	Prep Date: 12/20/2007	Run ID: MANUAL_071223A	
Client ID: LCSD-33925	Batch ID: 33925	Units: mg/L	Analysis Date: 12/23/2007	SeqNo: 740154	
Analyte		Result	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Oil & Grease, Total Recoverable		33.30	40.00	0	83.3 78 114 34.60 3.83 18



Qualifiers: ND - Not Detected at the Reporting Limit
 J - Analyte detected below quantitation limits
 S - Spike Recovery outside accepted recovery limits
 R - RPD outside accepted recovery limits
 B - Analyte detected in the associated Method Blank

Mitkem Laboratories**Date:** 02-Jan-08**Client:** Earth Tech**Client Sample ID:** EFF 121307**Lab ID:** F1865-01**Project:** NOW Corp. Site**Collection Date:** 12/13/07 11:35

Analyses	Result	Qual	RL	Units	DF	Date Analyzed	Batch ID
Metals by ICP							
			SW6010B_W				
Aluminum	ND		200	µg/L	1	12/20/2007 17:10	33887
Arsenic	26		20	µg/L	1	12/20/2007 17:10	33887
Barium	ND		200	µg/L	1	12/20/2007 17:10	33887
Chromium	ND		20	µg/L	1	12/20/2007 17:10	33887
Copper	ND		25	µg/L	1	12/20/2007 17:10	33887
Iron	230		200	µg/L	1	12/20/2007 17:10	33887
Manganese	89		50	µg/L	1	12/20/2007 17:10	33887
Nickel	ND		50	µg/L	1	12/20/2007 17:10	33887
Zinc	ND		50	µg/L	1	12/20/2007 17:10	33887
Mercury by FIA							
			SW7470A				
Mercury	ND		0.20	µg/L	1	12/18/2007 17:25	33884

Qualifiers: ND - Not Detected at the Reporting Limit
J - Analyte detected below quantitation limits
B - Analyte detected in the associated Method Blank
DF - Dilution Factor

S - Spike Recovery outside accepted recovery limits
R - RPD outside accepted recovery limits
E - Value above quantitation range
RL - Reporting Limit

Mitkem Laboratories

Date: 02-Jan-08

Client: Earth Tech
Client Sample ID: INF 121307
Lab ID: F1865-02

Project: NOW Corp. Site
Collection Date: 12/13/07 11:20

Analyses	Result	Qual	RL	Units	DF	Date Analyzed	Batch ID
Metals by ICP			SW6010B_W				
Aluminum	ND		200	µg/L	1	12/20/2007 17:13	33887
Arsenic	32		20	µg/L	1	12/20/2007 17:13	33887
Barium	ND		200	µg/L	1	12/20/2007 17:13	33887
Chromium	ND		20	µg/L	1	12/20/2007 17:13	33887
Copper	ND		25	µg/L	1	12/20/2007 17:13	33887
Iron	240		200	µg/L	1	12/20/2007 17:13	33887
Manganese	140		50	µg/L	1	12/20/2007 17:13	33887
Nickel	ND		50	µg/L	1	12/20/2007 17:13	33887
Zinc	ND		50	µg/L	1	12/20/2007 17:13	33887
Mercury by FIA			SW7470A				
Mercury	ND		0.20	µg/L	1	12/18/2007 17:26	33884

Qualifiers: ND - Not Detected at the Reporting Limit
J - Analyte detected below quantitation limits
B - Analyte detected in the associated Method Blank
DF - Dilution Factor

S - Spike Recovery outside accepted recovery limits
R - RPD outside accepted recovery limits
E - Value above quantitation range
RL - Reporting Limit

ANALYTICAL QC SUMMARY REPORT

CLIENT: Earth Tech
 Work Order: F1865
 Project: NOW Corp. Site

TestCode: SW6010B_W

Sample ID: MB-33887	SampType: MBLK	TestCode: SW6010B_W	Prep Date: 12/18/2007	Run ID: OPTIMA2_071220D							
Client ID: MB-33887	Batch ID: 33887	Units: µg/L	Analysis Date: 12/20/2007	SeqNo: 739479							
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Aluminum	ND	200									
Arsenic	ND	20									
Barium	ND	200									
Chromium	ND	20									
Copper	ND	30									
Iron	ND	200									
Manganese	ND	50									
Nickel	ND	50									
Zinc	ND	50									

Sample ID: LCS-33887	SampType: LCS	TestCode: SW6010B_W	Prep Date: 12/18/2007	Run ID: OPTIMA2_071220D							
Client ID: LCS-33887	Batch ID: 33887	Units: µg/L	Analysis Date: 12/20/2007	SeqNo: 739481							
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Aluminum	9339	200	9100	0	103	80	120	0			
Arsenic	465.1	20	455.0	0	102	80	120	0			
Barium	9529	200	9100	0	105	80	120	0			
Chromium	935.2	20	910.0	0	103	80	120	0			
Copper	1182	30	1130	0	105	80	120	0			
Iron	4787	200	4550	0	105	80	120	0			
Manganese	2315	50	2270	0	102	80	120	0			
Nickel	2371	50	2270	0	104	80	120	0			
Zinc	2334	50	2270	0	103	80	120	0			

9339
465.1
9529
935.2
1182
4787
2315
2371
2334

Qualifiers: ND - Not Detected at the Reporting Limit
 J - Analyte detected below quantitation limits
 S - Spike Recovery outside accepted recovery limits
 R - RPD outside accepted recovery limits
 B - Analyte detected in the associated Method Blank

Sample ID: LCSD-33887	SampType: LCSD	TestCode: SW6010B_W	Prep Date: 12/18/2007	Run ID: OPTIMA2_071220D							
Client ID: LCSD-33887	Batch ID: 33887	Units: µg/L	Analysis Date: 12/20/2007	SeqNo: 739483							
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Aluminum	9185	200	9100	0	101	80	120	9339	1.66	20	
Arsenic	456.2	20	455.0	0	100	80	120	465.1	1.93	20	
Barium	9403	200	9100	0	103	80	120	9529	1.34	20	
Chromium	921.4	20	910.0	0	101	80	120	935.2	1.49	20	
Copper	1165	30	1130	0	103	80	120	1182	1.43	20	
Iron	4790	200	4550	0	105	80	120	4787	0.0638	20	
Manganese	2297	50	2270	0	101	80	120	2315	0.786	20	
Nickel	2346	50	2270	0	103	80	120	2371	1.06	20	
Zinc	2297	50	2270	0	101	80	120	2334	1.61	20	

00100

Qualifiers:

ND - Not Detected at the Reporting Limit

J - Analyte detected below quantitation limits

S - Spike Recovery outside accepted recovery limits

R - RPD outside accepted recovery limits

B - Analyte detected in the associated Method Blank

CLIENT: Earth Tech
Work Order: F1865
Project: NOW Corp. Site

TestCode: SW7470A

Sample ID: MB-33884	SampType: MBLK	TestCode: SW7470A	Prep Date: 12/18/2007	Run ID: FIMS1_071218D	
Client ID: MB-33884	Batch ID: 33884	Units: µg/L	Analysis Date: 12/18/2007	SeqNo: 736610	
Analyte		Result	SPK Ref Val	RPD Ref Val	Qual
Mercury		ND	0.20		
Sample ID: LCS-33884	SampType: LCS	TestCode: SW7470A	Prep Date: 12/18/2007	Run ID: FIMS1_071218D	
Client ID: LCS-33884	Batch ID: 33884	Units: µg/L	Analysis Date: 12/18/2007	SeqNo: 736611	
Analyte		Result	SPK Ref Val	RPD Ref Val	Qual
Mercury		4.744	0	0	
Sample ID: LCSD-33884	SampType: LCSD	TestCode: SW7470A	Prep Date: 12/18/2007	Run ID: FIMS1_071218D	
Client ID: LCSD-33884	Batch ID: 33884	Units: µg/L	Analysis Date: 12/18/2007	SeqNo: 736612	
Analyte		Result	SPK Ref Val	RPD Ref Val	Qual
Mercury		4.572	0	0	

SEIN

Qualifiers:

ND - Not Detected at the Reporting Limit	S - Spike Recovery outside accepted recovery limits	B - Analyte detected in the associated Method Blank
J - Analyte detected below quantitation limits	R - RPD outside accepted recovery limits	

Mitkem Laboratories

Date: 24-Dec-07

Client: Earth Tech
Client Sample ID: EFF 121307
Lab ID: F1865-01

Project: NOW Corp. Site
Collection Date: 12/13/07 11:35

Analyses	Result	Qual	RL	Units	DF	Date Analyzed	Batch ID
TOTAL DISSOLVED SOLIDS							
Total Dissolved Solids	300			10 mg/L		1 12/18/2007 8:30	33852
TOTAL SUSPENDED SOLIDS							
Total Suspended Solids	ND			10 mg/L		1 12/18/2007 8:30	33853
Total Cyanide							
Cyanide	ND			10 µg/L		1 12/21/2007 10:53	33941

Qualifiers: ND - Not Detected at the Reporting Limit
J - Analyte detected below quantitation limits
B - Analyte detected in the associated Method Blank
DF - Dilution Factor

S - Spike Recovery outside accepted recovery limits
R - RPD outside accepted recovery limits
E - Value above quantitation range
RL - Reporting Limit

Mitkem Laboratories

Date: 24-Dec-07

Client: Earth Tech
Client Sample ID: INF 121307
Lab ID: F1865-02

Project: NOW Corp. Site
Collection Date: 12/13/07 11:20

Analyses	Result	Qual	RL	Units	DF	Date Analyzed	Batch ID
TOTAL DISSOLVED SOLIDS							
Total Dissolved Solids	350			10 mg/L	1	12/18/2007 8:30	33852
TOTAL SUSPENDED SOLIDS							
Total Suspended Solids	ND			10 mg/L	1	12/18/2007 8:30	33853
Total Cyanide							
Cyanide	ND			10 µg/L	1	12/21/2007 10:55	33941

Qualifiers: ND - Not Detected at the Reporting Limit
J - Analyte detected below quantitation limits
B - Analyte detected in the associated Method Blank
DF - Dilution Factor

S - Spike Recovery outside accepted recovery limits
R - RPD outside accepted recovery limits
E - Value above quantitation range
RL - Reporting Limit

CLIENT: Earth Tech
Work Order: F1865
Project: NOW Corp. Site

ANALYTICAL QC SUMMARY REPORT

TestCode: SM2540_TDS

Sample ID: MB-33852	SampType: MBLK	TestCode: SM2540_TDS	Prep Date: 12/17/2007	Run ID: MANUAL_071217B
Client ID: MB-33852	Batch ID: 33852	Units: mg/L	Analysis Date: 12/18/2007	SeqNo: 736452
Analyte			SPK Ref Val	SPK value
Total Dissolved Solids	Result	PQL	%REC	LowLimit HighLimit
	ND	10		

Sample ID: LCS-33852	SampType: LCS	TestCode: SM2540_TDS	Prep Date: 12/17/2007	Run ID: MANUAL_071217B
Client ID: LCS-33852	Batch ID: 33852	Units: mg/L	Analysis Date: 12/18/2007	SeqNo: 736451
Analyte			SPK Ref Val	SPK value
Total Dissolved Solids	Result	PQL	%REC	LowLimit HighLimit
	717.0	10	96.6	80 120

Sample ID: F1865-01DDUP	SampType: DUP	TestCode: SM2540_TDS	Prep Date: 12/17/2007	Run ID: MANUAL_071217B
Client ID: EFF 121307	Batch ID: 33852	Units: mg/L	Analysis Date: 12/18/2007	SeqNo: 736444
Analyte			SPK Ref Val	SPK value
Total Dissolved Solids	Result	PQL	%REC	LowLimit HighLimit
	299.0	10	0	0 0

Qualifiers: ND - Not Detected at the Reporting Limit
J - Analyte detected below quantitation limits

S - Spike Recovery outside accepted recovery limits
R - RPD outside accepted recovery limits

B - Analyte detected in the associated Method Blank

Sample ID: MB-33853	SampType: MBLK	TestCode: SM2540_TSS	Prep Date: 12/17/2007	Run ID: MANUAL_071217A
Client ID: MB-33853	Batch ID: 33853	Units: mg/L	Analysis Date: 12/18/2007	SeqNo: 736375
Analyte				
Total Suspended Solids		ND	SPK value	SPK Ref Val
		10	%REC	LowLimit HighLimit
			RPD Ref Val	%RPD RPDLimit
				Qual
Sample ID: LCS-33853	SampType: LCS	TestCode: SM2540_TSS	Prep Date: 12/17/2007	Run ID: MANUAL_071217A
Client ID: LCS-33853	Batch ID: 33853	Units: mg/L	Analysis Date: 12/18/2007	SeqNo: 736374
Analyte				
Total Suspended Solids		56.00	SPK value	SPK Ref Val
		10	%REC	LowLimit HighLimit
			RPD Ref Val	%RPD RPDLimit
				Qual
Sample ID: F1865-01DDUP	SampType: DUP	TestCode: SM2540_TSS	Prep Date: 12/17/2007	Run ID: MANUAL_071217A
Client ID: EFF 121307	Batch ID: 33853	Units: mg/L	Analysis Date: 12/18/2007	SeqNo: 736372
Analyte				
Total Suspended Solids		ND	SPK value	SPK Ref Val
		10	%REC	LowLimit HighLimit
			RPD Ref Val	%RPD RPDLimit
				Qual
				20

Client ID: EARTH_NY
Project: NOW Corp. Site
Location:
Comments: N/A

Case:
SDG:
PO: 94017.02

Report Level: LEVEL 2
EDD:
HC Due: 01/01/08
Fax Due:

Sample ID	HS Client Sample ID	Collection Date	Date Recv'd	Matrix	Test Code	Lab Test Comments	Hold	MS	SEL	Storage
F1865-01A	EFF 121307	12/13/2007 11:35	12/14/2007	Aqueous	SW8260B_25_W	use for VOCs, if can't, use OLC i	☐	☐	☒	VOA
F1865-01B	EFF 121307	12/13/2007 11:35	12/14/2007	Aqueous	SW6010B_W	See SEL list	☐	☐	☒	M4
					SW7470A	See SEL list	☐	☐	☐	M4
F1865-01C	EFF 121307	12/13/2007 11:35	12/14/2007	Aqueous	SW9012B_W		☐	☐	☒	F2
F1865-01D	EFF 121307	12/13/2007 11:35	12/14/2007	Aqueous	SM2540_TDS		☐	☐	☐	F2
					SM2540_TSS		☐	☐	☐	F2
F1865-01E	EFF 121307	12/13/2007 11:35	12/14/2007	Aqueous	E1664		☐	☐	☐	F2
F1865-02A	INF 121307	12/13/2007 11:20	12/14/2007	Aqueous	SW8260B_25_W	use for VOCs, if can't, use OLC i	☐	☐	☒	VOA
F1865-02B	INF 121307	12/13/2007 11:20	12/14/2007	Aqueous	SW6010B_W	See SEL list	☐	☐	☒	M4
					SW7470A	See SEL list	☐	☐	☐	M4
F1865-02C	INF 121307	12/13/2007 11:20	12/14/2007	Aqueous	SW9012B_W		☐	☐	☒	F2

Client Rep: Edward A Lawler

Page 1 of 2

Mitkem Laboratories

14/Dec/07 14:30

WorkOrder: F1865

Client ID: EARTH_NY
 Project: NOW Corp. Site
 Location:
 Comments: N/A

Case:
 SDG:
 PO: 94017.02

Report Level: LEVEL 2
 EDD:
 HC Due: 01/01/08
 Fax Due:

Sample ID	HS Client Sample ID	Collection Date	Date Recv'd	Matrix	Test Code	Lab Test Comments	Hold	MS	SEL	Storage
F1865-02D	INF 121307	12/13/2007 11:20	12/14/2007	Aqueous	SM2540_TDS		☐	☐	☐	F2
					SM2540_TSS		☐	☐	☐	F2
F1865-02E	INF 121307	12/13/2007 11:20	12/14/2007	Aqueous	E1664		☐	☐	☐	F2
F1865-03A	TW-1	12/13/2007 11:40	12/14/2007	Aqueous	SW8260B_25_W	use for VOCs, if can't, use OLC i	☐	☐	☒	VOA
F1865-04A	TW-2A	12/13/2007 11:45	12/14/2007	Aqueous	SW8260B_25_W	use for VOCs, if can't, use OLC i	☐	☐	☒	VOA
F1865-05A	TW-3	12/13/2007 11:50	12/14/2007	Aqueous	SW8260B_25_W	use for VOCs, if can't, use OLC i	☐	☐	☒	VOA
F1865-06A	TRIP BLANK	12/13/2007 00:00	12/14/2007	Aqueous	SW8260B_25_W	use for VOCs, if can't, use OLC i	☐	☐	☒	VOA

Client Rep: Edward A Lawler

Page 2 of 2

000000



175 Metro Center Boulevard
Warwick, Rhode Island 02886-1755
(401) 732-3400 • Fax (401) 732-3499
email: mitkem@mitkem.com

CHAIN-OF-CUSTODY RECORD

REPORT TO				INVOICE TO						
COMPANY	NAME	ADDRESS	CITY/ST/ZIP	COMPANY	NAME	ADDRESS	CITY/ST/ZIP			
Earth Tech	Steve Chainiere	40 British American Blvd.	Latham N.Y. 12110	Same						
CLIENT PROJECT NAME:				LAB PROJECT #:						
Now Corp				F1865						
CLIENT PROJECT #:				TURNAROUND TIME:						
94017.02										
SAMPLE IDENTIFICATION	DATE/TIME SAMPLED	COMPOSITE	GRAB	WATER	SOIL	OTHER	LAB ID	# OF CONTAINERS	REQUESTED ANALYSES	COMMENTS
EFF 121307	12/3/07 11:35		X	X			01			
INF 121307	11:20						02			
TW-1	11:40						03			
TW-2A	11:45						04			
TW-3	11:50						05			
Trip Blank	- - -						06			
RELINQUISHED BY		DATE/TIME		ACCEPTED BY		DATE/TIME		ADDITIONAL REMARKS:		COOLER TEMP:
Steve Day		12/13/07 3:30		Veronica J. Gaudreau		12/14/07 10:00		*Al, As, Ba, Cr, Cu, Fe, Mn, Hg, Zn, N		30 C
No TDS/ITSS Bottles Sent										
Samples in liter Brown										