

*Bi-Annual Sampling Report
For Treatment Systems*

July 2008 - December 2008

Now Corporation

Site Code # 3-14-008

Work Assignment Number D004445-6

Prepared for:

Superfund Standby Program

New York State Department of Environmental Conservation

625 Broadway, 12th Floor

Albany, New York 12233-7017

Prepared by:

Earth Tech Northeast

40 British American Boulevard

Latham, New York 12110

February 2009

TABLE OF CONTENTS

Chapter		Page
1.0	INTRODUCTION.....	1
1.1	SITE DESCRIPTION.....	1
1.2	TREATMENT SYSTEMS.....	1
	1.2.1 Tompkins.....	1
	1.2.2 Lawrence Montague.....	1
	1.2.3 Jan Mills.....	1
2.0	SAMPLING.....	2
2.1	SAMPLE LOCATIONS.....	2
2.2	SAMPLING PROTOCOL	2
2.3	SAMPLING AND FLOW READINGS	2
2.4	ANALYTICAL RESULTS.....	2
3.0	SYSTEM MAINTENANCE AND MODIFICATIONS.....	3
4.0	CONCLUSIONS	4

LIST OF TABLES

Table

1	Resident and System Information
2	Historical Raw Water Analytical Summary
3	Current Round Analytical Summary
4	Volatile Organic Compounds Included in EPA Method 524.2

1.0 INTRODUCTION

In accordance with the monitoring plan for the granular activated carbon (GAC) water treatment systems at the Now Corporation Site, the thirtieth round of sampling was performed on December 10, 2008, under NYSDEC Work Assignment # D004445-6. The results of laboratory analyses for this sampling event are summarized in this report, as are subsequent actions, if any, taken in response to those results. Routine system maintenance and/or required modifications are also discussed. This report describes activities that occurred during the period July 2008 through December 2008.

1.1 SITE DESCRIPTION

The site includes four contaminated water-supply wells and is located just north of Poughkeepsie in a rural area along Route 9G in the Town of Clinton, Dutchess County, New York. The wells are situated in the vicinity of the former Now Corporation. The main contaminants of concern at the site are 1,1-dichloroethane (1,1-DCA), 1,1,1-trichloroethane (1,1,1-TCA) and trichloroethene (TCE). The Now Corporation Site (Site Code #3-14-008) is listed as a Class 2 site under Title 13 of the New York State Environmental Conservation Law. Earth Tech continues to monitor groundwater quality at the Garden Center, whose water supply has apparently been impacted by past operations at the former Now Corporation.

1.2 TREATMENT SYSTEMS

1.2.1 Tompkins – 6 Creek Road

In 1992, the NYSDEC requested that a point of entry water treatment system be installed on the water supply well at the Tompkins residence. Culligan Water Conditioning (Culligan) of Poughkeepsie installed and maintained the system that consisted of two one-cubic-foot capacity GAC tanks. The NYSDEC rented the unit from Culligan until July 1994, at which time Earth Tech replaced the Culligan system with larger capacity (14" x 47") tanks.

1.2.2 Lawrence Montague – 8 Creek Road

In response to a request from NYSDEC, Earth Tech installed a GAC system at the Montague residence in July 2002. The system consists of two 14" x 47" tanks, connected in series and a Trojan model 708 UV unit for bacterial disinfection.

1.2.3 Jan Mills – 33 Creek Road

NYSDEC requested that a GAC system be installed on the well at the Mills residence. Rust Environment & Infrastructure installed a GAC system in June 1996. The installation included an Ideal Horizon UV unit.

The New York State Department of Health (NYSDOH) recommends treatment with two carbon tanks connected in series for organics removal from drinking water. This configuration provides a primary and secondary GAC unit and allows for monitoring water quality between these units.

2.0 SAMPLING

2.1 SAMPLE LOCATIONS

Table 1 presents project information including GAC system location and well ID. Sampling points include raw and intermediate ports. All final samples were collected at kitchen taps. A duplicate raw water sample was collected at the Montague residence. No sample was collected at the Garden Center since it is closed for the season.

2.2 SAMPLING PROTOCOL

Standard protocol at sites with limited water usage is to allow a sampling tap to run for at least 15 minutes prior to sampling. After purging, samples are collected in the following order: effluent, intermediate, and raw water in order to minimize the possibility of cross-contamination. Volatile organics samples are collected in 40-milliliter (ml) vials, capped and then checked to insure that no air bubbles are trapped in the vial. Care is taken during collection to minimize agitation and to immediately place sample containers on ice to prevent volatilization.

Bacteria sampling of the final (treated) water is conducted after volatile sampling. Sampling protocol requires decontamination of the water sampling port by heating with an open flame for one minute prior to sampling.

2.3 SAMPLING AND FLOW READINGS

All standard sampling procedures were followed except taps were not run for 15 minutes prior to sampling since frequent usage ensures that representative groundwater is readily available at the sampling taps.

Samples were packed on ice, and submitted with a chain-of-custody form for volatile organics analysis by EPA Method 524.2, and for bacteria analysis. The NYSDEC Division of Environmental Remediation Laboratory of Rensselaer, N.Y. provided analytical services for volatile organic analysis. Bacteria analysis services were provided by Smith Environmental Laboratory of Hyde Park, New York, an M/WBE enterprise.

Flow meters were installed as part of the DEC's requirements for the treatment systems, and flow totalizer readings, in gallons, are presented on Table 2.

2.4 ANALYTICAL RESULTS

The laboratory data sheets for volatile organics analyses are distributed electronically by the laboratory to Earth Tech and NYSDEC, and are not included in this report. Historical and current raw water analytical data are summarized on Table 2. VOC analytical results for raw, intermediate, and final water samples for this round (only) are summarized on Table 3. The final bacteria test results were negative for each sampled location, and are not tabulated. A copy of each bacteria analysis is included with this report.

Carbon changeout will normally occur when site contaminants are reported at 1 ug/l or above in the intermediate or final water sample. Breakthrough of VOCs was reported in the intermediate sample collected at the Tompkins residence and a carbon changeout was requested by the NYSDEC. This will be conducted in January 2009.

3.0 SYSTEM MAINTENANCE AND MODIFICATIONS

This round of sampling included cleaning the UV unit's quartz sleeves and changing particulate filters at all residences. The UV bulb was changed at the Tompkins residence.

No system modifications were performed during the reporting period.

4.0 CONCLUSIONS

All systems are in satisfactory working condition. The next sampling event and system check is due in June 2009.

TABLES

Table 1

**Now Corporation Site
Resident and System Information**

Owner	Location	Phone #	Well ID	System Location
Tompkins, Christy	Box 38 6 Creek Road Staatsburg, N.Y. 12580	Cell # 914-204-9357	T	downstairs closet
Jeremiah Riordan Garden Center	Route 9G Staatsburg, N.Y. 12580	845-889-8333 845-889-8446 HM.		No System
Mills, Jan	33 Creek Road Staatsburg, N.Y. 12580	(845) 889-3116	JM	downstairs in basement
Montague, Lawrence & Susan	8 Creek Road Staatsburg, N.Y. 12580	(845) 889-4916	MON	downstairs in basement

Table 2

Now Corporation Site
Historical Raw Water Analytical Summary

Location/ COC	Well ID	22-Apr-94	Flow Volume Reading in Gallons						16-Dec-96
			21-Jun-94	28-Dec-94	28-Jun.-95	21-Dec-95	5-Jun-96	6 mos. Vol. Total	
			6 mos. Vol. Total	6 mos. Vol. Total	6 mos. Vol. Total	6 mos. Total	6 mos. Vol. Total		
Elliott, Violette	VIOLEL	0000	NR	system removed Jul-94				96,720	
cis-1,2-Dichloroethene		0.9	ND	per owner request				ND	
1,1,1-Trichloroethane		4.0	5.5					ND	
Trichloroethene		6.0	11.0	no sampling				ND	
Chloroform		ND	0.2					ND	
1,1-Dichloroethane		ND	2.3						
Tompkins, Todd	T	NS	1,922	17,828	19,750	22,410	42,160	2	
1,1-Dichloroethane		NS	71.0	GAC Exchange 7-Jul-94	1.3			190	
1,1,1-Trichloroethane		NS	140.0		3.4	GAC Exchange 26-Jul-95	2.0	12	
Trichloroethene		NS	270.0		21		18.0	ND	
Garden Center	GC	no flow meter	no flow meter	no flow meter	no flow meter			200	
1,4-Dichlorobenzene		NS	ND	NS	NS			59	
1,1-Dichloroethane		NS	340.0	NS	NS			ND	
1,1-Dichloroethene		NS	19.0	NS	NS			18,540	
cis1,2-dichloroethene		NS	ND	NS	NS			ND	
1,1,1-Trichloroethane		NS	140.0	NS	NS			ND	
Trichloroethene		NS	66.0	NS	NS			ND	
Chloroethane		NS	ND	NS	NS			ND	
Mills, Jan	JM								
1,1-Dichloroethane									
1,1-Dichloroethene									
1,1,1-Trichloroethane									
Trichloroethene									

* indicates field duplicate result.

Concentrations in ug/l (ppb).

NS indicates no sample taken

ND indicates below detection limit

Results are shown only for detected analytes

J = estimated value

E = estimated, value exceeds calibration range for instrument

D = value determined by dilution

Table 2

**Now Corporation Site
Historical Raw Water Analytical Summary**

Location/ COC	Well ID	Flow Volume Reading in Gallons					
		June 16-97	17-Dec-97	Jul 1-98	5-Jan-99	11-Aug-99	11-Jan-00
		6 mos. Vol. Total	6 mos. Vol. Total	6 mos. Vol. Total	6 mos. Vol. Total	6 mos. Vol. Total	6 mos. Vol. Total
Tompkins, Todd	T						
1,1-Dichloroethane		21,220	117,940	16,060	134,000	21,510	155,510
1,1,1-Trichloroethane		2	2	11	59	1.3/ND	0.7/0.5
Trichloroethane		28	28	89	14/12	1.1	1.1
					12	9.7	9.7
Garden Center	GC						
1,4-Dichlorobenzene		<5	<5	<5	unable to sample, closed for the season.	ND	unable to sample, closed for the season.
1,1-Dichloroethane		290	290	750D	71	140	140
1,1-Dichloroethane		20	20	31	ND	7.8	7.8
cis-1,2-dichloroethane		ND	ND	8	3	0.96	0.96
1,1,1-Trichloroethane		220	220	1100D	40	1.6	1.6
Trichloroethane		100	100	200D	ND	10	10
Chloroethane		<5	<5	<5	2	ND	ND
Mills, Jan	JM						
1,1-Dichloroethane		21,290	39,830	19,780	59,610	21,470	81,080
1,1-Dichloroethane		15	15	31/28	ND	ND	ND
1,1,1-Trichloroethane		ND	ND	ND	ND	ND	ND
Trichloroethane		ND	ND	ND	ND	ND	ND
Montague	Mon						
Trichloroethane		ND	ND	ND	4.2	0.77	0.77
1,1,1-Trichloroethane		ND	ND	ND	0.67	ND	ND

* Indicates field duplicate result.

Concentrations in ug/l (ppb).

NS indicates no sample taken

ND indicates below detection limit

Results are shown only for detected analytes

J = estimated value

E= estimated, value exceeds calibration range for instrument

D= value determined by dilution

Table 2

NOW Corporation
Historical Raw Water Analytical Summary

Flow Volume Reading in Gallons		6 mos. Vol. Total														
Location/ COC	Well ID	26-Jul-00	10-Jan-01	18-Jul-01	29-Jan-02	23-Jul-02	27-Jan-03	2-Jul-03	16-Dec-03							
		6 mos. Vol. Total	6 mos. Vol. Total	6 mos. Vol. Total	6 mos. Vol. Total	6 mos. Vol. Total	6 mos. Vol. Total	6 mos. Vol. Total	6 mos. Vol. Total							
T																
Tompkins, Todd		17,580	236,720	17,070	253,790	19,460	273,250	24,160	297,410	19,430	316,840	19,130	20,570	356,540	19,150	375,690
1,1-Dichloroethane		ND	ND	ND	6,877.1	ND	0.3J/0.3J	2/2	2/2	2/2	32 E	6	ND	ND/ND	ND	ND
1,1,1-Trichloroethane		ND	ND	ND	2/2.1	ND	0.6J/0.7 J	2/2	2/2	2/2	130 E	5	0.4 J	ND/ND	ND	ND
Trichloroethane		3.6	3.6	ND	22/19	ND	6.0/6.0	ND	51 E/52 E	ND	0.8 J	2	ND	2/2	2	2
cis-1,2-Dichloroethane														ND/ND	ND	ND
1,1-Dichloroethane											0.6 J		ND	ND/ND	ND	ND
Methyl-t-butyl ether												2	ND	ND/ND	ND	ND
GC																
Garden Center																
1,4-Dichlorobenzene		ND	ND	ND	unable to sample, closed for the season.	ND	140.0	120 E	ND		140 D		unable to sample, closed for the season.	ND	ND	ND
1,1-Dichloroethane		140	140	140	8.0	8.0	0.5 J	9.0	9.0	10.0	10.0			140 D	15	15
1,1-Dichloroethane		ND	ND	ND	ND	ND	0.7 J	0.7 J	0.7 J	0.9 J	0.9 J			9	0.9 J	0.7 J
cis1,2-dichloroethane		ND	ND	ND	ND	ND	6.0	8.0	8.0	26 E	26 E			0.9 J	ND	ND
1,1,1-Trichloroethane		ND	ND	ND	ND	ND	13.0	24.0	24.0	27 E	27 E			1.0	ND	ND
Trichloroethane		ND	ND	ND	ND	ND	ND	0.8 J	0.8 J	1	1			11.0	2.0	2.0
Chloroethane														2	ND	ND
Methyl-t-butyl ether														0.3 J	ND	ND
JM																
Mills, Jan		21,530	170190	15,330	185520	22,800	208320	19,340	227660	19,000	246660	18,120	264780	283740	14,520	298260
1,1-Dichloroethane		ND/ND	ND/ND	ND/ND	3	ND	0.4 J	0.8 J	0.8 J	2/1	2/1		2	0.6 J		ND/ND
1,1-Dichloroethane		ND/ND	ND/ND	ND/ND	ND	ND	ND	ND	ND	ND/ND	ND/ND		ND	ND	ND	ND/ND
1,1,1-Trichloroethane		ND/ND	ND/ND	ND/ND	ND	ND	ND	ND	ND	ND/ND	ND/ND		ND	ND	ND	ND/ND
Trichloroethane		ND/ND	ND/ND	ND/ND	ND	ND	ND	ND	ND	ND/ND	ND/ND		ND	ND	ND	ND/ND
Methyl-t-butyl ether													1	2		ND/ND
Mon																
Montague													37980	55290	18,210	73500
Trichloroethane									12/14*	installed 7/23/02			ND/ND	0.3 J		ND
1,1,1-Trichloroethane								ND	ND				ND/ND	ND		ND
Methyl-t-butyl ether													3/3	0.8 J		ND

* indicates field duplicate result.

Concentrations in ug/l (ppb).

NS indicates no sample taken

ND or blank indicates below detection limit

Results are shown only for detected analytes

J = estimated value

E = estimated, value exceeds calibration range for instrument

D = value determined by dilution

Table 2

NOW Corportation
Historical Raw Water Analytical Summary

Location/ COC	Well ID	29-Jul-04	26-Jan-05	27-Jul-05	13-Dec-05	21-Jun-06	18-Dec-06	20-Jun-07	20-Dec-07	17-Jun-08	10-Dec-08
Tompkins, Todd											
6 Creek Road	T	408,470	428,120	448,790	462,300	482,390	498,130	515,660	528,910	547,080	565,610
1,1-Dichloroethane		0.4 J		0.3 J		0.2 J		0.2 J	ND/0.1 J*	0.1 J	0.3 J
1,1,1-Trichloroethane		0.5 J		0.6 J		0.2 J	0.1 J / 0.1 J*	0.2 J	0.1 J/0.1 J*		0.8 J
Trichloroethane		6	2	4	4/3*	6 J	3 / 2*	2	1/2*	1	6 J
Chloromethane				0.2 J							
Chloroform				0.1 J				0.2 JBS			
Toluene								0.1 J		0.1 J	0.3 J
cis-1,2-Dichloroethene											0.2 J
1,1-Dichloroethene											
Garden Center											
GC											
1,1-Dichloroethane		50 D	unable to sample,	150	unable to sample,	90 D	unable to sample,	91 D	unable to sample,	45 D	unable to sample,
1,1-Dichloroethane		6	closed for the season.	11	closed for the season.	11	closed for the season.	9	sample, closed for the season.	6	sample, closed for the season.
cis-1,2-dichloroethane		0.3 J		0.4 J		0.5 J		0.8 J		0.4 J	
1,1,1-Trichloroethane		0.9 J		0.6 J		0.7 J		0.2 J		0.2 J	
Trichloroethane		6.0		10		13 J		8		5	
Chloroethane		0.8 J		6		10		8		9	
Chloromethane				0.2 J							
Methyl-t-butyl ether								0.2 J		0.1 J	
Vinyl chloride								0.2 J		0.2 J	
Mills, Jan											
33 Creek Road	JM	323,240	338,650	357,000	372,400	398,790	414,660	428,850	440,350	462,870	477,120
1,1-Dichloroethane		0.9 J/0.9 J*	1	0.3 J	0.9 J	0.9 J	0.6 J	0.5 J	0.4 J	0.3 J/0.4 J*	0.1 J
Chloromethane				0.2 J							
Methyl-t-butyl ether								0.1 J			
Montague											
8 Creek Road	Mon	98,730	122,120	143,150	158,720	179,250	199,140	220,670	242,210	260,960	276,260
Trichloroethane		0.3 J		0.3 J/0.3 J*				0.2 J/0.2 J*	0.2 J		0.1 J/0.1 J*
1,1,1-Trichloroethane				0.3 J/0.3 J*							
Chloromethane				0.2 J/0.2 J*							
1,1-Dichloroethane				0.2 J/0.2 J*							

* indicates field duplicate result.

Concentrations in ug/l (ppb).

NS indicates no sample taken

ND or blank indicates below detection limit

Results are shown only for detected analytes

J = estimated value

E= estimated, value exceeds calibration range for instrument

D= value determined by dilution

Table 3
Now Corporation Site
Current Round Analytical Summary
Sample Date: 12/10/08

Compound	T-R	T-I	T-F	GC-R	JM-R	JM-I	JM-F	Mon-R	Mon-I	Mon-F
1,1-Dichloroethane	0.3 J	0.2 J		NS	0.1 J					
Trichloroethene	6 J			NS				0.1 J/0.1 J*		
1,1,1-Trichloroethane	0.8 J	0.3 J		NS						
Chloroethane				NS						
cis-1,2-Dichloroethene	0.3 J			NS						
1,1-Dichloroethene	0.2 J			NS						
Methyl-t-butyl ether				NS						
Vinyl chloride				NS						
Toluene				NS						

All results are in ppb.

J= estimated, below detection limit

R= raw water sample

I= intermediate water sample

F= final water sample

NS= not sampled

D= result determined by dilution


Blank cell or ND indicates below detection limit

* = field duplicate sample results

TABLE 4
Volatile Organic Compounds Included in EPA Method 524.2

Dichlorodifluoromethane	Toluene
Chloromethane	Ethyl methacrylate
Vinyl chloride	trans-1,3- Dichloropropene
Bromomethane	1,1,2- Trichloroethane
Chloroethane	Tetrachloroethene
Trichlorofluoromethane	1,3 - Dichloropropane
cis- 1,2- Dichloroethene	2- Hexanone
Diethyl ether	Dibromochloromethane
1,1- Dichloroethene	1,2- Dibromoethane
Acetone	Chlorobenzene
Iodomethane	Ethylbenzene
Carbon disulfide	1,1,1,2- Tetrachloroethane
Allyl chloride	m,p- Xylene
Methylene chloride	o- Xylene
trans- 1,2- Dichloroethene	Styrene
Methyl-t-butyl ether	Bromoform
Acrylonitrile	Isopropylbenzene
1,1- Dichloroethane	1,1,2,2- Tetrachloroethane
2,2 Dichloropropane	Bromobenzene
2-Butanone	n- Propylbenzene
Methyl acrylate	trans- 1,4-Dichloro- 2- buten
Propionitrile	1,2,3 - Trichloropropane
Bromodichloromethane	2- Chlorotoluene
Tetrahydrofuran	1,3,5- Trimethylbenzene
Methacrylonitrile	4- Chlorotoluene
Chloroform	tert- Butylbenzene
1,1,1- Trichloroethane	1,2,4- Trimethylbenzene
1- Chlorobutane	Pentachloroethane
Carbon Tetrachloride	sec- Butylbenzene
1,1- Dichloropropene	p- Isopropyltoluene
Benzene	1,3- Dichlorobenzene
1,2- Dichloroethane	1,4- Dichlorobenzene
Trichloroethene	n- Butylbenzene
1,2- Dichloropropane	1,2- Dichlorobenzene
Methyl methacrylate	Hexachloroethane
Dibromomethane	1,2- Dibromo-3- chloroprop
Bromodichloromethane	Nitrobenzene
2- Nitropropane	1,2,4- Trichlorobenzene
Chloroacetonitrile	Hexachlorobutadiene
cis- 1,3- Dichloropropene	Naphthalene
4-methyl-2-pentanone	1,2,3- Trichlorobenzene
1,1- dichloropropanone	

BACTERIA ANALYTICAL DATA



SMITH LABORATORY

ENVIRONMENTAL TESTING
4 SCENIC DRIVE & RT. 9
HYDE PARK, NEW YORK 12538
(845) 229-6536

CERTIFICATE OF ANALYSIS

Client: Earth Tech/AECOM
Attn: Lori Hoose
40 British-American Blvd.
Latham

NY 12110

PO #

Sample Type: Water
Client Project Name: Now Corp
Order ID: 71340
Order comment: Client project #95481.01

Sample Collected By: Client
Date/Time sample collected: 12/10/2008 9:35
Date/Time sample received: 12/10/2008 11:45 Received by: Kelly
Sample Comment: Temp = 16.0 C
Sample Location: Mills
Sample Number: 124177
Date/Time Sample Analyzed: 12/10/2008 17:15 Tech: VZ

Parameter	Test Result*	Units	Test Method
Total Coliform	Absent	CFU/100mL	SM 20 9223
E. Coli	Absent	CFU/100mL	SM 20 9223

Test results do meet / ~~do not meet~~ EPA drinking water standards.

*Bacteriological test results are expressed as Colony Forming Units.


Results Comment:

Reviewed by: Anne G. Smith, Laboratory Director, ELAP Lab ID #10924

15-Dec-08

Smith Laboratory is approved as an Environmental Laboratory in conformance with the National Environmental Laboratory Accreditation Conference (NELAC) Standards.

The total number of pages in this report is 1 (one).



SMITH LABORATORY

ENVIRONMENTAL TESTING
4 SCENIC DRIVE & RT. 9
HYDE PARK, NEW YORK 12538
(845) 229-6536

CERTIFICATE OF ANALYSIS

Client: Earth Tech/AECOM
Attn: Lori Hoose
40 British-American Blvd.
Latham

NY 12110

PO #

Sample Type: Water
Client Project Name: Now Corp
Order ID: 71340
Order comment: Client project #95481.01

Sample Collected By: Client
Date/Time sample collected: 12/10/2008 11:20
Date/Time sample received: 12/10/2008 11:45 Received by: Kelly
Sample Comment: Temp = 17.0 C
Sample Location: Montague
Sample Number: 124178
Date/Time Sample Analyzed: 12/10/2008 17:15 Tech: VZ

Parameter	Test Result*	Units	Test Method
Total Coliform	Absent	CFU/100mL	SM 20 9223
E. Coli	Absent	CFU/100mL	SM 20 9223

Test results do meet / ~~do not meet~~ EPA drinking water standards.

*Bacteriological test results are expressed as Colony Forming Units.


Results Comment:

Reviewed by: Anne G. Smith, Laboratory Director, ELAP Lab ID #10924

15-Dec-08

Smith Laboratory is approved as an Environmental Laboratory in conformance with the National Environmental Laboratory Accreditation Conference (NELAC) Standards.

The total number of pages in this report is 1 (one).



SMITH LABORATORY

ENVIRONMENTAL TESTING
4 SCENIC DRIVE & RT. 9
HYDE PARK, NEW YORK 12538
(845) 229-6536

CERTIFICATE OF ANALYSIS

Client: Earth Tech/AECOM
Attn: Lori Hoose
40 British-American Blvd.
Latham

NY 12110

PO #

Sample Type: Water
Client Project Name: Now Corp
Order ID: 71340
Order comment: Client project #95481.01

Sample Collected By: Client
Date/Time sample collected: 12/10/2008 10:35
Date/Time sample received: 12/10/2008 11:45 Received by: Kelly
Sample Comment: Temp = 15.0 C
Sample Location: Tompkins
Sample Number: 124179
Date/Time Sample Analyzed: 12/10/2008 17:15 Tech: VZ

Parameter	Test Result*	Units	Test Method
Total Coliform	Absent	CFU/100mL	SM 20 9223
E. Coli	Absent	CFU/100mL	SM 20 9223

Test results do meet / ~~do not meet~~ EPA drinking water standards.

*Bacteriological test results are expressed as Colony Forming Units.

Results Comment:

Reviewed by: Anne G. Smith, Laboratory Director, ELAP Lab ID #10924

15-Dec-08

Smith Laboratory is approved as an Environmental Laboratory in conformance with the National Environmental Laboratory Accreditation Conference (NELAC) Standards.

The total number of pages in this report is 1 (one).



40 British American Blvd.
Latham, NY 12110
www.earthtech.com

CHAIN-OF-CUSTODY RECORD

Page 1 of 1

REPORT TO		DATA DELIVERABLE INFORMATION		CHECK DELIVERY METHOD							
COMPANY	PHONE	☐ NEW YORK STATE ASP "B"	☒ SAMPLES DELIVERED IN PERSON								
NAME	FAX	☐ NEW YORK STATE ASP "A"	☐ BY COMMON CARRIER								
ADDRESS		☐ OTHER									
CITY / STATE / ZIP		FEDERAL EXPRESS AIRBILL NUMBER	UPS AIRBILL NUMBER								
CLIENT / PROJECT NAME		CLIENT PROJECT #		REQUESTED ANALYSES							
EARTH TECH / AE com		95481.01		Temp, °C 16.0 17.0 15.0							
Lori Hoose											
40 BRITISH AMERICAN BLVD.											
LATHAM, N.Y. 12110											
NOW CORP.											
SAMPLE IDENTIFICATION	DATE/TIME SAMPLED	COMPOSITE	GRAB	WATER	SOIL	OTHER	LAB ID	# OF CONTAINERS			
MILLS	12/10/08 9:35	X	X	X			71346-	1			
MONTAGUE	11:20	X	X	X			124178	1			
Tompkins	10:35	X	X	X			124179	1			
										TOTAL Coliform	
RELINQUISHED BY	DATE / TIME	ACCEPTED BY	DATE / TIME	ADDITIONAL REMARKS		COOLER TEMP.					
	12/10/08 11:45	Kelly Proctor	12/10/08 11:45	Samples rec'd in good condition							

WHITE: LABORATORY COPY

YELLOW: REPORT COPY

PINK: CLIENT'S COPY