

AVSC Pump Details

Well	Well Depth	Pump Depth	High / Low Water Level Depths (from PVE 11/6/15)	Documented Pumping Rate (gpm)	Observed Rate 11/5/15 (gpm)	Panel Status (11/5/15)	11/5/15 System Observation
RW-3	150	100'	39.5' / 56'		6	0 Off	Not pumping on 11/5 - malfunction - switched to off
AV-2	205	180'	40' / 70'		8	6 Auto	pumping
RW-2	150	100'	38' / 68'		0	0 Auto	Panel indicated low level condition during 11/5 inspection - not pumping
RW-1	160	100'	30' / 60.5'	1.5 to 2.0	1.5	Auto	pumping

Revised well shutdown sequence with above documented status:

- 1.) Leave RW-3 off
- 2.) RW-2 switch to off
- 3.) RW-1 switch to off
- 4.) AV-2 switch to off