

Table 2: Drinking Water Results for Optimum Window Facility
Greer Site, Wappingers Falls, New York

| Parameter | NYS DOH | Optimum Window Well | | | |
|--------------------------------|------------------|---------------------|---------|---------|---------|
| | Drinking Water | Before | After | Before | After |
| | Standards (ug/L) | 1/22/02 | 1/22/02 | 3/22/02 | 3/22/02 |
| Chlorobenzene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,2-Dichlorobenzene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,3-Dichlorobenzene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,4-Dichlorobenzene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Chloromethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Bromomethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Dichlorodifluoromethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Vinyl chloride | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Chloroethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Methylene chloride | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Trichlorofluoromethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1-Dichloroethene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Bromochloromethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1-Dichloroethane | 5 | 1.30 | 0.50 | 1.40 | 0.50 |
| trans-1,2-Dichloroethene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| cis-1,2-Dichloroethene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Chloroform | NA | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,2-Dichloroethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 2,2-Dichloropropane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,2-Dibromoethane (EDB) | NDL | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1,1-Trichloroethane | 5 | 0.80 | 0.50 | 0.62 | 0.50 |
| Carbon tetrachloride | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Bromodichloromethane | NA | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,2-Dichloropropane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1-Dichloropropene | NDL | 0.50 | 0.50 | 0.50 | 0.50 |
| Trichloroethene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,3-Dichloropropane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Dibromochloromethane | NA | 0.50 | 0.50 | 0.50 | 0.50 |
| Dibromomethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Bromoform | NA | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1,1,2-Tetrachloroethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,2,3-Trichloropropane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1,2,2-Tetrachloroethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Tetrachloroethene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Bromobenzene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 2-Chlorotoluene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 4-Chlorotoluene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| cis-1,3-Dichloropropene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| trans-1,3-Dichloropropene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1,2-Trichloroethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Methyl-tert-Butyl Ether (MTBE) | 5 | 3.20 | NS | 0.50 | NS |

* The principal organic contaminant standard for groundwater of 5 ug/l applies.

*** Applies to the sum of cis- and trans-1,3-dichloropropene

^ Before = Raw water sample

^^ After = at point of use, after carbon treatment

NA - Not Available in NYS DOH Drinking Water Standards

NS - Not Sampled

Table 2: Drinking Water Results for Optimum Window Facility
Greer Site, Wappingers Falls, New York

| Parameter | NYS DOH | Optimum Window Well | | | | Optimum W | |
|--------------------------------|------------------|---------------------|---------|---------|---------|-----------|---------|
| | Drinking Water | Before | After | Before | After | Before | After |
| | Standards (ug/L) | 6/20/02 | 6/20/02 | 9/30/02 | 9/30/02 | 1/27/03 | 1/27/03 |
| Chlorobenzene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,2-Dichlorobenzene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,3-Dichlorobenzene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,4-Dichlorobenzene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Chloromethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Bromomethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Dichlorodifluoromethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Vinyl chloride | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Chloroethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Methylene chloride | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Trichlorofluoromethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1-Dichloroethene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Bromochloromethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1-Dichloroethane | 5 | 1.30 | 0.50 | 2.20 | 0.50 | 1.20 | 0.50 |
| trans-1,2-Dichloroethene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| cis-1,2-Dichloroethene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Chloroform | NA | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,2-Dichloroethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 2,2-Dichloropropane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,2-Dibromoethane (EDB) | NDL | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1,1-Trichloroethane | 5 | 0.50 | 0.50 | 1.00 | 0.50 | 0.58 | 0.50 |
| Carbon tetrachloride | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Bromodichloromethane | NA | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,2-Dichloropropane | 5 | 0.50 | 0.59 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1-Dichloropropene | NDL | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Trichloroethene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,3-Dichloropropane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Dibromochloromethane | NA | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Dibromomethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Bromoform | NA | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1,1,2-Tetrachloroethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,2,3-Trichloropropane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1,2,2-Tetrachloroethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Tetrachloroethene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Bromobenzene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 2-Chlorotoluene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 4-Chlorotoluene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| cis-1,3-Dichloropropene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| trans-1,3-Dichloropropene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1,2-Trichloroethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Methyl-tert-Butyl Ether (MTBE) | 5 | 0.50 | NS | NS | NS | NS | NS |

* The principal organic contaminant standard for grc

*** Applies to the sum of cis- and trans-1,3,-dichloro

^ Before = Raw water sample

^^ After = at point of use, after carbon treatment

NA - Not Available in NYS DOH Drinking Water Sta

NS - Not Sampled

Table 2: Drinking Water Results for Optimum Window Facility
Greer Site, Wappingers Falls, New York

| Parameter | NYS DOH | Indow Well | | Optimum Window Well | | | |
|--------------------------------|------------------|------------|--------|---------------------|---------|---------|---------|
| | Drinking Water | Before | After | Before | After | Before | After |
| | Standards (ug/L) | 4/1/03 | 4/1/03 | 6/30/03 | 6/30/03 | 10/1/03 | 10/1/03 |
| Chlorobenzene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,2-Dichlorobenzene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,3-Dichlorobenzene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,4-Dichlorobenzene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Chloromethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Bromomethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Dichlorodifluoromethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Vinyl chloride | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Chloroethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Methylene chloride | 5 | 1.20 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Trichlorofluoromethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1-Dichloroethene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Bromochloromethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1-Dichloroethane | 5 | 0.76 | 0.50 | 1.40 | 0.50 | 0.68 | 0.50 |
| trans-1,2-Dichloroethene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| cis-1,2-Dichloroethene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Chloroform | NA | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,2-Dichloroethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 2,2-Dichloropropane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,2-Dibromoethane (EDB) | NDL | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1,1-Trichloroethane | 5 | 0.50 | 0.50 | 0.53 | 0.50 | 0.50 | 0.50 |
| Carbon tetrachloride | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Bromodichloromethane | NA | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,2-Dichloropropane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1-Dichloropropene | NDL | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Trichloroethene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,3-Dichloropropane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Dibromochloromethane | NA | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Dibromomethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Bromoform | NA | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1,1,2-Tetrachloroethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,2,3-Trichloropropane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1,2,2-Tetrachloroethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Tetrachloroethene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Bromobenzene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 2-Chlorotoluene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 4-Chlorotoluene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| cis-1,3-Dichloropropene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| trans-1,3-Dichloropropene | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1,2-Trichloroethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Methyl-tert-Butyl Ether (MTBE) | 5 | NS | NS | NS | NS | NS | NS |

* The principal organic contaminant standard for grc
 *** Applies to the sum of cis- and trans-1,3,-dichloro
 ^ Before = Raw water sample
 ^^ After = at point of use, after carbon treatment
 NA - Not Available in NYS DOH Drinking Water Stan
 NS - Not Sampled

Table 2: Drinking Water Results for Optimum Window Facility
Greer Site, Wappingers Falls, New York

| Parameter | NYS DOH | Optimum Window Well | | | |
|--------------------------------|------------------|---------------------|----------|---------|---------|
| | Drinking Water | Before | After | Before | After |
| | Standards (ug/L) | 12/19/03 | 12/19/03 | 3/31/04 | 3/31/04 |
| Chlorobenzene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,2-Dichlorobenzene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,3-Dichlorobenzene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,4-Dichlorobenzene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Chloromethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Bromomethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Dichlorodifluoromethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Vinyl chloride | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Chloroethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Methylene chloride | 5 | 0.80 | 0.50 | 0.50 | 0.50 |
| Trichlorofluoromethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1-Dichloroethene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Bromochloromethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1-Dichloroethane | 5 | 1.10 | 0.50 | 1.60 | 0.50 |
| trans-1,2-Dichloroethene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| cis-1,2-Dichloroethene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Chloroform | NA | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,2-Dichloroethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 2,2-Dichloropropane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,2-Dibromoethane (EDB) | NDL | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1,1-Trichloroethane | 5 | 0.52 | 0.50 | 0.92 | 0.50 |
| Carbon tetrachloride | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Bromodichloromethane | NA | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,2-Dichloropropane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1-Dichloropropene | NDL | 0.50 | 0.50 | 0.50 | 0.50 |
| Trichloroethene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,3-Dichloropropane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Dibromochloromethane | NA | 0.50 | 0.50 | 0.50 | 0.50 |
| Dibromomethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Bromoform | NA | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1,1,2-Tetrachloroethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,2,3-Trichloropropane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1,2,2-Tetrachloroethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Tetrachloroethene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Bromobenzene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 2-Chlorotoluene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 4-Chlorotoluene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| cis-1,3-Dichloropropene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| trans-1,3-Dichloropropene | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| 1,1,2-Trichloroethane | 5 | 0.50 | 0.50 | 0.50 | 0.50 |
| Methyl-tert-Butyl Ether (MTBE) | 5 | NS | NS | NS | NS |

* The principal organic contaminant standard for grc
 *** Applies to the sum of cis- and trans-1,3,-dichloro
 ^ Before = Raw water sample
 ^^ After = at point of use, after carbon treatment
 NA - Not Available in NYS DOH Drinking Water Sta
 NS - Not Sampled