




11000 N. MoPac Expressway, Suite 500
Austin, Texas 78759
Phone: (512) 451-6334
Fax: (512) 459-1459



Date Printed and Mailed: 5/27/2026

DEC-SCHENECTADY
REGION 4
1130 NORTH WESTCOTT ROAD
SCHENECTADY, NY 12306

Test Date: 5/11/2026
Order Number: 8618443

Dear Regulator,

Enclosed are the results of recent testing performed at the following facility:

CUMBERLAND FARMS #1511/ 3107
222 MOHAWK AVE/ RT 5 @ CENTER ST.
PBS# 4-036706
SCOTIA, NY 12302

Testing conducted in accordance with paragraph 613-2.3(d)(2) of NYCRR. Technician is a certified Vacutect tank tester and/or a certified TLD-1 line tester in accordance with company protocol. Technician address on file at Tanknology corporate office: 11000 N. MoPac Expressway, Suite 500, Austin, TX 78759

Testing performed:
IMPACT VALVE
LEAK DETECTOR
MONITOR CERTIFICATION

Sincerely,

A handwritten signature in black ink that reads 'Dawn Kohlmeier'.

Dawn Kohlmeier
Manager, Field Reporting



LDT 5000 Field Test Apparatus
Line Leak Detector Test

Work Order: 8618443 Date: 5/11/2026
Site Name / ID: CUMBERLAND FARMS #1511/ 3107 / 3107
Address: 222 MOHAWK AVE/ RT 5 @ CENTER ST. PBS# 4-036706
City: SCOTIA State: NY Zip: 12302

| Tank ID | T1 | T3 | T4 | | | |
|--|------------------|------------------|------------------|--|--|--|
| Product | RUL | SUL | Diesel | | | |
| Product Line | 1 | 1 | 1 | | | |
| Tested From | 8 | 8 | 8 | | | |
| Existing/New | Existing | Existing | Existing | | | |
| Mechanical/Electronic | Electronic | Electronic | Electronic | | | |
| Manufacturer/Model | Veeder Root PLLD | Veeder Root PLLD | Veeder Root PLLD | | | |
| Serial No. | | | | | | |
| Pump Operating Pressure (psi) | 30.00 | 30.00 | 34.00 | | | |
| Calibrated Leak (ml/min) | 189.0 | 189.0 | 189.0 | | | |
| Calibrated Leak (gph) | 3.00 | 3.00 | 3.00 | | | |
| Holding PSI *N/A for Electronic LD's | | | | | | |
| Resiliency (ml) *N/A for Electronic LD's | | | | | | |
| Metering PSI *N/A for Electronic LD's | | | | | | |
| Opening Time (sec) *N/A for Electronic LD's | | | | | | |
| Test Results | Pass | Pass | Pass | | | |

Technician Comments:

Technician Name: Jeffrey Claeys Certification #: 133137
Technician Signature: Expire Date: 6/18/2026

MONITORING SYSTEM CERTIFICATION

This form is used to document testing and servicing of tank and piping leak monitoring equipment. If required by applicable law, a copy of the completed form must be provided by the Testing Contractor or owner to the governing UST agency as required by regulation.

A. General Information


Facility Name: CUMBERLAND FARMS #1511/ 3107 Bldg. No.: _____
 Site Address: 222 MOHAWK AVE/ RT 5 @ CENTER ST.PBS# 4-036706 City: SCOTIA State: NY Zip: 12302
 Facility Contact Person: TIM JENOBIO Contact Phone No.: 518-346-5537
 Make/Model of Monitoring System: Veeder Root TLS-350 Date of Testing/Servicing: 5/11/2026

B. Inventory of Equipment Tested/Certified Check the appropriate boxes to indicate specific equipment inspected/serviced:

| | |
|--|---|
| Tank ID: T1 - RUL <input checked="" type="checkbox"/> In-Tank Gauging Probe. Model: <u>846390-109</u> <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>794380-303</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>794380-208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input type="checkbox"/> Mechanical Line Leak Detector. Model: _____ <input checked="" type="checkbox"/> Electronic Line Leak Detector. Model: <u>Veeder Root PLLD -</u> <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2). | Tank ID: T2 - RUL 2 <input checked="" type="checkbox"/> In-Tank Gauging Probe. Model: <u>846390-109</u> <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>794380-303</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>794380-208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input type="checkbox"/> Mechanical Line Leak Detector. Model: _____ <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2). |
| Tank ID: T3 - SUL <input checked="" type="checkbox"/> In-Tank Gauging Probe. Model: <u>846390-109</u> <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>794380-303</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>794380-208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input type="checkbox"/> Mechanical Line Leak Detector. Model: _____ <input checked="" type="checkbox"/> Electronic Line Leak Detector. Model: <u>Veeder Root PLLD -</u> <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2). | Tank ID: T4 - Diesel <input checked="" type="checkbox"/> In-Tank Gauging Probe. Model: <u>846390-109</u> <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>794380-303</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>794380-208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input type="checkbox"/> Mechanical Line Leak Detector. Model: _____ <input checked="" type="checkbox"/> Electronic Line Leak Detector. Model: <u>Veeder Root PLLD</u> <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2). |
| Dispenser ID: 1/2 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>794380-208</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s). | Dispenser ID: 3/4 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>794380-208</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s). |
| Dispenser ID: 5/6 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>794380-208</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s). | Dispenser ID: 7/8 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>794380-208</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s). |
| Dispenser ID: _____ <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s). | Dispenser ID: _____ <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s). |

*If the facility contains more tanks or dispensers, copy this form. Include information for every tank and dispenser at the facility.

C. Certification - I certify that the equipment identified in this document was inspected/serviced in accordance with the manufacturers' guidelines. Attached to this Certification is a Plot Plan showing the layout of monitoring equipment. For any equipment capable of generating such reports, I have also attached a copy of the report; (check all that apply): System set-up Alarm history report

Technician Name (print): Jeffrey Claeys Signature: 
 Certification No.: B48818 License. No.: _____
 Testing Company Name: Tanknology Phone No.: (800) 800-4633
 Testing Company Address: 11000 N. MoPac Expressway Suite 500 Date of Testing/Servicing: 5/11/2026

D. Results of Testing/Serviceing

Software Version Installed: 134.01

Complete the following checklist:

| | | |
|---|---|---|
| <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No* <input type="checkbox"/> N/A | Is the visual alarm on the console operational? |
| <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No* <input type="checkbox"/> N/A | Is the audible alarm on the console operational? |
| <input type="checkbox"/> Yes | <input checked="" type="checkbox"/> No | Is the external visual overfill alarm (light unit) present? |
| <input type="checkbox"/> Yes | <input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A | Is the external visual overfill alarm operating properly? |
| <input type="checkbox"/> Yes | <input checked="" type="checkbox"/> No | Is the external audible overfill alarm present? |
| <input type="checkbox"/> Yes | <input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A | Is the external audible overfill alarm operating properly? |
| % | <input checked="" type="checkbox"/> N/A | At what percent of tank(s) capacity is the external alarm programmed to trigger? <i>If different % between tanks, clarify in section E.</i> |
| <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No* <input type="checkbox"/> N/A | Were all sensors visually inspected, functionally tested, and confirmed operational? |
| <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No* <input type="checkbox"/> N/A | Were all sensors installed at lowest point of secondary containment and positioned so that other equipment will not interfere with their proper operation? |
| <input type="checkbox"/> Yes | <input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A | For pressurized piping systems, does the turbine automatically shut down if the piping secondary containment monitoring system detects a leak, fails to operate, or is electrically disconnected? If yes: which sensors initiate positive shut-down? <i>(Check all that apply)</i> <input type="checkbox"/> Sump/Trench Sensors; <input type="checkbox"/> Dispenser Containment Sensors. Did you confirm positive shut-down due to leaks <u>and</u> sensor failure/disconnection? <input type="checkbox"/> Yes; <input type="checkbox"/> No |
| <input type="checkbox"/> Yes* | <input checked="" type="checkbox"/> No | Was any monitoring equipment replaced? If yes, identify specific sensors, probes, or other equipment replaced and list the manufacturer name and model for all replacement parts in Section E, below. |
| <input type="checkbox"/> Yes* | <input checked="" type="checkbox"/> No | Was liquid found inside any secondary containment systems designed as dry systems? <i>(Check all that apply)</i> <input type="checkbox"/> Product; <input type="checkbox"/> Water. If yes, describe causes in Section E, below. |
| <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No* | Was monitoring system set-up reviewed to ensure proper settings? Attach set up reports, if applicable |
| <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No* | Is all monitoring equipment operational per manufacturer's specifications? |

* In Section E below, describe how and when these deficiencies were or will be corrected.

E. Comments:

Backup Battery reading, if applicable (Required for VR TLS 300/350):3.66v

F. In-Tank Gauging / SIR Equipment:

- Check this box if tank gauging is used only for inventory control.
- Check this box if no tank gauging or SIR equipment is installed.

This section must be completed if in-tank gauging equipment is used to perform leak detection monitoring.

Complete the following checklist:

| | | |
|---|------------------------------|---|
| <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No* | Were all tank gauging probes visually inspected for damage and residue buildup? |
| <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No* | Was accuracy of system product level readings tested? |
| <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No* | Was accuracy of system water level readings tested? |
| <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No* | Were all probes reinstalled properly? |
| <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No* | Were all items on the equipment manufacturer's maintenance checklist completed? |

* In the Section G, below, describe how and when these deficiencies were or will be corrected.

G. Comments:

DID OVERALL MONITOR SYSTEM TESTING PASS (Check One)? YES NO
INCONCLUSIVE




Site Diagram

(This site diagram is for reference only and is not drawn to scale)

Work Order: 8618443
Site ID / Name: 3107 / CUMBERLAND FARMS #1511/ 3107
Address: 222 MOHAWK AVE/ RT 5 @ CENTER ST. PBS# 4-036706
City: SCOTIA

State: NY Zip: 12302



ALARM HISTORY REPORT
 ----- IN-TANK ALARM -----
 T 1:RUL
 PRESSURE LINE LEAK Q 3:DSL PLLD
 GROSS LINE FAIL
 MAY 11, 2026 13:15
 SETUP DATA WARNING
 MAY 11, 2026 14:40
 MAY 11, 2026 14:20
 JUL 24, 2025 16:22
 HIGH WATER ALARM
 MAY 11, 2026 14:25
 JUL 24, 2025 16:20
 JUL 31, 2024 10:55
 OVERFILL ALARM
 MAY 11, 2026 14:22
 JUL 24, 2025 16:09
 MAY 28, 2025 16:10
 LOW PRODUCT ALARM
 MAY 11, 2026 14:21
 FEB 2, 2026 15:28
 JAN 28, 2026 17:24
 SUDDEN LOSS ALARM
 NOV 6, 2022 0:15
 OCT 18, 2022 5:21
 AUG 25, 2022 23:04
 HIGH PRODUCT ALARM
 MAY 11, 2026 14:22
 JUL 31, 2024 10:52
 AUG 29, 2023 11:52
 INVALID FUEL LEVEL
 MAY 11, 2026 14:21
 JUL 24, 2025 16:07
 DEC 16, 2023 20:45
 PROBE OUT
 DEC 16, 2023 20:47
 DEC 17, 2018 17:18
 HIGH WATER WARNING
 MAY 11, 2026 14:25
 JUL 24, 2025 16:20
 JUL 31, 2024 10:55
 DELIVERY NEEDED
 AUG 4, 2025 19:50
 JUL 24, 2025 16:07
 JUN 22, 2025 8:12
 MAX PRODUCT ALARM
 MAY 11, 2026 14:22
 JUL 31, 2024 10:52
 AUG 29, 2023 11:52
 LOW TEMP WARNING
 MAY 11, 2026 14:41
 JUL 24, 2025 16:22
 AUG 29, 2023 12:08
 PRESSURE LINE LEAK Q 2:SUL PLLD
 PLLD SHUTDOWN ALARM
 MAY 11, 2026 13:15

ALARM HISTORY REPORT
 ----- IN-TANK ALARM -----
 T 2:RU2
 SETUP DATA WARNING
 MAY 11, 2026 15:11
 JUL 24, 2025 16:56
 JUL 24, 2025 16:40
 HIGH WATER ALARM
 MAY 11, 2026 15:17
 JUL 24, 2025 16:44
 JUL 31, 2024 10:59
 OVERFILL ALARM
 MAY 11, 2026 15:13
 JUL 24, 2025 16:41
 JUL 31, 2024 10:56
 LOW PRODUCT ALARM
 JUL 24, 2025 16:40
 JUL 31, 2024 10:55
 AUG 29, 2023 11:45
 SUDDEN LOSS ALARM
 DEC 18, 2018 11:04
 HIGH PRODUCT ALARM
 MAY 11, 2026 15:13
 JUL 24, 2025 16:41
 JUL 31, 2024 10:56
 INVALID FUEL LEVEL
 JUL 31, 2024 10:55
 NOV 10, 2020 9:45
 DEC 17, 2018 13:21
 PROBE OUT
 OCT 10, 2022 15:10
 HIGH WATER WARNING
 MAY 11, 2026 15:17
 JUL 24, 2025 16:44
 JUL 31, 2024 10:59
 DELIVERY NEEDED
 JUL 24, 2025 16:40
 JUN 22, 2025 11:21
 DEC 28, 2024 14:45
 MAX PRODUCT ALARM
 JUL 31, 2024 10:56
 OCT 20, 2021 10:53
 NOV 10, 2020 10:06
 LOW TEMP WARNING
 OCT 10, 2022 15:41
 OCT 20, 2021 11:11
 DEC 18, 2019 8:53

ALARM HISTORY REPORT
 ----- IN-TANK ALARM -----
 T 3:SUL
 SETUP DATA WARNING
 MAY 11, 2026 14:42
 MAY 11, 2026 14:15
 MAR 20, 2026 17:39
 HIGH WATER ALARM
 MAY 11, 2026 14:22
 JUL 24, 2025 16:13
 JUL 31, 2024 11:03
 OVERFILL ALARM
 MAY 11, 2026 14:19
 JUL 24, 2025 16:10
 JUL 31, 2024 10:59
 LOW PRODUCT ALARM
 MAY 11, 2026 14:16
 JUL 24, 2025 16:08
 AUG 29, 2023 11:40
 SUDDEN LOSS ALARM
 OCT 20, 2021 11:11
 DEC 18, 2018 11:13
 DEC 17, 2018 13:20
 HIGH PRODUCT ALARM
 MAY 11, 2026 14:19
 JUL 31, 2024 10:59
 AUG 29, 2023 11:52
 INVALID FUEL LEVEL
 MAY 11, 2026 14:16
 OCT 20, 2021 11:10
 OCT 20, 2021 10:56
 PROBE OUT
 MAR 20, 2026 17:41
 OCT 10, 2022 15:07
 DEC 14, 2018 11:15
 HIGH WATER WARNING
 MAY 11, 2026 14:22
 JUL 24, 2025 16:13
 JUL 31, 2024 11:03
 DELIVERY NEEDED
 JUL 24, 2025 16:08
 MAY 11, 2025 21:18
 AUG 29, 2023 11:40
 MAX PRODUCT ALARM
 JUL 31, 2024 11:00
 AUG 29, 2023 11:52
 OCT 20, 2021 11:01
 LOW TEMP WARNING
 MAY 11, 2026 14:43
 AUG 29, 2023 12:06
 OCT 20, 2021 10:56
 FUEL QUALITY ALARM
 DEC 17, 2018 17:15
 DEC 17, 2018 10:19

***** END *****

ALARM HISTORY REPORT

***** END *****

----- IN-TANK ALARM

T 4:DSL

SETUP DATA WARNING
MAY 11, 2026 15:07
JUL 24, 2025 16:51
JUL 24, 2025 16:38

ALARM HISTORY REPORT

----- SENSOR ALARM
L 1:RUL STP SUMP

STP SUMP
FUEL ALARM
MAY 11, 2026 14:19

ALARM HISTORY REPORT

ALARM HISTORY REPORT

----- SENSOR ALARM
L 3:SUL STP SUMP

STP SUMP
FUEL ALARM
MAY 11, 2026 14:15

----- SENSOR ALARM -----
L 5:RUL-SUL INT

ANNULAR SPACE
LOW LIQUID ALARM
MAY 11, 2026 14:18

HIGH WATER ALARM
MAY 11, 2026 15:13
JUL 24, 2025 16:44
JUL 31, 2024 11:07

FUEL ALARM
JUL 24, 2025 16:05

FUEL ALARM
JUL 24, 2025 16:09

HIGH LIQUID ALARM
MAY 11, 2026 14:17

OVERFILL ALARM
MAY 11, 2026 15:11
JUL 24, 2025 16:41
JUL 31, 2024 11:07

FUEL ALARM
NOV 5, 2024 1:20

FUEL ALARM
NOV 2, 2024 17:56

LOW LIQUID ALARM
MAY 11, 2026 14:17

LOW PRODUCT ALARM
MAY 11, 2026 15:0
JUL 24, 2025 16:3
JUL 31, 2024 11:3

SUDDEN LOSS ALARM
OCT 20, 2021 11:
DEC 18, 2018 11:

HIGH PRODUCT ALARM
MAY 11, 2026 15:1
JUL 24, 2025 16:3
JUL 31, 2024 11:0

***** END *****

***** END *****

INVALID FUEL LEVEL
MAY 11, 2026 15:1
JUL 31, 2024 11:0
JUL 31, 2024 11:0

HIGH WATER WARNING
MAY 11, 2026 15:
JUL 24, 2025 16:
JUL 31, 2024 11:

ALARM HISTORY REPORT

----- SENSOR ALARM
L 2:RU2 STP SUMP

STP SUMP
FUEL ALARM
MAY 11, 2026 15:11

ALARM HISTORY REPORT

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 4:DSL STP SUMP

STP SUMP
FUEL ALARM
MAY 11, 2026 15:05

----- SENSOR ALARM -----
L 6:RU2-DSL INT

ANNULAR SPACE
LOW LIQUID ALARM
MAY 11, 2026 15:09

DELIVERY NEEDED
JUL 24, 2025 16:
JUL 31, 2024 11:
JUL 31, 2024 11:

FUEL ALARM
JUL 24, 2025 16:39

FUEL ALARM
JUL 24, 2025 16:37

HIGH LIQUID ALARM
MAY 11, 2026 15:08

MAX PRODUCT ALARM
JUL 31, 2024 11:
OCT 10, 2022 15:
OCT 20, 2021 11:

FUEL ALARM
NOV 4, 2024 23:58

FUEL ALARM
NOV 3, 2024 15:39

LOW LIQUID ALARM
MAY 11, 2026 15:08

LOW TEMP WARNING
JUL 24, 2025 16:
AUG 29, 2023 15:
OCT 20, 2021 11:

***** END *****

***** END *****

ALARM HISTORY REPORT

----- SENSOR ALARM -----
 L 7:DISP 7-8
 DISPENSER PAN
 FUEL ALARM
 MAY 11, 2026 13:49

FUEL ALARM
 JUL 24, 2025 15:53

FUEL ALARM
 JUL 31, 2024 10:25

***** END *****

ALARM HISTORY REPORT

----- SENSOR ALARM -----
 L 8:DISP 3-4
 DISPENSER PAN
 FUEL ALARM
 MAY 11, 2026 13:43

FUEL ALARM
 JAN 15, 2026 2:36

FUEL ALARM
 JUL 24, 2025 15:49

***** END *****

ALARM HISTORY REPORT

----- SENSOR ALARM -----
 L 9:DISP 5-6
 DISPENSER PAN
 FUEL ALARM
 MAY 11, 2026 13:47

FUEL ALARM
 JUL 24, 2025 15:51

FUEL ALARM
 JUL 31, 2024 10:21

***** END *****

ALARM HISTORY REPORT

----- SENSOR ALARM -----
 L10:DISP 1-2
 DISPENSER PAN
 FUEL ALARM
 MAY 11, 2026 13:35

FUEL ALARM
 JUL 24, 2025 15:15

FUEL ALARM
 JUL 31, 2024 10:16

***** END *****