

NEWYORK STATE DEPARTMENT OF ENVIRONMENTAL CONSERVATION

Division of Environmental Remediation
 Operation Maintenance and Monitoring Review Report
 Period covered by -- 2002

Site / Spill Number : 546022	Site Name: Rocket Test Site	Class: 02
Program Lead: Hazardous Waste Program	OM&M Funding Source: Responsible Party	
Start Date : 09/24/1999	ACT	
Annual IC/EC Certification : GROUND WATER USE RESTRICTION - confirmed by ANNUAL ENVIRONMENTAL BASEMENT RESTRICTION		
DEC Inspection Date: 04/30/2001	--- Last Date of DEC Inspection	
Report Used for Evaluation: Semi Annual O&M Report - thru June 2002		
ROD Compliance ? YES	Consent order/Decree Compliance ? YES	
LongTerm Monitoring(effectiveness of remedy): Yes	Frequency: Semi-Annually	Act. Date: 05/29/2002
Treatment System(Monitoring performance of remedy): Yes	Frequency: Quarterly	Pln. Date: 08/07/2002 #wells : 6
PROBLEM STATUS : 99A	None	AND 3 SURFACE WATER LOCATIONS
Evaluation : The Remedy is performing properly and is effective. CONTINUE W/ PRESENT OM&M PROGRAM.		
Comments/ Changes/ Attachments: 2002: Reclassify Site to a 4, once site is removed from NPL. 2001: The site O&M was transferred over to the O&M Section in the BHSC from the Federal Projects Section in August 2000.		
ROD/Consent Order Modifications?	NO	
Site reclassification recommended :	None	
Contaminant of concern	OU	Media/Receptor
01	DIMETHYLHYDRAZINE	Ground Water,Drinking water
01	SPENT SOLVENTS	Ground Water,Drinking water
Remedies	OU	Size of Treatment
01	AIR STRIPPER (POTABLE WATER)	Small (<10gpm or < 5 acres)
01	MONITORED NATURAL ATTENUATION	
		Date in Place
		Remedy Effective
		04/01/1995
		01/01/1998
		Yes
		Yes

WORK ELEMENT (WE) I - SITE DRINKING WATER SYSTEM (INCLUDES AIR STRIPPER)
 WE II - GW MONITORING PROGRAM, INCORPORATES EARLY WARNING MONITORING SYSTEM
 WE IV - INSTITUTIONAL CONTROL - GROUND WATER USE RESTRICTION.

Next Review 10/01/2003	Priority: 7
Protect Manager Strang	Reviewer: Rider
Signature John R Strang Date 12/21/2002	Signature Gerald J. Rider Date 1/29/03
Name JOHN R STRANG Region or Bureau BHSC Telephone (518) 402-9552	Name GERALD J. RIDER JR Region or Bureau BHSC Telephone 402-9641

Report: Ommrpt1.b.frx

☐ OM Certified
 All Data Entered