


Village of Endicott
Industrial Pretreatment Dept.
c/o 1009 E. Main St.
Endicott, New York 13760



October 1, 2008

USEPA, Region II
Emergency and Remediation Response Division
290 Broadway
New York, New York 10007

Attn: Sherrel Henry

Re: Supplemental Purge Well ,
Endicott Wellfield Site

Dear Ms. Henry:

Pursuant to EPA's approval of the Village of Endicott's proposal for a reduction in the frequency of monitoring and analysis for the Supplemental Purge Well, I am submitting a report for the 3rd quarter of 2008 for the supplemental purge well as well as for the final effluent.

The average daily flows for the months contained in this reporting period are:

July, 2008.....	567,615 gal/day (397 gal/min)
August, 2008.....	539,177 gal/day (374 gal/min)
September, 2008.....	564,583 gal/day (392 gal/min)

Within this report are summaries of daily SPW flows, a listing of detectable VOC's for the SPW and final effluent and water level readings for the 3rd quarter of 2008.

If you have any questions concerning this report, please call me at 607-757-5352.

Sincerely,

A handwritten signature in cursive script, appearing to read "Philip Grayson".

Philip Grayson

Sewage Pretreatment Admin.

cc: NYSDEC, Payson Long
NYSDEC, James Burke, P.E.
Malcolm Pirnie, Inc., Bruce Nelson

Supplemental Purge Well Daily Flow Readings: 2008 Gal./Day

	Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sept.	Oct.	Nov.	Dec.
1	580,000	331,000	349,000	403,000	468,000	562,000	730,000	605,000	586,500	-206,270,000	0	0
2	580,000	331,000	501,500	503,000	450,000	562,000	541,000	522,000	676,000	0	0	0
3	563,000	359,500	501,500	482,000	449,000	591,000	561,000	155,500	593,000	0	0	0
4	625,000	359,500	464,000	573,000	502,000	600,000	724,000	155,500	388,000	0	0	0
5	519,000	620,000	662,000	621,000	502,000	522,000	425,000	482,000	420,000	0	0	0
6	594,000	320,000	570,000	403,000	493,000	520,000	64,000	525,000	707,000	0	0	0
7	594,000	285,000	314,500	403,000	547,000	619,000	64,000	772,000	593,000	0	0	0
8	538,000	350,000	314,500	480,000	550,000	587,667	1,629,000	497,000	593,000	0	0	0
9	560,000	223,000	444,000	407,000	815,000	587,667	575,000	494,000	595,000	0	0	0
10	550,000	404,000	444,000	589,000	330,667	587,667	538,333	542,500	488,000	0	0	0
11	680,000	404,000	638,000	550,000	330,667	578,000	538,333	659,000	500,000	0	0	0
12	680,000	405,000	625,000	413,000	330,667	556,000	538,333	522,000	624,000	0	0	0
13	590,000	442,000	580,000	509,500	479,000	530,000	566,500	481,000	584,000	0	0	0
14	590,000	414,000	354,500	509,500	489,000	580,000	535,000	797,000	584,000	0	0	0
15	546,000	410,000	354,500	446,000	383,000	568,000	640,000	442,000	584,000	0	0	0
16	622,000	165,000	528,500	485,000	425,000	568,000	598,000	509,500	584,000	0	0	0
17	440,000	568,000	528,500	509,000	635,000	647,000	598,000	509,500	494,000	0	0	0
18	956,000	568,000	515,000	514,000	568,000	625,000	526,500	509,500	460,000	0	0	0
19	584,333	351,000	503,000	459,000	568,000	491,000	526,500	614,000	625,000	0	0	0
20	584,333	448,000	550,000	507,500	576,000	528,000	659,500	611,000	581,000	0	0	0
21	584,333	429,333	520,000	507,500	568,000	528,000	659,500	620,000	581,000	0	0	0
22	576,000	429,333	275,000	435,000	574,000	612,000	575,000	620,000	542,000	0	0	0
23	648,000	429,333	515,000	504,000	632,000	612,000	384,000	125,000	558,000	0	0	0
24	465,000	541,500	515,000	490,000	513,000	483,000	425,000	383,000	563,000	0	0	0
25	686,000	541,500	511,000	500,000	583,000	599,000	900,000	1,212,000	520,000	0	0	0
26	568,667	535,000	444,000	440,000	583,000	516,000	375,000	479,000	613,000	0	0	0
27	568,667	326,000	506,000	492,500	583,000	525,000	592,500	607,000	608,500	0	0	0
28	568,667	469,000	501,000	492,500	462,000	627,000	592,500	486,000	608,500	0	0	0
29	1,110,000	520,000	425,000	534,000	833,000	492,000	552,000	525,000	608,500	0	0	0
30	463,000		551,000	488,000	473,500	492,000	621,000	642,000	535,000	0	0	0
31	331,000		551,000		473,500		516,000	586,500		0		0
Total	18,545,000	11,979,000	15,056,000	14,630,000	16,169,000	16,896,000	17,739,000	16,714,500	16,937,500	-206,270,000	0	0
Ave	598,226	413,069	485,677	487,667	521,581	566,111	567,615	539,177	564,583	-6,653,871	0	0
Gal/Hr.	24,926	17,211	20,237	20,319	21,733	23,588	23,843	22,466	23,524	-277,245	0	0
Gal/Min	415	287	337	339	362	393	397	374	392	-4,621	0	0

Supplemental Purge Well Readings 2008

	Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sept.	Oct.	Nov.	Dec.
Prev.	268409		298933	313989	328619	344788	361684	379423				
1	268989		299282	314392	329087		362414	380028	396724			
2	269569	287616		314895	329537	345912	362955	380550	397400			
3	270132		300285	315357	329986	346503	363516		397993			
4	270757	288335	300749	315930		347103	364240	380861	398381			
5	271276	288955	301411	316551	330990	347625	364665	381343	398801			
6		289275	301981		331483	348145		381868	399508			
7	272464	289560		317357	332030	348764	364793	382640				
8	273002	289910	302610	317837	332580		366422	383137	400694			
9	273562	290133		318244	333395		366997	383631	401289			
10	274112		303498	318833		350527			401777			
11		290941	304136	319383		351105		384716	402326			
12	275472	291346	304761	319796	334387	351661	368612	385375	402826			
13		291788	305341		334866	352191		385897	403450			
14	276652	292202		320815	335355	352771	369745	386378				
15	277198	292612	306050	321261	335738		370280	387175				
16	277820	292777		321746	336163	353907	370920	387617				
17	278260		307107	322255	336798	354554	371518		405786			
18	279216	293913	307622	322769		355179		388636	406280			
19		294264	308125	323228	337934	355670	372571	389250	406740			
20		294712	308675		338510				407365			
21	280969		309195	324243	339078	356726	373890	390472				
22	281545		309470	324678	339652		374465	391092	408527			
23	282193	296000		325182	340284	357950	374849	391217	409069			
24	282658			325672	340797	358433	375274	391600	409627			
25	283344	297083	310500	326172		359032	376174	392812	410190			
26		297618	311011	326612		359548	376549	393291	410710			
27		297944	311455		342546	360073		393898	411323			
28	285050	298413	312462	327597	343008	360700	377734	394384				
29	286160	298933	312887	328131	343841		378286	394909	412540			
30	286623			328619		361684	378907	395551	413075			
31			313989		344788		379423					

Upstate Laboratories, Inc.

Shipping: 6034 Corporate Dr. * E. Syracuse, NY 13057-1017 * (315) 437-0255 * Fax (315) 437-1209

Mailing: Box 169 * Syracuse, NY 13206

Albany (518) 459-3134 * Binghamton (607) 724-0478 * Buffalo (716) 972-0371

Rochester (866) 437-0255 * New Jersey (908) 247-4313

Mr. Philip Grayson, Lab. Director
Village of Endicott
Wastewater Treatment Laboratory
1009 E. Main St.
Endicott, NY 13760

Tuesday, September 09, 2008

RE: Analytical Report:
SPW Quarterly

Order No.: U0808251

Dear Mr. Philip Grayson, Lab. Director:

Upstate Laboratories, Inc. received 2 sample(s) on 8/13/2008 for the analyses presented in the following report.

All analytical results relate to the samples as received by the laboratory.

All analytical data conforms with standard approved methodologies and quality control. Our quality control narrative will be included should any anomalies occur.


We have included the Chain of Custody Record as part of your report. You may need to reference this form for a more detailed explanation of your samples. Samples will be disposed of approximately one month from final report date.

Should you have any questions regarding these tests, please feel free to give us a call.

Thank you for your patronage.

Sincerely,

UPSTATE LABORATORIES, INC.


Anthony J. Scala
President/CEO

Confidentiality Statement: This report is meant for the use of the intended recipient. It may contain confidential information, which is legally privileged or otherwise protected by law. If you have received this report in error, you are strictly prohibited from reviewing, using, disseminating, distributing or copying the information.

Upstate Laboratories, Inc.

Analytical Report

Date: 09-Sep-08

CLIENT: Village of Endicott
Lab Order: U0808251
Project: SPW Quarterly
Lab ID: U0808251-001

Client Sample ID: SPW 081308G
Collection Date: 8/13/2008 7:50:00 AM

Matrix: WATER

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
PURGEABLES PRIORITY POLLUTANTS				E624		Analyst: CMM
1,1,1-Trichloroethane	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
1,1,2,2-Tetrachloroethane	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
1,1,2-Trichloroethane	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
1,1-Dichloroethane	3.8	3.0		µg/L	1	8/25/2008 1:30:00 PM
1,1-Dichloroethene	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
1,2-Dichlorobenzene	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
1,2-Dichloroethane	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
1,2-Dichloropropane	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
1,3-Dichlorobenzene	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
1,4-Dichlorobenzene	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
2-Chloroethyl vinyl ether	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
Acrolein	ND	50		µg/L	1	8/25/2008 1:30:00 PM
Acrylonitrile	ND	50		µg/L	1	8/25/2008 1:30:00 PM
Benzene	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
Bromodichloromethane	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
Bromoform	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
Bromomethane	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
Carbon tetrachloride	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
Chlorobenzene	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
Chloroethane	11	3.0		µg/L	1	8/25/2008 1:30:00 PM
Chloroform	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
Chloromethane	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
cis-1,2-Dichloroethene	17	3.0		µg/L	1	8/25/2008 1:30:00 PM
cis-1,3-Dichloropropene	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
Dibromochloromethane	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
Dichlorodifluoromethane	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
Ethylbenzene	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
m,p-Xylene	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
Methylene chloride	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
o-Xylene	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
Tetrachloroethene	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
Toluene	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
trans-1,2-Dichloroethene	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
trans-1,3-Dichloropropene	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
Trichloroethene	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
Trichlorofluoromethane	ND	3.0		µg/L	1	8/25/2008 1:30:00 PM
Vinyl chloride	54	2.0		µg/L	1	8/25/2008 1:30:00 PM

Approved By:

AP

Date:

9-9-08

Page 1 of 2

Qualifiers:

* Low Level
B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit

** Value exceeds Maximum Contaminant Value
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

Upstate Laboratories, Inc.

Analytical Report

Date: 09-Sep-08

CLIENT: Village of Endicott
Lab Order: U0808251
Project: SPW Quarterly
Lab ID: U0808251-002

Client Sample ID: Eff 081308G-A
Collection Date: 8/13/2008 8:00:00 AM

Matrix: WATER

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
PURGEABLES PRIORITY POLLUTANTS				E624		Analyst: CMM
1,1,1-Trichloroethane	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
1,1,2,2-Tetrachloroethane	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
1,1,2-Trichloroethane	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
1,1-Dichloroethane	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
1,1-Dichloroethene	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
1,2-Dichlorobenzene	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
1,2-Dichloroethane	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
1,2-Dichloropropane	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
1,3-Dichlorobenzene	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
1,4-Dichlorobenzene	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
2-Chloroethyl vinyl ether	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
Acrolein	ND	50		µg/L	1	8/25/2008 2:11:00 PM
Acrylonitrile	ND	50		µg/L	1	8/25/2008 2:11:00 PM
Benzene	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
Bromodichloromethane	10	3.0		µg/L	1	8/25/2008 2:11:00 PM
Bromoform	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
Bromomethane	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
Carbon tetrachloride	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
Chlorobenzene	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
Chloroethane	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
Chloroform	18	3.0		µg/L	1	8/25/2008 2:11:00 PM
Chloromethane	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
cis-1,2-Dichloroethene	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
cis-1,3-Dichloropropene	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
Dibromochloromethane	3.1	3.0		µg/L	1	8/25/2008 2:11:00 PM
Dichlorodifluoromethane	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
Ethylbenzene	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
m,p-Xylene	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
Methylene chloride	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
o-Xylene	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
Tetrachloroethene	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
Toluene	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
trans-1,2-Dichloroethene	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
trans-1,3-Dichloropropene	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
Trichloroethene	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
Trichlorofluoromethane	ND	3.0		µg/L	1	8/25/2008 2:11:00 PM
Vinyl chloride	ND	2.0		µg/L	1	8/25/2008 2:11:00 PM

Approved By:

AB

Date:

9-9-08

Page 2 of 2

Qualifiers:

- * Low Level
- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit

- ** Value exceeds Maximum Contaminant Value
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

Chain of Custody Record

Fax 437 1209

Project #/ Project Name

SPW-Quarterly

[illegible]

Endicott, NY

Full-Featured Line Out

No.	of	Remarks
1)		
2)		
3)		
4)		
5)		
6)		
7)		
8)		
9)		
10)		

Grab

Grab

again

1

10

1111

1111

Size

40

1

DATE: 11/11/2000

1111

D

Supplemental Purge Well
Monthly Analysis: VOC's
2008 Detectable Quantities

Parameter	Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sept.	Oct.	Nov.	Dec.	Total
Results in ug/L													
Vinyl Chloride	24				26			54					104
Chloromethane	<1				<3			<3					0
Chloroethane	9.4				8.9			11					29.3
Methylene Chloride	<1				<3			<3					0
Dichlorodifluoromethane	<1				<3			<3					0
Trichloroethene	<1				<3			<3					0
1,1-Dichloroethane	3.6				<3			3.8					7.4
1,1-Dichloroethene	<1				<3			<3					0
cis-1,2-Dichloroethene	19				14			17					50
cis-1,3-Dichloropropene	<1				<3			<3					0
Chlorobenzene	2.7				<3			<3					2.7
Benzene	1.2				<3			<3					1.2
Toluene	<1				<3			<3					0
Chloroform	<1				<3			<3					0
m-Xylene & p-Xylene	<2				<3			<3					0
Total VOC's	59.9				48.9			85.8					194.6

Final Effluent
Monthly Analysis: VOC's
2008 Detectable Quantities

Parameter	Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sept.	Oct.	Nov.	Dec.	Total
Results in ug/L													
Vinyl Chloride	<1				<2			<2					0
Chloromethane	<1				<3			<3					0
Chloroethane	<1				<3			<3					0
Methylene Chloride	<1				<3			<3					0
Dichlorodifluoromethane	<1				<3			<3					0
Trichloroethene	<1				<3			<3					0
1,1-Dichloroethane	<1				<3			<3					0
1,1-Dichloroethene	<1				<3			<3					0
cis-1,2-Dichloroethene	<1				<3			<3					0
cis-1,3-Dichloropropene	<1				<3			<3					0
Chlorobenzene	<1				<3			<3					0
Benzene	<1				<3			<3					0
Toluene	<1				<3			<3					0
Chloroform	6				<3			18					24
Bromodichloromethane	4				3.1			10					17.1
m-Xylene & p-Xylene	<2				<3			<3					0
Total VOC's	10				3.1			28					41.1

GROUNDWATER DEPTHS
VILLAGE OF ENDICOTT
ANNUAL SUMMARIES: 2008

Well No.	Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sept.	Oct.	Nov.	Dec.
B-4												
B-21												
EW-3D	13.2	13.0	13.8	14.8			21.9	22.5	27.9			
EW-8	19.2	20.9	18.6	22.2	25.1	31.3	24.6	25.1	27.2			
EW-9	16.1	15.6	10.8	16.8	20.8	23.4	18.7	19.2	22.1			
EW-11												
EW-12	14.5	13.8	14.6	15.8		31.9	19.2	20.1	25.1			
EW-14	15.2	14.7	15.2	21.1	22.8		18.5	19.1	25.6			
MW-3	16.2	16.6	20.1	15.1	31.7	26.6	17.6	18.3	22.9			
MW-6D	22.8	22.1	19.1	23.6	25.4	28.7	27.8	27.2	28.4			
MW-8D												
MW-9D	22.7	22.3	22.9	27.6	21.2	30.1	18.5	19.1	28.6			
MW-7S	15.2	15.6	13.7	16.8	19.3	23.6	20.5	21.1	23.9			
MW-7D	13.5	15.5	12.9	15.2	17.6	22.2	21.2	21.2	25.0			
MW-11	26.5	26.2	24.1	20.2	25.2	36.6	20.3	22.3	27.9			
MW-12	28.7	27.4	24.3	23.4	27.3	34.2	23.6	24.2	28.6			
MW-13D	7.4	7.1	8.4	11.6	14.9	28.1	21.1	33.9	16.1			
MW-21	30.5	29.9	27.2	31.6	33.8	35.9	33.5	32.6	34.8			
MW-22D	27.7	27.6	24.6	29.4	30.8	33.9	31.5	21.4	34.2			
MW-25D	15.9	15.7	14.6	17.1	19.2	22.4	19.6	21.1	22.3			
MW-29	9.3	8.8	12.3	11.8	15	27.7	23.6	18.5	15.7			
MW-30	22.4	21.3	14.6	22.6	26	28.4	21.7	22.7	27.9			
MW-31	22.1	20.6	16.3	22.8	25.8	29.9	17.5	19.6	27.4			
MW-32	7.2	6.5	4.2	8.6	11.4	25.5	18.2	21.2	13.7			
MW-33	17.7	17.4	14.3	18.8	21.8	23.7	20.1	20.4	25.7			
MW-34	13.9	18.3	10.6	23.2	17.9	24.8	19.7	21.6	26.1			
MW-35	18.1	15.8	13.6	19.8	22.7	24.7	22.6	23.0	24.5			
SPW	21.3	21.2	17.5	17.2	25.7	26.1	25.6	26.4	28.7			

GROUNDWATER ELEVATIONS
VILLAGE OF ENDICOTT
ANNUAL SUMMARIES: 2008

Well No.	Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sept.	Oct.	Nov.	Dec.
B-4												
B-21												
EW-3D	805.13	805.33	804.53	803.53			796.43	795.83	790.43			
EW-8	804.14	802.44	804.74	801.14	798.24	792.04	798.74	798.24	796.14			
EW-9	802.51	803.01	807.81	801.81	797.81	795.21	799.91	799.41	796.51			
EW-11												
EW-12	815.83	816.53	815.73	814.53		798.43	811.13	810.23	805.23			
EW-14	807.84	808.34	807.84	801.94	800.24		804.54	803.94	797.44			
MW-3	814.32	813.92	810.42	815.42	798.82	803.92	812.92	812.22	807.62			
MW-6D	803.75	804.45	807.45	802.95	801.15	797.85	798.75	799.35	798.15			
MW-8D												
MW-9D	809.37	809.77	809.17	8.4.47	810.87	801.97	813.57	812.97	803.47			
MW-7S	808.01	807.61	809.51	806.41	803.91	799.61	802.71	802.11	799.31			
MW-7D	809.78	807.78	810.38	808.08	805.68	801.08	802.08	802.08	798.28			
MW-11	801.11	801.41	803.51	807.41	802.41	791.01	807.31	805.31	799.71			
MW-12	801.04	802.34	805.44	806.34	802.44	795.54	806.14	805.54	801.14			
MW-13D	806.89	807.19	805.89	802.69	799.39	786.19	793.19	780.39	798.19			
MW-21	804.06	804.66	807.36	802.96	800.76	798.66	801.06	801.96	799.76			
MW-22D	804.13	804.23	807.23	802.43	801.03	797.93	800.33	810.43	797.63			
MW-25D	805.62	805.82	806.92	804.42	802.32	799.12	801.92	800.42	799.22			
MW-29	807.21	807.71	804.21	804.71	801.51	788.81	792.91	798.01	800.81			
MW-30	801.07	802.17	808.87	800.87	797.47	795.07	801.77	800.77	795.57			
MW-31	800.90	802.40	806.70	800.20	797.20	793.10	805.50	803.40	795.60			
MW-32	802.65	803.35	805.65	801.25	798.45	784.35	791.65	788.65	796.15			
MW-33	801.67	801.97	805.07	800.57	797.57	795.67	799.27	798.97	793.67			
MW-34	801.47	797.07	804.77	792.17	797.47	790.57	795.67	793.77	789.27			
MW-35	802.24	804.54	806.74	800.54	797.64	795.64	797.74	797.14	795.84			
SPW	801.07	801.17	804.87	805.17	796.67	796.27	796.77	795.97	793.67			

GROUNDWATER ELEVATIONS
VILLAGE OF ENDICOTT

SAMPLED BY: V. Briga

DATE: 7/28/2008

Well No.	Time	(TOR) Elevation	Water Depth	Water Elevation	Comments
B-4					
B-21					
EW-3D		818.33	21.9	796.43	
EW-8		823.34	24.6	798.74	
EW-9		818.61	18.7	799.91	
EW-11					
EW-12		830.33	19.2	811.13	
EW-14		823.04	18.5	804.54	
MW-3		830.52	17.6	812.92	
MW-6D		826.55	27.8	798.75	
MW-8D					
MW-9D		832.07	18.5	813.57	
MW-7S		823.21	20.5	802.71	
MW-7D		823.28	21.2	802.08	
MW-11		827.61	20.3	807.31	
MW-12		829.74	23.6	806.14	
MW-13D		814.29	21.1	793.19	
MW-21		834.56	33.5	801.06	
MW-22D		831.83	31.5	800.33	
MW-25D		821.52	19.6	801.92	
MW-29		816.51	23.6	792.91	
MW-30		823.47	21.7	801.77	
MW-31		823.00	17.5	805.50	
MW-32		809.85	18.2	791.65	
MW-33		819.37	20.1	799.27	
MW-34		815.37	19.7	795.67	
MW-35		820.34	22.6	797.74	
SPW		822.37	25.6	796.77	

GROUNDWATER ELEVATIONS
VILLAGE OF ENDICOTT

SAMPLED BY: V. Briga

DATE: 8/28/2008

Well No.	Time	(TOR) Elevation	Water Depth	Water Elevation	Comments
B-4					
B-21					
EW-3D		818.33	22.50	795.83	
EW-8		823.34	25.10	798.24	
EW-9		818.61	19.20	799.41	
EW-11					
EW-12		830.33	20.10	810.23	
EW-14		823.04	19.10	803.94	
MW-3		830.52	18.30	812.22	
MW-6D		826.55	27.20	799.35	
MW-8D					
MW-9D		832.07	19.10	812.97	
MW-7S		823.21	21.10	802.11	
MW-7D		823.28	21.20	802.08	
MW-11		827.61	22.30	805.31	
MW-12		829.74	24.20	805.54	
MW-13D		814.29	33.90	780.39	
MW-21		834.56	32.60	801.96	
MW-22D		831.83	21.40	810.43	
MW-25D		821.52	21.10	800.42	
MW-29		816.51	18.50	798.01	
MW-30		823.47	22.70	800.77	
MW-31		823.00	19.60	803.40	
MW-32		809.85	21.20	788.65	
MW-33		819.37	20.40	798.97	
MW-34		815.37	21.60	793.77	
MW-35		820.34	23.20	797.14	
SPW		822.37	26.40	795.97	

GROUNDWATER ELEVATIONS
VILLAGE OF ENDICOTT

SAMPLED BY: V. Briga

DATE: 9/23/2008

Well No.	Time	(TOR) Elevation	Water Depth	Water Elevation	Comments
B-4					
B-21					
EW-3D		818.33	27.9	790.43	
EW-8		823.34	27.2	796.14	
EW-9		818.61	22.1	796.51	
EW-11					
EW-12		830.33	25.1	805.23	
EW-14		823.04	25.6	797.44	
MW-3		830.52	22.9	807.62	
MW-6D		826.55	28.4	798.15	
MW-8D					
MW-9D		832.07	28.6	803.47	
MW-7S		823.21	23.9	799.31	
MW-7D		823.28	25.0	798.28	
MW-11		827.61	27.9	799.71	
MW-12		829.74	28.6	801.14	
MW-13D		814.29	16.1	798.19	
MW-21		834.56	34.8	799.76	
MW-22D		831.83	34.2	797.63	
MW-25D		821.52	22.3	799.22	
MW-29		816.51	15.7	800.81	
MW-30		823.47	27.9	795.57	
MW-31		823.00	27.4	795.60	
MW-32		809.85	13.7	796.15	
MW-33		819.37	25.7	793.67	
MW-34		815.37	26.1	789.27	
MW-35		820.34	24.5	795.84	
SPW		822.37	28.7	793.67	

Village of Endicott
Industrial Pretreatment Dept.
1009 E. Main St.
Endicott, New York 13760

October 1, 2008

Ms. Sherrel Henry
U.S. Environmental Protection Agency, Region II
Emergency & Remediation Response Division
290 Broadway
New York, New York 10007-1866

Re: Endicott Landfill
Operable Unit 2
Endicott, New York

Dear Ms. Henry:

Enclosed please find a copy of our quarterly Landfill Inspection Report (July, 2008 – September, 2008). The inspection was performed on September 19, 2008.

If you have any questions, please call me at 607-757-5307.

Sincerely,



Philip Grayson
Sewage Pretreatment Administrator

Cc: Mr. Payson Long, DEC
Mr. James Burke, P.E., DEC
Ms. Jean McCreary, EJ
Mr. Tom Morris, IBM
Mr. John Bernardo, Town of Union
Mayor Bertoni, Village of Endicott

POST CLOSURE INSPECTION FORM

Checklist

A. Capped Area

Capped area will be inspected by traversing the cover and observing for the following items:

	<u>No</u>	<u>Yes</u>
1. Is there bare, dead or damaged grassed area?	<u>X</u>	<u>—</u>
2. Is there evidence of cracks or subsidence?	<u>X</u>	<u>—</u>
3. Is there evidence of burrowing by animals?	<u>—</u>	<u>X</u>
4. Is there any deep-rooted vegetation present?	<u>X</u>	<u>—</u>
5. Is there any erosion damage to grassed areas?	<u>X</u>	<u>—</u>

Comments: (Required for each Yes answer)

At Monitoring Well #20 there
is evidence of burrowing
animals.

B. Paved Areas and Access Roads

The paved areas and access roads on the property will be inspected by traversing their entire length and observing for the following:

	<u>No</u>	<u>Yes</u>
1. Is there any erosion damage to road/paved surface?	<u>X</u>	<u>—</u>
2. Are there substantial potholes?	<u>X</u>	<u>—</u>
3. Is there evidence of cracks or subsidence?	<u>—</u>	<u>X</u>

Comments: (Required for each Yes answer)

There is subsidence and cracks in the
paved area located east of the
airport runway.

C. Site Drainage System

The drainage system will be inspected by traversing the full length of the system and examining for the following:

Over-Cover Drainage

No Yes

1. Is there any erosion damage to swales?
2. Is there any debris in swales?
3. Is there any sloughing of cap system?

X —
X —
X —

Perimeter Drainage

1. Is there any erosion damage to drainage ditch?
2. Is there any debris or sediment in drainage ditch?
3. Seeps Observed

X —
X —
X —

Comments: (Required for each Yes answer)

D. Monitoring Wells

Monitoring wells will be inspected for the following:

No Yes

1. Is there any damage to the lock or locking cap?
2. Is there any evidence of erosion of soils in the immediate area around the well casing?
3. Is concrete collar cracked or settled?

X —
X —
X —

Comments: (Required for each Yes answer)

E. Gas Vents

Gas vents will be inspected for the following:

- | | <u>No</u> | <u>Yes</u> |
|--|-----------|------------|
| 1. Is there any damage to the risers? | <u>X</u> | — |
| 2. Are any insert screens broken or missing? | <u>X</u> | — |

Comments: (Required for each Yes answer)

3. Description of Air Monitoring Activities (indicate readings)

F. Security

Site security of the facility will be inspected by examining the following items:

- | | <u>No</u> | <u>Yes</u> |
|--|-----------|------------|
| 1. Is there any damage to gates? | <u>X</u> | — |
| 2. Are there any damaged, missing or obstructed warning signs? | <u>X</u> | — |

Comments: (Required for each Yes answer)

Philip Grayson
Inspector

Philip Grayson
Signature

9/19/08
Date