



**New York State Department of  
Environmental Conservation**

**Site Number 7-09-009**

**Gladding Cordage Site Quarterly  
Report**

Second Quarter 2014

August 2014



Bruce Nelson, CPG  
Principal Geologist / Associate Vice President

Jeremy Wyckoff  
Staff Geologist

**Gladding Cordage Site  
Quarterly Report**

**Second Quarter 2014**

Site Number 7-09-009

Prepared for:  
New York State Department of  
Environmental Conservation

Prepared by:  
Malcolm Pirnie, Inc.  
855 Route 146  
Suite 210  
Clifton Park  
New York 12065  
Tel 518 250 7300  
Fax 518 250 7301

Our Ref.:  
00266406.0000

Date:  
August 2014

*Malcolm Pirnie, Inc. was acquired by  
ARCADIS in June 2009.*



## Table of Contents

<b>1. Introduction</b>	<b>1</b>
<b>2. Site Description</b>	<b>2</b>
<b>3. Operation and Maintenance</b>	<b>3</b>
3.1 Treatment Plant	3
3.1.1 Variable Frequency Drive	3
3.1.2 Treatment Plant Controls	3
3.1.3 Geothermal Heat Exchanger	4
3.2 Treatment Plant Operation	4
3.2.1 Treatment System Sampling	4
3.2.1.1 Influent Sample Results	5
3.2.1.2 Effluent Sample Results	5
<b>4. Groundwater Monitoring Program</b>	<b>6</b>
<b>5. Recommendations</b>	<b>7</b>
<b>6. Summary</b>	<b>8</b>
<b>7. References</b>	<b>9</b>

### Tables

Table 3-1	Treatment System Status and Flow Summary
Table 3-2	Groundwater Treatment System VOCs (Influent – RW-1)
Table 3-3	Groundwater Treatment System VOCs (Influent – RW-2)
Table 3-4	Summary of Groundwater Treatment System VOCs (Effluent)



## Table of Contents

### Figures

- Figure 2-1 Site Location
- Figure 2-2 Site Plan
- Figure 3-1 Treatment System Influent Sample Concentrations (1,1,1-TCA)

### Appendices

- A ProControl Daily Facsimile Reports
- B O&M Checklists and System Operation Logs
- C Analytical Reporting Forms



## **1. Introduction**

The New York State Department of Environmental Conservation (NYSDEC) has issued a Work Assignment (# D007618-9) to Malcolm Pirnie, Inc. (Malcolm Pirnie) for Operation, Maintenance, and Monitoring at the Gladding Cordage Site in New York State (Site # 7-09-009). This Quarterly Report has been prepared in accordance with the NYSDEC-approved Work Plan to summarize site activities.



## **2. Site Description**

The Gladding Cordage Site is located on Ridge Road, South Otselic, Chenango County, New York (Figure 2-1), along the western bank of the Otselic River. The site contains an active braided wire and rope manufacturing facility that has been in operation since 1892 (Figure 2-2).

### **3. Operation and Maintenance**

On August 23, 2007, NYSDEC provided a training session to Malcolm Pirnie personnel on the operation and maintenance (O&M) of the groundwater treatment plant at the Gladding Cordage Site. Since then, Malcolm Pirnie has maintained operation of the groundwater treatment plant. This includes the operation, maintenance, and influent/effluent sampling in accordance with the NYSDEC O&M manual (Operation and Maintenance Manual, Volume I, Gladding Cordage Site, Site 7-09-009, TAMS Consultants, Inc., 1996) (O&M Manual).

#### **3.1 Treatment Plant**

##### **3.1.1 Variable Frequency Drive**

A variable frequency drive (VFD) was installed on January 9, 2008 to regulate the speed of the air stripper blower motor. Following the installation of the VFD, effluent samples were collected at various blower motor frequencies (speeds) including 40 HZ, 50 HZ, and 60 HZ. The analyte 1,1,1-trichloroethane (1,1,1-TCA) was detected at 6 µg/l in the 40 HZ effluent sample but was not detected in the 50 HZ and 60 HZ samples. Following the completion of the January 9, 2008 sampling event the VFD was set to 50 HZ. Additional sampling was conducted in February 2008 to optimize the treatment system blower speed. Based on the results, the VFD setting was reduced to 42 HZ beginning in March 2008. The VFD setting is evaluated on a monthly basis. The current VFD setting (46 HZ) has been maintained since September 2010.

##### **3.1.2 Treatment Plant Controls**

In August 2011, the NYSDEC authorized construction and installation of a new treatment plant controls system. The new control system is designed to provide remote access to treatment plant operating parameters and improve reliability of the groundwater remediation system. The treatment plant was shut down to begin repairs and upgrades on January 30, 2012 by Aztech Technologies, Inc. (Aztech). The upgrades to the treatment system controls were completed and the treatment plant resumed operation on March 22, 2012. The treatment plant functions are controlled and monitored using an EOS Research Ltd. ProControl Programmable Logic Controller (PLC). The interface software allows remote connection to the PLC via analog phone line. The PLC and interface software also allows the treatment system to be started or stopped remotely. The PLC is programmed to send a facsimile with the status of various system inputs and outputs on a daily basis. If input and/or output

device signals exceed defined operating parameters, an alarm condition is set and the corresponding alarm information is sent via facsimile to the system user (i.e. Malcolm Pirnie).

### 3.1.3 Geothermal Heat Exchanger

The NYSDEC authorized the installation of a geothermal heat exchanger to provide climate control (heating and humidity) for the treatment system building. The treatment plant was shut down to begin installation of the geothermal heat exchanger on May 8, 2012 by Aztech. The geothermal heat exchanger installation and testing was completed on May 10, 2012. The heat-exchanger uses groundwater from the treatment plant as a geo-thermal energy source.

## 3.2 Treatment Plant Operation

As shown on PLC facsimile reports (Appendix A) and O&M Checklists (Appendix B), the Gladding Cordage groundwater treatment system had to be restarted manually during the April 10, 2014 site inspection. The system shut down was likely related to a power interruption, but no alarm faxes were sent to indicate an error. As indicated in the First Quarter 2014 Gladding Cordage O&M Report (Malcolm Pirnie, 2014), during the March 17, 2014 inspection, the cause of the problem was identified as a faulty battery in the uninterrupted power supply (UPS) for the PLC. The system also had to be restarted manually on April 23, 2014 due to a suspected power failure. However, as indicated on the April 23, 2014 O&M Checklist, a new UPS was installed. Following installation of the new UPS, the system only shut down for approximately three hours on May 16<sup>th</sup> and for approximately one day in June, with system restarts performed remotely.

The average monthly flow rates and total flow volumes are summarized in Table 3-1. As shown in Table 3-1, the average monthly flow rates from recovery wells RW-1 and RW-2 were each approximately 22 gpm. Based on the total flow values, approximately 4.8 million gallons of water were treated between April and June 2014.

### 3.2.1 Treatment System Sampling

Influent and effluent groundwater samples were collected from the Gladding Cordage treatment system in accordance with the Work Plan. The samples were submitted to Contest Analytical following chain-of-custody protocols for analysis of volatile organic



compounds (VOCs) by United States Environmental Protection Agency (USEPA) Method 624. Analytical Reporting Forms are provided in Appendix B.

#### *3.2.1.1 Influent Sample Results*

Table 3-2 and Table 3-3 summarize the previous year of influent VOC sample results from recovery wells RW-1 and RW-2, respectively. Figure 3-1 provides a summary of 1,1,1-TCA concentrations in samples from recovery wells RW-1 and RW-2 since September 2007. Tables 3-2 and 3-3, and Figure 3-1 show that the concentrations of 1,1,1-TCA in the May 2014 samples from recovery well RW-1 and RW-2 were 31 ug/L and 27 ug/L, respectively. These results were the lowest concentrations reported during the second quarter 2014 operating period and since January 2013. Tables 3-1 and 3-2 and Figure 3-1 show that the maximum concentrations of 1,1,1-TCA during the second quarter were reported in the June 2014 samples from RW-1 (43 ug/L) and the April 2014 samples from RW-2 (44 ug/L). As shown in Tables 3-1 and 3-2, these results exceed the corresponding NYSDEC Class GA Standard of 5 µg/L; however, Figure 3-1 shows that the concentrations are consistent with previous results.

As shown in Tables 3-2 and 3-3, 1,1-dichloroethene (1,1-DCE) and 1,1-dichloroethane (1,1-DCA) were detected in the influent samples from recovery wells RW-1 and RW-2. However, these concentrations were less than the applicable NYSDEC Class GA Standard of 5 µg/L. Tables 3-2 and 3-3 show that the 1,1-DCE and 1,1-DCA concentrations are consistent with previous results.

#### *3.2.1.2 Effluent Sample Results*

Table 3-4 summarizes laboratory analytical data for effluent samples collected from the treatment system. As shown in Table 3-4, no VOCs were detected in any of the second quarter 2014 effluent samples. Based on influent sample concentrations and total flow volumes from the Gladding Cordage treatment system, approximately 1.5 pounds of VOCs were removed by the treatment system during the second quarter, 2014.



#### **4. Groundwater Monitoring Program**

Groundwater samples were collected from the site during the fourth quarter 2013 in accordance with the Work Plan. The results of the sampling even were submitted in the fourth quarter 2013 Gladding Cordage Site Quarterly Report (Malcolm Pirnie, 2014b). The next groundwater sampling even is scheduled to take place during the first quarter 2015.



## **5. Recommendations**

No recommendations are suggested at this time.



## **6. Summary**

The Gladding Cordage groundwater treatment system was shut down for a total of 15 days in April, with no alarm conditions reported by the PLC. The UPS was replaced during the April 23, 2014 inspection, which resolved the communication problem with the PLC. The treatment system operated at approximately 99 percent and 97 percent during the months of May and June, respectively.

The average total flow through the treatment system between April and June 2014 was 44 GPM. No VOCs were detected in the first quarter 2014 effluent samples. Based on monthly influent and effluent sampling, the treatment successfully removes VOCs from groundwater extracted from the capture zone at the current VFD setting of 46 Hz. The VFD setting will continue to be evaluated based on system monitoring results. Approximately 1.5 pounds of VOCs were removed by the treatment system during the second quarter 2014.

Groundwater samples were collected in October 2013. The next monitoring event is scheduled for first quarter 2015.




## **7. References**

Malcolm Pirnie, 2007, Gladding Cordage Site Work Plan, Site 7-09-009, June, 2007.

Malcolm Pirnie, 2014a, Gladding Cordage Site Quarterly Report, Second Quarter 2014, Site 7-09-009, June, 2014.

Malcolm Pirnie, 2014b, Gladding Cordage Site Quarterly Report, Fourth Quarter 2013, Site 7-09-009, June, 2014.

TAMS Consultants, 1996, Operation and Maintenance Manual, Volume I, Gladding Cordage Site. Site 7-09-009.



SOURCE: U.S.G.S 7.5 MIN. SOUTH OTSELIC QUAD, 1988




NYSDEC STANDBY CONTRACT NO. D007618-9  
GLADDING CORDAGE – SITE NUMBER 7-09-009  
SOUTH OTSELIC, NEW YORK  
**SITE LOCATION**

**FIGURE 2-1**



Copyright © 2014 Esri, DeLorme, HERE, TomTom, Source: Esri, DigitalGlobe, GeoEye, swisstopo, and the GIS User Community

G:\GIS\MOD\0266365\SMP2013\Wells.mxd  
G:\PROJECT\00266406\0000\Reports\Figure 2-2.pdf



**Legend**

- ⊕ Monitoring Well
- ⊕ Recovery Well
- Approximate Site Boundary

NYSDEC STANDBY CONTRACT NO. D004443-5  
GLADDING CORDAGE SITE 7-09-009  
SOUTH OTSELIC, NEW YORK


**SITE PLAN**



FIGURE

**2-2**

Figure 3-1  
Treatment System Influent Sample Concentrations (1,1,1-TCA)  
Gladding Cordage Site  
NYSDEC Site Number 7-09-009





**TABLE 3-1  
TREATMENT SYSTEM STATUS AND FLOW SUMMARY  
GLADDING CORDAGE SITE  
SOUTH OTSELIC, NEW YORK  
NYSDEC SITE NO. 7-04-009A**

Date	System Operation (days)	System On-time (% of possible days)	Well On-time		Flow Rates		Totalizer		Recovery Well Total Flows		Total System Flow (gallons)	Quarterly Totals (gallons)
			RW-1 (% possible)	RW-2 (% possible)	RW-1 (gpm)	RW-2 (gpm)	RW-1 (gallons)	RW-2 (gallons)	RW-1 (gallons)	RW-2 (gallons)		
August-07	8 <sup>(1)</sup>	100%	100%	100%	38	24	-		437,760 <sup>(3)</sup>	276,480 <sup>(3)</sup>	714,240	3,435,840
September-07	30	100%	100%	100%	38	25	-		1,641,600 <sup>(3)</sup>	1,080,000 <sup>(3)</sup>	2,721,600	
October-07	20	65%	100%	100%	38.2	25.7	2,276,270		1,100,160 <sup>(3)</sup>	740,160 <sup>(3)</sup>	1,840,320	6,172,646
November-07	30	100%	67%	100%	39.9	24.9 <sup>(2)</sup>	3,235,110		958,840 <sup>(4)</sup>	1,075,680 <sup>(3)</sup>	2,034,520	
December-07	31	100%	39%	100%	31.8	24.9 <sup>(2)</sup>	4,421,380		1,186,270 <sup>(4)</sup>	1,111,536 <sup>(3)</sup>	2,297,806	
January-08	31	100%	100%	100%	31.8	24.9 <sup>(2)</sup>	5,278,000		856,620 <sup>(4)</sup>	1,111,536 <sup>(3)</sup>	1,968,156	5,503,499
February-08	26	90%	69%	88%	32	24.9 <sup>(2)</sup>	6,457,610		1,179,610 <sup>(4)</sup>	820,385 <sup>(3)</sup>	1,999,995	
March-08	23	74%	100%	100%	32.9	24.9 <sup>(2)</sup>	7,168,270		710,660 <sup>(4)</sup>	824,688 <sup>(3)</sup>	1,535,348	
April-08	30	100%	100%	100%	30.8	24.9 <sup>(2)</sup>	8,219,790		1,051,520 <sup>(4)</sup>	1,075,680 <sup>(3)</sup>	2,127,200	6,846,908
May-08	31	100%	100%	100%	31.3	24.9 <sup>(2)</sup>	9,458,370		1,238,580 <sup>(4)</sup>	1,111,536 <sup>(3)</sup>	2,350,116	
June-08	27	90%	100%	100%	30.5	24.9 <sup>(2)</sup>	10,859,850		1,401,480 <sup>(4)</sup>	968,112 <sup>(3)</sup>	2,369,592	
July-08	28	90%	68%	100%	30.1	24.9 <sup>(2)</sup>	11,889,440		1,029,590 <sup>(4)</sup>	1,003,968 <sup>(3)</sup>	2,033,558	6,201,456
August-08	28	90%	100%	100%	30	24.9 <sup>(2)</sup>	12,832,500		943,060 <sup>(4)</sup>	1,003,968 <sup>(3)</sup>	1,947,028	
September-08	30	100%	100%	100%	29.8	24.9 <sup>(2)</sup>	13,977,690		1,145,190 <sup>(4)</sup>	1,075,680 <sup>(3)</sup>	2,220,870	
October-08	31	100%	100%	100%	30	24.9 <sup>(2)</sup>	15,190,100		1,212,410 <sup>(4)</sup>	1,111,536 <sup>(3)</sup>	2,323,946	7,494,552
November-08	30	100%	100%	100%	31.7	24.9 <sup>(2)</sup>	16,722,470		1,532,370 <sup>(4)</sup>	1,075,680 <sup>(3)</sup>	2,608,050	
December-08	31	100%	100%	100%	31.3	24.9 <sup>(2)</sup>	18,173,490		1,451,020 <sup>(4)</sup>	1,111,536 <sup>(3)</sup>	2,562,556	
<b>Total Flow 2007</b>									<b>5,324,630</b>	<b>4,283,856</b>	<b>9,608,486</b>	
<b>Total Flow 2008</b>									<b>13,752,110</b>	<b>12,294,305</b>	<b>26,046,415</b>	

Notes:

- 1 - System started on 8/23/07.
  - 2 - Flow meter inoperative. Flow based on average flow from August, September, and October 2008.
  - 3 - Calculated based on percentage of system on-time, flow rate, and percentage of recovery well on-time.
  - 4 - Calculated from totalizer values.
- gpm - Gallons per minute

**TABLE 3-1  
TREATMENT SYSTEM STATUS AND FLOW SUMMARY  
GLADDING CORDAGE SITE  
SOUTH OTSELIC, NEW YORK  
NYSDEC SITE NO. 7-04-009A**

Date	System Operation (days)	System On-time (% of possible days)	Well On-time		Flow Rates		Totalizer	Totalizer	Recovery Well Total Flows		Total System Flow (gallons)	Quarterly Totals (gallons)
			RW-1 (% possible)	RW-2 (% possible)	RW-1 (gpm)	RW-2 (gpm)	RW-1 (gallons)	RW-2 (gallons)	RW-1 (gallons)	RW-2 (gallons)		
January-09	31	100%	100%	100%	31.3	24.9 <sup>(2)</sup>	19,566,200		1,392,710 <sup>(4)</sup>	1,111,536 <sup>(3)</sup>	2,504,246	6,931,910
February-09	28	100%	100%	100%	30.8	24.9 <sup>(2)</sup>	20,929,320		1,363,120 <sup>(4)</sup>	1,003,968 <sup>(3)</sup>	2,367,088	
March-09	31	100%	100%	100%	30.8	24.9 <sup>(2)</sup>	21,878,360		949,040 <sup>(4)</sup>	1,111,536 <sup>(3)</sup>	2,060,576	
April-09	30	100%	100%	100%	31.2	24.9 <sup>(2)</sup>	23,159,480		1,281,120 <sup>(4)</sup>	1,075,680 <sup>(3)</sup>	2,356,800	8,217,156
May-09	31	100%	100%	100%	31.5	24.9 <sup>(2)</sup>	25,128,390		1,968,910 <sup>(4)</sup>	1,111,536 <sup>(3)</sup>	3,080,446	
June-09	30	100%	100%	100%	31.1	24.9 <sup>(2)</sup>	26,832,620		1,704,230 <sup>(4)</sup>	1,075,680 <sup>(3)</sup>	2,779,910	
July-09	28	90%	100%	100%	30.4	24.9 <sup>(2)</sup>	27,568,640		736,020 <sup>(4)</sup>	1,003,968 <sup>(3)</sup>	1,739,988	5,833,432
August-09	29	94%	100%	100%	30.6	24.9 <sup>(2)</sup>	28,551,120		982,480 <sup>(4)</sup>	1,039,824 <sup>(3)</sup>	2,022,304	
September-09	30	100%	100%	100%	30.3	24.9 <sup>(2)</sup>	29,546,580		995,460 <sup>(4)</sup>	1,075,680 <sup>(3)</sup>	2,071,140	
October-09	20	65%	100%	100%	34.1	24.9 <sup>(2)</sup>	30,909,620		1,363,040 <sup>(4)</sup>	717,120 <sup>(3)</sup>	2,080,160	6,228,096
November-09	29	97%	100%	100%	31.7	24.9 <sup>(2)</sup>	31,775,760		866,140 <sup>(4)</sup>	1,039,824 <sup>(3)</sup>	1,905,964	
December-09	27	87%	100%	100%	33.7	24.9 <sup>(2)</sup>	33,049,620		1,273,860 <sup>(4)</sup>	968,112 <sup>(3)</sup>	2,241,972	
January-10	31	100%	100%	100%	29.2	24.9 <sup>(2)</sup>	34,376,810		1,327,190 <sup>(4)</sup>	1,111,536 <sup>(3)</sup>	2,438,726	7,478,090
February-10	28	100%	100%	100%	34.8	24.9 <sup>(2)</sup>	36,406,400		2,029,590 <sup>(4)</sup>	1,003,968 <sup>(3)</sup>	3,033,558	
March-10	31	100%	100%	100%	33	24.9 <sup>(2)</sup>	37,300,670		894,270 <sup>(4)</sup>	1,111,536 <sup>(3)</sup>	2,005,806	
April-10	26	87%	100%	100%	35.2	24.9 <sup>(2)</sup>	38,443,930		1,143,260 <sup>(4)</sup>	932,256 <sup>(3)</sup>	2,075,516	3,981,724
May-10	28	90%	36%	100%	35.2	24.9 <sup>(2)</sup>	38,734,170		290,240 <sup>(4)</sup>	1,003,968 <sup>(3)</sup>	1,294,208	
June-10	17	57%	0%	100%	0	25 <sup>(2)</sup>	38,734,170		0 <sup>(4)</sup>	612,000 <sup>(3)</sup>	612,000	
July-10	18	58%	0%	100%	0	24.9 <sup>(2)</sup>	NA		0 <sup>(3)</sup>	645,408 <sup>(3)</sup>	645,408	4,034,736
August-10	23	74%	0%	100%	0	24.9 <sup>(2)</sup>	NA		0 <sup>(3)</sup>	824,688 <sup>(3)</sup>	824,688	
September-10	30	100%	100%	100%	34.5 <sup>(2)</sup>	24.9 <sup>(2)</sup>	NA		1,488,960 <sup>(3)</sup>	1,075,680 <sup>(3)</sup>	2,564,640	
October-10	31	100%	100%	90%	33.4 <sup>(2)</sup>	24.9 <sup>(2)</sup>	NA		1,489,302 <sup>(3)</sup>	1,000,382 <sup>(3)</sup>	2,489,684	7,271,870
November-10	30	100%	100%	100%	33.4 <sup>(2)</sup>	24.9 <sup>(2)</sup>	NA		1,441,260 <sup>(3)</sup>	1,075,680 <sup>(3)</sup>	2,516,940	
December-10	27	87%	100%	100%	33.4 <sup>(2)</sup>	24.9 <sup>(2)</sup>	NA		1,297,134 <sup>(3)</sup>	968,112 <sup>(3)</sup>	2,265,246	
<b>Total Flow 2009</b>									<b>14,876,130</b>	<b>12,334,464</b>	<b>27,210,594</b>	
<b>Total Flow 2010</b>									<b>11,401,206</b>	<b>11,365,214</b>	<b>22,766,420</b>	

Notes:

- 1 - System started on 8/23/07.
  - 2 - Flow meter inoperative. Flow based on previous average flows or from manual tests.
  - 3 - Calculated based on percentage of system on-time, flow rate, and percentage of recovery well on-time.
  - 4 - Calculated from totalizer values.
- gpm - Gallons per minute

**TABLE 3-1  
TREATMENT SYSTEM STATUS AND FLOW SUMMARY  
GLADDING CORDAGE SITE  
SOUTH OTSELIC, NEW YORK  
NYSDEC SITE NO. 7-04-009A**

Date	System Operation (days)	System On-time (% of possible days)	Well On-time		Flow Rates		Totalizer		Recovery Well Total Flows		Total System Flow (gallons)	Quarterly Totals (gallons)
			RW-1 (% possible)	RW-2 (% possible)	RW-1 (gpm)	RW-2 (gpm)	RW-1 (gallons)	RW-2 (gallons)	RW-1 (gallons)	RW-2 (gallons)		
January-11	31	100%	100%	100%	33.4 <sup>(2)</sup>	24.9 <sup>(2)</sup>			1,489,302 <sup>(3)</sup>	1,111,536 <sup>(3)</sup>	2,600,838	6,292,350
February-11	20	71%	100%	100%	33.4 <sup>(2)</sup>	24.9 <sup>(2)</sup>			960,840 <sup>(3)</sup>	717,120 <sup>(3)</sup>	1,677,960	
March-11	24	77%	100%	100%	33.4 <sup>(2)</sup>	24.9 <sup>(2)</sup>			1,153,008 <sup>(3)</sup>	860,544 <sup>(3)</sup>	2,013,552	
April-11	27	90%	100%	100%	33.36 <sup>(2)</sup>	24.9 <sup>(2)</sup>			1,297,134 <sup>(3)</sup>	968,112 <sup>(3)</sup>	2,265,246	6,544,044
May-11	28	90%	100%	100%	33.36 <sup>(2)</sup>	24.9 <sup>(2)</sup>			1,345,176 <sup>(3)</sup>	1,003,968 <sup>(3)</sup>	2,349,144	
June-11	23	77%	100%	100%	33.36 <sup>(2)</sup>	24.9 <sup>(2)</sup>			1,104,966 <sup>(3)</sup>	824,688 <sup>(3)</sup>	1,929,654	
July-11	6	19%	100%	100%	33.4 <sup>(2)</sup>	24.9 <sup>(2)</sup>			288,576 <sup>(3)</sup>	215,136 <sup>(3)</sup>	503,712	5,592,514
August-11	31	100%	100%	100%	33.4 <sup>(2)</sup>	24.9 <sup>(2)</sup>			1,490,976 <sup>(3)</sup>	1,111,536 <sup>(3)</sup>	2,602,512	
September-11	30	100%	100%	97%	33.4 <sup>(2)</sup>	24.9 <sup>(2)</sup>			1,442,880 <sup>(3)</sup>	1,043,410 <sup>(3)</sup>	2,486,290	
October-11	28	90%	100%	54%	33.4 <sup>(2)</sup>	24.9 <sup>(2)</sup>			1,346,688 <sup>(3)</sup>	542,143 <sup>(3)</sup>	1,888,831	7,009,903
November-11	30	100%	100%	100%	33.4 <sup>(2)</sup>	24.9 <sup>(2)</sup>			1,442,880 <sup>(3)</sup>	1,075,680 <sup>(3)</sup>	2,518,560	
December-11	31	100%	100%	100%	33.4 <sup>(2)</sup>	24.9 <sup>(2)</sup>			1,490,976 <sup>(3)</sup>	1,111,536 <sup>(3)</sup>	2,602,512	
January-12	30	97%	100%	100%	22.7 <sup>(6)</sup>	18.0 <sup>(6)</sup>			980,640 <sup>(3)</sup>	777,600 <sup>(3)</sup>	1,758,240	2,311,830
February-12	0 <sup>(5)</sup>	0%	0%	0%	0	0	0	0	0	0	0	
March-12	10	32%	100%	100%	22.7	18.0	308,309	245,281	308,309 <sup>(4)</sup>	245,281 <sup>(4)</sup>	553,590	
April-12	30	100%	100%	100%	22.2	18.2	1,274,180	1,027,406	965,871 <sup>(4)</sup>	782,125 <sup>(4)</sup>	1,747,996	5,130,889
May-12	26	84%	100%	100%	22.8	20.3	2,156,600	1,773,905	882,420 <sup>(4)</sup>	746,499 <sup>(4)</sup>	1,628,919	
June-12	26	87%	100%	100%	23.6	19.9	3,100,285	2,584,194	943,685 <sup>(4)</sup>	810,289 <sup>(4)</sup>	1,753,974	
July-12	20	65%	100%	100%	23.8	19.7	3,770,411	3,157,520	670,126 <sup>(4)</sup>	573,326 <sup>(4)</sup>	1,243,452	5,540,244
August-12	31	100%	100%	100%	23.7	19.4	5,092,016	4,262,219	1,321,605 <sup>(4)</sup>	1,104,699 <sup>(4)</sup>	2,426,304	
September-12	30	100%	100%	100%	23.5	20.1	6,104,443	5,120,280	1,012,427 <sup>(4)</sup>	858,061 <sup>(4)</sup>	1,870,488	
October-12	16	52%	100%	100%	23.4	20.3	6,676,877	5,607,870	572,434 <sup>(4)</sup>	487,590 <sup>(4)</sup>	1,060,024	3,956,859
November-12	30	100%	100%	100%	23.6	19.6	7,769,986	6,536,938	1,093,109 <sup>(4)</sup>	929,068 <sup>(4)</sup>	2,022,177	
December-12	17	55%	100%	100%	24.3	19.7	8,250,333	6,931,249	480,347 <sup>(3)</sup>	394,311 <sup>(3)</sup>	874,658	
<b>Total Flow 2011</b>									<b>14,853,402</b>	<b>10,585,408</b>	<b>25,438,810</b>	
<b>Total Flow 2012</b>									<b>9,230,973</b>	<b>7,708,849</b>	<b>16,939,822</b>	

Notes:

- 1 - System started on 8/23/07.
  - 2 - Flow meter inoperative. Flow based on previous average flows or from manual tests.
  - 3 - Calculated based on percentage of system on-time, flow rate, and percentage of recovery well on-time.
  - 4 - Calculated from totalizer values.
  - 5 - System shut down for repairs.
  - 6 - Flow based on March 2012 PLC data.
- gpm - Gallons per minute

**TABLE 3-1  
TREATMENT SYSTEM STATUS AND FLOW SUMMARY  
GLADDING CORDAGE SITE  
SOUTH OTSELIC, NEW YORK  
NYSDEC SITE NO. 7-04-009A**

Date	System Operation (days)	System On-time (% of possible days)	Well On-time		Flow Rates		Totalizer		Recovery Well Total Flows		Total System Flow (gallons)	Quarterly Totals (gallons)
			RW-1 (% possible)	RW-2 (% possible)	RW-1 (gpm)	RW-2 (gpm)	RW-1 (gallons)	RW-2 (gallons)	RW-1 (gallons)	RW-2 (gallons)		
January-13	26	84%	100%	100%	23.1	19.5	9,140,834	7,699,661	890,501	768,412	1,658,913	5,239,914
February-13	28	100%	100%	100%	22.7	19.4	10,078,542	8,496,541	937,708	796,880	1,734,588	
March-13	31	100%	100%	100%	23.2	19.6	11,077,204	9,344,292	998,662	847,751	1,846,413	
April-13	27	90%	100%	100%	23.4	19.7	11,750,528	9,913,754	673,324	569,462	1,242,786	5,371,547
May-13	30	97%	100%	100%	24.2	19.4	12,984,742	10,944,208	1,234,214	1,030,454	2,264,668	
June-13	31	100%	100%	100%	23.2	19.6	14,002,162	11,790,881	1,017,420	846,673	1,864,093	
July-13	26	84%	100%	100%	23.8	19.3	14,893,234	12,513,473	891,072	722,592	1,613,664	4,241,225
August-13	19	61%	100%	100%	22.9	19.4	15,519,778	13,044,257	626,544	530,784	1,157,328	
September-13	20	67%	100%	100%	21.7	19.7	16,291,084	13,743,184	771,306	698,927	1,470,233	
October-13	13	42%	100%	100%	21.3	20.0	16,558,269	14,001,381	267,185	258,197	525,382	3,722,666
November-13	30	100%	100%	100%	21.6	22.6	17,493,334	14,962,574	935,065	961,193	1,896,258	
December-13	20	65%	100%	100%	21.3	22.3	18,132,181	15,624,753	638,847	662,179	1,301,026	
January-14	12	39%	100%	100%	22.2	22.9	18,507,983	16,012,662	375,802	387,909	763,711	2,680,630
February-14	14	50%	100%	100%	21.8	22.7	18,881,664	16,397,973	373,681	385,311	758,992	
March-14	17	55%	100%	100%	22.2	23.2	19,447,410	16,990,154	565,746	592,181	1,157,927	
April-14	15	50%	100%	100%	21.7	23.2	19,914,906	17,482,200	467,496	492,046	959,542	4,810,632
May-14	31	99%	100%	100%	21.8	22.5	20,883,319	18,490,607	968,413	1,008,407	1,976,820	
June-14	29	97%	100%	100%	21.4	21.6	21,800,646	19,447,550	917,327	956,943	1,874,270	
<b>Total Flow 2013</b>									<b>9,881,848</b>	<b>8,693,504</b>	<b>18,575,352</b>	
<b>Total Flow 2014</b>									<b>3,668,465</b>	<b>3,822,797</b>	<b>7,491,262</b>	

Notes:

- 1 - System started on 8/23/07.
  - 2 - Flow meter inoperative. Flow based on previous average flows or from manual tests.
  - 3 - Calculated based on percentage of system on-time, flow rate, and percentage of recovery well on-time.
  - 4 - Calculated from totalizer values.
  - 5 - System shut down for repairs.
  - 6 - Flow based on March 2012 PLC data.
- gpm - Gallons per minute

**TABLE 3-2**  
**GROUNDWATER TREATMENT SYSTEM VOCS (INFLUENT - RW-1)**  
**GLADDING CORDAGE**  
**SOUTH OTSELIC, NEW YORK**  
**NYSDEC Site No. 7-09-009**

Sample ID Sampling Date Matrix Units	NYSDEC Class GA Standard ug/L	RW-1 6/25/2013 WATER ug/L	RW-1 7/16/2013 WATER ug/L	RW-1 8/15/2013 WATER ug/L	RW-1 9/23/2013 WATER ug/L	RW-1 10/29/2013 WATER ug/L	RW-1 11/15/2013 WATER ug/L	RW-1 12/20/2013 WATER ug/L	RW-1 1/30/2014 WATER ug/L	RW-1 2/21/2014 WATER ug/L	RW-1 3/17/2014 WATER ug/L	RW-1 4/10/2014 WATER ug/L	RW-1 5/22/2014 WATER ug/L	RW-1 6/25/2014 WATER ug/L
<b>VOCs</b>														
1,1,1-Trichloroethane	5	48	51	46	43	53	40	42	47	45	50	42	31	43
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0	1.4	2.0	1.9	1.2	1.6
1,1-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	1.7	1.2	1.1	0.92	1.00	0.71	0.63
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Toluene	5	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	2.0 U	2.0 U	5.0 U	5.0 U	2.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
<b>Total VOCs</b>		48.0	51.0	46.0	43.0	53.0	40.0	43.7	50.2	47.5	52.9	44.9	32.9	45.2

  - Concentration exceeds corresponding NYSDEC  
Class GA Standard.

U - Not detected at the indicated concentration

J - Estimated concentration.

**TABLE 3-3  
GROUNDWATER TREATMENT SYSTEM VOCS (INFLUENT - RW-2)  
GLADDING CORDAGE  
SOUTH OTSELIC, NEW YORK  
NYSDEC Site No. 7-09-009**

Sample ID Sampling Date Matrix Units	NYSDEC Class GA Standard ug/L	RW-2 6/25/2013 WATER ug/L	RW-2 7/16/2013 WATER ug/L	RW-2 8/15/2013 WATER ug/L	RW-2 9/23/2013 WATER ug/L	RW-2 10/29/2013 WATER ug/L	RW-2 11/15/2013 WATER ug/L	RW-2 12/20/2013 WATER ug/L	RW-2 1/30/2014 WATER ug/L	RW-2 2/21/2014 WATER ug/L	RW-2 3/17/2014 WATER ug/L	RW-2 4/10/2014 WATER ug/L	RW-2 5/22/2014 WATER ug/L	RW-2 6/25/2014 WATER ug/L
<b>VOCS</b>														
1,1,1-Trichloroethane	5	42	58	42	50	49	36	35	46	51	57	44	27	38
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	0.77	1.0	0.9	1.3	1.2	0.57	0.81
1,1-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	0.69	0.97	0.8	1.0	0.88	0.63	0.62
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Toluene	5	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	2.0 U	2.0 U	5.0 U	5.0 U	2.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
<b>Total VOCs</b>		42.0	58.0	42.0	50.0	49.0	36.0	36.5	48.0	52.7	59.3	46.1	28.2	39.4

     - Concentration exceeds corresponding NYSDEC  
Class GA Standard.

U - Not detected at the indicated concentration

J - Estimated concentration.

**TABLE 3-4  
GROUNDWATER TREATMENT SYSTEM VOCS (EFFLUENT)  
GLADDING CORDAGE  
SOUTH OTSELIC, NEW YORK  
NYSDEC Site No. 7-09-009**

Sample ID Sampling Date Matrix Units	NYSDEC GA Standard ug/L	EFF(46HZ) 6/25/2013 WATER ug/L	EFF(46HZ) 7/16/2013 WATER ug/L	EFF(46HZ) 8/15/2013 WATER ug/L	EFF(46HZ) 9/23/2013 WATER ug/L	EFF(46HZ) 10/29/2013 WATER ug/L	EFF(46HZ) 11/15/2013 WATER ug/L	EFF(46HZ) 12/20/2013 WATER ug/L
<b>VOCS</b>								
1,1,1-Trichloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Toluene	5	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	2.0 U	2.0 U	5.0 U	5.0 U	2.0 U	5.0 U	5.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U

Notes

U - Not detected at the indicated concentration.

J - Estimated concentration.

**TABLE 3-4  
GROUNDWATER TREATMENT SYSTEM VOCS (EFFLUENT)  
GLADDING CORDAGE  
SOUTH OTSELIC, NEW YORK  
NYSDEC Site No. 7-09-009**

Sample ID Sampling Date Matrix Units	NYSDEC GA Standard ug/L	EFF(46HZ) 1/30/2014 WATER ug/L	EFF(46HZ) 2/21/2014 WATER ug/L	EFF(46HZ) 3/17/2014 WATER ug/L	EFF(46HZ) 4/10/2014 WATER ug/L	EFF(46HZ) 5/22/2014 WATER ug/L	EFF(46HZ) 6/25/2014 WATER ug/L
<b>VOCS</b>							
1,1,1-Trichloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Toluene	5	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	2.0 U	5.0 U	5.0 U	2.0 U	5.0 U	5.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U

Notes

U - Not detected at the indicated concentration.


J - Estimated concentration.





## **Appendix A**

ProControl Daily Facsimile Reports



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/01/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO P35 : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

## Analog Inputs:

W1_FLO is 21.8	GPM TOTAL FLOW is 19479118	GAL	
W2_FLO is 22.8	GPM TOTAL FLOW is 17023591	GAL	
ASBPRS is 11.0	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 261414	GAL	
HP_PRS is 1.6	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 36.43	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.27	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 52.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/02/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO P35 : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 22.0	GPM TOTAL FLOW is 19510769	GAL	
W2_FLO is 23.1	GPM TOTAL FLOW is 17057015	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 261922	GAL	
HP_PRS is 1.7	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 36.26	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.27	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 55.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/03/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO P35 : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVED is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 22.3	GPM TOTAL FLOW is 19542402	GAL	
W2_FLO is 23.2	GPM TOTAL FLOW is 17090458	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 2.44	GPM TOTAL FLOW is 262421	GAL	
HP_PRS is 9.1	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 4.79	AMP LIMITS are L: 0.00	AMP	H: . . . . .
W1_AMP is 4.45	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 36.56	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 57.39	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 54.8	DEG LIMITS are L: 42.0	DEG	H: 130.0

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/04/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO P35 : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACEFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACEFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 22.1	GPM TOTAL FLOW is 19574007	GAL	
W2_FLO is 23.4	GPM TOTAL FLOW is 17123891	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 262905	GAL	
HP_PRS is 1.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.64	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 36.00	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.93	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 56.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd. Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/05/2014  
 SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO P35 : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVED is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

**Analog Inputs:**

W1_FLO is 22.4	GPM TOTAL FLOW is 19605604	GAL	
W2_FLO is 23.7	GPM TOTAL FLOW is 17157319	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 263393	GAL	
HP_PRS is 1.7	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.65	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.91	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.14	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 56.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd. Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/06/2014  
 SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO P35 : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

**Analog Inputs:**

W1_FLO is 22.1	GPM TOTAL FLOW is 19637245	GAL	
W2_FLO is 23.1	GPM TOTAL FLOW is 17190759	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 264074	GAL	
HP_PRS is 1.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.64	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 36.11	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.97	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 55.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/07/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO P35 : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	


**Analog Inputs:**

W1_FLO is 21.9	GPM TOTAL FLOW is 19668812	GAL	
W2_FLO is 23.2	GPM TOTAL FLOW is 17224162	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 264575	GAL	
HP_PRS is 1.7	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.91	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.82	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 53.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN





# ProControl Series II+

EOS Research Ltd.

Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/24/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACEFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACEFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

**Analog Inputs:**

W1_FLO is 22.1	GPM TOTAL FLOW is 19725524	GAL	
W2_FLO is 22.9	GPM TOTAL FLOW is 17283682	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 265447	GAL	
HP_PRS is 1.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: ..... AMP
W1_AMP is 4.65	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.68	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.86	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.02	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 55.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/25/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACEFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVED is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACEFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 21.9	GPM TOTAL FLOW is 19757246	GAL	
W2_FLO is 22.8	GPM TOTAL FLOW is 17316819	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 265925	GAL	
HP_PRS is 1.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.47	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.84	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.91	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 54.2	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/26/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 21.9	GPM TOTAL FLOW is 19788862	GAL	
W2_FLO is 23.0	GPM TOTAL FLOW is 17349905	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 2.44	GPM TOTAL FLOW is 266211	GAL	
HP_PRS is 9.1	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 4.98	AMP LIMITS are L: 0.00	AMP	H: ..... AMP
W1_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.63	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.52	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.87	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 60.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/27/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 21.9	GPM TOTAL FLOW is 19820436	GAL	
W2_FLO is 23.4	GPM TOTAL FLOW is 17383001	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 266562	GAL	
HP_PRS is 1.7	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: ..... AMP
W1_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.65	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.75	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.85	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 56.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd. Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/28/2014  
 SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVED is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

**Analog Inputs:**

W1_FLO is 22.0	GPM TOTAL FLOW is 19851988	GAL	
W2_FLO is 22.9	GPM TOTAL FLOW is 17416089	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 266987	GAL	
HP_PRS is 1.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.87	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.83	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 55.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/29/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPOGO is ON	

## Analog Inputs:

W1_FLO is 22.1	GPM TOTAL FLOW is 19883444	GAL	
W2_FLO is 23.1	GPM TOTAL FLOW is 17449135	GAL	
ASBPRES is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 267265	GAL	
HP_PRS is 1.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.63	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.82	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.70	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 58.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/30/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMGO is ON	

## Analog Inputs:

W1_FLO is 22.0	GPM TOTAL FLOW is 19914906	GAL	
W2_FLO is 23.1	GPM TOTAL FLOW is 17482200	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 267646	GAL	
HP_PRS is 1.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.64	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.19	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.02	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 57.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/01/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	


## Analog Inputs:

W1_FLO is 21.7	GPM TOTAL FLOW is 19946404	GAL	
W2_FLO is 22.5	GPM TOTAL FLOW is 17515275	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 267958	GAL	
HP_PRS is 1.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.85	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.02	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 59.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN





# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/02/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 22.0	GPM TOTAL FLOW is 19977883	GAL	
W2_FLO is 22.5	GPM TOTAL FLOW is 17548338	GAL	
ASBP RS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 268212	GAL	
HP_PRS is 1.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.63	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.86	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.17	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 58.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/03/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

**Analog Inputs:**

W1_FLO is 22.0	GPM TOTAL FLOW is 20009364	GAL	
W2_FLO is 22.8	GPM TOTAL FLOW is 17581409	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 268503	GAL	
HP_PRS is 1.7	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.85	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.04	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 58.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EGS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/04/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACEFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACEFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 22.1	GPM	TOTAL FLOW is 20040837	GAL		
W2_FLO is 23.0	GPM	TOTAL FLOW is 17614449	GAL		
ASBPRS is 10.5	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 268784	GAL		
HP_PRS is 1.7	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: . . . . .	AMP
W1_AMP is 4.59	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.64	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.66	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.04	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.2	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.6	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 57.1	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/05/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 21.6	GPM TOTAL FLOW is 20072298	GAL	
W2_FLO is 22.8	GPM TOTAL FLOW is 17647467	GAL	
ASBP RS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 269137	GAL	
HP_PRS is 1.8	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . . . .
W1_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.84	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.96	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 57.6	DEG LIMITS are L: 42.0	DEG	H: 130.0

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/06/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

## Analog Inputs:

W1_FLO is 22.1	GPM TOTAL FLOW is 20103708	GAL	
W2_FLO is 23.0	GPM TOTAL FLOW is 17680471	GAL	
ASBPERS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 269453	GAL	
HP_PRS is 1.7	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . . . .
W1_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.75	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.89	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 57.4	DEG LIMITS are L: 42.0	DEG	H: 130.0

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/07/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPCGO is ON	

## Analog Inputs:

W1_FLO is 21.5	GPM TOTAL FLOW is 20135079	GAL	
W2_FLO is 22.6	GPM TOTAL FLOW is 17713395	GAL	
ASBPFRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 269777	GAL	
HP_PRS is 1.7	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.52	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.95	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.83	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 55.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/08/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VEDRST is OFF	HPHPGO is ON	

## Analog Inputs:

W1_FLO is 21.7	GPM TOTAL FLOW is 20166434	GAL	
W2_FLO is 22.7	GPM TOTAL FLOW is 17746249	GAL	
ASBP RS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 270031	GAL	
HP_PRS is 1.7	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.76	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.74	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 60.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd. Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/09/2014  
 SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACEFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACEFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	


**Analog Inputs:**

W1_FLO is 21.8	GPM TOTAL FLOW is 20197764	GAL	
W2_FLO is 22.4	GPM TOTAL FLOW is 17779052	GAL	
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 270136	GAL	
HP_PRS is 1.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.60	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.72	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 62.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN





# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/10/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 22.2	GPM TOTAL FLOW is 20229093	GAL	
W2_FLO is 23.0	GPM TOTAL FLOW is 17811842	GAL	
ASBPRS is 10.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 270225	GAL	
HP_PRS is 1.7	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: ..... AMP
W1_AMP is 4.64	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.46	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.79	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 64.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/11/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 21.6	GPM TOTAL FLOW is 20260442	GAL	
W2_FLO is 23.2	GPM TOTAL FLOW is 17844647	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 270348	GAL	
HP_PRS is 1.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.67	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.71	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.57	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.87	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 61.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/12/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASHPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 21.7	GPM TOTAL FLOW is 20291761	GAL	
W2_FLO is 22.6	GPM TOTAL FLOW is 17877444	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 270522	GAL	
HP_PRS is 1.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.58	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.79	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 61.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/13/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

**Analog Inputs:**

W1_FLO is 22.3	GPM TOTAL FLOW is 20323053	GAL	
W2_FLO is 22.7	GPM TOTAL FLOW is 17910242	GAL	
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 270702	GAL	
HP_PRS is 1.7	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: ..... AMP
W1_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.44	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.68	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 63.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/14/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMAGO is ON	

## Analog Inputs:

W1_FLO is 22.0	GPM TOTAL FLOW is 20354333	GAL	
W2_FLO is 22.6	GPM TOTAL FLOW is 17942985	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 271005	GAL	
HP_PRS is 1.6	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 36.04	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.20	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 62.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/15/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 21.7	GPM TOTAL FLOW is 20385741	GAL	
W2_FLO is 22.4	GPM TOTAL FLOW is 17975540	GAL	
ASBPRS is 10.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 271210	GAL	
HP_PRS is 1.7	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.09	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.63	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.64	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.25	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.46	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 64.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/16/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVED is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMAGO is ON	

## Analog Inputs:

W1_FLO is 21.9	GPM TOTAL FLOW is 20417081	GAL	
W2_FLO is 22.5	GPM TOTAL FLOW is 18007976	GAL	
ASBPRS is 10.1	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 271313	GAL	
HP_PRS is 1.7	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.09	AMP LIMITS are L: 0.00	AMP	H: ..... AMP
W1_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.65	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.21	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 64.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ALARM Fax Report

EOS Research Ltd.

ProControl Series II+

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 12:30:32 ON 05/16/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO P19 : LAST SHUTDOWN @ 21:49:45 ON 12/20/2013 BY ACFAIL  
FAX REPORT INITIATED BY PROCESS 18

## Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is ON	E_STOP is OFF		

## Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	


## Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 20425566	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 18016755	GAL	
ASBPRS is 0.0	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 271352	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 0.00	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 0.00	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 0.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN





# ALARM Fax Report

EOS Research Ltd.

ProControl Series II+

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 12:43:00 ON 05/16/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

MANUAL : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACFAIL  
FAX REPORT INITIATED BY PROCESS 19

## Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is ON	E_STOP is OFF		

## Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is OFF	

## Analog Inputs:

W1_FLO is 0.0	GPM	TOTAL FLOW is 20425566	GAL		
W2_FLO is 0.0	GPM	TOTAL FLOW is 18016755	GAL		
ASBPRES is 0.0	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 271352	GAL		
HP_PRS is 0.0	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.00	AMP	LIMITS are L: 0.00	AMP	H: . . . . .	AMP
W1_AMP is 0.00	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 0.00	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 0.00	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 0.00	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 0.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 0.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 0.0	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/17/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVED is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMGO is ON	

**Analog Inputs:**

W1_FLO is 22.0	GPM TOTAL FLOW is 20444973	GAL	
W2_FLO is 23.1	GPM TOTAL FLOW is 18036840	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 271567	GAL	
HP_PRS is 1.7	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . . . .
W1_AMP is 4.64	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.65	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 36.32	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 57.84	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.0	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 59.8	DEG LIMITS are L: 42.0	DEG	H: 130.0

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EGS Research Ltd. Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/18/2014  
 SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

**Analog Inputs:**

W1_FLO is 22.2	GPM	TOTAL FLOW is 20476627	GAL		
W2_FLO is 22.5	GPM	TOTAL FLOW is 18069532	GAL		
ASBPRS is 10.8	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 271855	GAL		
HP_PRS is 1.7	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: . . . . .	AMP
W1_AMP is 4.63	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.64	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 35.87	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 57.10	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.1	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.4	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 58.8	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/19/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACEFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACEFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 21.9	GPM	TOTAL FLOW is 20508174	GAL		
W2_FLO is 23.1	GPM	TOTAL FLOW is 18102131	GAL		
ASBPRS is 10.8	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 272173	GAL		
HP_PRS is 1.8	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: . . . . .	AMP
W1_AMP is 4.53	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.56	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 35.57	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.80	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.1	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.5	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 55.4	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/20/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACEFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACEFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

**Analog Inputs:**

W1_FLO is 21.3	GPM	TOTAL FLOW is 20539610	GAL		
W2_FLO is 22.3	GPM	TOTAL FLOW is 18134692	GAL		
ASBPERS is 10.7	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 272437	GAL		
HP_PRS is 1.8	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: . . . . .	AMP
W1_AMP is 4.51	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.54	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 35.29	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.50	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.2	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.5	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 57.5	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/21/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMAGO is ON	

## Analog Inputs:

W1_FLO is 21.6	GPM TOTAL FLOW is 20570972	GAL	
W2_FLO is 22.6	GPM TOTAL FLOW is 18167230	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 2.45	GPM TOTAL FLOW is 272599	GAL	
HP_PRS is 9.1	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 4.89	AMP LIMITS are L: 0.00	AMP	H: ..... AMP
W1_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.87	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.31	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 61.2	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd. Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/22/2014  
 SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

**Analog Inputs:**

W1_FLO is 21.8	GPM TOTAL FLOW is 20602297	GAL	
W2_FLO is 22.6	GPM TOTAL FLOW is 18199737	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 272719	GAL	
HP_PRS is 1.7	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.58	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.15	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 62.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd. Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/23/2014  
 SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	


**Analog Inputs:**

W1_FLO is 21.6	GPM TOTAL FLOW is 20633568	GAL	
W2_FLO is 22.2	GPM TOTAL FLOW is 18232246	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 272774	GAL	
HP_PRS is 1.7	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.09	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.65	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.54	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.06	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 62.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN





# ProControl Series II+

EGS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/24/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 21.5	GPM TOTAL FLOW is 20664857	GAL	
W2_FLO is 22.5	GPM TOTAL FLOW is 18264782	GAL	
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 272774	GAL	
HP_PRS is 1.7	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.09	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.64	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.65	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.70	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.06	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 61.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/25/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACEFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACEFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 21.9	GPM TOTAL FLOW is 20696125	GAL	
W2_FLO is 22.4	GPM TOTAL FLOW is 18297177	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 272794	GAL	
HP_PRS is 1.4	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.09	AMP LIMITS are L: 0.00	AMP	H: . . . . .
W1_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.70	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.98	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.0	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 59.1	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/26/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

**Analog Inputs:**

W1_FLO is 21.8	GPM	TOTAL FLOW is 20727349	GAL		
W2_FLO is 22.3	GPM	TOTAL FLOW is 18329484	GAL		
ASBPRS is 10.4	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 272878	GAL		
HP_PRS is 1.7	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . .	AMP
W1_AMP is 4.59	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.61	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.52	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.87	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.3	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 61.4	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/27/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACEFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACEFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

## Analog Inputs:

W1_FLO is 21.6	GPM	TOTAL FLOW is 20758541	GAL		
W2_FLO is 22.6	GPM	TOTAL FLOW is 18361746	GAL		
ASBPRS is 10.3	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 273073	GAL		
HP_PRS is 1.7	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . .	AMP
W1_AMP is 4.60	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.62	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.26	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.74	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.3	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 62.2	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/28/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

## Analog Inputs:

W1_FLO is 21.7	GPM	TOTAL FLOW is 20789741	GAL	
W2_FLO is 22.5	GPM	TOTAL FLOW is 18393988	GAL	
ASBPRS is 10.2	IWC	LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM	TOTAL FLOW is 273250	GAL	
HP_PRS is 1.4	PSI	LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . .
W1_AMP is 4.53	AMP	LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.54	AMP	LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.13	FT	LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.68	FT	LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 3.9	PSI	LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.3	PSI	LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 63.9	DEG	LIMITS are L: 42.0	DEG	H: 130.0

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/29/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACEFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACEFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

## Analog Inputs:

W1_FLO is 22.0	GPM	TOTAL FLOW is 20820947	GAL	
W2_FLO is 22.2	GPM	TOTAL FLOW is 18426247	GAL	
ASBPRS is 10.4	IWC	LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM	TOTAL FLOW is 273250	GAL	
HP_PRS is 1.7	PSI	LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . .
W1_AMP is 4.53	AMP	LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.55	AMP	LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.43	FT	LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.64	FT	LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.3	PSI	LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 61.4	DEG	LIMITS are L: 42.0	DEG	H: 130.0

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/30/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVED is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VEDRST is OFF	HPMPO is ON	

## Analog Inputs:

W1_FLO is 21.3	GPM	TOTAL FLOW is 20852141	GAL	
W2_FLO is 22.0	GPM	TOTAL FLOW is 18458452	GAL	
ASBPRS is 10.4	IWC	LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM	TOTAL FLOW is 273250	GAL	
HP_PRS is 1.5	PSI	LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . .
W1_AMP is 4.60	AMP	LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.61	AMP	LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.31	FT	LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.62	FT	LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.3	PSI	LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 60.9	DEG	LIMITS are L: 42.0	DEG	H: 130.0

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd. *Fax Report*

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/31/2014  
 SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

**Analog Inputs:**

W1_FLO is 21.4	GPM	TOTAL FLOW is 20883319	GAL		
W2_FLO is 22.3	GPM	TOTAL FLOW is 18490607	GAL		
ASBPRS is 10.6	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 273250	GAL		
HP_PRS is 1.4	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . .	AMP
W1_AMP is 4.60	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.62	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.35	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.58	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.3	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 59.2	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN





# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/01/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

## Analog Inputs:

W1_FLO is 21.6	GPM	TOTAL FLOW is 20914495	GAL		
W2_FLO is 22.3	GPM	TOTAL FLOW is 18522820	GAL		
ASBPRS is 10.7	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 273294	GAL		
HP_PRS is 1.5	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . .	AMP
W1_AMP is 4.59	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.62	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.42	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.53	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.1	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.5	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 59.1	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

ECS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/02/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMAGO is ON	

## Analog Inputs:

W1_FLO is 21.7	GPM	TOTAL FLOW is 20945623	GAL		
W2_FLO is 22.5	GPM	TOTAL FLOW is 18555003	GAL		
ASBPRS is 10.5	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 273461	GAL		
HP_PRS is 1.4	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . .	AMP
W1_AMP is 4.50	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.53	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.19	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.47	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.1	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.3	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 60.7	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/03/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVED is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

## Analog Inputs:

W1_FLO is 22.0	GPM	TOTAL FLOW is 20976686	GAL		
W2_FLO is 22.2	GPM	TOTAL FLOW is 18587073	GAL		
ASBPRS is 10.2	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 273757	GAL		
HP_PRS is 1.4	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . .	AMP
W1_AMP is 4.51	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.55	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.88	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.43	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.3	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 64.4	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/04/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM	TOTAL FLOW is 21007756	GAL	
W2_FLO is 22.6	GPM	TOTAL FLOW is 18619160	GAL	
ASBPRS is 10.4	IWC	LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM	TOTAL FLOW is 273899	GAL	
HP_PRS is 1.5	PSI	LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . .
W1_AMP is 4.56	AMP	LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.60	AMP	LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 33.89	FT	LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.60	FT	LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.3	PSI	LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 61.3	DEG	LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/05/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

**Analog Inputs:**

W1_FLO is 21.5	GPM TOTAL FLOW is 21038820	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 18651223	GAL	
ASBPRS is 10.2	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 273899	GAL	
HP_PRS is 1.7	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.09	AMP LIMITS are L: 0.00	AMP	H: . . . . .
W1_AMP is 4.47	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 33.64	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.49	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 3.9	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 61.3	DEG LIMITS are L: 42.0	DEG	H: 130.0

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/06/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVED is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

**Analog Inputs:**

W1_FLO is 21.5	GPM	TOTAL FLOW is 21069863	GAL		
W2_FLO is 22.6	GPM	TOTAL FLOW is 18683528	GAL		
ASBPRS is 10.3	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 273899	GAL		
HP_PRS is 1.4	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . .	AMP
W1_AMP is 4.55	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.57	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.75	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.43	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.3	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 62.4	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/07/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMGO is ON	

**Analog Inputs:**

W1_FLO is 21.5	GPM	TOTAL FLOW is 21100888	GAL	
W2_FLO is 22.5	GPM	TOTAL FLOW is 18715922	GAL	
ASBPRS is 10.6	IWC	LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 273971	GAL	
HP_PRS is 1.4	PSI	LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.52	AMP	LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.57	AMP	LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.87	FT	LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.43	FT	LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.4	PSI	LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 58.9	DEG	LIMITS are L: 42.0	DEG	H: 130.0 DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/08/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACEFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM	TOTAL FLOW is 21131833	GAL	
W2_FLO is 22.9	GPM	TOTAL FLOW is 18748389	GAL	
ASBPRS is 10.5	IWC	LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 274180	GAL	
HP_PRS is 1.4	PSI	LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.58	AMP	LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.61	AMP	LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.76	FT	LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.39	FT	LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.3	PSI	LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 59.8	DEG	LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN





# ProControl Series II+

EOS Research Ltd. Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/09/2014  
 SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVED is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

**Analog Inputs:**

W1_FLO is 21.7	GPM	TOTAL FLOW is 21162760	GAL	
W2_FLO is 22.7	GPM	TOTAL FLOW is 18780937	GAL	
ASBPRS is 10.2	IWC	LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM	TOTAL FLOW is 274340	GAL	
HP_PRS is 1.5	PSI	LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . .
W1_AMP is 4.51	AMP	LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.57	AMP	LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 33.98	FT	LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.64	FT	LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.3	PSI	LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 64.1	DEG	LIMITS are L: 42.0	DEG	H: 130.0

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# PROCONTROL Series II+

EGS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/10/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

## Analog Inputs:

W1_FLO is 21.5	GPM TOTAL FLOW is 21193723	GAL	
W2_FLO is 22.7	GPM TOTAL FLOW is 18813531	GAL	
ASBPRS is 10.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 274340	GAL	
HP_PRS is 1.7	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.09	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.52	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.97	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.58	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 64.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd. Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/11/2014  
 SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

**Analog Inputs:**

W1_FLO is 21.5	GPM	TOTAL FLOW is 21224644	GAL	
W2_FLO is 22.3	GPM	TOTAL FLOW is 18846100	GAL	
ASBPRS is 10.1	IWC	LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 274431	GAL	
HP_PRS is 1.4	PSI	LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.53	AMP	LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.58	AMP	LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.92	FT	LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.49	FT	LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 3.8	PSI	LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.1	PSI	LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 63.9	DEG	LIMITS are L: 42.0	DEG	H: 130.0 DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd. Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/12/2014  
 SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

**Analog Inputs:**

W1_FLO is 21.6	GPM	TOTAL FLOW is 21255594	GAL	
W2_FLO is 22.4	GPM	TOTAL FLOW is 18878653	GAL	
ASBPRS is 10.2	IWC	LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM	TOTAL FLOW is 274431	GAL	
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . .
W1_AMP is 4.56	AMP	LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.61	AMP	LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 33.91	FT	LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.51	FT	LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 3.8	PSI	LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 63.1	DEG	LIMITS are L: 42.0	DEG	H: 130.0

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/13/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

## Analog Inputs:

W1_FLO is 21.5	GPM	TOTAL FLOW is 21286540	GAL		
W2_FLO is 22.7	GPM	TOTAL FLOW is 18911209	GAL		
ASBPRS is 10.1	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 274431	GAL		
HP_PRS is 1.4	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . .	AMP
W1_AMP is 4.55	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.58	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.80	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.53	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.5	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.9	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 64.7	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EGS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/14/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACEFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACEFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 21.9	GPM	TOTAL FLOW is 21317533	GAL		
W2_FLO is 22.5	GPM	TOTAL FLOW is 18943835	GAL		
ASBPRS is 10.3	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 274440	GAL		
HP_PRS is 1.4	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . .	AMP
W1_AMP is 4.61	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.63	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.64	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.27	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.6	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 61.7	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd. Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/15/2014  
 SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VEDRST is OFF	HPMPO is ON	

**Analog Inputs:**

W1_FLO is 21.6	GPM	TOTAL FLOW is 21348544	GAL	
W2_FLO is 22.8	GPM	TOTAL FLOW is 18976499	GAL	
ASBPRS is 10.5	IWC	LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM	TOTAL FLOW is 274440	GAL	
HP_PRS is 1.4	PSI	LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . .
W1_AMP is 4.66	AMP	LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.68	AMP	LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.42	FT	LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.87	FT	LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 3.8	PSI	LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 60.8	DEG	LIMITS are L: 42.0	DEG	H: 130.0

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd. Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/16/2014  
 SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

**Analog Inputs:**

W1_FLO is 21.8	GPM TOTAL FLOW is 21379487	GAL	
W2_FLO is 22.7	GPM TOTAL FLOW is 19009137	GAL	
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 274549	GAL	
HP_PRS is 1.4	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.09	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.29	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.70	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 3.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 59.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN





# ProControl Series II+

EOS Research Ltd. Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/17/2014  
 SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACEFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVED is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACEFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

**Analog Inputs:**

W1_FLO is 21.3	GPM	TOTAL FLOW is 21410396	GAL	
W2_FLO is 22.5	GPM	TOTAL FLOW is 19041711	GAL	
ASBPRS is 10.2	IWC	LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 274767	GAL	
HP_PRS is 1.7	PSI	LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.51	AMP	LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.56	AMP	LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.09	FT	LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.58	FT	LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 3.7	PSI	LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 62.7	DEG	LIMITS are L: 42.0	DEG	H: 130.0 DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ALARM Fax Report

EOS Research Ltd.

ProControl Series II+

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 23:15:54 ON 06/17/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO P19 : LAST SHUTDOWN @ 12:40:32 ON 05/16/2014 BY ACFAIL  
FAX REPORT INITIATED BY PROCESS 18

## Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

## Analog Inputs:

W1_FLO is 0.0	GPM	TOTAL FLOW is 21432590	GAL		
W2_FLO is 0.0	GPM	TOTAL FLOW is 19065104	GAL		
ASBPRS is 0.4	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 275116	GAL		
HP_PRS is 1.0	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.11	AMP	LIMITS are L: 0.00	AMP	H: . . . . .	AMP
W1_AMP is 0.01	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 0.00	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 35.35	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.48	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 0.5	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 0.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 66.7	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ALARM Fax Report

EOS Research Ltd.

ProControl Series II+

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 23:37:00 ON 06/17/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

MANUAL : LAST SHUTDOWN @ 23:25:55 ON 06/17/2014 BY ACFAIL  
FAX REPORT INITIATED BY PROCESS 19

## Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is OFF	

## Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 21432590	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 19065104	GAL	
ASBPRS is 0.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 275117	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.10	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 0.01	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.67	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.61	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 65.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd. Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/19/2014  
 SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO P35 : LAST SHUTDOWN @ 23:25:55 ON 06/17/2014 BY ACFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

**Analog Inputs:**

W1_FLO is 21.6	GPM TOTAL FLOW is 21459875	GAL	
W2_FLO is 22.2	GPM TOTAL FLOW is 19093409	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 275247	GAL	
HP_PRS is 1.4	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.09	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.63	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.44	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.98	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 3.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 64.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/20/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO P35 : LAST SHUTDOWN @ 23:25:55 ON 06/17/2014 BY ACEFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACEFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 21.5	GPM	TOTAL FLOW is 21491100	GAL		
W2_FLO is 22.4	GPM	TOTAL FLOW is 19125843	GAL		
ASBPRS is 10.5	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 275395	GAL		
HP_PRS is 1.5	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . .	AMP
W1_AMP is 4.54	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.57	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.26	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.83	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.8	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.1	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 59.9	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/21/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO P35 : LAST SHUTDOWN @ 23:25:55 ON 06/17/2014 BY ACEFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACEFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 21.8	GPM TOTAL FLOW is 21522221	GAL	
W2_FLO is 22.4	GPM TOTAL FLOW is 19158231	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 275452	GAL	
HP_PRS is 1.6	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.09	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.05	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.72	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 58.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/22/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO P35 : LAST SHUTDOWN @ 23:25:55 ON 06/17/2014 BY ACEFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACEFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 22.1	GPM TOTAL FLOW is 21553290	GAL	
W2_FLO is 22.8	GPM TOTAL FLOW is 19190575	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 275607	GAL	
HP_PRS is 1.5	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.09	AMP LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.97	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.62	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 59.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/23/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO P35 : LAST SHUTDOWN @ 23:25:55 ON 06/17/2014 BY ACEFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACEFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 21.3	GPM	TOTAL FLOW is 21584319	GAL	
W2_FLO is 22.2	GPM	TOTAL FLOW is 19222896	GAL	
ASBPRS is 10.4	IWC	LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 275815	GAL	
HP_PRS is 1.6	PSI	LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.55	AMP	LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.57	AMP	LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.99	FT	LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.58	FT	LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.1	PSI	LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.3	PSI	LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 59.9	DEG	LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN





# ProControl Series II+

EOS Research Ltd.

Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/24/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO P35 : LAST SHUTDOWN @ 23:25:55 ON 06/17/2014 BY ACEFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACEFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

**Analog Inputs:**

W1_FLO is 21.4	GPM	TOTAL FLOW is 21615262	GAL		
W2_FLO is 22.5	GPM	TOTAL FLOW is 19255027	GAL		
ASBPRS is 10.2	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 276008	GAL		
HP_PRS is 1.4	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . .	AMP
W1_AMP is 4.54	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.57	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.91	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.47	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.3	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 64.7	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/25/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO P35 : LAST SHUTDOWN @ 23:25:55 ON 06/17/2014 BY ACFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

**Analog Inputs:**

W1_FLO is 21.6	GPM	TOTAL FLOW is 21646132	GAL	
W2_FLO is 22.1	GPM	TOTAL FLOW is 19287083	GAL	
ASBPRS is 10.0	IWC	LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 276158	GAL	
HP_PRS is 1.4	PSI	LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.53	AMP	LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.55	AMP	LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.76	FT	LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.47	FT	LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 3.8	PSI	LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.1	PSI	LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 64.9	DEG	LIMITS are L: 42.0	DEG	H: 130.0 DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/26/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO P35 : LAST SHUTDOWN @ 23:25:55 ON 06/17/2014 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVED is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

## Analog Inputs:

W1_FLO is 21.4	GPM	TOTAL FLOW is 21677065	GAL		
W2_FLO is 22.7	GPM	TOTAL FLOW is 19319184	GAL		
ASBPRS is 10.1	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 276425	GAL		
HP_PRS is 1.5	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . .	AMP
W1_AMP is 4.52	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.54	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.40	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.08	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.8	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.1	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 64.1	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/27/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO P35 : LAST SHUTDOWN @ 23:25:55 ON 06/17/2014 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVED is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

## Analog Inputs:

W1_FLO is 21.2	GPM	TOTAL FLOW is 21707995	GAL	
W2_FLO is 22.1	GPM	TOTAL FLOW is 19351303	GAL	
ASBPRS is 10.3	IWC	LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM	TOTAL FLOW is 276769	GAL	
HP_PRS is 1.7	PSI	LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . .
W1_AMP is 4.52	AMP	LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.55	AMP	LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.31	FT	LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.85	FT	LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 3.8	PSI	LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.1	PSI	LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 62.5	DEG	LIMITS are L: 42.0	DEG	H: 130.0

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

ECOS Research Ltd. *Fax Report*

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/28/2014  
 SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO P35 : LAST SHUTDOWN @ 23:25:55 ON 06/17/2014 BY ACFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMAGO is ON	

**Analog Inputs:**

W1_FLO is 21.5	GPM	TOTAL FLOW is 21738893	GAL	
W2_FLO is 22.1	GPM	TOTAL FLOW is 19383389	GAL	
ASBPRS is 10.4	IWC	LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 277270	GAL	
HP_PRS is 1.4	PSI	LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . . AMP
W1_AMP is 4.53	AMP	LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.54	AMP	LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.36	FT	LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.74	FT	LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 3.8	PSI	LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.1	PSI	LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 61.7	DEG	LIMITS are L: 42.0	DEG	H: 130.0 DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/29/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO P35 : LAST SHUTDOWN @ 23:25:55 ON 06/17/2014 BY ACEFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACEFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

## Analog Inputs:

W1_FLO is 21.7	GPM	TOTAL FLOW is 21769783	GAL		
W2_FLO is 22.5	GPM	TOTAL FLOW is 19415469	GAL		
ASBPRS is 10.3	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 277765	GAL		
HP_PRS is 1.7	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.09	AMP	LIMITS are L: 0.00	AMP	H: . . . . .	AMP
W1_AMP is 4.62	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.65	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.19	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.62	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.9	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.2	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 62.4	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

ECS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/30/2014  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO P35 : LAST SHUTDOWN @ 23:25:55 ON 06/17/2014 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

## Analog Inputs:

W1_FLO is 21.3	GPM TOTAL FLOW is 21800646	GAL	
W2_FLO is 22.4	GPM TOTAL FLOW is 19447550	GAL	
ASBPRS is 10.2	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 278402	GAL	
HP_PRS is 1.7	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.09	AMP LIMITS are L: 0.00	AMP	H: . . . . .
W1_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 33.96	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.58	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 3.9	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 65.1	DEG LIMITS are L: 42.0	DEG	H: 130.0

## Analog Outputs:

ASBSPD 0.0 PCT MAN



## **Appendix B**

O&M Checklists and System  
Operation Logs













## **Appendix C**

Analytical Reporting Forms

April 21, 2014

Jeremy Wyckoff  
Arcadis US, Inc. - Clifton Park-NY  
855 Route 146, Suite 210  
Clifton Park, NY 12065

Project Location: 00266406.0000-South Otselic, NY  
Client Job Number:  
Project Number: 00266406.0000  
Laboratory Work Order Number: 14D0477

Enclosed are results of analyses for samples received by the laboratory on April 12, 2014. If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Aaron L. Benoit  
Project Manager

Arcadis US, Inc. - Clifton Park-NY  
855 Route 146, Suite 210  
Clifton Park, NY 12065  
ATTN: Jeremy Wyckoff

REPORT DATE: 4/21/2014

PURCHASE ORDER NUMBER:

PROJECT NUMBER: 00266406.0000

**ANALYTICAL SUMMARY**

WORK ORDER NUMBER: 14D0477

The results of analyses performed on the following samples submitted to the CON-TEST Analytical Laboratory are found in this report.

PROJECT LOCATION: 00266406.0000-South Otselic, NY

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
RW-1	14D0477-01	Ground Water		EPA 624	
RW-2	14D0477-02	Ground Water		EPA 624	
EFF 46HZ	14D0477-03	Ground Water		EPA 624	
Trip Blank	14D0477-04	Trip Blank Water		EPA 624	

**CASE NARRATIVE SUMMARY**

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Con-Test Analytical Laboratory for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.

A handwritten signature in black ink, appearing to read "M. Erickson", is written on a light gray rectangular background.

Michael A. Erickson  
Laboratory Director





39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

Project Location: 00266406.0000-South Otselic, NY

Sample Description:

Work Order: 14D0477

Date Received: 4/12/2014

Field Sample #: RW-1

Sampled: 4/10/2014 13:40

Sample ID: 14D0477-01

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
1,1-Dichloroethane	1.9	2.0	0.16	µg/L	1	J	EPA 624	4/15/14	4/16/14 5:32	LBD
1,1-Dichloroethylene	1.0	2.0	0.21	µg/L	1	J	EPA 624	4/15/14	4/16/14 5:32	LBD
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
1,1,1-Trichloroethane	42	2.0	0.094	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	4/15/14	4/16/14 5:32	LBD
Surrogates		% Recovery	Recovery Limits			Flag/Qual				
1,2-Dichloroethane-d4		88.4	70-130						4/16/14 5:32	
Toluene-d8		102	70-130						4/16/14 5:32	
4-Bromofluorobenzene		101	70-130						4/16/14 5:32	



39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

Project Location: 00266406.0000-South Otselic, NY

Sample Description:

Work Order: 14D0477

Date Received: 4/12/2014

Field Sample #: RW-2

Sampled: 4/10/2014 13:45

Sample ID: 14D0477-02

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
1,1-Dichloroethane	1.2	2.0	0.16	µg/L	1	J	EPA 624	4/15/14	4/16/14 6:03	LBD
1,1-Dichloroethylene	0.88	2.0	0.21	µg/L	1	J	EPA 624	4/15/14	4/16/14 6:03	LBD
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
1,1,1-Trichloroethane	44	2.0	0.094	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	4/15/14	4/16/14 6:03	LBD
Surrogates		% Recovery	Recovery Limits			Flag/Qual				
1,2-Dichloroethane-d4		86.5	70-130						4/16/14 6:03	
Toluene-d8		101	70-130						4/16/14 6:03	
4-Bromofluorobenzene		99.7	70-130						4/16/14 6:03	

Project Location: 00266406.0000-South Otselic, NY

Sample Description:

Work Order: 14D0477

Date Received: 4/12/2014

Field Sample #: EFF 46HZ

Sampled: 4/10/2014 13:50

Sample ID: 14D0477-03

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	4/15/14	4/16/14 5:01	LBD
Surrogates		% Recovery	Recovery Limits			Flag/Qual				
1,2-Dichloroethane-d4		89.7	70-130						4/16/14 5:01	
Toluene-d8		101	70-130						4/16/14 5:01	
4-Bromofluorobenzene		101	70-130						4/16/14 5:01	

Project Location: 00266406.0000-South Otselic, NY

Sample Description:

Work Order: 14D0477

Date Received: 4/12/2014

Field Sample #: Trip Blank

Sampled: 4/10/2014 00:00

Sample ID: 14D0477-04

Sample Matrix: Trip Blank Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	4/15/14	4/16/14 4:30	LBD

Surrogates	% Recovery	Recovery Limits	Flag/Qual
1,2-Dichloroethane-d4	89.4	70-130	4/16/14 4:30
Toluene-d8	100	70-130	4/16/14 4:30
4-Bromofluorobenzene	99.2	70-130	4/16/14 4:30

**Sample Extraction Data**

**Prep Method: SW-846 5030B-EPA 624**

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
14D0477-01 [RW-1]	B093814	5	5.00	04/15/14
14D0477-02 [RW-2]	B093814	5	5.00	04/15/14
14D0477-03 [EFF 46HZ]	B093814	5	5.00	04/15/14
14D0477-04 [Trip Blank]	B093814	5	5.00	04/15/14

**QUALITY CONTROL**

**Volatile Organic Compounds by GC/MS - Quality Control**

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

**Batch B093814 - SW-846 5030B**

**Blank (B093814-BLK1)**

Prepared & Analyzed: 04/15/14

Benzene	ND	1.0	µg/L							
Bromodichloromethane	ND	2.0	µg/L							
Bromoform	ND	2.0	µg/L							
Bromomethane	ND	2.0	µg/L							
Carbon Tetrachloride	ND	2.0	µg/L							
Chlorobenzene	ND	2.0	µg/L							
Chlorodibromomethane	ND	2.0	µg/L							
Chloroethane	ND	2.0	µg/L							
2-Chloroethyl Vinyl Ether	ND	10	µg/L							
Chloroform	ND	2.0	µg/L							
Chloromethane	ND	2.0	µg/L							
1,2-Dichlorobenzene	ND	2.0	µg/L							
1,3-Dichlorobenzene	ND	2.0	µg/L							
1,4-Dichlorobenzene	ND	2.0	µg/L							
1,2-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethylene	ND	2.0	µg/L							
trans-1,2-Dichloroethylene	ND	2.0	µg/L							
1,2-Dichloropropane	ND	2.0	µg/L							
cis-1,3-Dichloropropene	ND	2.0	µg/L							
trans-1,3-Dichloropropene	ND	2.0	µg/L							
Ethylbenzene	ND	2.0	µg/L							
Methyl tert-Butyl Ether (MTBE)	ND	2.0	µg/L							
Methylene Chloride	ND	5.0	µg/L							
1,1,2,2-Tetrachloroethane	ND	2.0	µg/L							
Tetrachloroethylene	ND	2.0	µg/L							
Toluene	ND	1.0	µg/L							
1,1,1-Trichloroethane	ND	2.0	µg/L							
1,1,2-Trichloroethane	ND	2.0	µg/L							
Trichloroethylene	ND	2.0	µg/L							
Trichlorofluoromethane (Freon 11)	ND	2.0	µg/L							
Vinyl Chloride	ND	2.0	µg/L							
m+p Xylene	ND	2.0	µg/L							
o-Xylene	ND	2.0	µg/L							
Surrogate: 1,2-Dichloroethane-d4	21.2		µg/L	25.0		84.6	70-130			
Surrogate: Toluene-d8	25.4		µg/L	25.0		102	70-130			
Surrogate: 4-Bromofluorobenzene	25.3		µg/L	25.0		101	70-130			

**LCS (B093814-BS1)**

Prepared & Analyzed: 04/15/14

Benzene	12.2	1.0	µg/L	10.0		122	37-151			
Bromodichloromethane	8.38	2.0	µg/L	10.0		83.8	35-155			
Bromoform	6.68	2.0	µg/L	10.0		66.8	45-169			
Bromomethane	12.7	2.0	µg/L	10.0		127	20-242			
Carbon Tetrachloride	8.31	2.0	µg/L	10.0		83.1	70-140			
Chlorobenzene	11.2	2.0	µg/L	10.0		112	37-160			
Chlorodibromomethane	7.50	2.0	µg/L	10.0		75.0	53-149			
Chloroethane	9.63	2.0	µg/L	10.0		96.3	70-130			
2-Chloroethyl Vinyl Ether	98.9	10	µg/L	100		98.9	10-305			
Chloroform	10.9	2.0	µg/L	10.0		109	51-138			
Chloromethane	9.76	2.0	µg/L	10.0		97.6	20-273			
1,2-Dichlorobenzene	10.1	2.0	µg/L	10.0		101	18-190			
1,3-Dichlorobenzene	10.2	2.0	µg/L	10.0		102	59-156			

QUALITY CONTROL

Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
<b>Batch B093814 - SW-846 5030B</b>										
<b>LCS (B093814-BS1)</b>										
Prepared & Analyzed: 04/15/14										
1,4-Dichlorobenzene	9.86	2.0	µg/L	10.0		98.6	18-190			
1,2-Dichloroethane	9.24	2.0	µg/L	10.0		92.4	49-155			
1,1-Dichloroethane	11.0	2.0	µg/L	10.0		110	59-155			
1,1-Dichloroethylene	10.2	2.0	µg/L	10.0		102	20-234			
trans-1,2-Dichloroethylene	9.81	2.0	µg/L	10.0		98.1	54-156			
1,2-Dichloropropane	10.9	2.0	µg/L	10.0		109	20-210			
cis-1,3-Dichloropropene	9.42	2.0	µg/L	10.0		94.2	20-227			
trans-1,3-Dichloropropene	7.60	2.0	µg/L	10.0		76.0	17-183			
Ethylbenzene	10.9	2.0	µg/L	10.0		109	37-162			
Methyl tert-Butyl Ether (MTBE)	8.94	2.0	µg/L	10.0		89.4	70-130			
Methylene Chloride	9.15	5.0	µg/L	10.0		91.5	50-221			
1,1,2,2-Tetrachloroethane	11.2	2.0	µg/L	10.0		112	46-157			
Tetrachloroethylene	12.1	2.0	µg/L	10.0		121	64-148			
Toluene	11.6	1.0	µg/L	10.0		116	47-150			
1,1,1-Trichloroethane	9.06	2.0	µg/L	10.0		90.6	52-162			
1,1,2-Trichloroethane	11.6	2.0	µg/L	10.0		116	52-150			
Trichloroethylene	11.5	2.0	µg/L	10.0		115	71-157			
Trichlorofluoromethane (Freon 11)	10.3	2.0	µg/L	10.0		103	17-181			
Vinyl Chloride	10.3	2.0	µg/L	10.0		103	20-251			
m+p Xylene	21.6	2.0	µg/L	20.0		108	70-130			
o-Xylene	10.3	2.0	µg/L	10.0		103	70-130			
Surrogate: 1,2-Dichloroethane-d4	21.1		µg/L	25.0		84.3	70-130			
Surrogate: Toluene-d8	26.3		µg/L	25.0		105	70-130			
Surrogate: 4-Bromofluorobenzene	27.6		µg/L	25.0		111	70-130			

**FLAG/QUALIFIER SUMMARY**

- \* QC result is outside of established limits.
  - † Wide recovery limits established for difficult compound.
  - ‡ Wide RPD limits established for difficult compound.
  - # Data exceeded client recommended or regulatory level
- Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.  
No results have been blank subtracted unless specified in the case narrative section.
- J Detected but below the Reporting Limit (lowest calibration standard); therefore, result is an estimated concentration (CLP J-Flag).



**CERTIFICATIONS**

**Certified Analyses included in this Report**

Analyte	Certifications
<i>EPA 624 in Water</i>	
Benzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromodichloromethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromoform	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromomethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Carbon Tetrachloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chlorodibromomethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
2-Chloroethyl Vinyl Ether	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloroform	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloromethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,3-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,4-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
trans-1,2-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichloropropane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
cis-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
trans-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Ethylbenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Methyl tert-Butyl Ether (MTBE)	NC
Methylene Chloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,2,2-Tetrachloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Tetrachloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Toluene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,1-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,2-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Trichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Trichlorofluoromethane (Freon 11)	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Vinyl Chloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
m+p Xylene	CT,MA,NH,NY,RI,NC,VA,NJ
o-Xylene	CT,MA,NH,NY,RI,NC,VA,NJ

The CON-TEST Environmental Laboratory operates under the following certifications and accreditations:

Code	Description	Number	Expires
AIHA	AIHA-LAP, LLC	100033	02/1/2016
MA	Massachusetts DEP	M-MA100	06/30/2014
CT	Connecticut Department of Public Health	PH-0567	09/30/2015
NY	New York State Department of Health	10899 NELAP	04/1/2015
NH-S	New Hampshire Environmental Lab	2516 NELAP	02/5/2015
RI	Rhode Island Department of Health	LAO00112	12/30/2014
NC	North Carolina Div. of Water Quality	652	12/31/2014
NJ	New Jersey DEP	MA007 NELAP	06/30/2014
FL	Florida Department of Health	E871027 NELAP	06/30/2014
VT	Vermont Department of Health Lead Laboratory	LL015036	07/30/2014
WA	State of Washington Department of Ecology	C2065	02/23/2015
ME	State of Maine	2011028	06/9/2015
VA	Commonwealth of Virginia	460217	12/14/2014
NH-P	New Hampshire Environmental Lab	2557 NELAP	09/6/2014



**CON-TEST**  
ANALYTICAL LABORATORY

Phone: 413-525-2332  
Fax: 413-525-6405  
Email: info@contestlabs.com  
www.contestlabs.com

**CHAIN OF CUSTODY RECORD**

39 Spruce Street  
East Longmeadow, MA 01028

Page 1 of 1

Rev 04.05.12

14D0477

Company Name: APCADITS

Telephone: 518-250-7300

Address: 855 Route 146, STE 210

Project # 00266460000

Attention: Jeremy Wyckoff

Project Location: South Otselic, NY

Sampled By: J. Wyckoff

Project Proposal Provided? (for billing purposes)  
 Yes  No  
Proposal date

Client PO#

DATA DELIVERY (check all that apply)

FAX  EMAIL  WEBSITE

Fax #

Email: jerry.wyckoff@apcadits.com

Format  PDF  EXCEL  OGIS  OTHER NYSDDEC COMPLIANT

Collection

"Enhanced Data Package"

Con-Test Lab ID <small>(laboratory use only)</small>	Client Sample ID / Description	Beginning Date/Time	Ending Date/Time	Composite	Grab	*Matrix Code	Matrix Code	Analysis Requested
01	RW-1	4/10/14	1340	X		GW	M	X
02	RW-2	4/10/14	1345	X		GW	M	X
03	EFF 46HZ	4/10/14	1350	X		GW	L	X
04	TRIP Blank	4/10/14	-					X

Comments:

Please use the following codes to let Con-Test know if a specific sample may be high in concentration in Matrix/Conc. Code Box:

H - High; M - Medium; L - Low; C - Clean; U - Unknown

Relinquished by: (signature) *Jeremy Wyckoff*  
Date/Time: 4/10/14

Turnaround <sup>†</sup>  
 7-Day  
 10-0 Day  
 Other \_\_\_\_\_  
RUSH <sup>†</sup>

Detection Limit Requirements  
Mass constituents: \_\_\_\_\_  
Connecticut: \_\_\_\_\_  
Other: NY5 ASP CATTB

Is your project MCP or RCP?  
 MCP Form Required  
 RCP Form Required  
 MA State DW Form Required PWSID # \_\_\_\_\_

\*\*\*Container Co  
Dissolved Met  
 Field Filtered  
 Lab to Filter

Received by: (signature) *Jeremy Wyckoff*  
Date/Time: 4/10/14

Received by: (signature) *Jeremy Wyckoff*  
Date/Time: 4/10/14

Received by: (signature) \_\_\_\_\_  
Date/Time: \_\_\_\_\_

\*\*\*Cont. Code:  
A=amber glass  
G=glass  
P=plastic  
ST=sterile  
V=vial  
S=summa can  
T=tetlar bag  
O=Other

\*\*\*Preservation  
1=iced  
H=HCL  
M=Methanol  
N=Nitric Acid  
S=Sulfuric Acid  
B=Sodium bisulf  
X=Na hydroxide  
T=Na thiosulfate  
O=Other

Received by: (signature) \_\_\_\_\_  
Date/Time: \_\_\_\_\_

Received by: (signature) \_\_\_\_\_  
Date/Time: \_\_\_\_\_

Received by: (signature) \_\_\_\_\_  
Date/Time: \_\_\_\_\_

\*\*\*Matrix Code:  
GW=groundwater  
WW=wastewater  
DW=drinking water  
A=air  
S=soil/solid  
SL=sludge  
O=other

\*\*\*Cont. Code:  
A=amber glass  
G=glass  
P=plastic  
ST=sterile  
V=vial  
S=summa can  
T=tetlar bag  
O=Other

TURNAROUND TIME STARTS AT 9:00 A.M. THE DAY AFTER SAMPLE RECEIPT UNLESS THERE ARE QUESTIONS ON YOUR CHAIN. IF THIS FORM IS NOT FILLED OUT COMPLETELY OR IS INCORRECT, TURNAROUND TIME WILL NOT START UNTIL ALL QUESTIONS ARE ANSWERED BY OUR CLIENT. PLEASE BE CAREFUL NOT TO CONTAMINATE THIS DOCUMENT

APACADITS  
NELAC & AIHA-LAP, LLC  
Accredited  
WBE/DBE Certified


**901560238775**

 Ship (P/U) date  
**Fri 4/11/2014 4:42 pm**

CLIFTON PARK, NY US


**Delivered**
*Signed for by M. JONES*

 Actual delivery  
**Sat 4/12/2014 11:53 am**

East Longmeadow, MA US

Let us tell you when your shipment arrives. Sign up for delivery notifications


**Travel History**

Date/Time	Activity	Location
- 4/12/2014 - Saturday		
11 53 am	Delivered	East Longmeadow, MA
8 33 am	On FedEx vehicle for delivery	WINDSOR LOCKS, CT
8 24 am	At local FedEx facility	WINDSOR LOCKS, CT
6 56 am	At destination sort facility	EAST GRANBY, CT
3 43 am	Departed FedEx location	MEMPHIS, TN
- 4/11/2014 - Friday		
11 24 pm	Arrived at FedEx location	MEMPHIS, TN
8 34 pm	Left FedEx origin facility	MENANDS, NY
3 47 pm	Shipment information sent to FedEx	
4 42 pm	Picked up	MENANDS, NY

 Local Scan Time 
**Shipment Facts**

<b>Tracking number</b>	901560238775	<b>Service</b>	FedEx Priority Overnight
<b>Weight</b>	11 lbs	<b>Delivered To</b>	Shipping/Receiving
<b>Total pieces</b>	1	<b>Total shipment weight</b>	11 lbs / 4.99 kgs
<b>Shipper reference</b>	00266406 000015194-HUNZIKER LINDSAY	<b>Packaging</b>	Your Packaging
<b>Special handling section</b>	For Saturday Delivery		

39 Spruce St.  
 East Longmeadow, MA. 01028  
 P: 413-525-2332  
 F: 413-525-6405  
 www.contestlabs.com



### Sample Receipt Checklist

CLIENT NAME: Acadus RECEIVED BY: RUF DATE: 4/12/14

1) Was the chain(s) of custody relinquished and signed?  Yes No No CoC Included

2) Does the chain agree with the samples?  Yes No

If not, explain:

3) Are all the samples in good condition?  Yes No

If not, explain:

4) How were the samples received:

On Ice  Direct from Sampling  Ambient  In Cooler(s)

Were the samples received in Temperature Compliance of (2-6°C)?  Yes No N/A

Temperature °C by Temp blank \_\_\_\_\_ Temperature °C by Temp gun 4.4°C

5) Are there Dissolved samples for the lab to filter? Yes  No

Who was notified \_\_\_\_\_ Date \_\_\_\_\_ Time \_\_\_\_\_

6) Are there any RUSH or SHORT HOLDING TIME samples? Yes  No

Who was notified \_\_\_\_\_ Date \_\_\_\_\_ Time \_\_\_\_\_

7) Location where samples are stored:

19

Permission to subcontract samples? Yes No  
 (Walk-in clients only) if not already approved  
 Client Signature: \_\_\_\_\_

8) Do all samples have the proper Acid pH: Yes No  N/A

9) Do all samples have the proper Base pH: Yes No  N/A

10) Was the PC notified of any discrepancies with the CoC vs the samples: Yes No  N/A

### Containers received at Con-Test

	# of containers		# of containers
1 Liter Amber		8 oz amber/clear jar	
500 mL Amber		4 oz amber/clear jar	
250 mL Amber (8oz amber)		2 oz amber/clear jar	
1 Liter Plastic		Plastic Bag / Ziploc	
500 mL Plastic		SOC Kit	
250 mL plastic		Non-ConTest Container	
40 mL Vial - type listed below	<u>12</u>	Perchlorate Kit	
Colisure / bacteria bottle		Flashpoint bottle	
Dissolved Oxygen bottle		Other glass jar	
Encore		Other	

Laboratory Comments:

40 mL vials: # HCl 12 # Methanol \_\_\_\_\_  
 # Bisulfate \_\_\_\_\_ # DI Water \_\_\_\_\_  
 # Thiosulfate \_\_\_\_\_

Time and Date Frozen:

**Login Sample Receipt Checklist**  
**(Rejection Criteria Listing - Using Sample Acceptance Policy)**  
**Any False statement will be brought to the attention of Client**

<u>Question</u>	<u>Answer (True/False)</u>		<u>Comment</u>
	T	F/NA	
1) The cooler's custody seal, if present, is intact.	T		
2) The cooler or samples do not appear to have been compromised or tampered with.	T		
3) Samples were received on ice.	T		
4) Cooler Temperature is acceptable.	T		
5) Cooler Temperature is recorded.	T		
6) COC is filled out in ink and legible.	T		
7) COC is filled out with all pertinent information.	T		
8) Field Sampler's name present on COC.	T		
9) There are no discrepancies between the sample IDs on the container and the COC.	T		
10) Samples are received within Holding Time.	T		
11) Sample containers have legible labels.	T		
12) Containers are not broken or leaking.	T		
13) Air Cassettes are not broken/open.	NA		
14) Sample collection date/times are provided.	T		
15) Appropriate sample containers are used.	T		
16) Proper collection media used.	T		
17) No headspace sample bottles are completely filled.	T		
18) There is sufficient volume for all requested analyses, including any requested MS/MSDs.	T		
19) Trip blanks provided if applicable.	T		
20) VOA sample vials do not have head space or bubble is <6mm (1/4") in diameter.	T		
21) Samples do not require splitting or compositing.	T		

Doc #277 Rev. 4 August 2013

Who notified of False statements?  
 Log-In Technician Initials:

Date/Time:  
 Date/Time:

RLT 4/12/14 1153

May 30, 2014

Jeremy Wyckoff  
Arcadis US, Inc. - Clifton Park-NY  
855 Route 146, Suite 210  
Clifton Park, NY 12065

Project Location: South Otselic, NY  
Client Job Number:  
Project Number: 00266406.0000  
Laboratory Work Order Number: 14E0863

Enclosed are results of analyses for samples received by the laboratory on May 23, 2014. If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Aaron L. Benoit  
Project Manager

Arcadis US, Inc. - Clifton Park-NY  
855 Route 146, Suite 210  
Clifton Park, NY 12065  
ATTN: Jeremy Wyckoff

REPORT DATE: 5/30/2014

PURCHASE ORDER NUMBER:

PROJECT NUMBER: 00266406.0000

**ANALYTICAL SUMMARY**

WORK ORDER NUMBER: 14E0863

The results of analyses performed on the following samples submitted to the CON-TEST Analytical Laboratory are found in this report.

PROJECT LOCATION: South Otselic, NY

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
RW-1	14E0863-01	Ground Water		EPA 624	
RW-2	14E0863-02	Ground Water		EPA 624	
EFF46HZ	14E0863-03	Ground Water		EPA 624	
Trip Blank	14E0863-04	Trip Blank Water		EPA 624	



**CASE NARRATIVE SUMMARY**

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

**EPA 624**

**Qualifications:**

---

Laboratory fortified blank/laboratory control sample recovery is outside of control limits. Reported value for this compound is likely to be biased on the low side.

**Analyte & Samples(s) Qualified:**

**Chloroethane**

14E0863-01[RW-1], 14E0863-02[RW-2], 14E0863-03[EFF46HZ], 14E0863-04[Trip Blank], B096439-BLK1, B096439-BS1

---

The results of analyses reported only relate to samples submitted to the Con-Test Analytical Laboratory for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.



Daren J. Damboragian  
Laboratory Manager

Project Location: South Otselic, NY

Sample Description:

Work Order: 14E0863

Date Received: 5/23/2014

Field Sample #: RW-1

Sampled: 5/22/2014 14:00

Sample ID: 14E0863-01

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
Chloroethane	ND	2.0	0.16	µg/L	1	L-03	EPA 624	5/27/14	5/28/14 0:49	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
1,1-Dichloroethane	1.2	2.0	0.16	µg/L	1	J	EPA 624	5/27/14	5/28/14 0:49	MFF
1,1-Dichloroethylene	0.71	2.0	0.21	µg/L	1	J	EPA 624	5/27/14	5/28/14 0:49	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
1,1,1-Trichloroethane	31	2.0	0.094	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	5/27/14	5/28/14 0:49	MFF
Surrogates		% Recovery	Recovery Limits			Flag/Qual				
1,2-Dichloroethane-d4		97.5	70-130						5/28/14 0:49	
Toluene-d8		95.9	70-130						5/28/14 0:49	
4-Bromofluorobenzene		89.0	70-130						5/28/14 0:49	

Project Location: South Otselic, NY

Sample Description:

Work Order: 14E0863

Date Received: 5/23/2014

Field Sample #: RW-2

Sampled: 5/22/2014 14:05

Sample ID: 14E0863-02

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
								Prepared	Analyzed	
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
Chloroethane	ND	2.0	0.16	µg/L	1	L-03	EPA 624	5/27/14	5/28/14 1:21	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
1,1-Dichloroethane	0.57	2.0	0.16	µg/L	1	J	EPA 624	5/27/14	5/28/14 1:21	MFF
1,1-Dichloroethylene	0.63	2.0	0.21	µg/L	1	J	EPA 624	5/27/14	5/28/14 1:21	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
1,1,1-Trichloroethane	27	2.0	0.094	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	5/27/14	5/28/14 1:21	MFF
Surrogates	% Recovery		Recovery Limits		Flag/Qual					
1,2-Dichloroethane-d4	98.6		70-130						5/28/14 1:21	
Toluene-d8	96.4		70-130						5/28/14 1:21	
4-Bromofluorobenzene	89.2		70-130						5/28/14 1:21	



39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

Project Location: South Otselic, NY

Sample Description:

Work Order: 14E0863

Date Received: 5/23/2014

Field Sample #: EFF46HZ

Sampled: 5/22/2014 14:10

Sample ID: 14E0863-03

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
Chloroethane	ND	2.0	0.16	µg/L	1	L-03	EPA 624	5/27/14	5/28/14 0:18	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	5/27/14	5/28/14 0:18	MFF
Surrogates		% Recovery	Recovery Limits			Flag/Qual				
1,2-Dichloroethane-d4		99.6	70-130						5/28/14 0:18	
Toluene-d8		95.8	70-130						5/28/14 0:18	
4-Bromofluorobenzene		89.0	70-130						5/28/14 0:18	

Project Location: South Otselic, NY

Sample Description:

Work Order: 14E0863

Date Received: 5/23/2014

Field Sample #: Trip Blank

Sampled: 5/22/2014 00:00

Sample ID: 14E0863-04

Sample Matrix: Trip Blank Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
Chloroethane	ND	2.0	0.16	µg/L	1	L-03	EPA 624	5/27/14	5/27/14 23:47	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	5/27/14	5/27/14 23:47	MFF

Surrogates	% Recovery	Recovery Limits	Flag/Qual
1,2-Dichloroethane-d4	99.2	70-130	5/27/14 23:47
Toluene-d8	96.0	70-130	5/27/14 23:47
4-Bromofluorobenzene	88.8	70-130	5/27/14 23:47

**Sample Extraction Data**

**Prep Method: SW-846 5030B-EPA 624**

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
14E0863-01 [RW-1]	B096439	5	5.00	05/27/14
14E0863-02 [RW-2]	B096439	5	5.00	05/27/14
14E0863-03 [EFF46HZ]	B096439	5	5.00	05/27/14
14E0863-04 [Trip Blank]	B096439	5	5.00	05/27/14

QUALITY CONTROL

Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

Batch B096439 - SW-846 5030B

Blank (B096439-BLK1)

Prepared & Analyzed: 05/27/14

Benzene	ND	1.0	µg/L							
Bromodichloromethane	ND	2.0	µg/L							
Bromoform	ND	2.0	µg/L							
Bromomethane	ND	2.0	µg/L							
Carbon Tetrachloride	ND	2.0	µg/L							
Chlorobenzene	ND	2.0	µg/L							
Chlorodibromomethane	ND	2.0	µg/L							
Chloroethane	ND	2.0	µg/L							L-03
2-Chloroethyl Vinyl Ether	ND	10	µg/L							
Chloroform	ND	2.0	µg/L							
Chloromethane	ND	2.0	µg/L							
1,2-Dichlorobenzene	ND	2.0	µg/L							
1,3-Dichlorobenzene	ND	2.0	µg/L							
1,4-Dichlorobenzene	ND	2.0	µg/L							
1,2-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethylene	ND	2.0	µg/L							
trans-1,2-Dichloroethylene	ND	2.0	µg/L							
1,2-Dichloropropane	ND	2.0	µg/L							
cis-1,3-Dichloropropene	ND	2.0	µg/L							
trans-1,3-Dichloropropene	ND	2.0	µg/L							
Ethylbenzene	ND	2.0	µg/L							
Methyl tert-Butyl Ether (MTBE)	ND	2.0	µg/L							
Methylene Chloride	ND	5.0	µg/L							
1,1,2,2-Tetrachloroethane	ND	2.0	µg/L							
Tetrachloroethylene	ND	2.0	µg/L							
Toluene	ND	1.0	µg/L							
1,1,1-Trichloroethane	ND	2.0	µg/L							
1,1,2-Trichloroethane	ND	2.0	µg/L							
Trichloroethylene	ND	2.0	µg/L							
Trichlorofluoromethane (Freon 11)	ND	2.0	µg/L							
Vinyl Chloride	ND	2.0	µg/L							
m+p Xylene	ND	2.0	µg/L							
o-Xylene	ND	2.0	µg/L							
Surrogate: 1,2-Dichloroethane-d4	24.3		µg/L	25.0		97.2	70-130			
Surrogate: Toluene-d8	24.0		µg/L	25.0		96.1	70-130			
Surrogate: 4-Bromofluorobenzene	22.4		µg/L	25.0		89.8	70-130			

LCS (B096439-BS1)

Prepared & Analyzed: 05/27/14

Benzene	8.84	1.0	µg/L	10.0		88.4	37-151			
Bromodichloromethane	8.97	2.0	µg/L	10.0		89.7	35-155			
Bromoform	9.07	2.0	µg/L	10.0		90.7	45-169			
Bromomethane	11.1	2.0	µg/L	10.0		111	20-242			
Carbon Tetrachloride	8.30	2.0	µg/L	10.0		83.0	70-140			
Chlorobenzene	10.5	2.0	µg/L	10.0		105	37-160			
Chlorodibromomethane	9.89	2.0	µg/L	10.0		98.9	53-149			
<b>Chloroethane</b>	6.99	2.0	µg/L	10.0		<b>69.9</b> *	70-130			L-03
2-Chloroethyl Vinyl Ether	101	10	µg/L	100		101	10-305			
Chloroform	8.86	2.0	µg/L	10.0		88.6	51-138			
Chloromethane	6.50	2.0	µg/L	10.0		65.0	20-273			
1,2-Dichlorobenzene	10.6	2.0	µg/L	10.0		106	18-190			
1,3-Dichlorobenzene	10.5	2.0	µg/L	10.0		105	59-156			

**QUALITY CONTROL**

**Volatile Organic Compounds by GC/MS - Quality Control**

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
<b>Batch B096439 - SW-846 5030B</b>										
<b>LCS (B096439-BS1)</b>										
Prepared & Analyzed: 05/27/14										
1,4-Dichlorobenzene	10.4	2.0	µg/L	10.0		104	18-190			
1,2-Dichloroethane	9.46	2.0	µg/L	10.0		94.6	49-155			
1,1-Dichloroethane	8.55	2.0	µg/L	10.0		85.5	59-155			
1,1-Dichloroethylene	7.96	2.0	µg/L	10.0		79.6	20-234			
trans-1,2-Dichloroethylene	9.41	2.0	µg/L	10.0		94.1	54-156			
1,2-Dichloropropane	9.21	2.0	µg/L	10.0		92.1	20-210			
cis-1,3-Dichloropropene	8.45	2.0	µg/L	10.0		84.5	20-227			
trans-1,3-Dichloropropene	8.11	2.0	µg/L	10.0		81.1	17-183			
Ethylbenzene	10.4	2.0	µg/L	10.0		104	37-162			
Methyl tert-Butyl Ether (MTBE)	8.86	2.0	µg/L	10.0		88.6	70-130			
Methylene Chloride	12.4	5.0	µg/L	10.0		124	50-221			
1,1,2,2-Tetrachloroethane	10.4	2.0	µg/L	10.0		104	46-157			
Tetrachloroethylene	10.2	2.0	µg/L	10.0		102	64-148			
Toluene	9.67	1.0	µg/L	10.0		96.7	47-150			
1,1,1-Trichloroethane	8.44	2.0	µg/L	10.0		84.4	52-162			
1,1,2-Trichloroethane	9.89	2.0	µg/L	10.0		98.9	52-150			
Trichloroethylene	9.53	2.0	µg/L	10.0		95.3	71-157			
Trichlorofluoromethane (Freon 11)	9.29	2.0	µg/L	10.0		92.9	17-181			
Vinyl Chloride	7.29	2.0	µg/L	10.0		72.9	20-251			
m+p Xylene	21.2	2.0	µg/L	20.0		106	70-130			
o-Xylene	10.3	2.0	µg/L	10.0		103	70-130			
Surrogate: 1,2-Dichloroethane-d4	23.5		µg/L	25.0		94.2	70-130			
Surrogate: Toluene-d8	24.6		µg/L	25.0		98.4	70-130			
Surrogate: 4-Bromofluorobenzene	24.0		µg/L	25.0		95.8	70-130			



**FLAG/QUALIFIER SUMMARY**

- \* QC result is outside of established limits.
  - † Wide recovery limits established for difficult compound.
  - ‡ Wide RPD limits established for difficult compound.
  - # Data exceeded client recommended or regulatory level
- Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.  
No results have been blank subtracted unless specified in the case narrative section.
- J Detected but below the Reporting Limit (lowest calibration standard); therefore, result is an estimated concentration (CLP J-Flag).
  - L-03 Laboratory fortified blank/laboratory control sample recovery is outside of control limits. Reported value for this compound is likely to be biased on the low side.

**CERTIFICATIONS**

**Certified Analyses included in this Report**

Analyte	Certifications
<i>EPA 624 in Water</i>	
Benzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromodichloromethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromoform	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromomethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Carbon Tetrachloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chlorodibromomethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
2-Chloroethyl Vinyl Ether	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloroform	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloromethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,3-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,4-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
trans-1,2-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichloropropane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
cis-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
trans-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Ethylbenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Methyl tert-Butyl Ether (MTBE)	NC
Methylene Chloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,2,2-Tetrachloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Tetrachloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Toluene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,1-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,2-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Trichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Trichlorofluoromethane (Freon 11)	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Vinyl Chloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
m+p Xylene	CT,MA,NH,NY,RI,NC,VA,NJ
o-Xylene	CT,MA,NH,NY,RI,NC,VA,NJ

The CON-TEST Environmental Laboratory operates under the following certifications and accreditations:

Code	Description	Number	Expires
AIHA	AIHA-LAP, LLC	100033	02/1/2016
MA	Massachusetts DEP	M-MA100	06/30/2014
CT	Connecticut Department of Public Health	PH-0567	09/30/2015
NY	New York State Department of Health	10899 NELAP	04/1/2015
NH-S	New Hampshire Environmental Lab	2516 NELAP	02/5/2015
RI	Rhode Island Department of Health	LAO00112	12/30/2014
NC	North Carolina Div. of Water Quality	652	12/31/2014
NJ	New Jersey DEP	MA007 NELAP	06/30/2014
FL	Florida Department of Health	E871027 NELAP	06/30/2014
VT	Vermont Department of Health Lead Laboratory	LL015036	07/30/2014
WA	State of Washington Department of Ecology	C2065	02/23/2015
ME	State of Maine	2011028	06/9/2015
VA	Commonwealth of Virginia	460217	12/14/2014
NH-P	New Hampshire Environmental Lab	2557 NELAP	09/6/2014



**CON-TEST**

ANALYTICAL LABORATORY

Phone: 413-525-2332  
Fax: 413-525-6405  
Email: info@contestlabs.com  
www.contestlabs.com

**CHAIN OF CUSTODY RECORD**

39 Spruce Street  
East Longmeadow, MA 01028

Rev 04.05.12

Company Name: **ARCA DES**

Telephone: **518-250-7300**

Address: **855 Route 146, Ste 218**

Project # **00266406.0000**

Attention: **Jeremy Wyckoff**

Client PO#

Project Location: **S. Otselee, NY**

DATA DELIVERY (check all that apply)  
 FAX  EMAIL  WEBSITE

Sampled By: **T. Wyckoff**

Format

PDF  EXCEL  OGIS  
 OTHER **DocSign**

Project Proposal Provided? (for billing purposes)  
 Yes  No

Con-Test Lab ID

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite Grab

\*Matrix Code

Sample Code

Matrix Code

Matrix Code

Matrix Code

Matrix Code

Matrix Code

01 RW-1

Start/14

1400

X

GW

M

X

02 RW-2

1410

X

X

M

X

03 EFF 46HZ

1410

X

X

L

X

04 TEIP Blask

-

X

X

-

X

Comments:

Please use the following codes to let Con-Test know if a specific sample may be high in concentration in Matrix/Conc. Code Box:

H - High; M - Medium; L - Low; C - Clean; U - Unknown

Relinquished by: (signature) *[Signature]*

Date/Time: **5/24/14**

Turnaround  7-Day  10-Day  Other

Detection Limit Requirements

Massachusetts: \_\_\_\_\_

Is your project MCP or RCP?  MCP Form Required  RCP Form Required  MA State DW Form Required  PWSID # \_\_\_\_\_

\*Matrix Code: GW = groundwater WW = wastewater DW = drinking water A = air S = soil/solid SL = sludge O = other

Relinquished by: (signature) *[Signature]*

Date/Time: **5:23:14**

Turnaround  7-Day  10-Day  Other

Detection Limit Requirements

Massachusetts: \_\_\_\_\_

Is your project MCP or RCP?  MCP Form Required  RCP Form Required  MA State DW Form Required  PWSID # \_\_\_\_\_

\*Matrix Code: GW = groundwater WW = wastewater DW = drinking water A = air S = soil/solid SL = sludge O = other

Received by: (signature) *[Signature]*

Date/Time: **9:34**

Turnaround  7-Day  10-Day  Other

Detection Limit Requirements

Massachusetts: \_\_\_\_\_

Is your project MCP or RCP?  MCP Form Required  RCP Form Required  MA State DW Form Required  PWSID # \_\_\_\_\_

\*Matrix Code: GW = groundwater WW = wastewater DW = drinking water A = air S = soil/solid SL = sludge O = other

† TURNAROUND TIME STARTS AT 9:00 A.M. THE DAY AFTER SAMPLE RECEIPT UNLESS THERE ARE QUESTIONS ON YOUR CHAIN. IF THIS FORM IS NOT FILLED OUT COMPLETELY OR IS INCORRECT, TURNAROUND TIME WILL NOT START UNTIL ALL QUESTIONS ARE ANSWERED BY OUR CLIENT. PLEASE BE CAREFUL NOT TO CONTAMINATE THIS DOCUMENT.



803029861254

Ship (P/U) date :  
Thur 5/22/2014 4:41 pm



Actual delivery :  
Fri 5/23/2014 9:34 am

CLI US

MA US

**Delivered**

Signed for by: P BLAKE

**Travel History**

▲ Date/Time	Activity	Location
- 5/23/2014 - Friday		
9:34 am	Delivered	MA
8:12 am	On FedEx vehicle for delivery	WINDSOR LOCKS, CT
7:49 am	At local FedEx facility	WINDSOR LOCKS, CT
2:10 am	Departed FedEx location	NEWARK, NJ
12:49 am	In transit	NEWARK, NJ
12:06 am	Arrived at FedEx location	NEWARK, NJ
- 5/22/2014 - Thursday		
7:21 pm	Left FedEx origin facility	BINGHAMTON, NY
4:41 pm	Picked up	BINGHAMTON, NY

Local Scan Time

**Shipment Facts**

Tracking number	803029861254	Service	FedEx Priority Overnight
Weight	11 lbs	Delivered To	Receptionist/Front Desk
Total pieces	1	Total shipment weight	11 lbs / 4.99 kgs
Shipper reference	00266406 0000	Packaging	Your Packaging
Special handling section	Deliver Weekday		

39 Spruce St.  
 East Longmeadow, MA. 01028  
 P: 413-525-2332  
 F: 413-525-6405  
 www.contestlabs.com



### Sample Receipt Checklist

CLIENT NAME: Arcadis RECEIVED BY: PB DATE: 5.23.14

- 1) Was the chain(s) of custody relinquished and signed?  Yes  No  No CoC Included
- 2) Does the chain agree with the samples?  Yes  No  
 If not, explain: \_\_\_\_\_
- 3) Are all the samples in good condition?  Yes  No  
 If not, explain: \_\_\_\_\_
- 4) How were the samples received:  
 On Ice  Direct from Sampling  Ambient  In Cooler(s)
- Were the samples received in Temperature Compliance of (2-6°C)?  Yes  No  N/A  
 Temperature °C by Temp blank \_\_\_\_\_ Temperature °C by Temp gun 3.5
- 5) Are there Dissolved samples for the lab to filter? Yes  No   
 Who was notified \_\_\_\_\_ Date \_\_\_\_\_ Time \_\_\_\_\_
- 6) Are there any RUSH or SHORT HOLDING TIME samples? Yes  No   
 Who was notified \_\_\_\_\_ Date \_\_\_\_\_ Time \_\_\_\_\_
- 7) Location where samples are stored: log in  
 Permission to subcontract samples? Yes  No   
 (Walk-in clients only) if not already approved  
 Client Signature: \_\_\_\_\_
- 8) Do all samples have the proper Acid pH: Yes  No  N/A
- 9) Do all samples have the proper Base pH: Yes  No  N/A
- 10) Was the PC notified of any discrepancies with the CoC vs the samples: Yes  No  N/A

### Containers received at Con-Test

		# of containers			# of containers
1 Liter Amber			8 oz amber/clear jar		
500 mL Amber			4 oz amber/clear jar		
250 mL Amber (8oz amber)			2 oz amber/clear jar		
1 Liter Plastic			Plastic Bag / Ziploc		
500 mL Plastic			SOC Kit		
250 mL plastic			Non-ConTest Container		
40 mL Vial - type listed below	<u>12</u>		Perchlorate Kit		
Colisure / bacteria bottle			Flashpoint bottle		
Dissolved Oxygen bottle			Other glass jar		
Encore			Other		

Laboratory Comments:

40 mL vials: # HCl 12 # Methanol \_\_\_\_\_  
 # Bisulfate \_\_\_\_\_ # DI Water \_\_\_\_\_  
 # Thiosulfate \_\_\_\_\_ Unpreserved \_\_\_\_\_

Time and Date Frozen: \_\_\_\_\_

Doc# 277

Rev. 4 August 2013

**Login Sample Receipt Checklist**  
**(Rejection Criteria Listing - Using Sample Acceptance Policy)**  
**Any False statement will be brought to the attention of Client**

<u>Question</u>	<u>Answer (True/False)</u>		<u>Comment</u>
	T/F/NA		
1) The cooler's custody seal, if present, is intact.	NA		
2) The cooler or samples do not appear to have been compromised or tampered with.	T		
3) Samples were received on ice.	T		
4) Cooler Temperature is acceptable.	T		
5) Cooler Temperature is recorded.	T		
6) COC is filled out in ink and legible.	T		
7) COC is filled out with all pertinent information.	T		
8) Field Sampler's name present on COC.	T		
9) There are no discrepancies between the sample IDs on the container and the COC.	T		
10) Samples are received within Holding Time.	T		
11) Sample containers have legible labels.	T		
12) Containers are not broken or leaking.	T		
13) Air Cassettes are not broken/open.	NA		
14) Sample collection date/times are provided.	T		
15) Appropriate sample containers are used.	T		
16) Proper collection media used.	T		
17) No headspace sample bottles are completely filled.	ALT		
18) There is sufficient volume for all requested analyses, including any requested MS/MSDs.	T		
19) Trip blanks provided if applicable.	T		
20) VOA sample vials do not have head space or bubble is <6mm (1/4") in diameter.	T		
21) Samples do not require splitting or compositing.	T		

Doc #277 Rev. 4 August 2013

Who notified of False statements?

Log-In Technician Initials: **PB**

Date/Time:

Date/Time: **5.23.14**

**9:34**

July 7, 2014

Jeremy Wyckoff  
Arcadis US, Inc. - Clifton Park-NY  
855 Route 146, Suite 210  
Clifton Park, NY 12065

Project Location: South Otselic, NY  
Client Job Number:  
Project Number: 00266406.0000  
Laboratory Work Order Number: 14F1222

Enclosed are results of analyses for samples received by the laboratory on June 26, 2014. If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Aaron L. Benoit  
Project Manager



## Table of Contents

Sample Summary	3
Case Narrative	4
Sample Results	5
14F1222-01	5
14F1222-02	6
14F1222-03	7
14F1222-04	8
Sample Preparation Information	9
QC Data	10
Volatile Organic Compounds by GC/MS	10
B098918	10
Flag/Qualifier Summary	12
Certifications	13
Chain of Custody/Sample Receipt	15

39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

Arcadis US, Inc. - Clifton Park-NY  
855 Route 146, Suite 210  
Clifton Park, NY 12065  
ATTN: Jeremy Wyckoff

REPORT DATE: 7/7/2014

PURCHASE ORDER NUMBER:

PROJECT NUMBER: 00266406.0000

**ANALYTICAL SUMMARY**

WORK ORDER NUMBER: 14F1222

The results of analyses performed on the following samples submitted to the CON-TEST Analytical Laboratory are found in this report.

PROJECT LOCATION: South Otselic, NY

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
RW-1	14F1222-01	Ground Water		EPA 624	
RW-2	14F1222-02	Ground Water		EPA 624	
EFF46HZ	14F1222-03	Ground Water		EPA 624	
Trip Blank	14F1222-04	Trip Blank Water		EPA 624	

#### CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Con-Test Analytical Laboratory for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.

A handwritten signature in black ink, appearing to read "M Erickson", is written on a light gray rectangular background.

Michael A. Erickson  
Laboratory Director

39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

Project Location: South Otselic, NY

Sample Description:

Work Order: 14F1222

Date Received: 6/26/2014

Field Sample #: RW-1

Sampled: 6/25/2014 10:50

Sample ID: 14F1222-01

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
1,2-Dichloroethane	ND	5.0	0.19	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
1,1-Dichloroethane	1.6	2.0	0.16	µg/L	1	J	EPA 624	6/27/14	7/1/14 10:26	EEH
1,1-Dichloroethylene	0.92	2.0	0.21	µg/L	1	J	EPA 624	6/27/14	7/1/14 10:26	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
1,1,1-Trichloroethane	43	2.0	0.094	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	6/27/14	7/1/14 10:26	EEH
Surrogates		% Recovery	Recovery Limits			Flag/Qual				
1,2-Dichloroethane-d4		98.8	70-130						7/1/14 10:26	
Toluene-d8		99.2	70-130						7/1/14 10:26	
4-Bromofluorobenzene		97.4	70-130						7/1/14 10:26	

39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

Project Location: South Otselic, NY

Sample Description:

Work Order: 14F1222

Date Received: 6/26/2014

Field Sample #: RW-2

Sampled: 6/25/2014 10:55

Sample ID: 14F1222-02

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
1,2-Dichloroethane	ND	5.0	0.19	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
1,1-Dichloroethane	0.81	2.0	0.16	µg/L	1	J	EPA 624	6/27/14	7/1/14 10:53	EEH
1,1-Dichloroethylene	0.62	2.0	0.21	µg/L	1	J	EPA 624	6/27/14	7/1/14 10:53	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
1,1,1-Trichloroethane	38	2.0	0.094	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	6/27/14	7/1/14 10:53	EEH
Surrogates		% Recovery	Recovery Limits			Flag/Qual				
1,2-Dichloroethane-d4		102	70-130						7/1/14 10:53	
Toluene-d8		98.6	70-130						7/1/14 10:53	
4-Bromofluorobenzene		97.7	70-130						7/1/14 10:53	

39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

Project Location: South Otselic, NY

Sample Description:

Work Order: 14F1222

Date Received: 6/26/2014

Field Sample #: EFF46HZ

Sampled: 6/25/2014 11:00

Sample ID: 14F1222-03

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
1,2-Dichloroethane	ND	5.0	0.19	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	6/27/14	7/1/14 10:00	EEH
Surrogates		% Recovery	Recovery Limits			Flag/Qual				
1,2-Dichloroethane-d4		101	70-130						7/1/14 10:00	
Toluene-d8		99.4	70-130						7/1/14 10:00	
4-Bromofluorobenzene		96.6	70-130						7/1/14 10:00	

39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

Project Location: South Otselic, NY

Sample Description:

Work Order: 14F1222

Date Received: 6/26/2014

Field Sample #: Trip Blank

Sampled: 6/25/2014 00:00

Sample ID: 14F1222-04

Sample Matrix: Trip Blank Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
1,2-Dichloroethane	ND	5.0	0.19	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	6/27/14	7/1/14 9:33	EEH
Surrogates		% Recovery	Recovery Limits			Flag/Qual				
1,2-Dichloroethane-d4		101	70-130						7/1/14 9:33	
Toluene-d8		100	70-130						7/1/14 9:33	
4-Bromofluorobenzene		97.3	70-130						7/1/14 9:33	

39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

### Sample Extraction Data

Prep Method: SW-846 5030B-EPA 624

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
14F1222-01 [RW-1]	B098918	5	5.00	06/27/14
14F1222-02 [RW-2]	B098918	5	5.00	06/27/14
14F1222-03 [EFF46HZ]	B098918	5	5.00	06/27/14
14F1222-04 [Trip Blank]	B098918	5	5.00	06/27/14



QUALITY CONTROL

Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

Batch B098918 - SW-846 5030B

Blank (B098918-BLK1)

Prepared: 06/27/14 Analyzed: 07/01/14

Benzene	ND	1.0	µg/L							
Bromodichloromethane	ND	2.0	µg/L							
Bromoform	ND	2.0	µg/L							
Bromomethane	ND	2.0	µg/L							
Carbon Tetrachloride	ND	2.0	µg/L							
Chlorobenzene	ND	2.0	µg/L							
Chlorodibromomethane	ND	2.0	µg/L							
Chloroethane	ND	2.0	µg/L							
2-Chloroethyl Vinyl Ether	ND	10	µg/L							
Chloroform	ND	2.0	µg/L							
Chloromethane	ND	2.0	µg/L							
1,2-Dichlorobenzene	ND	2.0	µg/L							
1,3-Dichlorobenzene	ND	2.0	µg/L							
1,4-Dichlorobenzene	ND	2.0	µg/L							
1,2-Dichloroethane	ND	5.0	µg/L							
1,1-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethylene	ND	2.0	µg/L							
trans-1,2-Dichloroethylene	ND	2.0	µg/L							
1,2-Dichloropropane	ND	2.0	µg/L							
cis-1,3-Dichloropropene	ND	2.0	µg/L							
trans-1,3-Dichloropropene	ND	2.0	µg/L							
Ethylbenzene	ND	2.0	µg/L							
Methyl tert-Butyl Ether (MTBE)	ND	2.0	µg/L							
Methylene Chloride	ND	5.0	µg/L							
1,1,2,2-Tetrachloroethane	ND	2.0	µg/L							
Tetrachloroethylene	ND	2.0	µg/L							
Toluene	ND	1.0	µg/L							
1,1,1-Trichloroethane	ND	2.0	µg/L							
1,1,2-Trichloroethane	ND	2.0	µg/L							
Trichloroethylene	ND	2.0	µg/L							
Trichlorofluoromethane (Freon 11)	ND	2.0	µg/L							
Vinyl Chloride	ND	2.0	µg/L							
m+p Xylene	ND	2.0	µg/L							
o-Xylene	ND	2.0	µg/L							
Surrogate: 1,2-Dichloroethane-d4	24.4		µg/L	25.0		97.6	70-130			
Surrogate: Toluene-d8	24.6		µg/L	25.0		98.6	70-130			
Surrogate: 4-Bromofluorobenzene	24.4		µg/L	25.0		97.6	70-130			

LCS (B098918-BS1)

Prepared: 06/27/14 Analyzed: 06/30/14

Benzene	10.8	1.0	µg/L	10.0		108	37-151			
Bromodichloromethane	10.1	2.0	µg/L	10.0		101	35-155			
Bromoform	11.7	2.0	µg/L	10.0		117	45-169			
Bromomethane	8.93	2.0	µg/L	10.0		89.3	20-242			
Carbon Tetrachloride	11.0	2.0	µg/L	10.0		110	70-140			
Chlorobenzene	9.65	2.0	µg/L	10.0		96.5	37-160			
Chlorodibromomethane	9.75	2.0	µg/L	10.0		97.5	53-149			
Chloroethane	10.4	2.0	µg/L	10.0		104	70-130			
2-Chloroethyl Vinyl Ether	99.4	10	µg/L	100		99.4	10-305			
Chloroform	9.98	2.0	µg/L	10.0		99.8	51-138			
Chloromethane	10.2	2.0	µg/L	10.0		102	20-273			
1,2-Dichlorobenzene	9.65	2.0	µg/L	10.0		96.5	18-190			
1,3-Dichlorobenzene	9.50	2.0	µg/L	10.0		95.0	59-156			

39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

QUALITY CONTROL

Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
<b>Batch B098918 - SW-846 5030B</b>										
<b>LCS (B098918-BS1)</b>										
Prepared: 06/27/14 Analyzed: 06/30/14										
1,4-Dichlorobenzene	9.48	2.0	µg/L	10.0		94.8	18-190			
1,2-Dichloroethane	9.76	5.0	µg/L	10.0		97.6	49-155			
1,1-Dichloroethane	10.7	2.0	µg/L	10.0		107	59-155			
1,1-Dichloroethylene	8.86	2.0	µg/L	10.0		88.6	20-234			
trans-1,2-Dichloroethylene	10.6	2.0	µg/L	10.0		106	54-156			
1,2-Dichloropropane	9.75	2.0	µg/L	10.0		97.5	20-210			
cis-1,3-Dichloropropene	10.2	2.0	µg/L	10.0		102	20-227			
trans-1,3-Dichloropropene	10.2	2.0	µg/L	10.0		102	17-183			
Ethylbenzene	9.77	2.0	µg/L	10.0		97.7	37-162			
Methyl tert-Butyl Ether (MTBE)	10.7	2.0	µg/L	10.0		107	70-130			
Methylene Chloride	9.37	5.0	µg/L	10.0		93.7	50-221			
1,1,2,2-Tetrachloroethane	10.4	2.0	µg/L	10.0		104	46-157			
Tetrachloroethylene	9.87	2.0	µg/L	10.0		98.7	64-148			
Toluene	9.60	1.0	µg/L	10.0		96.0	47-150			
1,1,1-Trichloroethane	10.6	2.0	µg/L	10.0		106	52-162			
1,1,2-Trichloroethane	10.3	2.0	µg/L	10.0		103	52-150			
Trichloroethylene	10.4	2.0	µg/L	10.0		104	71-157			
Trichlorofluoromethane (Freon 11)	10.6	2.0	µg/L	10.0		106	17-181			
Vinyl Chloride	11.0	2.0	µg/L	10.0		110	20-251			
m+p Xylene	19.0	2.0	µg/L	20.0		95.2	70-130			
o-Xylene	9.62	2.0	µg/L	10.0		96.2	70-130			
Surrogate: 1,2-Dichloroethane-d4	25.0		µg/L	25.0		99.9	70-130			
Surrogate: Toluene-d8	24.7		µg/L	25.0		98.7	70-130			
Surrogate: 4-Bromofluorobenzene	24.1		µg/L	25.0		96.2	70-130			

**FLAG/QUALIFIER SUMMARY**

- \* QC result is outside of established limits.
  - † Wide recovery limits established for difficult compound.
  - ‡ Wide RPD limits established for difficult compound.
  - # Data exceeded client recommended or regulatory level
- Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.  
No results have been blank subtracted unless specified in the case narrative section.
- J Detected but below the Reporting Limit (lowest calibration standard); therefore, result is an estimated concentration (CLP J-Flag).

**CERTIFICATIONS**

**Certified Analyses included in this Report**

Analyte	Certifications
<i>EPA 624 in Water</i>	
Benzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromodichloromethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromoform	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromomethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Carbon Tetrachloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chlorodibromomethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
2-Chloroethyl Vinyl Ether	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloroform	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloromethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,3-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,4-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
trans-1,2-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichloropropane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
cis-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
trans-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Ethylbenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Methyl tert-Butyl Ether (MTBE)	NC
Methylene Chloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,2,2-Tetrachloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Tetrachloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Toluene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,1-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,2-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Trichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Trichlorofluoromethane (Freon 11)	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Vinyl Chloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
m+p Xylene	CT,MA,NH,NY,RI,NC,VA,NJ
o-Xylene	CT,MA,NH,NY,RI,NC,VA,NJ

39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

The CON-TEST Environmental Laboratory operates under the following certifications and accreditations:

Code	Description	Number	Expires
AIHA	AIHA-LAP, LLC	100033	02/1/2016
MA	Massachusetts DEP	M-MA100	06/30/2015
CT	Connecticut Department of Public Health	PH-0567	09/30/2015
NY	New York State Department of Health	10899 NELAP	04/1/2015
NH-S	New Hampshire Environmental Lab	2516 NELAP	02/5/2015
RI	Rhode Island Department of Health	LAO00112	12/30/2014
NC	North Carolina Div. of Water Quality	652	12/31/2014
NJ	New Jersey DEP	MA007 NELAP	06/30/2015
FL	Florida Department of Health	E871027 NELAP	06/30/2015
VT	Vermont Department of Health Lead Laboratory	LL015036	07/30/2015
WA	State of Washington Department of Ecology	C2065	02/23/2015
ME	State of Maine	2011028	06/9/2015
VA	Commonwealth of Virginia	460217	12/14/2014
NH-P	New Hampshire Environmental Lab	2557 NELAP	09/6/2014



**CON-test**  
ANALYTICAL LABORATORY

Phone: 413-525-2332  
Fax: 413-525-6405  
Email: info@contestlabs.com  
www.contestlabs.com

**CHAIN OF CUSTODY RECORD**

Rev 04.05.12

39 Spruce Street  
East Longmeadow, MA 01028

Company Name: **ARCADIS** Telephone: **518-250-7300**

Address: **855 Route 146, STE 210** Project # **00266406.6000**

Attention: **Jenny Wyckoff** Client PO#

Project Location: **S. Otselic, NY**

Sampled By: **J. Wyckoff**

Project Proposal Provided? (for billing purposes)  
 Yes  No (proposal date)

DATA DELIVERY (check all that apply)  
 FAX  EMAIL  WEBSITE

Email: **jenny.wyckoff@arcadis-usa.com**

Con-Test Lab ID <small>(Laboratory use only)</small>	Client Sample ID / Description	Collection		Composite	Grab	*Matrix Code	*Bottle Code	ANALYSIS REQUESTED
		Beginning Date/Time	Ending Date/Time					
-01	RW-1	6/25/14	1050	X	GW	M		X
-02	RW-2	6/25/14	1055	X	GW	M		X
-03	EFC-46112	6/25/14	1100	X	GW	L		X
-04	TAIP Blank	6/25/14						X

Comments:

Relinquished by: (signature) **[Signature]** Date/Time: **6/25/14**

Received by: (signature) **[Signature]** Date/Time: **6/26/14**

Relinquished by: (signature) **[Signature]** Date/Time: **6/26/14**

Received by: (signature) **[Signature]** Date/Time: **6/26/14**

TURNAROUND TIME STARTS AT 9:00 A.M. THE DAY AFTER SAMPLE RECEIPT UNLESS THERE ARE QUESTIONS ON YOUR CHAIN. IF THIS FORM IS NOT FILLED OUT COMPLETELY OR IS INCORRECT, TURNAROUND TIME WILL NOT START UNTIL ALL QUESTIONS ARE ANSWERED BY OUR CLIENT. PLEASE BE CAREFUL NOT TO CONTAMINATE THIS DOCUMENT.

# of Containers  
\*\* Preservation  
\*\*\* Container Co  
Dissolved Metal  
 Field Filtered  
 Lab to Filter

\*\*\*Cont. Code:  
A=amber glass  
G=glass  
P=plastic  
ST=sterile  
V= vial

Summa can  
T=tedlar bag  
O=Other

\*\*Preservation  
I=iced  
H=HCL  
M=Methanol  
N=Nitric Acid  
S=Sulfuric Acid  
B=Sodium bisulfite  
X=Na hydroxide  
T=Na thiosulfate  
O=Other

\*Matrix Code:  
GW=groundwater  
WW=wastewater  
DW=drinking water  
A=air  
S=soli/solid  
SL=sludge  
O=other

Is your project MCP or RCP?  
 MCP Form Required  
 RCP Form Required  
 MA State DW Form Required  
 PWSID # \_\_\_\_\_  
NELAC & AIHA-LAP, LLC  
Accredited  
WBE/DBE Certified

MA STATE DEPARTMENT OF ENVIRONMENTAL CONSERVATION  
NELAC & AIHA-LAP, LLC  
Accredited  
WBE/DBE Certified



**805045360070**

Ship (P/U) date :  
**Wed 6/25/2014 2:59 pm**



Actual delivery :  
**Thur 6/26/2014 10:03 am**

CLI US

**Delivered**

MA US

Signed for by: F WILSON

**Travel History**


Date/Time	Activity	Location
- 6/26/2014 - Thursday		
10:03 am	Delivered	MA
8:19 am	On FedEx vehicle for delivery	WINDSOR LOCKS, CT
7:03 am	At local FedEx facility	WINDSOR LOCKS, CT
3:15 am	Departed FedEx location	NEWARK, NJ
- 6/25/2014 - Wednesday		
11:35 pm	Arrived at FedEx location	NEWARK, NJ
2:59 pm	Picked up	BINGHAMTON, NY

Local Scan Time

**Shipment Facts**

<b>Tracking number</b>	805045360070	<b>Service</b>	FedEx Priority Overnight
<b>Weight</b>	10 lbs	<b>Delivered To</b>	Receptionist/Front Desk
<b>Total pieces</b>	1	<b>Total shipment weight</b>	10 lbs / 4.54 kgs
<b>Shipper reference</b>	0026640 60000	<b>Packaging</b>	Your Packaging
<b>Special handling section</b>	Deliver Weekday		

39 Spruce St.  
 East Longmeadow, MA. 01028  
 P: 413-525-2332  
 F: 413-525-6405  
 www.contestlabs.com



### Sample Receipt Checklist

CLIENT NAME: Arcadis RECEIVED BY: CEC DATE: 6/26/14

- 1) Was the chain(s) of custody relinquished and signed?  Yes No No CoC Included
- 2) Does the chain agree with the samples?  Yes No  
If not, explain:
- 3) Are all the samples in good condition?  Yes No  
If not, explain:

4) How were the samples received:  
 On Ice  Direct from Sampling  Ambient  In Cooler(s)   
 Were the samples received in Temperature Compliance of (2-6°C)?  Yes No N/A  
 Temperature °C by Temp blank \_\_\_\_\_ Temperature °C by Temp gun 5.0°

- 5) Are there Dissolved samples for the lab to filter? Yes  No
- Who was notified \_\_\_\_\_ Date \_\_\_\_\_ Time \_\_\_\_\_
- 6) Are there any RUSH or SHORT HOLDING TIME samples? Yes  No
- Who was notified \_\_\_\_\_ Date \_\_\_\_\_ Time \_\_\_\_\_

7) Location where samples are stored: 19  
 Permission to subcontract samples? Yes No  
 (Walk-in clients only) if not already approved  
 Client Signature: \_\_\_\_\_

- 8) Do all samples have the proper Acid pH: Yes No  N/A
- 9) Do all samples have the proper Base pH: Yes No  N/A
- 10) Was the PC notified of any discrepancies with the CoC vs the samples: Yes No  N/A

### Containers received at Con-Test

	# of containers		# of containers
1 Liter Amber		8 oz amber/clear jar	
500 mL Amber		4 oz amber/clear jar	
250 mL Amber (8oz amber)		2 oz amber/clear jar	
1 Liter Plastic		Plastic Bag / Ziploc	
500 mL Plastic		SOC Kit	
250 mL plastic		Non-ConTest Container	
40 mL Vial - type listed below	12	Perchlorate Kit	
Colisure / bacteria bottle		Flashpoint bottle	
Dissolved Oxygen bottle		Other glass jar	
Encore		Other	

Laboratory Comments:

40 mL vials: # HCl 12 # Methanol \_\_\_\_\_  
 # Bisulfate \_\_\_\_\_ # DI Water \_\_\_\_\_  
 # Thiosulfate \_\_\_\_\_

Time and Date Frozen: \_\_\_\_\_



Page 2 of 2

**Login Sample Receipt Checklist**  
**(Rejection Criteria Listing - Using Sample Acceptance Policy)**  
**Any False statement will be brought to the attention of Client**

Question	Answer (True/False)	Comment
	T/F/NA	
1) The cooler's custody seal, if present, is intact.	T	
2) The cooler or samples do not appear to have been compromised or tampered with.	T	
3) Samples were received on ice.	T	
4) Cooler Temperature is acceptable.	T	
5) Cooler Temperature is recorded.	T	
6) COC is filled out in ink and legible.	T	
7) COC is filled out with all pertinent information.	T	
8) Field Sampler's name present on COC.	T	
9) There are no discrepancies between the sample IDs on the container and the COC.	T	
10) Samples are received within Holding Time.	T	
11) Sample containers have legible labels.	T	
12) Containers are not broken or leaking.	T	
13) Air Cassettes are not broken/open.	NA	
14) Sample collection date/times are provided.	T	
15) Appropriate sample containers are used.	T	
16) Proper collection media used.	NA	
17) No headspace sample bottles are completely filled.	T	
18) There is sufficient volume for all requested analyses, including any requested MS/MSDs.	T	
19) Trip blanks provided if applicable.	T	
20) VOA sample vials do not have head space or bubble is <6mm (1/4") in diameter.	T	
21) Samples do not require splitting or compositing.	T	

Doc #277 Rev. 4 August 2013      Who notified of False statements?  
 Log-In Technician Initials:

CEC

Date/Time:

Date/Time:

6/26/14 1003