

**New York State Department of
Environmental Conservation**

Site Number 7-09-009

**Gladding Cordage Site Quarterly
Report**

First Quarter 2015

August 2015



A blue ink signature of Andrew Vitolins, consisting of a series of loops and a long horizontal stroke.

Andrew Vitolins, PG
Associate Vice President

A black ink signature of Jeremy Wyckoff, featuring a stylized, cursive script.

Jeremy Wyckoff
Project Geologist

**Gladding Cordage Site
Quarterly Report**

First Quarter 2015

Site Number 7-09-009

Prepared for:
New York State Department of
Environmental Conservation

Prepared by:
Malcolm Pirnie, Inc.
855 Route 146
Suite 210
Clifton Park
New York 12065
Tel 518 250 7300
Fax 518 250 7301

Our Ref.:
00266406.0000

Date:
August 2015

*Malcolm Pirnie, Inc. was acquired by
ARCADIS in July 2009.*

1. Introduction	1
2. Site Description	2
3. Operation and Maintenance	3
3.1 Treatment Plant Upgrades	3
3.1.1 Variable Frequency Drive	3
3.1.2 Treatment Plant Controls	4
3.1.3 Geothermal Heat Exchanger	4
3.2 Treatment Plant Operation	4
3.2.1 Treatment System Sampling	5
3.2.1.1 Influent Sample Results	5
3.2.1.2 Effluent Sample Results	6
4. Groundwater Monitoring Program	7
5. Recommendations	8
6. Summary	9
7. References	10

Tables

Table 3-1	Treatment System Status and Flow Summary
Table 3-2	Groundwater Treatment System VOCs (Influent – RW-1)
Table 3-3	Groundwater Treatment System VOCs (Influent – RW-2)
Table 3-4	Summary of Groundwater Treatment System VOCs (Effluent)

Figures

Figure 2-1 Site Location

Figure 2-2 Site Plan

Figure 3-1 Treatment System Influent Sample Concentrations (1,1,1-TCA)

Appendices

A ProControl Daily Facsimile Reports

B O&M Checklists and System Operation Logs

C Analytical Reporting Forms

1. Introduction

The New York State Department of Environmental Conservation (NYSDEC) has issued a Work Assignment (# D007618-9) to Malcolm Pirnie, Inc. (Malcolm Pirnie) for Operation, Maintenance, and Monitoring at the Gladding Cordage Site in New York State (Site # 7-09-009). This Quarterly Report has been prepared in accordance with the NYSDEC-approved Work Plan to summarize site activities.

2. Site Description

The Gladding Cordage Site is located on Ridge Road, South Otselic, Chenango County, New York (Figure 2-1), along the western bank of the Otselic River. The site contains an active braided wire and rope manufacturing facility that has been in operation since 1892 (Figure 2-2).

3. Operation and Maintenance

On August 23, 2007, NYSDEC provided a training session to Malcolm Pirnie personnel on the operation and maintenance (O&M) of the groundwater treatment plant at the Gladding Cordage Site. Since then, Malcolm Pirnie has maintained operation of the groundwater treatment plant. This includes the operation, maintenance, and influent/effluent sampling in accordance with the NYSDEC O&M manual (Operation and Maintenance Manual, Volume I, Gladding Cordage Site, Site 7-09-009, TAMS Consultants, Inc., 1996) (O&M Manual).

3.1 Treatment Plant Upgrades

3.1.1 Variable Frequency Drive

A variable frequency drive (VFD) was installed on January 9, 2008 to regulate the speed of the air stripper blower motor. Following the installation of the VFD, effluent samples were collected at various blower motor frequencies (speeds) including 40 HZ, 50 HZ, and 60 HZ. The analyte 1,1,1-trichloroethane (1,1,1-TCA) was detected at 6 µg/l in the 40 HZ effluent sample but was not detected in the 50 HZ and 60 HZ samples. Following the completion of the January 9, 2008 sampling event the VFD was set to 50 HZ. Additional sampling was conducted in February 2008 to further optimize the treatment system blower speed. Based on the results, the VFD setting was reduced to 42 HZ beginning in March 2008. Based on the detection of low-level VOCs in effluent samples from the treatment system, the VFD setting was subsequently increased to 46 HZ in September 2010 and maintained that frequency until November 19, 2014.

Based on a general trend of lower concentrations of VOCs in influent treatment system samples since September 2010, the NYSDEC authorized a reduction of the VFD frequency to 44 HZ in an attempt to further optimize treatment plant operations and reduce electric usage. The VFD frequency was lowered to 44 HZ on November 19, 2014. Following approximately one-half hour of operation, post-treatment effluent samples were collected in accordance with the Work Plan (see Section 3.2.1). Based on a review of post-treatment effluent sample data from November 19, 2014, 1,1,1 TCA and toluene were detected with the air stripper blower operating at 44 HZ, but at concentrations below the corresponding NYSDEC Class GA Standards. The NYSDEC was notified of the VOC detections and the blower motor frequency was subsequently increased to 46 HZ during the next (December 18, 2014) O&M event.

3.1.2 Treatment Plant Controls

In August 2011, the NYSDEC authorized construction and installation of a new treatment plant controls system. The new control system is designed to provide remote access to treatment plant operating parameters and improve reliability of the groundwater remediation system. The treatment plant was shut down to begin repairs and upgrades on January 30, 2012 by Aztech Technologies, Inc. (Aztech). The upgrades to the treatment system controls were completed and the treatment plant resumed operation on March 22, 2012. The treatment plant functions are controlled and monitored using an EOS Research Ltd. ProControl Programmable Logic Controller (PLC). The interface software allows remote connection to the PLC via analog phone line. The PLC and interface software also allows the treatment system to be started or stopped remotely. The PLC is programmed to send a facsimile with the status of system inputs and outputs on a daily basis. If input and/or output device values exceed the defined operating parameters, an alarm condition is set and the corresponding alarm information is sent via facsimile to the system user (i.e. Malcolm Pirnie).

3.1.3 Geothermal Heat Exchanger

The NYSDEC authorized the installation of a geothermal heat exchanger to provide climate control (heating and humidity) for the treatment system building. The treatment plant was shut down to begin installation of the geothermal heat exchanger on May 8, 2012 by Aztech. The geothermal heat exchanger installation and testing was completed on May 10, 2012. The heat-exchanger uses groundwater from the treatment plant as a geo-thermal energy source.

3.2 Treatment Plant Operation

As shown on PLC facsimile reports (Appendix A) and O&M Checklists (Appendix B), the Gladding Cordage groundwater treatment system shut down for approximately one day in January 2015 and one day in February 2015 due to power interruptions. The treatment plant was restarted remotely after each event. The treatment plant operated without interruption during March 2015; however, the daily facsimile reports were not sent from the PLC from March 24 through the end of the month. The PLC was re-booted on April 1, 2015 and facsimile reporting was restored.

During the January 2015 inspection, a defective pressure sensor for the heat pump was replaced. The heat pump was tested with no faults reported.

During the March 2015 inspection, a noise was identified from the air stripper blower motor. The motor was greased as part of the monthly routine maintenance, but the grease fittings would not accept new grease. The system was shut down and the grease passages in the motor were cleaned and new grease was applied. The system was restarted with no abnormal noises from the motor. The motor will continue to be observed for abnormal noises.

The average monthly flow rates and total flow volumes are summarized in Table 3-1. As shown in Table 3-1, the average quarterly flow rates from recovery wells RW-1 and RW-2 were approximately 22 gpm and 23 gpm, respectively. Based on the total flow values, approximately 5.8 million gallons of water were treated between January 1, 2015 and March 31, 2015.

3.2.1 Treatment System Sampling

Influent and effluent groundwater samples were collected from the Gladding Cordage treatment system in accordance with the Work Plan. The samples were submitted to Contest Analytical following chain-of-custody protocols for analysis of volatile organic compounds (VOCs) by United States Environmental Protection Agency (USEPA) Method 624. Analytical Reporting Forms are provided in Appendix B.

3.2.1.1 Influent Sample Results

Table 3-2 and Table 3-3 summarize the previous year of influent VOC sample results from recovery wells RW-1 and RW-2, respectively. Figure 3-1 provides a summary of 1,1,1-TCA concentrations in samples from recovery wells RW-1 and RW-2 since September 2007. Tables 3-2 and 3-3, and Figure 3-1 show that the concentration of 1,1,1-TCA in the January 2015 sample from RW-2 (15 ug/L) is the lowest concentration reported from this recovery well since 2007. The concentration of 1,1,1-TCA in the samples from RW-2 increased to 35 ug/L in February 2015 and remained consistent with previous results for the remainder of the quarter. The groundwater samples from RW-1 were consistent with previous results and ranged from 46.1 ug/L in January 2015 to 33.4 ug/L in March 2015. As shown in Tables 3-1 and 3-2, these results exceed the corresponding NYSDEC Class GA Standard of 5 µg/L; however, Figure 3-1 shows that the concentrations are within the range of previous results. In addition, Figure 3-1 shows a general trend of decreasing groundwater concentrations over time.

As shown in Tables 3-2 and 3-3, 1,1-dichloroethene (1,1-DCE) and 1,1-dichloroethane (1,1-DCA) were detected in the influent samples from recovery wells RW-1 and RW-2. However, these concentrations were less than the applicable NYSDEC Class GA Standard of 5 µg/L. Tables 3-2 and 3-3 show that the 1,1-DCE and 1,1-DCA concentrations are consistent with previous results.

3.2.1.2 Effluent Sample Results

Table 3-4 summarizes laboratory analytical data for effluent samples collected from the treatment system. As shown in Table 3-4, no VOCs were detected in any of the first quarter 2015 effluent sample.

Based on influent sample concentrations and total flow volumes from the Gladding Cordage treatment system, approximately 1.7 pounds of VOCs were removed by the treatment system during the first quarter, 2015.

4. Groundwater Monitoring Program

Groundwater samples were collected from the site during the fourth quarter 2013 in accordance with the Work Plan. The results of the sampling event were submitted in the fourth quarter 2013 Gladding Cordage Site Quarterly Report (Malcolm Pirnie, 2014). The next groundwater sampling event was scheduled to take place during the first quarter 2015. However, due to significant snow and ice accumulations at the site throughout the first quarter, Malcom Pirnie contacted the NYSDEC and received permission to postpone sampling until the second quarter 2015.

5. Recommendations

No changes to site operations are recommended at this time.

6. Summary

The Gladding Cordage groundwater treatment system was shut down for a total of two days during the first quarter 2015 operating period due to power interruptions.

A new pressure sensor was installed on the geothermal heat pump.

The air stripper blower motor was making noise and it was found that the grease passages on the blower motor need to be cleaned. The motor was greased and the noise was subsequently repaired.

The average total flow through the treatment system between January and March 2015 was approximately 46 GPM. Based on monthly influent and effluent sampling, the treatment successfully removes VOCs from groundwater extracted from the capture zone at the current VFD setting of 46 Hz. The VFD setting will continue to be evaluated based on system monitoring results. Approximately 1.7 pounds of VOCs were removed by the treatment system during the first quarter 2015.

Groundwater samples were collected in October 2013. The next monitoring event was scheduled for first quarter 2015. However, due to significant snow and ice cover, sampling was postponed until the second quarter 2015.


No changes to site operations are recommenced at this time.

7. References

Malcolm Pirnie, 2007, Gladding Cordage Site Work Plan, Site 7-09-009, June, 2007.

Malcolm Pirnie, 2014, Gladding Cordage Site Quarterly Report, Fourth Quarter 2013, Site 7-09-009, June, 2014.

TAMS Consultants, 1996, Operation and Maintenance Manual, Volume I, Gladding Cordage Site. Site 7-09-009.




SOURCE: U.S.G.S 7.5 MIN. SOUTH OTSELIC QUAD, 1988

SCALE IN FEET
0 500 1000 2000




NYSDEC STANDBY CONTRACT NO. D007618-9
GLADDING CORDAGE – SITE NUMBER 7-09-009
SOUTH OTSELIC, NEW YORK
SITE LOCATION

FIGURE 2-1



Copyright © 2014 Esri, DeLorme, HERE, TomTom, Source: Esri, DigitalGlobe, GeoEye, swisstopo, and the GIS User Community




- Legend**
- Monitoring Well
 - Recovery Well
 - Approximate Site Boundary

NYSDEC STANDBY CONTRACT NO. D004443-5
GLADDING CORDAGE SITE 7-09-009
SOUTH OTSELIC, NEW YORK

SITE PLAN



Figure 3-1
Treatment System Influent Sample Concentrations (1,1,1-TCA)
Gladding Cordage Site
NYSDEC Site Number 7-09-009



**TABLE 3-1
TREATMENT SYSTEM STATUS AND FLOW SUMMARY
GLADDING CORDAGE SITE
SOUTH OTSELIC, NEW YORK
NYSDEC SITE NO. 7-04-009A**

Date	System Operation (days)	System On-time (% of possible days)	Well On-time		Flow Rates		Totalizer		Recovery Well Total Flows		Total System Flow (gallons)	Quarterly Totals (gallons)
			RW-1 (% possible)	RW-2 (% possible)	RW-1 (gpm)	RW-2 (gpm)	RW-1 (gallons)	RW-2 (gallons)	RW-1 (gallons)	RW-2 (gallons)		
August-07	8 ⁽¹⁾	100%	100%	100%	38	24	-		437,760 ⁽³⁾	276,480 ⁽³⁾	714,240	3,435,840
September-07	30	100%	100%	100%	38	25	-		1,641,600 ⁽³⁾	1,080,000 ⁽³⁾	2,721,600	
October-07	20	65%	100%	100%	38.2	25.7	2,276,270		1,100,160 ⁽³⁾	740,160 ⁽³⁾	1,840,320	
November-07	30	100%	67%	100%	39.9	24.9 ⁽²⁾	3,235,110		958,840 ⁽⁴⁾	1,075,680 ⁽³⁾	2,034,520	6,172,646
December-07	31	100%	39%	100%	31.8	24.9 ⁽²⁾	4,421,380		1,186,270 ⁽⁴⁾	1,111,536 ⁽³⁾	2,297,806	
January-08	31	100%	100%	100%	31.8	24.9 ⁽²⁾	5,278,000		856,620 ⁽⁴⁾	1,111,536 ⁽³⁾	1,968,156	
February-08	26	90%	69%	88%	32	24.9 ⁽²⁾	6,457,610		1,179,610 ⁽⁴⁾	820,385 ⁽³⁾	1,999,995	5,503,499
March-08	23	74%	100%	100%	32.9	24.9 ⁽²⁾	7,168,270		710,660 ⁽⁴⁾	824,688 ⁽³⁾	1,535,348	
April-08	30	100%	100%	100%	30.8	24.9 ⁽²⁾	8,219,790		1,051,520 ⁽⁴⁾	1,075,680 ⁽³⁾	2,127,200	
May-08	31	100%	100%	100%	31.3	24.9 ⁽²⁾	9,458,370		1,238,580 ⁽⁴⁾	1,111,536 ⁽³⁾	2,350,116	6,846,908
June-08	27	90%	100%	100%	30.5	24.9 ⁽²⁾	10,859,850		1,401,480 ⁽⁴⁾	968,112 ⁽³⁾	2,369,592	
July-08	28	90%	68%	100%	30.1	24.9 ⁽²⁾	11,889,440		1,029,590 ⁽⁴⁾	1,003,968 ⁽³⁾	2,033,558	
August-08	28	90%	100%	100%	30	24.9 ⁽²⁾	12,832,500		943,060 ⁽⁴⁾	1,003,968 ⁽³⁾	1,947,028	6,201,456
September-08	30	100%	100%	100%	29.8	24.9 ⁽²⁾	13,977,690		1,145,190 ⁽⁴⁾	1,075,680 ⁽³⁾	2,220,870	
October-08	31	100%	100%	100%	30	24.9 ⁽²⁾	15,190,100		1,212,410 ⁽⁴⁾	1,111,536 ⁽³⁾	2,323,946	
November-08	30	100%	100%	100%	31.7	24.9 ⁽²⁾	16,722,470		1,532,370 ⁽⁴⁾	1,075,680 ⁽³⁾	2,608,050	7,494,552
December-08	31	100%	100%	100%	31.3	24.9 ⁽²⁾	18,173,490		1,451,020 ⁽⁴⁾	1,111,536 ⁽³⁾	2,562,556	
Total Flow 2007									5,324,630	4,283,856	9,608,486	
Total Flow 2008									13,752,110	12,294,305	26,046,415	

Notes:

- 1 - System started on 8/23/07.
 - 2 - Flow meter inoperative. Flow based on average flow from August, September, and October 2008.
 - 3 - Calculated based on percentage of system on-time, flow rate, and percentage of recovery well on-time.
 - 4 - Calculated from totalizer values.
- gpm - Gallons per minute

TABLE 3-1
TREATMENT SYSTEM STATUS AND FLOW SUMMARY
GLADDING CORDAGE SITE
SOUTH OTSELIC, NEW YORK
NYSDEC SITE NO. 7-04-009A

Date	System Operation (days)	System On-time (% of possible days)	Well On-time		Flow Rates		Totalizer	Totalizer	Recovery Well Total Flows		Total System Flow	Quarterly Totals (gallons)
			RW-1 (% possible)	RW-2 (% possible)	RW-1 (gpm)	RW-2 (gpm)	RW-1 (gallons)	RW-2 (gallons)	RW-1 (gallons)	RW-2 (gallons)	(gallons)	
January-09	31	100%	100%	100%	31.3	24.9 ⁽²⁾	19,566,200		1,392,710 ⁽⁴⁾	1,111,536 ⁽³⁾	2,504,246	6,931,910
February-09	28	100%	100%	100%	30.8	24.9 ⁽²⁾	20,929,320		1,363,120 ⁽⁴⁾	1,003,968 ⁽³⁾	2,367,088	
March-09	31	100%	100%	100%	30.8	24.9 ⁽²⁾	21,878,360		949,040 ⁽⁴⁾	1,111,536 ⁽³⁾	2,060,576	
April-09	30	100%	100%	100%	31.2	24.9 ⁽²⁾	23,159,480		1,281,120 ⁽⁴⁾	1,075,680 ⁽³⁾	2,356,800	8,217,156
May-09	31	100%	100%	100%	31.5	24.9 ⁽²⁾	25,128,390		1,968,910 ⁽⁴⁾	1,111,536 ⁽³⁾	3,080,446	
June-09	30	100%	100%	100%	31.1	24.9 ⁽²⁾	26,832,620		1,704,230 ⁽⁴⁾	1,075,680 ⁽³⁾	2,779,910	
July-09	28	90%	100%	100%	30.4	24.9 ⁽²⁾	27,568,640		736,220 ⁽⁴⁾	1,003,968 ⁽³⁾	1,739,988	5,833,432
August-09	29	94%	100%	100%	30.6	24.9 ⁽²⁾	28,551,120		982,480 ⁽⁴⁾	1,039,824 ⁽³⁾	2,022,304	
September-09	30	100%	100%	100%	30.3	24.9 ⁽²⁾	29,546,580		995,460 ⁽⁴⁾	1,075,680 ⁽³⁾	2,071,140	
October-09	20	65%	100%	100%	34.1	24.9 ⁽²⁾	30,909,620		1,363,040 ⁽⁴⁾	717,120 ⁽³⁾	2,080,160	6,228,096
November-09	29	97%	100%	100%	31.7	24.9 ⁽²⁾	31,775,760		866,140 ⁽⁴⁾	1,039,824 ⁽³⁾	1,905,964	
December-09	27	87%	100%	100%	33.7	24.9 ⁽²⁾	33,049,620		1,273,860 ⁽⁴⁾	968,112 ⁽³⁾	2,241,972	
January-10	31	100%	100%	100%	29.2	24.9 ⁽²⁾	34,376,810		1,327,190 ⁽⁴⁾	1,111,536 ⁽³⁾	2,438,726	7,478,090
February-10	28	100%	100%	100%	34.8	24.9 ⁽²⁾	36,406,400		2,029,590 ⁽⁴⁾	1,003,968 ⁽³⁾	3,033,558	
March-10	31	100%	100%	100%	33	24.9 ⁽²⁾	37,300,670		894,270 ⁽⁴⁾	1,111,536 ⁽³⁾	2,005,806	
April-10	26	87%	100%	100%	35.2	24.9 ⁽²⁾	38,443,930		1,143,260 ⁽⁴⁾	932,256 ⁽³⁾	2,075,516	3,981,724
May-10	28	90%	36%	100%	35.2	24.9 ⁽²⁾	38,734,170		290,240 ⁽⁴⁾	1,003,968 ⁽³⁾	1,294,208	
June-10	17	57%	0%	100%	0	25 ⁽²⁾	38,734,170		0 ⁽⁴⁾	612,000 ⁽³⁾	612,000	
July-10	18	58%	0%	100%	0	24.9 ⁽²⁾	NA		0 ⁽³⁾	645,408 ⁽³⁾	645,408	4,034,736
August-10	23	74%	0%	100%	0	24.9 ⁽²⁾	NA		0 ⁽³⁾	824,688 ⁽³⁾	824,688	
September-10	30	100%	100%	100%	34.5 ⁽²⁾	24.9 ⁽²⁾	NA		1,488,960 ⁽³⁾	1,075,680 ⁽³⁾	2,564,640	
October-10	31	100%	100%	90%	33.4 ⁽²⁾	24.9 ⁽²⁾	NA		1,489,302 ⁽³⁾	1,000,382 ⁽³⁾	2,489,684	7,271,870
November-10	30	100%	100%	100%	33.4 ⁽²⁾	24.9 ⁽²⁾	NA		1,441,260 ⁽³⁾	1,075,680 ⁽³⁾	2,516,940	
December-10	27	87%	100%	100%	33.4 ⁽²⁾	24.9 ⁽²⁾	NA		1,297,134 ⁽³⁾	968,112 ⁽³⁾	2,265,246	
Total Flow 2009									14,876,130	12,334,464	27,210,594	
Total Flow 2010									11,401,206	11,365,214	22,766,420	

Notes:

- 1 - System started on 8/23/07.
 - 2 - Flow meter inoperative. Flow based on previous average flows or from manual tests.
 - 3 - Calculated based on percentage of system on-time, flow rate, and percentage of recovery well on-time.
 - 4 - Calculated from totalizer values.
- gpm - Gallons per minute

TABLE 3-1
TREATMENT SYSTEM STATUS AND FLOW SUMMARY
GLADDING CORDAGE SITE
SOUTH OTSELIC, NEW YORK
NYSDEC SITE NO. 7-04-009A

Date	System Operation (days)	System On-time (% of possible days)	Well On-time		Flow Rates		Totalizer	Totalizer	Recovery Well Total Flows		Total System Flow	Quarterly Totals (gallons)
			RW-1 (% possible)	RW-2 (% possible)	RW-1 (gpm)	RW-2 (gpm)	RW-1 (gallons)	RW-2 (gallons)	RW-1 (gallons)	RW-2 (gallons)	(gallons)	
January-11	31	100%	100%	100%	33.4 ⁽²⁾	24.9 ⁽²⁾			1,489,302 ⁽³⁾	1,111,536 ⁽³⁾	2,600,838	6,292,350
February-11	20	71%	100%	100%	33.4 ⁽²⁾	24.9 ⁽²⁾			960,840 ⁽³⁾	717,120 ⁽³⁾	1,677,960	
March-11	24	77%	100%	100%	33.4 ⁽²⁾	24.9 ⁽²⁾			1,153,008 ⁽³⁾	860,544 ⁽³⁾	2,013,552	
April-11	27	90%	100%	100%	33.36 ⁽²⁾	24.9 ⁽²⁾			1,297,134 ⁽³⁾	968,112 ⁽³⁾	2,265,246	6,544,044
May-11	28	90%	100%	100%	33.36 ⁽²⁾	24.9 ⁽²⁾			1,345,176 ⁽³⁾	1,003,968 ⁽³⁾	2,349,144	
June-11	23	77%	100%	100%	33.36 ⁽²⁾	24.9 ⁽²⁾			1,104,966 ⁽³⁾	824,688 ⁽³⁾	1,929,654	
July-11	6	19%	100%	100%	33.4 ⁽²⁾	24.9 ⁽²⁾			288,576 ⁽³⁾	215,136 ⁽³⁾	503,712	5,592,514
August-11	31	100%	100%	100%	33.4 ⁽²⁾	24.9 ⁽²⁾			1,490,976 ⁽³⁾	1,111,536 ⁽³⁾	2,602,512	
September-11	30	100%	100%	97%	33.4 ⁽²⁾	24.9 ⁽²⁾			1,442,880 ⁽³⁾	1,043,410 ⁽³⁾	2,486,290	
October-11	28	90%	100%	54%	33.4 ⁽²⁾	24.9 ⁽²⁾			1,346,688 ⁽³⁾	542,143 ⁽³⁾	1,888,831	7,009,903
November-11	30	100%	100%	100%	33.4 ⁽²⁾	24.9 ⁽²⁾			1,442,880 ⁽³⁾	1,075,680 ⁽³⁾	2,518,560	
December-11	31	100%	100%	100%	33.4 ⁽²⁾	24.9 ⁽²⁾			1,490,976 ⁽³⁾	1,111,536 ⁽³⁾	2,602,512	
January-12	30	97%	100%	100%	22.7 ⁽⁶⁾	18.0 ⁽⁶⁾			980,640 ⁽³⁾	777,600 ⁽³⁾	1,758,240	2,311,830
February-12	0 ⁽⁵⁾	0%	0%	0%	0	0	0	0	0	0	0	
March-12	10	32%	100%	100%	22.7	18.0	308,309	245,281	308,309 ⁽⁴⁾	245,281 ⁽⁴⁾	553,590	
April-12	30	100%	100%	100%	22.2	18.2	1,274,180	1,027,406	965,871 ⁽⁴⁾	782,125 ⁽⁴⁾	1,747,996	5,130,889
May-12	26	84%	100%	100%	22.8	20.3	2,156,600	1,773,905	882,420 ⁽⁴⁾	746,499 ⁽⁴⁾	1,628,919	
June-12	26	87%	100%	100%	23.6	19.9	3,100,285	2,584,194	943,685 ⁽⁴⁾	810,289 ⁽⁴⁾	1,753,974	
July-12	20	65%	100%	100%	23.8	19.7	3,770,411	3,157,520	670,126 ⁽⁴⁾	573,326 ⁽⁴⁾	1,243,452	5,540,244
August-12	31	100%	100%	100%	23.7	19.4	5,092,016	4,262,219	1,321,605 ⁽⁴⁾	1,104,699 ⁽⁴⁾	2,426,304	
September-12	30	100%	100%	100%	23.5	20.1	6,104,443	5,120,280	1,012,427 ⁽⁴⁾	858,061 ⁽⁴⁾	1,870,488	
October-12	16	52%	100%	100%	23.4	20.3	6,676,877	5,607,870	572,434 ⁽⁴⁾	487,590 ⁽⁴⁾	1,060,024	3,956,859
November-12	30	100%	100%	100%	23.6	19.6	7,769,986	6,536,938	1,093,109 ⁽⁴⁾	929,068 ⁽⁴⁾	2,022,177	
December-12	17	55%	100%	100%	24.3	19.7	8,250,333	6,931,249	480,347 ⁽³⁾	394,311 ⁽³⁾	874,658	
Total Flow 2011									14,853,402	10,585,408	25,438,810	
Total Flow 2012									9,230,973	7,708,849	16,939,822	

Notes:

- 1 - System started on 8/23/07.
 - 2 - Flow meter inoperative. Flow based on previous average flows or from manual tests.
 - 3 - Calculated based on percentage of system on-time, flow rate, and percentage of recovery well on-time.
 - 4 - Calculated from totalizer values.
 - 5 - System shut down for repairs.
 - 6 - Flow based on March 2012 PLC data.
- gpm - Gallons per minute

**TABLE 3-1
TREATMENT SYSTEM STATUS AND FLOW SUMMARY
GLADDING CORDAGE SITE
SOUTH OTSELIC, NEW YORK
NYSDEC SITE NO. 7-04-009A**

Date	System Operation (days)	System On-time (% of possible days)	Well On-time		Flow Rates		Totalizer		Recovery Well Total Flows		Total System Flow (gallons)	Quarterly Totals (gallons)
			RW-1 (% possible)	RW-2 (% possible)	RW-1 (gpm)	RW-2 (gpm)	RW-1 (gallons)	RW-2 (gallons)	RW-1 (gallons)	RW-2 (gallons)		
January-13	26	84%	100%	100%	23.1	19.5	9,140,834	7,699,661	890,501	768,412	1,658,913	5,239,914
February-13	28	100%	100%	100%	22.7	19.4	10,078,542	8,496,541	937,708	796,880	1,734,588	
March-13	31	100%	100%	100%	23.2	19.6	11,077,204	9,344,292	998,662	847,751	1,846,413	
April-13	27	90%	100%	100%	23.4	19.7	11,750,528	9,913,754	673,324	569,462	1,242,786	5,371,547
May-13	30	97%	100%	100%	24.2	19.4	12,984,742	10,944,208	1,234,214	1,030,454	2,264,668	
June-13	31	100%	100%	100%	23.2	19.6	14,002,162	11,790,881	1,017,420	846,673	1,864,093	
July-13	26	84%	100%	100%	23.8	19.3	14,893,234	12,513,473	891,072	722,592	1,613,664	4,241,225
August-13	19	61%	100%	100%	22.9	19.4	15,519,778	13,044,257	626,544	530,784	1,157,328	
September-13	20	67%	100%	100%	21.7	19.7	16,291,084	13,743,184	771,306	698,927	1,470,233	
October-13	13	42%	100%	100%	21.3	20.0	16,558,269	14,001,381	267,185	258,197	525,382	3,722,666
November-13	30	100%	100%	100%	21.6	22.6	17,493,334	14,962,574	935,065	961,193	1,896,258	
December-13	20	65%	100%	100%	21.3	22.3	18,132,181	15,624,753	638,847	662,179	1,301,026	
January-14	12	39%	100%	100%	22.2	22.9	18,507,983	16,012,662	375,802	387,909	763,711	2,680,630
February-14	14	50%	100%	100%	21.8	22.7	18,881,664	16,397,973	373,681	385,311	758,992	
March-14	17	55%	100%	100%	22.2	23.2	19,447,410	16,990,154	565,746	592,181	1,157,927	
April-14	15	50%	100%	100%	21.7	23.2	19,914,906	17,482,200	467,496	492,046	959,542	4,810,632
May-14	31	99%	100%	100%	21.8	22.5	20,883,319	18,490,607	968,413	1,008,407	1,976,820	
June-14	29	97%	100%	100%	21.4	21.6	21,800,646	19,447,550	917,327	956,943	1,874,270	
July-14	24	77%	100%	100%	22.5	22.6	22,568,327	20,221,473	767,681	773,923	1,541,604	4,053,935
August-14	17	55%	100%	100%	22.2	22.5	23,152,553	20,797,422	584,226	575,949	1,160,175	
September-14	21	70%	100%	100%	22.5	22.8	23,822,623	21,479,508	670,070	682,086	1,352,156	
October-14	31	100%	100%	100%	22.4	23.0	24,817,777	22,505,592	995,154	1,026,084	2,021,238	5,312,917
November-14	27	90%	100%	100%	21.9	22.6	25,671,847	23,393,737	854,070	888,145	1,742,215	
December-14	24	77%	100%	100%	24.4	22.9	26,465,671	24,149,377	793,824	755,640	1,549,464	
Total Flow 2013									9,881,848	8,693,504	18,575,352	
Total Flow 2014									8,333,490	8,524,624	16,858,114	

Notes:

- 1 - System started on 8/23/07.
 - 2 - Flow meter inoperative. Flow based on previous average flows or from manual tests.
 - 3 - Calculated based on percentage of system on-time, flow rate, and percentage of recovery well on-time.
 - 4 - Calculated from totalizer values.
 - 5 - System shut down for repairs.
 - 6 - Flow based on March 2012 PLC data.
- gpm - Gallons per minute

**TABLE 3-1
TREATMENT SYSTEM STATUS AND FLOW SUMMARY
GLADDING CORDAGE SITE
SOUTH OTSELIC, NEW YORK
NYSDEC SITE NO. 7-04-009A**

Date	System Operation (days)	System On-time (% of possible days)	Well On-time		Flow Rates		Totalizer		Recovery Well Total Flows		Total System Flow (gallons)	Quarterly Totals (gallons)
			RW-1 (% possible)	RW-2 (% possible)	RW-1 (gpm)	RW-2 (gpm)	RW-1 (gallons)	RW-2 (gallons)	RW-1 (gallons)	RW-2 (gallons)		
January-15	30	97%	100%	100%	23.8	22.3	27,482,764	25,089,994	1,017,093	940,617	1,957,710	5,839,875
February-15	27	96%	100%	100%	21.3	24.1	28,457,483	25,964,709	974,719	874,715	1,849,434	
March-15	31	100%	100%	100%	21.7	23.9	29,512,439	26,942,484	1,054,956	977,775	2,032,731	
Total Flow 2015									3,046,768	2,793,107	5,839,875	

Notes:

- 1 - System started on 8/23/07.
 - 2 - Flow meter inoperative. Flow based on previous average flows or from manual tests.
 - 3 - Calculated based on percentage of system on-time, flow rate, and percentage of recovery well on-time.
 - 4 - Calculated from totalizer values.
 - 5 - System shut down for repairs.
 - 6 - Flow based on March 2012 PLC data.
- gpm - Gallons per minute

TABLE 3-2
GROUNDWATER TREATMENT SYSTEM VOCS (INFLUENT - RW-1)
GLADDING CORDAGE
SOUTH OTSELIC, NEW YORK
NYSDEC Site No. 7-09-009

Sample ID Sampling Date Matrix Units	NYSDEC Class GA Standard ug/L	RW-1 3/17/2014 WATER ug/L	RW-1 4/10/2014 WATER ug/L	RW-1 5/22/2014 WATER ug/L	RW-1 6/25/2014 WATER ug/L	RW-1 7/30/2014 WATER ug/L	RW-1 8/21/2014 WATER ug/L	RW-1 9/30/2014 WATER ug/L	RW-1 10/21/2014 WATER ug/L	RW-1 11/19/2014 WATER ug/L	RW-1 12/18/2014 WATER ug/L	RW-1 1/20/2015 WATER ug/L	RW-1 2/25/2015 WATER ug/L	RW-1 3/19/2015 WATER ug/L
VOCs														
1,1,1-Trichloroethane	5	50	42	31	43	42	42	36	43	51	44	43	40	36
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	0.16	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	2.0	1.9	1.2	1.6	1.6	1.6	1.5	1.6	1.8	1.5	1.8 J	1.6 J	1.5 J
1,1-Dichloroethene	5	0.92	1.0	0.71	0.63	0.85	0.83	0.87	1.2	2.4	2.0 U	1.3 J	0.93 J	0.89 J
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Toluene	5	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Total VOCs		52.9	44.9	32.9	45.2	44.5	44.4	38.4	45.8	55.4	45.5	46.1	44.5	38.4

- Concentration exceeds corresponding NYSDEC
Class GA Standard.
U - Not detected at the indicated concentration
J - Estimated concentration.

TABLE 3-3
GROUNDWATER TREATMENT SYSTEM VOCS (INFLUENT - RW-2)
GLADDING CORDAGE
SOUTH OTSELIC, NEW YORK
NYSDEC Site No. 7-09-009

Sample ID Sampling Date Matrix Units	NYSDEC Class GA Standard ug/L	RW-2 3/17/2014 WATER ug/L	RW-2 4/10/2014 WATER ug/L	RW-2 5/22/2014 WATER ug/L	RW-2 6/25/2014 WATER ug/L	RW-2 7/30/2014 WATER ug/L	RW-2 8/21/2014 WATER ug/L	RW-2 9/29/2014 WATER ug/L	RW-2 10/21/2014 WATER ug/L	RW-2 11/19/2014 WATER ug/L	RW-2 12/18/2014 WATER ug/L	RW-2 1/20/2015 WATER ug/L	RW-2 2/25/2015 WATER ug/L	RW-2 3/19/2015 WATER ug/L
VOCS														
1,1,1-Trichloroethane	5	57	44	27	38	37	37	32	37	45	37	15	34	31
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	1.3	1.2	0.57	0.81	0.73	0.80	0.66	0.82	0.99	0.72	2.0 U	0.76 J	0.69 J
1,1-Dichloroethene	5	1.0	0.88	0.63	0.62	0.63	0.62	0.76	1.3	1.4	0.93	0.38 J	0.7 J	0.68 J
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Toluene	5	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Total VOCs		59.3	46.1	28.2	39.4	38.4	38.4	33.4	39.1	47.4	38.7	15.4	35.4	32.4

- Concentration exceeds corresponding NYSDEC
Class GA Standard.
U - Not detected at the indicated concentration
J - Estimated concentration.

TABLE 3-4
GROUNDWATER TREATMENT SYSTEM VOCS (EFFLUENT)
GLADDING CORDAGE
SOUTH OTSELIC, NEW YORK
NYSDEC Site No. 7-09-009

Sample ID Sampling Date Matrix Units	NYSDEC GA Standard ug/L	EFF(46HZ) 3/17/2014 WATER ug/L	EFF(46HZ) 4/10/2014 WATER ug/L	EFF(46HZ) 5/22/2014 WATER ug/L	EFF(46HZ) 6/25/2014 WATER ug/L	EFF(46HZ) 7/30/2014 WATER ug/L	EFF(46HZ) 8/21/2014 WATER ug/L	EFF(46HZ) 9/30/2014 WATER ug/L
VOCs								
1,1,1-Trichloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Toluene	5	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	5.0 U	2.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U

Notes

U - Not detected at the indicated concentration.

J - Estimated concentration.

TABLE 3-4
GROUNDWATER TREATMENT SYSTEM VOCS (EFFLUENT)
GLADDING CORDAGE
SOUTH OTSELIC, NEW YORK
NYSDEC Site No. 7-09-009

Sample ID Sampling Date Matrix Units	NYSDEC GA Standard ug/L	EFF(46HZ) 10/21/2014 WATER ug/L	EFF(44HZ) 11/19/2014 WATER ug/L	EFF(46HZ) 12/18/2014 WATER ug/L	EFF(46HZ) 1/20/2015 WATER ug/L	EFF(46HZ) 2/25/2015 WATER ug/L	EFF(46HZ) 3/19/2015 WATER ug/L
VOCs							
1,1,1-Trichloroethane	5	2.0 U	0.16	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Toluene	5	1.0 U	0.19	1.0 U	1.0 U	1.0 U	1.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U

Notes

U - Not detected at the indicated concentration.

J - Estimated concentration.



Appendix A

ProControl Daily Facsimile Reports



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/01/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 16:02:49 ON 12/14/2014 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.1	GPM TOTAL FLOW is 26500086	GAL	
W2_FLO is 22.8	GPM TOTAL FLOW is 24182198	GAL	
ASBPRS is 11.1	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 335838	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.20	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.57	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 51.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/02/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 16:02:49 ON 12/14/2014 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 23.7	GPM TOTAL FLOW is 26534487	GAL	
W2_FLO is 22.8	GPM TOTAL FLOW is 24214835	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 337043	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.64	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.18	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.53	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 53.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/03/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 16:02:49 ON 12/14/2014 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.1	GPM TOTAL FLOW is 26568876	GAL	
W2_FLO is 22.5	GPM TOTAL FLOW is 24247445	GAL	
ASBPFR is 11.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 338241	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.54	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.57	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 52.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/04/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 16:02:49 ON 12/14/2014 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 23.6	GPM TOTAL FLOW is 26603253	GAL	
W2_FLO is 22.3	GPM TOTAL FLOW is 24280042	GAL	
ASBPFRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 339312	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.34	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.78	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 56.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/05/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 16:02:49 ON 12/14/2014 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 23.8	GPM TOTAL FLOW is 26637733	GAL	
W2_FLO is 22.4	GPM TOTAL FLOW is 24312731	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 2.40	GPM TOTAL FLOW is 340108	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 4.77	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.65	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 36.02	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.46	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 50.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/06/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 16:02:49 ON 12/14/2014 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 23.9	GPM TOTAL FLOW is 26672188	GAL	
W2_FLO is 22.6	GPM TOTAL FLOW is 24345340	GAL	
ASBPRS is 11.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 2.40	GPM TOTAL FLOW is 341946	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 4.77	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.52	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.69	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.93	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 51.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/07/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 16:02:49 ON 12/14/2014 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 23.9	GPM TOTAL FLOW is 26706581	GAL	
W2_FLO is 22.8	GPM TOTAL FLOW is 24377885	GAL	
ASBPRS is 11.0	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 2.38	GPM TOTAL FLOW is 343670	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 4.74	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.14	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.72	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 51.2	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ALARM Fax Report

EOS Research Ltd.

ProControl Series II+

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 21:54:58 ON 01/07/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P19 : LAST SHUTDOWN @ 16:02:49 ON 12/14/2014 BY ASBVFD
FAX REPORT INITIATED BY PROCESS 18

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 26729363	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 24399436	GAL	
ASBPRS is 0.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 345126	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 0.01	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 37.19	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 58.24	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 48.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ALARM Fax Report

EOS Research Ltd.

ProControl Series II+

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 22:01:00 ON 01/07/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

SHUTD P02 : LAST SHUTDOWN @ 16:02:49 ON 12/14/2014 BY ASBVFD
FAX REPORT INITIATED BY PROCESS 19

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 26729363	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 24399436	GAL	
ASBPRS is 0.1	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 345126	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 37.44	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 58.36	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 46.2	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/08/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

MANUAL : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is OFF	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 26729363	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 24399436	GAL	
ASBPRS is 0.0	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 345127	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.98	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 37.42	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 58.41	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 35.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ALARM Fax Report

EOS Research Ltd.

ProControl Series II+

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 11:46:54 ON 01/08/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P26 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL
FAX REPORT INITIATED BY INTEMP

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMP_L is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 23.8	GPM TOTAL FLOW is 26729723	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 24399774	GAL	
ASBPRS is 11.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 345136	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.98	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.47	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.54	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.97	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 36.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/09/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P26 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.2	GPM TOTAL FLOW is 26755929	GAL	
W2_FLO is 22.1	GPM TOTAL FLOW is 24424051	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 2.40	GPM TOTAL FLOW is 345727	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 4.84	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.04	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.61	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTemp is 56.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/10/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P26 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 23.9	GPM TOTAL FLOW is 26790418	GAL	
W2_FLO is 22.2	GPM TOTAL FLOW is 24456010	GAL	
ASBPRS is 11.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 346459	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.47	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.33	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 53.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/11/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P26 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 23.8	GPM TOTAL FLOW is 26824900	GAL	
W2_FLO is 22.7	GPM TOTAL FLOW is 24487990	GAL	
ASBPRS is 11.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 347311	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.68	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.05	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 51.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/12/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P26 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 23.9	GPM TOTAL FLOW is 26859366	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 24519941	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 347854	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.65	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.42	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.48	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 57.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/13/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P26 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVED is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.2	GPM TOTAL FLOW is 26893788	GAL	
W2_FLO is 22.4	GPM TOTAL FLOW is 24551864	GAL	
ASBPRS is 11.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 348309	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.69	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.82	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 52.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/14/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P26 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 23.8	GPM TOTAL FLOW is 26928261	GAL	
W2_FLO is 22.1	GPM TOTAL FLOW is 24583795	GAL	
ASBPRS is 11.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 349337	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.63	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.60	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.95	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 51.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/15/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P26 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 24.2	GPM TOTAL FLOW is 26962885	GAL	
W2_FLO is 22.1	GPM TOTAL FLOW is 24615703	GAL	
ASBPRS is 11.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 350161	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.52	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.35	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.67	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 53.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/16/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P26 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 23.8	GPM TOTAL FLOW is 26997556	GAL	
W2_FLO is 22.3	GPM TOTAL FLOW is 24647560	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 350757	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.71	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.63	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.71	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.27	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 56.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/17/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P26 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.5	GPM TOTAL FLOW is 27032202	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 24679382	GAL	
ASBPRS is 11.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 351436	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.19	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.65	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 49.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/20/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P26 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVED is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.3	GPM TOTAL FLOW is 27135935	GAL	
W2_FLO is 22.1	GPM TOTAL FLOW is 24774673	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 352893	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.59	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.34	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 56.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ALARM Fax Report

EOS Research Ltd.

ProControl Series II+

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 08:42:58 ON 01/20/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P12 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL
FAX REPORT INITIATED BY PROCESS 11

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.2	GPM TOTAL FLOW is 27139844	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 24778256	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 352946	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.64	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.36	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 57.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ALARM Fax Report

EOS Research Ltd.

ProControl Series II+

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 08:49:00 ON 01/20/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL
FAX REPORT INITIATED BY PROCESS 12

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 24.2	GPM TOTAL FLOW is 27139990	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 24778389	GAL	
ASBPRS is 11.0	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 352946	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.60	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.36	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 57.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/21/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 24.1	GPM TOTAL FLOW is 27170604	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 24806358	GAL	
ASBPRS is 11.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 2.38	GPM TOTAL FLOW is 353843	GAL	
HP_PRS is 8.5	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 4.70	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.46	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.77	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.61	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 52.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/22/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.5	GPM TOTAL FLOW is 27205306	GAL	
W2_FLO is 22.1	GPM TOTAL FLOW is 24838022	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 2.39	GPM TOTAL FLOW is 354769	GAL	
HP_PRS is 8.5	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 4.88	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.79	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.31	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 57.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/23/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 23.5	GPM TOTAL FLOW is 27240016	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 24869657	GAL	
ASBPRS is 11.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 2.41	GPM TOTAL FLOW is 355587	GAL	
HP_PRS is 8.5	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 4.68	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.87	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.31	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 53.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/24/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.1	GPM TOTAL FLOW is 27274736	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 24901275	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 356346	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.19	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.08	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 55.5	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/25/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.3	GPM TOTAL FLOW is 27309425	GAL	
W2_FLO is 22.6	GPM TOTAL FLOW is 24932833	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 356898	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.09	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.21	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTTEMP is 55.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/26/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 24.4	GPM TOTAL FLOW is 27344128	GAL	
W2_FLO is 22.2	GPM TOTAL FLOW is 24964298	GAL	
ASBPRS is 11.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 357862	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.46	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.29	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 51.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/27/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.1	GPM TOTAL FLOW is 27378803	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 24995727	GAL	
ASBPRS is 11.1	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 358753	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.36	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.17	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 53.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/28/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMP_LL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.0	GPM TOTAL FLOW is 27413477	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 25027144	GAL	
ASBPRS is 11.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 359823	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.52	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.34	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 53.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/29/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 23.8	GPM TOTAL FLOW is 27448116	GAL	
W2_FLO is 22.1	GPM TOTAL FLOW is 25058582	GAL	
ASBPRS is 11.5	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 2.39	GPM TOTAL FLOW is 361044	GAL	
HP_PRS is 8.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 4.74	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.79	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.50	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTTEMP is 52.4	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/30/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMP_LLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.6	GPM TOTAL FLOW is 27482764	GAL	
W2_FLO is 21.8	GPM TOTAL FLOW is 25089994	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 361937	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.31	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.08	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 54.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/31/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 24.2	GPM TOTAL FLOW is 27517429	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 25121414	GAL	
ASBPRS is 11.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 362876	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.52	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.69	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.42	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 51.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/01/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.1	GPM TOTAL FLOW is 27552100	GAL	
W2_FLO is 21.4	GPM TOTAL FLOW is 25152804	GAL	
ASBPRS is 11.1	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 2.38	GPM TOTAL FLOW is 363932	GAL	
HP_PRS is 8.5	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 4.91	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.60	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.17	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 56.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/02/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.2	GPM TOTAL FLOW is 27586736	GAL	
W2_FLO is 21.8	GPM TOTAL FLOW is 25184122	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 364701	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.68	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 33.97	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.00	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 57.3	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/03/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 24.2	GPM TOTAL FLOW is 27621347	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 25215415	GAL	
ASBPRS is 11.4	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 365737	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.53	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.38	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 50.5	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/04/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 23.8	GPM TOTAL FLOW is 27655949	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 25246728	GAL	
ASBPRS is 11.2	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 366797	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.60	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.10	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 51.3	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/05/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 24.2	GPM TOTAL FLOW is 27690551	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 25278035	GAL	
ASBPRS is 11.0	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 367506	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.49	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.08	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 54.9	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/06/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 23.8	GPM TOTAL FLOW is 27725149	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 25309363	GAL	
ASBPRS is 11.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 368626	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.64	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.65	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.40	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 47.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/07/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.3	GPM TOTAL FLOW is 27759741	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 25340684	GAL	
ASBPRS is 11.1	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 369696	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.60	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.06	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 52.8	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/08/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 22:04:58 ON 01/07/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 23.6	GPM TOTAL FLOW is 27794323	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 25372002	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 370389	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.68	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.37	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.87	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 55.5	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ALARM Fax Report

EOS Research Ltd.

ProControl Series II+

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 13:03:00 ON 02/09/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

MANUAL : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL
FAX REPORT INITIATED BY PROCESS 19

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is OFF	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 27838595	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 25412118	GAL	
ASBPRS is 0.1	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 371116	GAL	
HP_PRS is 0.9	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 0.01	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 36.52	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.01	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTTEMP is 55.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/10/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

MANUAL : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is OFF	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 27838595	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 25412118	GAL	
ASBPRS is 0.1	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 371116	GAL	
HP_PRS is 0.9	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.96	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 0.01	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 36.79	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 57.16	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 58.9	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/11/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.5	GPM TOTAL FLOW is 27868289	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 25438572	GAL	
ASBPRS is 11.2	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 371819	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.63	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.12	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 55.7	DEG LIMITS are L: 42.0	DEG	H: 130.0
			PSI
			DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/12/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.4	GPM TOTAL FLOW is 27903091	GAL	
W2_FLO is 21.0	GPM TOTAL FLOW is 25469538	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 372479	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.20	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.91	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 57.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/13/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.4	GPM TOTAL FLOW is 27937888	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 25500508	GAL	
ASBPRS is 11.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 373493	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.55	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.72	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 49.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/14/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 23.8	GPM TOTAL FLOW is 27972630	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 25531510	GAL	
ASBPRS is 11.2	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 374846	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.65	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.26	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.04	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 50.3	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/15/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.1	GPM TOTAL FLOW is 28007370	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 25562486	GAL	
ASBPRS is 11.1	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 2.39	GPM TOTAL FLOW is 375831	GAL	
HP_PRS is 8.5	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 4.74	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.65	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.29	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.08	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 50.7	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/16/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.3	GPM TOTAL FLOW is 28042067	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 25593522	GAL	
ASBPRS is 11.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 2.36	GPM TOTAL FLOW is 377527	GAL	
HP_PRS is 8.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 4.70	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.74	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.34	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 51.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/17/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 23.9	GPM TOTAL FLOW is 28076737	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 25624548	GAL	
ASBPRS is 11.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 378931	GAL	
HP_PRS is 1.4	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.47	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.46	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.15	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 51.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/18/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 23.6	GPM TOTAL FLOW is 28111402	GAL	
W2_FLO is 21.8	GPM TOTAL FLOW is 25655575	GAL	
ASBPRS is 11.5	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 380210	GAL	
HP_PRS is 1.4	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.41	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.40	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTMP is 48.3	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/19/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 23.9	GPM TOTAL FLOW is 28146057	GAL	
W2_FLO is 21.0	GPM TOTAL FLOW is 25686570	GAL	
ASBPRS is 11.1	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 2.38	GPM TOTAL FLOW is 381260	GAL	
HP_PRS is 8.5	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 4.69	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.24	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.25	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 51.0	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/20/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.1	GPM TOTAL FLOW is 28180691	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 25717544	GAL	
ASBPRS is 11.4	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 382798	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.55	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.74	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 5.1	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 50.7	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/21/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPIL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 23.9	GPM TOTAL FLOW is 28215323	GAL	
W2_FLO is 21.8	GPM TOTAL FLOW is 25748452	GAL	
ASBPRS is 11.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 2.42	GPM TOTAL FLOW is 384507	GAL	
HP_PRS is 8.5	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.86	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.91	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 48.2	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/22/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.2	GPM TOTAL FLOW is 28249929	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 25779361	GAL	
ASBPRS is 11.1	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 385507	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.52	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.66	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.15	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 55.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/23/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 23.7	GPM TOTAL FLOW is 28284533	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 25810264	GAL	
ASBPRS is 11.3	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 2.38	GPM TOTAL FLOW is 386255	GAL	
HP_PRS is 8.6	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 4.67	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.63	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.91	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.02	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 5.1	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 50.9	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/24/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 23.7	GPM TOTAL FLOW is 28319113	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 25841149	GAL	
ASBPRS is 11.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 387737	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.63	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.52	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.73	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.29	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 53.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/25/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 24.2	GPM TOTAL FLOW is 28353707	GAL	
W2_FLO is 21.2	GPM TOTAL FLOW is 25872041	GAL	
ASBPRS is 11.1	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 388797	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.18	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.02	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 53.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/26/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.2	GPM TOTAL FLOW is 28388315	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 25902922	GAL	
ASBPRS is 11.3	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 389756	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.47	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.55	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.15	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 5.1	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 52.1	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/27/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 23.9	GPM TOTAL FLOW is 28422900	GAL		
W2_FLO is 21.3	GPM TOTAL FLOW is 25933792	GAL		
ASBPRS is 11.6	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 2.40	GPM TOTAL FLOW is 390672	GAL		
HP_PRS is 8.5	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 4.68	AMP LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.82	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.23	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 5.1	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTMP is 52.4	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT HAN



ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/28/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVED is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 23.8	GPM TOTAL FLOW is 28457483	GAL	
W2_FLO is 21.3	GPM TOTAL FLOW is 25964709	GAL	
ASBPRS is 11.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 391955	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.26	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.31	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 49.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/01/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.1	GPM TOTAL FLOW is 28492055	GAL	
W2_FLO is 21.3	GPM TOTAL FLOW is 25995628	GAL	
ASBPRS is 11.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 2.42	GPM TOTAL FLOW is 393182	GAL	
HP_PRS is 8.5	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 4.77	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.43	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.12	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.91	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 52.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/03/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACEFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACEFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.9	GPM TOTAL FLOW is 28561211	GAL	
W2_FLO is 21.0	GPM TOTAL FLOW is 26057444	GAL	
ASBPRS is 11.4	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 2.36	GPM TOTAL FLOW is 394762	GAL	
HP_PRS is 8.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 4.81	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.42	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.93	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.04	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 55.4	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/04/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.2	GPM TOTAL FLOW is 28595765	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 26088338	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 395503	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.27	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.64	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTTEMP is 57.0	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT HAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/05/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 23.7	GPM TOTAL FLOW is 28630308	GAL	
W2_FLO is 21.3	GPM TOTAL FLOW is 26119225	GAL	
ASBPRS is 11.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 396061	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.44	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.65	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.98	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 53.2	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/06/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 23.9	GPM TOTAL FLOW is 28664860	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 26150119	GAL	
ASBPRS is 11.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 396973	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.43	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.99	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.17	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 50.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/07/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.1	GPM TOTAL FLOW is 28699385	GAL	
W2_FLO is 21.4	GPM TOTAL FLOW is 26180998	GAL	
ASBPERS is 11.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 397883	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.46	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.70	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.91	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTTEMP is 50.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/08/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 23.7	GPM TOTAL FLOW is 28733925	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 26211863	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 398586	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.48	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.70	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 55.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/09/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.2	GPM TOTAL FLOW is 28768475	GAL	
W2_FLO is 21.4	GPM TOTAL FLOW is 26242729	GAL	
ASBPRS is 11.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 2.34	GPM TOTAL FLOW is 399262	GAL	
HP_PRS is 8.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 4.82	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.39	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.58	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.79	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTTEMP is 54.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/10/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 24.1	GPM TOTAL FLOW is 28802987	GAL	
W2_FLO is 20.7	GPM TOTAL FLOW is 26273580	GAL	
ASBPRS is 11.2	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 2.36	GPM TOTAL FLOW is 399886	GAL	
HP_PRS is 8.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 4.79	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.37	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.79	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.85	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 55.1	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/11/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 23.8	GPM TOTAL FLOW is 28837484	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 26304426	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 400331	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.44	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.57	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.81	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 57.6	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/12/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.3	GPM TOTAL FLOW is 28872007	GAL	
W2_FLO is 21.1	GPM TOTAL FLOW is 26335299	GAL	
ASBPRS is 11.0	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 400728	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.39	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.32	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.21	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 56.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/14/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VEDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 23.8	GPM TOTAL FLOW is 28941152	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 26397101	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 401867	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.07	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.10	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 58.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/15/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 23.8	GPM TOTAL FLOW is 28975718	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 26428011	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.16	GPM TOTAL FLOW is 402260	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.64	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.52	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.74	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.15	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 58.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/16/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 23.8	GPM TOTAL FLOW is 29010309	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 26458897	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 2.35	GPM TOTAL FLOW is 402809	GAL	
HP_PRS is 8.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 4.93	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.43	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 35.03	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.27	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTMP is 59.4	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/17/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.2	GPM TOTAL FLOW is 29044839	GAL	
W2_FLO is 21.8	GPM TOTAL FLOW is 26489788	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 403172	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.52	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.41	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.64	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.10	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 59.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/18/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.2	GPM TOTAL FLOW is 29079419	GAL	
W2_FLO is 21.3	GPM TOTAL FLOW is 26520672	GAL	
ASBPRS is 11.0	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 403771	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.43	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.18	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.72	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTemp is 54.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/19/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:55:16 ON 02/09/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.2	GPM TOTAL FLOW is 29114011	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 26551528	GAL	
ASBPRS is 11.4	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 404534	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.44	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 35.36	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.61	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 52.7	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/20/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:33:04 ON 03/19/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 23.9	GPM TOTAL FLOW is 29148122	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 26582270	GAL	
ASBPRS is 11.1	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 405211	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.44	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.31	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.36	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 53.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/21/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:33:04 ON 03/19/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.4	GPM TOTAL FLOW is 29182827	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 26613633	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 405752	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.12	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.25	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 57.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/22/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:33:04 ON 03/19/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 23.8	GPM TOTAL FLOW is 29217516	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 26645012	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 406276	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.09	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.31	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTTEMP is 56.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT HAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/23/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:33:04 ON 03/19/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACEFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.3	GPM TOTAL FLOW is 29252200	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 26676373	GAL	
ASBPRS is 11.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 407007	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.41	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.20	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.40	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTTEMP is 51.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/24/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:33:04 ON 03/19/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.2	GPM TOTAL FLOW is 29286862	GAL	
W2_FLO is 21.8	GPM TOTAL FLOW is 26707713	GAL	
ASBPRS is 11.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 2.34	GPM TOTAL FLOW is 407826	GAL	
HP_PRS is 8.4	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 4.70	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.45	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.37	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.30	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.42	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 53.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/25/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:33:04 ON 03/19/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACEAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.2	GPM TOTAL FLOW is 29321543	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 26739052	GAL	
ASBPRS is 11.3	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 408494	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.63	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 35.34	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.29	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 56.0	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/26/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:33:04 ON 03/19/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 23.9	GPM TOTAL FLOW is 29356199	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 26770404	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 409004	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.46	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.97	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.15	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 59.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



Appendix B

O&M Checklists and System
Operation Logs

Date	1/20/2015
Inspector	J. Wyckoff
Time	7:30

[illegible]

Date	2/25/2015
Inspector	J.Wyckoff
Time	11:30

Approximately 3ft snow. Monitoring wells not inspected.

Gladding Cordage
South Otselic, New York
NYSDEC Site #709009

Date 3/19/2015
Inspector J.Wyckoff
Time 9:20

Treatment System Operation		Alarms	
System On (Y/N)	Y	A/C Fail (Y/N)	N
RW-1 On (Y/N)	Y	RW-1 (Y/N)	N
RW-2 On (Y/N)	Y	RW-2 (Y/N)	N
Blower On (Y/N)	Y	Blower Pressure (Y/N)	N
Sump Pump On (Y/N)	N	Sump Level (Y/N)	N

Recovery Wells	RW-1	RW-2
Flow Rate (GPM)	21.7	23.9
Total Flow (Gallons)	29114011	26551528
Water Level (Feet Above Probe)	35.40	56.36
Probe Depth (Feet BTOC)	40.00	65.00

Air Stripper			
Blower VFD Setting (Hertz)	46	Intake/Exhaust Piping OK? (Y/N)	Y
System Pressure (inches water)	11.2	Water Leaks (Y/N)	N
Influent/Effluent Piping OK? (Y/N)	Y	Water Temperature (°F)	50

Heat Exchanger			
Heat (On/Off)	On	Building Temperature (°F)	53
Heat Exchanger Flow (GPM)	0.0	Heat Exchanger Pressure (PSI)	1.4

General Building/Site			
Building Condition OK? (Y/N)	Y	Circuit Breakers Checked (Y/N)	Y
Grass Mowed (Y/N)	NA	Outfall Condition OK? (Y/N)	Y
Monitoring Wells OK? (Y/N)	NA	Samples Collected (Y/N)	Y

Notes:

Aproximately 1ft snow/ice.

Blower motor bearing making noise. Attempt to grease bearing but did not readily take grease.
Shut down blower. Clean grease passages in motor. Grease blower - noise gone.



Appendix C

Analytical Reporting Forms

February 17, 2015

Jeremy Wyckoff
Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065

Project Location: S. Ostellic, NY
Client Job Number:
Project Number: 00266406.0000
Laboratory Work Order Number: 15A0677

Enclosed are results of analyses for samples received by the laboratory on January 21, 2015. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "Aaron L. Benoit", with a long horizontal line extending to the right.

Aaron L. Benoit
Project Manager

Table of Contents

Sample Summary	3
Case Narrative	4
Sample Results	5
15A0677-01	5
15A0677-02	6
15A0677-03	7
15A0677-04	8
Sample Preparation Information	9
QC Data	10
Volatile Organic Compounds by GC/MS	10
B114193	10
Flag/Qualifier Summary	12
Certifications	13
Chain of Custody/Sample Receipt	15

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065
ATTN: Jeremy Wyckoff

REPORT DATE: 2/17/2015

PURCHASE ORDER NUMBER:

PROJECT NUMBER: 00266406.0000

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 15A0677

The results of analyses performed on the following samples submitted to the CON-TEST Analytical Laboratory are found in this report.

PROJECT LOCATION: S. Ostellic, NY


FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
RW-1	15A0677-01	Ground Water		EPA 624	
RW-2	15A0677-02	Ground Water		EPA 624	
EFF 46HZ	15A0677-03	Ground Water		EPA 624	
Trip Blank	15A0677-04	Trip Blank Water		EPA 624	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Con-Test Analytical Laboratory for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.

A handwritten signature in dark ink, appearing to read "Johanna Harrington", is written over a light-colored, slightly textured background.

Johanna K. Harrington

Manager, Laboratory Reporting

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Ostellic, NY

Sample Description:

Work Order: 15A0677

Date Received: 1/21/2015

Field Sample #: RW-1

Sampled: 1/20/2015 08:50

Sample ID: 15A0677-01

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
1,1-Dichloroethane	1.8	2.0	0.16	µg/L	1	J	EPA 624	1/26/15	1/30/15 20:38	EEH
1,1-Dichloroethylene	1.3	2.0	0.21	µg/L	1	J	EPA 624	1/26/15	1/30/15 20:38	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
1,1,1-Trichloroethane	43	2.0	0.094	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	1/26/15	1/30/15 20:38	EEH

Surrogates	% Recovery	Recovery Limits	Flag/Qual
1,2-Dichloroethane-d4	100	70-130	1/30/15 20:38
Toluene-d8	99.4	70-130	1/30/15 20:38
4-Bromofluorobenzene	96.4	70-130	1/30/15 20:38

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Ostellic, NY

Sample Description:

Work Order: 15A0677

Date Received: 1/21/2015

Sampled: 1/20/2015 08:55

Field Sample #: RW-2

Sample ID: 15A0677-02

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
1,1-Dichloroethylene	0.38	2.0	0.21	µg/L	1	J	EPA 624	1/26/15	1/30/15 21:05	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
1,1,1-Trichloroethane	15	2.0	0.094	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	1/26/15	1/30/15 21:05	EEH
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	97.0	70-130				1/30/15 21:05				
Toluene-d8	98.1	70-130				1/30/15 21:05				
4-Bromofluorobenzene	95.8	70-130				1/30/15 21:05				

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Ostellic, NY

Sample Description:

Work Order: 15A0677

Date Received: 1/21/2015

Field Sample #: EFF 46HZ

Sampled: 1/20/2015 09:00

Sample ID: 15A0677-03

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	1/26/15	1/30/15 20:12	EEH

Surrogates	% Recovery	Recovery Limits	Flag/Qual
1,2-Dichloroethane-d4	100	70-130	1/30/15 20:12
Toluene-d8	98.4	70-130	1/30/15 20:12
4-Bromofluorobenzene	95.1	70-130	1/30/15 20:12

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Ostellic, NY

Sample Description:

Work Order: 15A0677

Date Received: 1/21/2015

Field Sample #: Trip Blank

Sampled: 1/20/2015 00:00

Sample ID: 15A0677-04

Sample Matrix: Trip Blank Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	1/26/15	1/30/15 19:45	EEH
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	99.2	70-130				1/30/15 19:45				
Toluene-d8	99.4	70-130				1/30/15 19:45				
4-Bromofluorobenzene	97.3	70-130				1/30/15 19:45				

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Sample Extraction Data

Prep Method: SW-846 5030B-EPA 624

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
15A0677-01 [RW-1]	B114193	5	5.00	01/26/15
15A0677-02 [RW-2]	B114193	5	5.00	01/26/15
15A0677-03 [EFF 46HZ]	B114193	5	5.00	01/26/15
15A0677-04 [Trip Blank]	B114193	5	5.00	01/26/15

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL
Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

Batch B114193 - SW-846 5030B
Blank (B114193-BLK1)

Prepared: 01/26/15 Analyzed: 01/30/15

Benzene	ND	1.0	µg/L							
Bromodichloromethane	ND	2.0	µg/L							
Bromoform	ND	2.0	µg/L							
Bromomethane	ND	2.0	µg/L							
Carbon Tetrachloride	ND	2.0	µg/L							
Chlorobenzene	ND	2.0	µg/L							
Chlorodibromomethane	ND	2.0	µg/L							
Chloroethane	ND	2.0	µg/L							
2-Chloroethyl Vinyl Ether	ND	10	µg/L							
Chloroform	ND	2.0	µg/L							
Chloromethane	ND	2.0	µg/L							
1,2-Dichlorobenzene	ND	2.0	µg/L							
1,3-Dichlorobenzene	ND	2.0	µg/L							
1,4-Dichlorobenzene	ND	2.0	µg/L							
1,2-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethylene	ND	2.0	µg/L							
trans-1,2-Dichloroethylene	ND	2.0	µg/L							
1,2-Dichloropropane	ND	2.0	µg/L							
cis-1,3-Dichloropropene	ND	2.0	µg/L							
trans-1,3-Dichloropropene	ND	2.0	µg/L							
Ethylbenzene	ND	2.0	µg/L							
Methyl tert-Butyl Ether (MTBE)	ND	2.0	µg/L							
Methylene Chloride	ND	5.0	µg/L							
1,1,2,2-Tetrachloroethane	ND	2.0	µg/L							
Tetrachloroethylene	ND	2.0	µg/L							
Toluene	ND	1.0	µg/L							
1,1,1-Trichloroethane	ND	2.0	µg/L							
1,1,2-Trichloroethane	ND	2.0	µg/L							
Trichloroethylene	ND	2.0	µg/L							
Trichlorofluoromethane (Freon 11)	ND	2.0	µg/L							
Vinyl Chloride	ND	2.0	µg/L							
m+p Xylene	ND	2.0	µg/L							
o-Xylene	ND	2.0	µg/L							
Surrogate: 1,2-Dichloroethane-d4	25.0		µg/L	25.0		100	70-130			
Surrogate: Toluene-d8	24.7		µg/L	25.0		98.9	70-130			
Surrogate: 4-Bromofluorobenzene	24.0		µg/L	25.0		95.8	70-130			

LCS (B114193-BS1)

Prepared: 01/26/15 Analyzed: 01/30/15

Benzene	10.3	1.0	µg/L	10.0		103	37-151			
Bromodichloromethane	10.4	2.0	µg/L	10.0		104	35-155			
Bromoform	10.6	2.0	µg/L	10.0		106	45-169			
Bromomethane	12.1	2.0	µg/L	10.0		121	20-242			
Carbon Tetrachloride	9.93	2.0	µg/L	10.0		99.3	70-140			
Chlorobenzene	10.1	2.0	µg/L	10.0		101	37-160			
Chlorodibromomethane	9.39	2.0	µg/L	10.0		93.9	53-149			
Chloroethane	9.77	2.0	µg/L	10.0		97.7	70-130			
2-Chloroethyl Vinyl Ether	94.0	10	µg/L	100		94.0	10-305			
Chloroform	10.2	2.0	µg/L	10.0		102	51-138			
Chloromethane	9.96	2.0	µg/L	10.0		99.6	20-273			
1,2-Dichlorobenzene	10.4	2.0	µg/L	10.0		104	18-190			
1,3-Dichlorobenzene	10.3	2.0	µg/L	10.0		103	59-156			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL

Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch B114193 - SW-846 5030B										
LCS (B114193-BS1)				Prepared: 01/26/15 Analyzed: 01/30/15						
1,4-Dichlorobenzene	9.96	2.0	µg/L	10.0		99.6	18-190			
1,2-Dichloroethane	9.41	2.0	µg/L	10.0		94.1	49-155			
1,1-Dichloroethane	10.5	2.0	µg/L	10.0		105	59-155			
1,1-Dichloroethylene	10.3	2.0	µg/L	10.0		103	20-234			
trans-1,2-Dichloroethylene	10.4	2.0	µg/L	10.0		104	54-156			
1,2-Dichloropropane	10.3	2.0	µg/L	10.0		103	20-210			
cis-1,3-Dichloropropene	9.76	2.0	µg/L	10.0		97.6	20-227			
trans-1,3-Dichloropropene	10.5	2.0	µg/L	10.0		105	17-183			
Ethylbenzene	10.1	2.0	µg/L	10.0		101	37-162			
Methyl tert-Butyl Ether (MTBE)	11.2	2.0	µg/L	10.0		112	70-130			
Methylene Chloride	10.7	5.0	µg/L	10.0		107	50-221			
1,1,2,2-Tetrachloroethane	11.9	2.0	µg/L	10.0		119	46-157			
Tetrachloroethylene	10.1	2.0	µg/L	10.0		101	64-148			
Toluene	9.89	1.0	µg/L	10.0		98.9	47-150			
1,1,1-Trichloroethane	10.5	2.0	µg/L	10.0		105	52-162			
1,1,2-Trichloroethane	10.2	2.0	µg/L	10.0		102	52-150			
Trichloroethylene	10.6	2.0	µg/L	10.0		106	71-157			
Trichlorofluoromethane (Freon 11)	10.2	2.0	µg/L	10.0		102	17-181			
Vinyl Chloride	11.1	2.0	µg/L	10.0		111	20-251			
m+p Xylene	19.9	2.0	µg/L	20.0		99.4	70-130			
o-Xylene	9.97	2.0	µg/L	10.0		99.7	70-130			
Surrogate: 1,2-Dichloroethane-d4	25.8		µg/L	25.0		103	70-130			
Surrogate: Toluene-d8	24.2		µg/L	25.0		97.0	70-130			
Surrogate: 4-Bromofluorobenzene	24.2		µg/L	25.0		96.9	70-130			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
	Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
	No results have been blank subtracted unless specified in the case narrative section.
J	Detected but below the Reporting Limit (lowest calibration standard); therefore, result is an estimated concentration (CLP J-Flag).

CERTIFICATIONS

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 624 in Water</i>	
Benzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromodichloromethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromoform	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromomethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Carbon Tetrachloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chlorodibromomethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
2-Chloroethyl Vinyl Ether	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloroform	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloromethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,3-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,4-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
trans-1,2-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichloropropane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
cis-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
trans-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Ethylbenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Methyl tert-Butyl Ether (MTBE)	NC
Methylene Chloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,2,2-Tetrachloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Tetrachloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Toluene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,1-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,2-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Trichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Trichlorofluoromethane (Freon 11)	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Vinyl Chloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
m+p Xylene	CT,MA,NH,NY,RI,NC,VA,NJ
o-Xylene	CT,MA,NH,NY,RI,NC,VA,NJ

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

The CON-TEST Environmental Laboratory operates under the following certifications and accreditations:

Code	Description	Number	Expires
AIHA	AIHA-LAP, LLC	100033	02/1/2016
MA	Massachusetts DEP	M-MA100	06/30/2015
CT	Connecticut Department of Public Health	PH-0567	09/30/2015
NY	New York State Department of Health	10899 NELAP	04/1/2015
NH-S	New Hampshire Environmental Lab	2516 NELAP	02/5/2016
RI	Rhode Island Department of Health	LAO00112	12/30/2015
NC	North Carolina Div. of Water Quality	652	12/31/2015
NJ	New Jersey DEP	MA007 NELAP	06/30/2015
FL	Florida Department of Health	E871027 NELAP	06/30/2015
VT	Vermont Department of Health Lead Laboratory	LL015036	07/30/2015
WA	State of Washington Department of Ecology	C2065	02/23/2015
ME	State of Maine	2011028	06/9/2015
VA	Commonwealth of Virginia	460217	12/14/2015
NH-P	New Hampshire Environmental Lab	2557 NELAP	09/6/2015



Phone: 413-525-2332
Fax: 413-525-6405
Email: info@contestlabs.com
www.contestlabs.com

CHAIN OF CUSTODY RECORD

39 Spruce Street
East longmeadow, MA 01028

Page 1 of 1

Company Name: **ARCADIS**

Address: **855 Route 146, Ste 210
Clifton Park, NY 12065**

Attention: **J. Wyckoff**

Project Location: **S. Oteselic, NY**

Sampled By: **J. Wyckoff**

Project Proposal Provided? (for billing purposes)
☐ Yes ☐ No proposal date

Telephone: **518-250-7300**

Project # **60266406.0000**

Client PO#

DATA DELIVERY (check all that apply)

☐ FAX ☒ EMAIL ☐ WEBSITE

Fax #

Email: **j.cremy.wyckoff@arcadis**

Format: ☒ PDF ☒ EXCEL ☐ GIS

☐ OTHER **NYS DEC 604-ES**

☐ "Enhanced Data Package"

Collection

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Data

Conc. Date

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

01 RW-1

02 RW-2

03 EFF 46 HZ

04 Trip Blank

Relinquished by: (signature)

Date/Time: 1/21/15

Received by: (signature)

Date/Time: 1/21/15

Relinquished by: (signature)

Date/Time: 1/21/15

Received by: (signature)

Date/Time: 1/22/15

Relinquished by: (signature)

Date/Time: 1/22/15

Turnaround ^{††}

☐ 7-Day

☒ 10-Day

☐ Other

RUSH [†]

☐ 24-Hr ☐ 48-Hr

☐ 72-Hr ☐ 14-Day

☐ Require lab approval

Detection Limit Requirements

Massachusetts:

Connecticut:

Other: **NYS ASD B.**

Is your project MCP or RCP?

☐ MCP Form Required

☐ RCP Form Required

☐ MA State DW Form Required PWSID #

NELAC & AIHA-LAP, LLC

Accredited

WBE/DBE Certified

My Profile

Support

Locations

English

Search



Ship

Track

Manage

Learn

FedEx Office®

Login

FedEx® Tracking

772660763747Ship (P/U) date :
Wed 1/21/2015 4:41 pmActual delivery :
Thur 1/22/2015 10:17 am

ALBANY, NY US

**Delivered**

Signed for by: P.BLAKE

EAST LONGMEADOW, MA US

3 Piece shipment

Travel History

▲ Date/Time	Activity	Location
■ 1/22/2015 - Thursday		
10:17 am	Delivered	EAST LONGMEADOW, MA
8:20 am	On FedEx vehicle for delivery	WINDSOR LOCKS, CT
8:13 am	At local FedEx facility	WINDSOR LOCKS, CT
3:30 am	Departed FedEx location	NEWARK, NJ
12:21 am	Arrived at FedEx location	NEWARK, NJ
■ 1/21/2015 - Wednesday		
9:00 pm	Left FedEx origin facility	MENANDS, NY
4:41 pm	Picked up	MENANDS, NY
2:16 pm	Shipment information sent to FedEx	

Shipment Facts

Tracking number	772660763747	Service	FedEx Priority Overnight
Master tracking number	772660764169	Weight	9 lbs / 4.08 kgs
Dimensions	13x9x9 in.	Delivered To	Shipping/Receiving
Total pieces	3	Total shipment weight	9 lbs / 4.08 kgs
Shipper reference	85	Packaging	Your Packaging
Special handling section	Deliver Weekday		



Search

Customer Focus

New Customer Center
Small Business Center
Service Guide
Customer Support
My FedEx Office Rewards

Company Information

About FedEx
Careers
Investor Relations

Featured Services

FedEx One Rate
FedEx SameDay
FedEx Home Delivery
Healthcare Solutions
Online Retail Solutions
Packaging Services
Ancillary Clearance Services

Other Resources

FedEx Compatible
Developer Resource Center
FedEx Ship Manager Software
FedEx Mobile

Companies

FedEx Express
FedEx Ground
FedEx Office
FedEx Freight
FedEx Custom Critical
FedEx Trade Networks
FedEx SupplyChain
FedEx TechConnect

Follow FedEx

United States - English

39 Spruce St.
East Longmeadow, MA. 01028
P: 413-525-2332
F: 413-525-6405
www.contestlabs.com



Page 1 of 2



Sample Receipt Checklist

CLIENT NAME: Accadis RECEIVED BY: MT DATE: 11/22/15

1) Was the chain(s) of custody relinquished and signed? Yes No No CoC Included

2) Does the chain agree with the samples? Yes No

If not, explain:

3) Are all the samples in good condition? Yes No

If not, explain:

4) How were the samples received:

On Ice ☒ Direct from Sampling ☐ Ambient ☐ In Cooler(s) ☒

Were the samples received in Temperature Compliance of (2-6°C)? Yes No N/A

Temperature °C by Temp blank 3.0 °C Temperature °C by Temp gun _____

5) Are there Dissolved samples for the lab to filter? Yes No

Who was notified _____ Date _____ Time _____

6) Are there any RUSH or SHORT HOLDING TIME samples? Yes No

Who was notified _____ Date _____ Time _____

7) Location where samples are stored:

19

Permission to subcontract samples? Yes No

(Walk-in clients only) if not already approved

Client Signature: _____

8) Do all samples have the proper Acid pH: Yes No N/A

9) Do all samples have the proper Base pH: Yes No N/A

10) Was the PC notified of any discrepancies with the CoC vs the samples: Yes No N/A

Containers received at Con-Test

	# of containers		# of containers
1 Liter Amber		8 oz amber/clear jar	
500 mL Amber		4 oz amber/clear jar	
250 mL Amber (8oz amber)		2 oz amber/clear jar	
1 Liter Plastic		Plastic Bag / Ziploc	
500 mL Plastic		SOC Kit	
250 mL plastic		Non-ConTest Container	
40 mL Vial - type listed below	<u>14</u>	Perchlorate Kit	
Colisure / bacteria bottle		Flashpoint bottle	
Dissolved Oxygen bottle		Other glass jar	
Encore		Other	

Laboratory Comments:

40 mL vials: # HCl 14 # Methanol _____

Time and Date Frozen:

Doc# 277 # Bisulfate _____ # DI Water _____

Rev. 4 August 2013 # Thiosulfate _____ Unpreserved _____

Login Sample Receipt Checklist**(Rejection Criteria Listing - Using Sample Acceptance Policy)****Any False statement will be brought to the attention of Client**

Question	Answer (True/False)	Comment
	T/F/NA	
1) The cooler's custody seal, if present, is intact.	T	
2) The cooler or samples do not appear to have been compromised or tampered with.	T	
3) Samples were received on ice.	T	
4) Cooler Temperature is acceptable.	T	
5) Cooler Temperature is recorded.	T	
6) COC is filled out in ink and legible.	T	
7) COC is filled out with all pertinent information.	T	
8) Field Sampler's name present on COC.	T	
9) There are no discrepancies between the sample IDs on the container and the COC.	T	
10) Samples are received within Holding Time.	T	
11) Sample containers have legible labels.	T	
12) Containers are not broken or leaking.	T	
13) Air Cassettes are not broken/open.	NA	
14) Sample collection date/times are provided.	T	
15) Appropriate sample containers are used.	T	
16) Proper collection media used.	T	
17) No headspace sample bottles are completely filled.	T	
18) There is sufficient volume for all requested analyses, including any requested MS/MSDs.	T	
19) Trip blanks provided if applicable.	T	
20) VOA sample vials do not have head space or bubble is <6mm (1/4") in diameter.	T	
21) Samples do not require splitting or compositing.	T	

Doc #277 Rev. 4 August 2013

Who notified of False statements?

Log-In Technician Initials:

Date/Time:

Date/Time:

MJ

11/22/15

10:17

March 11, 2015

Jeremy Wyckoff
Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065

Project Location: South Otselic, NY
Client Job Number:
Project Number: 00266406.0000
Laboratory Work Order Number: 15B0871

Enclosed are results of analyses for samples received by the laboratory on February 26, 2015. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "Aaron L. Benoit", with a horizontal line extending to the right.

Aaron L. Benoit
Project Manager

Table of Contents

Sample Summary	3
Case Narrative	4
Sample Results	5
15B0871-01	5
15B0871-02	6
15B0871-03	7
15B0871-04	8
Sample Preparation Information	9
QC Data	10
Volatile Organic Compounds by GC/MS	10
B116090	10
Flag/Qualifier Summary	12
Certifications	13
Chain of Custody/Sample Receipt	15

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065
ATTN: Jeremy Wyckoff

REPORT DATE: 3/11/2015

PURCHASE ORDER NUMBER:

PROJECT NUMBER: 00266406.0000

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 15B0871

The results of analyses performed on the following samples submitted to the CON-TEST Analytical Laboratory are found in this report.

PROJECT LOCATION: South Otselic, NY


FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
RW-1	15B0871-01	Ground Water		EPA 624	
RW-2	15B0871-02	Ground Water		EPA 624	
Eff 46 HZ	15B0871-03	Ground Water		EPA 624	
Trip Blank	15B0871-04	Trip Blank Water		EPA 624	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Con-Test Analytical Laboratory for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.

A handwritten signature in dark ink, appearing to read "Johanna Harrington", is written over a light-colored, slightly textured background.

Johanna K. Harrington

Manager, Laboratory Reporting

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: South Otselic, NY

Sample Description:

Work Order: 15B0871

Date Received: 2/26/2015

Field Sample #: RW-1

Sampled: 2/25/2015 10:50

Sample ID: 15B0871-01

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
1,1-Dichloroethane	1.6	2.0	0.16	µg/L	1	J	EPA 624	2/27/15	2/27/15 18:52	CMR
1,1-Dichloroethylene	0.93	2.0	0.21	µg/L	1	J	EPA 624	2/27/15	2/27/15 18:52	CMR
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
1,1,1-Trichloroethane	40	2.0	0.094	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	2/27/15	2/27/15 18:52	CMR

Surrogates	% Recovery	Recovery Limits	Flag/Qual
1,2-Dichloroethane-d4	101	70-130	2/27/15 18:52
Toluene-d8	101	70-130	2/27/15 18:52
4-Bromofluorobenzene	96.7	70-130	2/27/15 18:52

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: South Otselic, NY

Sample Description:

Work Order: 15B0871

Date Received: 2/26/2015

Field Sample #: RW-2

Sampled: 2/25/2015 10:55

Sample ID: 15B0871-02

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
1,1-Dichloroethane	0.76	2.0	0.16	µg/L	1	J	EPA 624	2/27/15	2/27/15 19:20	CMR
1,1-Dichloroethylene	0.68	2.0	0.21	µg/L	1	J	EPA 624	2/27/15	2/27/15 19:20	CMR
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
1,1,1-Trichloroethane	34	2.0	0.094	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	2/27/15	2/27/15 19:20	CMR

Surrogates	% Recovery	Recovery Limits	Flag/Qual
1,2-Dichloroethane-d4	104	70-130	2/27/15 19:20
Toluene-d8	98.9	70-130	2/27/15 19:20
4-Bromofluorobenzene	97.9	70-130	2/27/15 19:20

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: South Otselic, NY

Sample Description:

Work Order: 15B0871

Date Received: 2/26/2015

Sampled: 2/25/2015 11:00

Field Sample #: Eff 46 HZ

Sample ID: 15B0871-03

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	2/27/15	2/27/15 18:24	CMR

Surrogates	% Recovery	Recovery Limits	Flag/Qual
1,2-Dichloroethane-d4	107	70-130	2/27/15 18:24
Toluene-d8	97.9	70-130	2/27/15 18:24
4-Bromofluorobenzene	96.8	70-130	2/27/15 18:24

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: South Otselic, NY

Sample Description:

Work Order: 15B0871

Date Received: 2/26/2015

Field Sample #: Trip Blank

Sampled: 2/25/2015 00:00

Sample ID: 15B0871-04

Sample Matrix: Trip Blank Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	2/27/15	2/27/15 17:56	CMR
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	104	70-130				2/27/15 17:56				
Toluene-d8	97.5	70-130				2/27/15 17:56				
4-Bromofluorobenzene	97.8	70-130				2/27/15 17:56				

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Sample Extraction Data

Prep Method: SW-846 5030B-EPA 624

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
15B0871-01 [RW-1]	B116090	5	5.00	02/27/15
15B0871-02 [RW-2]	B116090	5	5.00	02/27/15
15B0871-03 [Eff 46 HZ]	B116090	5	5.00	02/27/15
15B0871-04 [Trip Blank]	B116090	5	5.00	02/27/15

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL

Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

Batch B116090 - SW-846 5030B

Blank (B116090-BLK1)

Prepared & Analyzed: 02/27/15

Benzene	ND	1.0	µg/L							
Bromodichloromethane	ND	2.0	µg/L							
Bromoform	ND	2.0	µg/L							
Bromomethane	ND	2.0	µg/L							
Carbon Tetrachloride	ND	2.0	µg/L							
Chlorobenzene	ND	2.0	µg/L							
Chlorodibromomethane	ND	2.0	µg/L							
Chloroethane	ND	2.0	µg/L							
2-Chloroethyl Vinyl Ether	ND	10	µg/L							
Chloroform	ND	2.0	µg/L							
Chloromethane	ND	2.0	µg/L							
1,2-Dichlorobenzene	ND	2.0	µg/L							
1,3-Dichlorobenzene	ND	2.0	µg/L							
1,4-Dichlorobenzene	ND	2.0	µg/L							
1,2-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethylene	ND	2.0	µg/L							
trans-1,2-Dichloroethylene	ND	2.0	µg/L							
1,2-Dichloropropane	ND	2.0	µg/L							
cis-1,3-Dichloropropene	ND	2.0	µg/L							
trans-1,3-Dichloropropene	ND	2.0	µg/L							
Ethylbenzene	ND	2.0	µg/L							
Methyl tert-Butyl Ether (MTBE)	ND	2.0	µg/L							
Methylene Chloride	ND	5.0	µg/L							
1,1,2,2-Tetrachloroethane	ND	2.0	µg/L							
Tetrachloroethylene	ND	2.0	µg/L							
Toluene	ND	1.0	µg/L							
1,1,1-Trichloroethane	ND	2.0	µg/L							
1,1,2-Trichloroethane	ND	2.0	µg/L							
Trichloroethylene	ND	2.0	µg/L							
Trichlorofluoromethane (Freon 11)	ND	2.0	µg/L							
Vinyl Chloride	ND	2.0	µg/L							
m+p Xylene	ND	2.0	µg/L							
o-Xylene	ND	2.0	µg/L							
Surrogate: 1,2-Dichloroethane-d4	26.3		µg/L	25.0		105	70-130			
Surrogate: Toluene-d8	24.6		µg/L	25.0		98.6	70-130			
Surrogate: 4-Bromofluorobenzene	24.3		µg/L	25.0		97.2	70-130			

LCS (B116090-BS1)

Prepared & Analyzed: 02/27/15

Benzene	10.4	1.0	µg/L	10.0		104	37-151			
Bromodichloromethane	10.3	2.0	µg/L	10.0		103	35-155			
Bromoform	10.6	2.0	µg/L	10.0		106	45-169			
Bromomethane	8.08	2.0	µg/L	10.0		80.8	20-242			
Carbon Tetrachloride	9.46	2.0	µg/L	10.0		94.6	70-140			
Chlorobenzene	9.36	2.0	µg/L	10.0		93.6	37-160			
Chlorodibromomethane	9.69	2.0	µg/L	10.0		96.9	53-149			
Chloroethane	9.09	2.0	µg/L	10.0		90.9	70-130			
2-Chloroethyl Vinyl Ether	137	10	µg/L	100		137	10-305			
Chloroform	9.45	2.0	µg/L	10.0		94.5	51-138			
Chloromethane	6.44	2.0	µg/L	10.0		64.4	20-273			
1,2-Dichlorobenzene	9.84	2.0	µg/L	10.0		98.4	18-190			
1,3-Dichlorobenzene	9.72	2.0	µg/L	10.0		97.2	59-156			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL

Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch B116090 - SW-846 5030B										
LCS (B116090-BS1)				Prepared & Analyzed: 02/27/15						
1,4-Dichlorobenzene	9.61	2.0	µg/L	10.0		96.1	18-190			
1,2-Dichloroethane	9.41	2.0	µg/L	10.0		94.1	49-155			
1,1-Dichloroethane	10.0	2.0	µg/L	10.0		100	59-155			
1,1-Dichloroethylene	9.52	2.0	µg/L	10.0		95.2	20-234			
trans-1,2-Dichloroethylene	9.67	2.0	µg/L	10.0		96.7	54-156			
1,2-Dichloropropane	9.95	2.0	µg/L	10.0		99.5	20-210			
cis-1,3-Dichloropropene	10.3	2.0	µg/L	10.0		103	20-227			
trans-1,3-Dichloropropene	11.1	2.0	µg/L	10.0		111	17-183			
Ethylbenzene	9.81	2.0	µg/L	10.0		98.1	37-162			
Methyl tert-Butyl Ether (MTBE)	11.7	2.0	µg/L	10.0		117	70-130			
Methylene Chloride	8.96	5.0	µg/L	10.0		89.6	50-221			
1,1,2,2-Tetrachloroethane	11.1	2.0	µg/L	10.0		111	46-157			
Tetrachloroethylene	9.65	2.0	µg/L	10.0		96.5	64-148			
Toluene	10.1	1.0	µg/L	10.0		101	47-150			
1,1,1-Trichloroethane	10.0	2.0	µg/L	10.0		100	52-162			
1,1,2-Trichloroethane	10.4	2.0	µg/L	10.0		104	52-150			
Trichloroethylene	10.0	2.0	µg/L	10.0		100	71-157			
Trichlorofluoromethane (Freon 11)	10.0	2.0	µg/L	10.0		100	17-181			
Vinyl Chloride	10.1	2.0	µg/L	10.0		101	20-251			
m+p Xylene	19.5	2.0	µg/L	20.0		97.4	70-130			
o-Xylene	9.78	2.0	µg/L	10.0		97.8	70-130			
Surrogate: 1,2-Dichloroethane-d4	26.6		µg/L	25.0		106	70-130			
Surrogate: Toluene-d8	24.7		µg/L	25.0		98.9	70-130			
Surrogate: 4-Bromofluorobenzene	24.7		µg/L	25.0		98.8	70-130			

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
	Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
	No results have been blank subtracted unless specified in the case narrative section.
J	Detected but below the Reporting Limit (lowest calibration standard); therefore, result is an estimated concentration (CLP J-Flag).

CERTIFICATIONS

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 624 in Water</i>	
Benzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromodichloromethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromoform	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromomethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Carbon Tetrachloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chlorodibromomethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
2-Chloroethyl Vinyl Ether	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloroform	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloromethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,3-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,4-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
trans-1,2-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichloropropane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
cis-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
trans-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Ethylbenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Methyl tert-Butyl Ether (MTBE)	NC
Methylene Chloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,2,2-Tetrachloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Tetrachloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Toluene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,1-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,2-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Trichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Trichlorofluoromethane (Freon 11)	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Vinyl Chloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
m+p Xylene	CT,MA,NH,NY,RI,NC,VA,NJ
o-Xylene	CT,MA,NH,NY,RI,NC,VA,NJ

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

The CON-TEST Environmental Laboratory operates under the following certifications and accreditations:

Code	Description	Number	Expires
AIHA	AIHA-LAP, LLC	100033	02/1/2016
MA	Massachusetts DEP	M-MA100	06/30/2015
CT	Connecticut Department of Public Health	PH-0567	09/30/2015
NY	New York State Department of Health	10899 NELAP	04/1/2015
NH-S	New Hampshire Environmental Lab	2516 NELAP	02/5/2016
RI	Rhode Island Department of Health	LAO00112	12/30/2015
NC	North Carolina Div. of Water Quality	652	12/31/2015
NJ	New Jersey DEP	MA007 NELAP	06/30/2015
FL	Florida Department of Health	E871027 NELAP	06/30/2015
VT	Vermont Department of Health Lead Laboratory	LL015036	07/30/2015
WA	State of Washington Department of Ecology	C2065	02/23/2016
ME	State of Maine	2011028	06/9/2015
VA	Commonwealth of Virginia	460217	12/14/2015
NH-P	New Hampshire Environmental Lab	2557 NELAP	09/6/2015



Phone: 413-525-2332
Fax: 413-525-6405
Email: info@contestlabs.com
www.contestlabs.com

CHAIN OF CUSTODY RECORD

39 Spruce Street
East longmeadow, MA 01028

Page 1 of 1

Company Name: ARCADIS

Address: 855 Route 146, Ste 210

Clifton Park, NY 12065

Attention: Jerry Wyckoff

Project Location: South Otsego, NY

Sampled By: J. Wyckoff

Project Proposal Provided? (for billing purposes)
☐ Yes ☐ No proposal date

Telephone: 518-250-7300

Project # 0026640610000

Client PO#

DATA DELIVERY (check all that apply)

☐ FAX ☒ EMAIL ☐ WEBSITE

Fax #

Email: jerry.wyckoff@arcadis-us.com

Format: ☒ PDF ☒ EXCEL ☐ GIS

☒ OTHER MSPEC Eqs. 15.1

☐ "Enhanced Data Package"

Con-Test Lab ID (laboratory use only)	Client Sample ID / Description	Beginning Date/Time	Ending Date/Time	Collection	Composite	Grab	*Matrix Code
01	RW-1	8/25/15	1050			X	GW M
02	RW-2		1055			X	GW M
03	EFF 46 HZ		1100			X	GW L
04	TEIP Blank						- - -

Comments:

Relinquished by: (signature) <u>Jerry Wyckoff</u>	Date/Time: 11/50 2/15/15
Received by: (signature) <u>5.1</u>	Date/Time: 2/26/15 1101
Relinquished by: (signature) <u>Jerry Wyckoff</u>	Date/Time: 2/26/15 1101
Received by: (signature)	Date/Time:

Turnaround ^{††}	7-Day ☐	10-Day ☒	Other ☐
RUSH [†]	☐ 24-Hr ☐ 48-Hr	☐ 72-Hr ☐ 14-Day	Require lab approval

Detection Limit Requirements	Massachusetts:	Connecticut:	Other: <u>MSPEC ASP B</u>
------------------------------	----------------	--------------	---------------------------

Is your project MCP or RCP?

- ☐ MCP Form Required
☐ RCP Form Required
☐ MA State DW Form Required

PWSID #

NELAC & AIHA-LAP, LLC
Accredited

WBE/DBE Certified

TURNAROUND TIME STARTS AT 9:00 A.M. THE DAY AFTER SAMPLE RECEIPT UNLESS THERE ARE QUESTIONS ON YOUR CHAIN. IF THIS FORM IS NOT FILLED OUT COMPLETELY OR IS INCORRECT, TURNAROUND TIME WILL NOT START UNTIL ALL QUESTIONS ARE ANSWERED BY OUR CLIENT.

PLEASE BE CAREFUL NOT TO CONTAMINATE THIS DOCUMENT



Ship

Track

Manage

Learn

FedEx Office®

Login

IMPORTANT!**FedEx is closely monitoring the winter storm in the midwest and southeastern U.S. Learn More**

FedEx Tracking

780263177170Ship (P/U) date :
Wed 2/25/2015 2:20 pm

CLIFTON PARK, NY US

**Delivered**

Signed for by: P.BLAKE

Actual delivery :
Thur 2/26/2015 11:01 am

East longmeadow, MA US

Travel History

▲ Date/Time	Activity	Location
■ 2/26/2015 - Thursday		
11:01 am	Delivered	East longmeadow, MA
8:29 am	On FedEx vehicle for delivery	WINDSOR LOCKS, CT
8:22 am	At local FedEx facility	WINDSOR LOCKS, CT
4:11 am	Departed FedEx location	NEWARK, NJ
■ 2/25/2015 - Wednesday		
11:15 pm	Arrived at FedEx location	NEWARK, NJ
7:17 pm	Left FedEx origin facility	BINGHAMTON, NY
2:20 pm	Picked up	BINGHAMTON, NY
1:24 pm	Shipment information sent to FedEx	

Shipment Facts

Tracking number	780263177170	Service	FedEx Priority Overnight
Weight	8 lbs / 3.63 kgs	Dimensions	13x10x10 in.
Delivered To	Shipping/Receiving	Total pieces	1
Total shipment weight	8 lbs / 3.63 kgs	Packaging	Your Packaging
Special handling section	Deliver Weekday		



Search

Customer Focus

New Customer Center
Small Business Center
Service Guide
Customer Support

Company Information

About FedEx
Careers
Investor Relations

Featured Services

FedEx One Rate
FedEx SameDay
FedEx Home Delivery
Healthcare Solutions
Online Retail Solutions
Packaging Services
Ancillary Clearance Services

Other Resources

FedEx Compatible
Developer Resource Center
FedEx Ship Manager Software
FedEx Mobile

Companies

FedEx Express
FedEx Ground
FedEx Office
FedEx Freight
FedEx Custom Critical
FedEx Trade Networks
FedEx SupplyChain
FedEx TechConnect

Follow FedEx

United States - English

39 Spruce St.
East Longmeadow, MA. 01028
P: 413-525-2332
F: 413-525-6405
www.contestlabs.com



Page 1 of 2



Sample Receipt Checklist

CLIENT NAME: Arcadis RECEIVED BY: JDL DATE: 2/26/15

- 1) Was the chain(s) of custody relinquished and signed? Yes No No CoC Included
- 2) Does the chain agree with the samples? Yes No
If not, explain:
- 3) Are all the samples in good condition? Yes No
If not, explain:

4) How were the samples received:

On Ice ☒ Direct from Sampling ☐ Ambient ☐ In Cooler(s) ☒

Were the samples received in Temperature Compliance of (2-6°C)? Yes No N/A

Temperature °C by Temp blank _____ Temperature °C by Temp gun 5.1

5) Are there Dissolved samples for the lab to filter? Yes No

Who was notified _____ Date _____ Time _____

6) Are there any RUSH or SHORT HOLDING TIME samples? Yes No

Who was notified _____ Date _____ Time _____

7) Location where samples are stored:

19

Permission to subcontract samples? Yes No

(Walk-in clients only) if not already approved

Client Signature: _____

8) Do all samples have the proper Acid pH: Yes No N/A

9) Do all samples have the proper Base pH: Yes No N/A

10) Was the PC notified of any discrepancies with the CoC vs the samples: Yes No N/A

Containers received at Con-Test

	# of containers			# of containers
1 Liter Amber			8 oz amber/clear jar	
500 mL Amber			4 oz amber/clear jar	
250 mL Amber (8oz amber)			2 oz amber/clear jar	
1 Liter Plastic			Plastic Bag / Ziploc	
500 mL Plastic			SOC Kit	
250 mL plastic			Non-ConTest Container	
40 mL Vial - type listed below	<u>11</u>		Perchlorate Kit	
Colisure / bacteria bottle			Flashpoint bottle	
Dissolved Oxygen bottle			Other glass jar	
Encore			Other	

Laboratory Comments:

40 mL vials: # HCl 11 # Methanol _____

Doc# 277 # Bisulfate _____ # DI Water _____

Rev. 4 August 2013 # Thiosulfate _____ Unpreserved _____

Time and Date Frozen:

Login Sample Receipt Checklist

(Rejection Criteria Listing - Using Sample Acceptance Policy)

Any False statement will be brought to the attention of Client

Question	Answer (True/False)		Comment
	T/F/NA		
1) The cooler's custody seal, if present, is intact.	NA		
2) The cooler or samples do not appear to have been compromised or tampered with.	T		
3) Samples were received on ice.	T		
4) Cooler Temperature is acceptable.	T		
5) Cooler Temperature is recorded.	T		
6) COC is filled out in ink and legible.	T		
7) COC is filled out with all pertinent information.	T		
8) Field Sampler's name present on COC.	T		
9) There are no discrepancies between the sample IDs on the container and the COC.	T		
10) Samples are received within Holding Time.	T		
11) Sample containers have legible labels.	T		
12) Containers are not broken or leaking.	T		
13) Air Cassettes are not broken/open.	NA		
14) Sample collection date/times are provided.	T		
15) Appropriate sample containers are used.	T		
16) Proper collection media used.	T		
17) No headspace sample bottles are completely filled.	T		
18) There is sufficient volume for all requested analyses, including any requested MS/MSDs.	T		
19) Trip blanks provided if applicable.	T		
20) VOA sample vials do not have head space or bubble is <6mm (1/4") in diameter.	T		
21) Samples do not require splitting or compositing.	T		

Doc #277 Rev. 4 August 2013

Who notified of False statements?

Log-In Technician Initials: JDL

Date/Time:

Date/Time: 2/26/15 1101

April 2, 2015

Jeremy Wyckoff
Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065

Project Location: S. Otselic, NY
Client Job Number:
Project Number: 00266406.0000
Laboratory Work Order Number: 15C0779

Enclosed are results of analyses for samples received by the laboratory on March 20, 2015. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "Aaron L. Benoit", with a long horizontal line extending to the right.

Aaron L. Benoit
Project Manager

Table of Contents

Sample Summary	3
Case Narrative	4
Sample Results	5
15C0779-01	5
15C0779-02	6
15C0779-03	7
15C0779-04	8
Sample Preparation Information	9
QC Data	10
Volatile Organic Compounds by GC/MS	10
B117960	10
Flag/Qualifier Summary	12
Certifications	13
Chain of Custody/Sample Receipt	15

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065
ATTN: Jeremy Wyckoff

REPORT DATE: 4/2/2015

PURCHASE ORDER NUMBER:

PROJECT NUMBER: 00266406.0000

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 15C0779

The results of analyses performed on the following samples submitted to the CON-TEST Analytical Laboratory are found in this report.

PROJECT LOCATION: S. Otselic, NY


FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
RW-1	15C0779-01	Ground Water		EPA 624	
RW-2	15C0779-02	Ground Water		EPA 624	
Eff 46 HZ	15C0779-03	Ground Water		EPA 624	
Trip Blank	15C0779-04	Trip Blank Water		EPA 624	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Con-Test Analytical Laboratory for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.

A handwritten signature in dark ink, appearing to read "Johanna Harrington", is written over a light-colored, slightly textured background.

Johanna K. Harrington
Manager, Laboratory Reporting

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 15C0779

Date Received: 3/20/2015

Sampled: 3/19/2015 09:10

Field Sample #: RW-1

Sample ID: 15C0779-01

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
1,1-Dichloroethane	1.5	2.0	0.16	µg/L	1	J	EPA 624	3/27/15	3/27/15 18:33	EEH
1,1-Dichloroethylene	0.89	2.0	0.21	µg/L	1	J	EPA 624	3/27/15	3/27/15 18:33	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
1,1,1-Trichloroethane	36	2.0	0.094	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	3/27/15	3/27/15 18:33	EEH

Surrogates	% Recovery	Recovery Limits	Flag/Qual
1,2-Dichloroethane-d4	103	70-130	3/27/15 18:33
Toluene-d8	95.7	70-130	3/27/15 18:33
4-Bromofluorobenzene	95.9	70-130	3/27/15 18:33

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 15C0779

Date Received: 3/20/2015

Sampled: 3/19/2015 09:15

Field Sample #: RW-2

Sample ID: 15C0779-02

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
1,1-Dichloroethane	0.69	2.0	0.16	µg/L	1	J	EPA 624	3/27/15	3/27/15 19:00	EEH
1,1-Dichloroethylene	0.68	2.0	0.21	µg/L	1	J	EPA 624	3/27/15	3/27/15 19:00	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
1,1,1-Trichloroethane	31	2.0	0.094	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	3/27/15	3/27/15 19:00	EEH
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	104	70-130				3/27/15 19:00				
Toluene-d8	95.4	70-130				3/27/15 19:00				
4-Bromofluorobenzene	94.8	70-130				3/27/15 19:00				

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 15C0779

Date Received: 3/20/2015

Sampled: 3/19/2015 09:20

Field Sample #: Eff 46 HZ

Sample ID: 15C0779-03

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	3/27/15	3/27/15 18:07	EEH
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	102	70-130				3/27/15 18:07				
Toluene-d8	96.7	70-130				3/27/15 18:07				
4-Bromofluorobenzene	95.3	70-130				3/27/15 18:07				

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 15C0779

Date Received: 3/20/2015

Field Sample #: Trip Blank

Sampled: 3/19/2015 00:00

Sample ID: 15C0779-04

Sample Matrix: Trip Blank Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	3/27/15	3/27/15 17:41	EEH

Surrogates	% Recovery	Recovery Limits	Flag/Qual
1,2-Dichloroethane-d4	104	70-130	3/27/15 17:41
Toluene-d8	97.2	70-130	3/27/15 17:41
4-Bromofluorobenzene	94.9	70-130	3/27/15 17:41

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Sample Extraction Data

Prep Method: SW-846 5030B-EPA 624

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
15C0779-01 [RW-1]	B117960	5	5.00	03/27/15
15C0779-02 [RW-2]	B117960	5	5.00	03/27/15
15C0779-03 [Eff 46 HZ]	B117960	5	5.00	03/27/15
15C0779-04 [Trip Blank]	B117960	5	5.00	03/27/15

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL

Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

Batch B117960 - SW-846 5030B

Blank (B117960-BLK1)

Prepared & Analyzed: 03/27/15

Benzene	ND	1.0	µg/L							
Bromodichloromethane	ND	2.0	µg/L							
Bromoform	ND	2.0	µg/L							
Bromomethane	ND	2.0	µg/L							
Carbon Tetrachloride	ND	2.0	µg/L							
Chlorobenzene	ND	2.0	µg/L							
Chlorodibromomethane	ND	2.0	µg/L							
Chloroethane	ND	2.0	µg/L							
2-Chloroethyl Vinyl Ether	ND	10	µg/L							
Chloroform	ND	2.0	µg/L							
Chloromethane	ND	2.0	µg/L							
1,2-Dichlorobenzene	ND	2.0	µg/L							
1,3-Dichlorobenzene	ND	2.0	µg/L							
1,4-Dichlorobenzene	ND	2.0	µg/L							
1,2-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethylene	ND	2.0	µg/L							
trans-1,2-Dichloroethylene	ND	2.0	µg/L							
1,2-Dichloropropane	ND	2.0	µg/L							
cis-1,3-Dichloropropene	ND	2.0	µg/L							
trans-1,3-Dichloropropene	ND	2.0	µg/L							
Ethylbenzene	ND	2.0	µg/L							
Methyl tert-Butyl Ether (MTBE)	ND	2.0	µg/L							
Methylene Chloride	ND	5.0	µg/L							
1,1,2,2-Tetrachloroethane	ND	2.0	µg/L							
Tetrachloroethylene	ND	2.0	µg/L							
Toluene	ND	1.0	µg/L							
1,1,1-Trichloroethane	ND	2.0	µg/L							
1,1,2-Trichloroethane	ND	2.0	µg/L							
Trichloroethylene	ND	2.0	µg/L							
Trichlorofluoromethane (Freon 11)	ND	2.0	µg/L							
Vinyl Chloride	ND	2.0	µg/L							
m+p Xylene	ND	2.0	µg/L							
o-Xylene	ND	2.0	µg/L							
Surrogate: 1,2-Dichloroethane-d4	25.7		µg/L	25.0		103	70-130			
Surrogate: Toluene-d8	24.5		µg/L	25.0		98.0	70-130			
Surrogate: 4-Bromofluorobenzene	23.8		µg/L	25.0		95.4	70-130			

LCS (B117960-BS1)

Prepared & Analyzed: 03/27/15

Benzene	9.11	1.0	µg/L	10.0		91.1	37-151			
Bromodichloromethane	9.34	2.0	µg/L	10.0		93.4	35-155			
Bromoform	10.0	2.0	µg/L	10.0		100	45-169			
Bromomethane	8.41	2.0	µg/L	10.0		84.1	20-242			
Carbon Tetrachloride	8.67	2.0	µg/L	10.0		86.7	70-140			
Chlorobenzene	8.82	2.0	µg/L	10.0		88.2	37-160			
Chlorodibromomethane	8.42	2.0	µg/L	10.0		84.2	53-149			
Chloroethane	8.41	2.0	µg/L	10.0		84.1	70-130			
2-Chloroethyl Vinyl Ether	126	10	µg/L	100		126	10-305			
Chloroform	9.89	2.0	µg/L	10.0		98.9	51-138			
Chloromethane	7.27	2.0	µg/L	10.0		72.7	20-273			
1,2-Dichlorobenzene	9.50	2.0	µg/L	10.0		95.0	18-190			
1,3-Dichlorobenzene	9.20	2.0	µg/L	10.0		92.0	59-156			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL

Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch B117960 - SW-846 5030B										
LCS (B117960-BS1)				Prepared & Analyzed: 03/27/15						
1,4-Dichlorobenzene	9.04	2.0	µg/L	10.0		90.4	18-190			
1,2-Dichloroethane	9.09	2.0	µg/L	10.0		90.9	49-155			
1,1-Dichloroethane	9.40	2.0	µg/L	10.0		94.0	59-155			
1,1-Dichloroethylene	8.77	2.0	µg/L	10.0		87.7	20-234			
trans-1,2-Dichloroethylene	9.15	2.0	µg/L	10.0		91.5	54-156			
1,2-Dichloropropane	9.21	2.0	µg/L	10.0		92.1	20-210			
cis-1,3-Dichloropropene	8.87	2.0	µg/L	10.0		88.7	20-227			
trans-1,3-Dichloropropene	9.93	2.0	µg/L	10.0		99.3	17-183			
Ethylbenzene	8.66	2.0	µg/L	10.0		86.6	37-162			
Methyl tert-Butyl Ether (MTBE)	11.0	2.0	µg/L	10.0		110	70-130			
Methylene Chloride	9.71	5.0	µg/L	10.0		97.1	50-221			
1,1,2,2-Tetrachloroethane	10.7	2.0	µg/L	10.0		107	46-157			
Tetrachloroethylene	8.77	2.0	µg/L	10.0		87.7	64-148			
Toluene	8.64	1.0	µg/L	10.0		86.4	47-150			
1,1,1-Trichloroethane	9.12	2.0	µg/L	10.0		91.2	52-162			
1,1,2-Trichloroethane	10.0	2.0	µg/L	10.0		100	52-150			
Trichloroethylene	9.53	2.0	µg/L	10.0		95.3	71-157			
Trichlorofluoromethane (Freon 11)	9.12	2.0	µg/L	10.0		91.2	17-181			
Vinyl Chloride	9.54	2.0	µg/L	10.0		95.4	20-251			
m+p Xylene	17.1	2.0	µg/L	20.0		85.4	70-130			
o-Xylene	8.72	2.0	µg/L	10.0		87.2	70-130			
Surrogate: 1,2-Dichloroethane-d4	26.7		µg/L	25.0		107	70-130			
Surrogate: Toluene-d8	23.7		µg/L	25.0		94.8	70-130			
Surrogate: 4-Bromofluorobenzene	24.2		µg/L	25.0		96.6	70-130			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
	Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
	No results have been blank subtracted unless specified in the case narrative section.
J	Detected but below the Reporting Limit (lowest calibration standard); therefore, result is an estimated concentration (CLP J-Flag).

CERTIFICATIONS

Certified Analyses included in this Report

Analyte	Certifications
EPA 624 in Water	
Benzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromodichloromethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromoform	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromomethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Carbon Tetrachloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chlorodibromomethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
2-Chloroethyl Vinyl Ether	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloroform	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloromethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,3-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,4-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
trans-1,2-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichloropropane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
cis-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
trans-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Ethylbenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Methyl tert-Butyl Ether (MTBE)	NC
Methylene Chloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,2,2-Tetrachloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Tetrachloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Toluene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,1-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,2-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Trichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Trichlorofluoromethane (Freon 11)	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Vinyl Chloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
m+p Xylene	CT,MA,NH,NY,RI,NC,VA,NJ
o-Xylene	CT,MA,NH,NY,RI,NC,VA,NJ

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

The CON-TEST Environmental Laboratory operates under the following certifications and accreditations:

Code	Description	Number	Expires
AIHA	AIHA-LAP, LLC	100033	02/1/2016
MA	Massachusetts DEP	M-MA100	06/30/2015
CT	Connecticut Department of Public Health	PH-0567	09/30/2015
NY	New York State Department of Health	10899 NELAP	04/1/2016
NH-S	New Hampshire Environmental Lab	2516 NELAP	02/5/2016
RI	Rhode Island Department of Health	LAO00112	12/30/2015
NC	North Carolina Div. of Water Quality	652	12/31/2015
NJ	New Jersey DEP	MA007 NELAP	06/30/2015
FL	Florida Department of Health	E871027 NELAP	06/30/2015
VT	Vermont Department of Health Lead Laboratory	LL015036	07/30/2015
WA	State of Washington Department of Ecology	C2065	02/23/2016
ME	State of Maine	2011028	06/9/2015
VA	Commonwealth of Virginia	460217	12/14/2015
NH-P	New Hampshire Environmental Lab	2557 NELAP	09/6/2015



Phone: 413-525-2332
Fax: 413-525-6405
Email: info@contestlabs.com
www.contestlabs.com

CHAIN OF CUSTODY RECORD

39 Spruce Street
East longmeadow, MA 01028

Page 1 of 1

Company Name: ARCADIS

Address: 855 Route 146, Ste 210
Clifton Park, NY 12065

Attention: J. Wyckoff

Project Location: S. Oteselic, NY

Sampled By: J. Wyckoff

Project Proposal Provided? (for billing purposes)
☐ yes ☐ no proposal date

Telephone: 518-250-7300

Project # 00266406,0000

Client PO#

DATA DELIVERY (check all that apply)

☐ FAX ☒ EMAIL ☐ WEBSITE

Fax #

Email: jerry.wyckoff@arcadis-

Format: PDF EXCEL OGIS USIOM

OTHER: NYSDEL 6015

☐ "Enhanced Data Package"

Collection

Beginning Date/Time

Ending Date/Time

Composite

Grab

Matrix Date

Canis Data

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

01 RW-1

02 RW-2

03 EFF 46 Hz

04 TRIP Blank

Relinquished by: (signature)

Date/Time: 3/19/15 12:00

Received by: (signature)

Date/Time: 3/20/15 9:25

Relinquished by: (signature)

Date/Time: 3/20/15 9:25

Received by: (signature)

Date/Time: 3/20/15 9:25

Relinquished by: (signature)

Date/Time: 3/20/15 9:25

Received by: (signature)

Date/Time: 3/20/15 9:25

Detection Limit Requirements

Massachusetts:

Connecticut:

Other: NYS ASP CAT B

Is your project MCP or RCP?

☐ MCP Form Required

☐ RCP Form Required

☐ MA State DW Form Required

PWSID #

Accredited

WBE/DBE Certified



NELAC & AIHA-LAP, LLC

Accredited

WBE/DBE Certified



Ship

Track

Manage

Learn

FedEx Office®

Login

FedEx Tracking

807076203429Ship (P/U) date
Thur 3/19/2015 1:47 pmActual delivery :
Fri 3/20/2015 9:25 am

CLIUS

**Delivered**

Signed for by: K.MCNEE

MA US

Travel History

▲ Date/Time	Activity	Location
- 3/20/2015 - Friday		
9:25 am	Delivered	MA
7:31 am	On FedEx vehicle for delivery	WINDSOR LOCKS CT
7:23 am	At local FedEx facility	WINDSOR LOCKS CT
3:15 am	Departed FedEx location	NEWARK NJ
- 3/19/2015 - Thursday		
11:19 pm	Arrived at FedEx location	NEWARK NJ
7:12 pm	Left FedEx origin facility	BINGHAMTON NY
1:47 pm	Picked up	BINGHAMTON, NY

Shipment Facts

Tracking number	807076203429	Service	FedEx Priority Overnight
Delivered To		Delivered To	Shipping/Receiving
Dimensions	12x12x12 in.	Shipper reference	00265 406 0000
Total pieces	1	Special handling section	Deliver Weekday
Packaging	Your Packaging		



Search

Customer Focus

New Customer Center
Small Business Center
Service Guide
Customer Support

Company Information

About FedEx
Careers
Investor Relations

Featured Services

FedEx One Rate
FedEx SameDay
FedEx Home Delivery
Healthcare Solutions
Online Retail Solutions
Packaging Services
Ancillary Clearance Services

Other Resources

FedEx Compatible
Developer Resource Center
FedEx Ship Manager Software
FedEx Mobile

Companies

FedEx Express
FedEx Ground
FedEx Office
FedEx Freight
FedEx Custom Critical
FedEx Trade Networks
FedEx SupplyChain
FedEx TechConnect


Follow FedEx

United States - English

39 Spruce St.
East Longmeadow, MA. 01028
P: 413-525-2332
F: 413-525-6405
www.contestlabs.com



Page 1 of 2



Sample Receipt Checklist

CLIENT NAME: Arcadis RECEIVED BY: JDL DATE: 3/20/15

1) Was the chain(s) of custody relinquished and signed?

Yes No No CoC Included

2) Does the chain agree with the samples?

Yes No

If not, explain:

3) Are all the samples in good condition?

Yes No

If not, explain:

4) How were the samples received:

On Ice ☒ Direct from Sampling ☐ Ambient ☐ In Cooler(s) ☒

Were the samples received in Temperature Compliance of (2-6°C)? Yes No N/A

Temperature °C by Temp blank _____ Temperature °C by Temp gun 5.4

5) Are there Dissolved samples for the lab to filter?

Yes No

Who was notified _____ Date _____ Time _____

6) Are there any RUSH or SHORT HOLDING TIME samples?

Yes No

Who was notified _____ Date _____ Time _____

7) Location where samples are stored:

19

Permission to subcontract samples? Yes No
(Walk-in clients only) if not already approved
Client Signature: _____

8) Do all samples have the proper Acid pH: Yes No N/A

9) Do all samples have the proper Base pH: Yes No N/A

10) Was the PC notified of any discrepancies with the CoC vs the samples: Yes No N/A

Containers received at Con-Test

	# of containers		# of containers
1 Liter Amber		8 oz amber/clear jar	
500 mL Amber		4 oz amber/clear jar	
250 mL Amber (8oz amber)		2 oz amber/clear jar	
1 Liter Plastic		Plastic Bag / Ziploc	
500 mL Plastic		SOC Kit	
250 mL plastic		Non-ConTest Container	
40 mL Vial - type listed below	<u>11</u>	Perchlorate Kit	
Colisure / bacteria bottle		Flashpoint bottle	
Dissolved Oxygen bottle		Other glass jar	
Encore		Other	

Laboratory Comments:

Time and Date Frozen:

40 mL vials: # HCl ((# Methanol _____

Doc# 277 # Bisulfate _____ # DI Water _____

Rev. 4 August 2013 # Thiosulfate _____ Unpreserved _____

Login Sample Receipt Checklist

(Rejection Criteria Listing - Using Sample Acceptance Policy)

Any False statement will be brought to the attention of Client

Question	Answer (True/False)	Comment
	T/F/NA	
1) The cooler's custody seal, if present, is intact.	NA	
2) The cooler or samples do not appear to have been compromised or tampered with.	T	
3) Samples were received on ice.	T	
4) Cooler Temperature is acceptable.	T	
5) Cooler Temperature is recorded.	T	
6) COC is filled out in ink and legible.	T	
7) COC is filled out with all pertinent information.	T	
8) Field Sampler's name present on COC.	T	
9) There are no discrepancies between the sample IDs on the container and the COC.	T	
10) Samples are received within Holding Time.	T	
11) Sample containers have legible labels.	T	
12) Containers are not broken or leaking.	T	
13) Air Cassettes are not broken/open.	NA	
14) Sample collection date/times are provided.	T	
15) Appropriate sample containers are used.	T	
16) Proper collection media used.	T	
17) No headspace sample bottles are completely filled.	T	
18) There is sufficient volume for all requested analyses, including any requested MS/MSDs.	T	
19) Trip blanks provided if applicable.	JDL NA T	
20) VOA sample vials do not have head space or bubble is <6mm (1/4") in diameter.	T	
21) Samples do not require splitting or compositing.	T	

Doc #277 Rev. 4 August 2013

Who notified of False statements?

Log-In Technician Initials: JDL

Date/Time:

Date/Time: 3/20/15 9:25