

New York State Department of Environmental
Conservation

GLADDING CORDAGE SITE QUARTERLY REPORT

Fourth Quarter 2015

May 2016

A large orange geometric shape, consisting of a triangle and a rectangle, is positioned in the bottom right corner of the page. A thin white line runs diagonally across the orange shape. A thin white horizontal line runs across the page, intersecting the orange shape.

GLADDING CORDAGE SITE QUARTERLY REPORT

Fourth Quarter 2015



Andy Vitolins, PG
Associate Vice President

Prepared for:

New York State Department of
Environmental Conservation – Division of
Environmental Remediation

625 Broadway
Albany, NY 12233-7011



Jeremy Wyckoff
Project Geologist

Prepared by:

Arcadis CE, Inc.
855 Route 146
Suite 210
Clifton Park
New York 12065
Tel 518 250 7300
Fax 518 250 7301

Our Ref.:

00266406.0000

Date:

May 2016

This document is intended only for the use of the individual or entity for which it was prepared and may contain information that is privileged, confidential and exempt from disclosure under applicable law. Any dissemination, distribution or copying of this document is strictly prohibited.

CONTENTS

Acronyms and Abbreviations.....	iii
1 INTRODUCTION.....	1
2 SITE DESCRIPTION	2
3 OPERATION AND MAINTENANCE	3
3.1 Treatment Plant Upgrades.....	3
3.1.1 Variable Frequency Drive.....	3
3.1.2 Treatment Plant Controls	3
3.1.3 Geothermal Heat Exchanger	4
3.2 Treatment Plant Operation	4
3.3 Treatment System Sampling	4
3.3.1 Influent Sample Results	4
3.3.2 Effluent Sample Results	5
4 GROUNDWATER MONITORING PROGRAM.....	6
5 RECOMMENDATIONS.....	7
6 SUMMARY	8
7 REFERENCES.....	9

TABLES

Table 3-1	Treatment System Status and Flow Summary
Table 3-2	Groundwater Treatment System VOCs (RW-1)
Table 3-3	Groundwater Treatment System VOCs (RW-2)
Table 3-4	Groundwater Treatment System VOCs (Effluent)

FIGURES

Figure 2-1	Site Location
Figure 3-1	Treatment System Influent Sample Concentration (1,1,1-TCA)

APPENDICES

- A PLC Facsimile Reports
- B O&M Checklists
- C Analytical Reporting Forms
- D Groundwater 1,1,1-TCA Concentrations – May 2015

ACRONYMS AND ABBREVIATIONS

Amsl	above mean sea level
BTEX	Benzene, toluene, ethylbenzene, and xylene.
Ft	feet
GAP	generally accepted procedure
HZ	hertz
µg/L	micrograms per liter
NYSDEC	New York State Department of Environmental Conservation
O&M	operation and maintenance
PDB	passive diffusion bag
PLC	programmable logic controller
PCE	Tetrachloroethene
USEPA	United States Environmental Protection Agency
VFD	variable frequency drive
VOC	volatile organic compound
1,1-DCA	1,2-dichloroethane
1,1-DCE	1,2-dichloroethene
1,1,1-TCA	1,1,1-trichloroethane

1 INTRODUCTION

The New York State Department of Environmental Conservation (NYSDEC) has issued a Work Assignment (# D007618-9) to ARCADIS CE, Inc. (Arcadis) for Operation, Maintenance, and Monitoring at the Gladding Cordage Site (Site # 7-09-009). This Quarterly Report has been prepared in accordance with the NYSDEC-approved Work Plan to summarize fourth quarter 2015 site activities.

2 SITE DESCRIPTION

The Gladding Cordage Site is located on Ridge Road, South Otselic, Chenango County, New York (Figure 2-1), along the western bank of the Otselic River. The site contains an active braided wire and rope manufacturing facility that has been in operation since 1892.

3 OPERATION AND MAINTENANCE

On August 23, 2007, the NYSDEC provided a training session to Arcadis personnel on the operation and maintenance (O&M) of the groundwater treatment plant at the Gladding Cordage Site. Since then, Arcadis has maintained operation of the groundwater treatment plant. This includes the operation, maintenance, and influent/effluent sampling in accordance with the NYSDEC O&M manual (Operation and Maintenance Manual, Volume I, Gladding Cordage Site, Site 7-09-009, TAMS Consultants, Inc., 1996) (O&M Manual).

3.1 Treatment Plant Upgrades

3.1.1 Variable Frequency Drive

A variable frequency drive (VFD) was installed on January 9, 2008 to regulate the speed of the air stripper blower motor for reduced energy usage. Following the installation of the VFD, effluent samples were collected at various blower motor frequencies (speeds) including 40 HZ, 50 HZ, and 60 HZ. The analyte 1,1,1-trichloroethane (1,1,1-TCA) was detected at 6 µg/l in the 40 HZ effluent sample but was not detected in the 50 HZ and 60 HZ samples. Following the completion of the January 9, 2008 sampling event the VFD was set to 50 HZ. Additional sampling was conducted in February 2008 to further optimize the treatment system blower speed. Based on the results, the VFD setting was reduced to 42 HZ beginning in March 2008. Based on the detection of low-level VOCs in effluent samples from the treatment system, the VFD setting was subsequently increased to 46 HZ in September 2010 and was maintained at that frequency until November 19, 2014.

Based on a general trend of lower concentrations of VOCs in influent treatment system samples since September 2010, the NYSDEC authorized a reduction of the VFD frequency to 44 HZ in an attempt to further optimize treatment plant operations and reduce electric usage. The VFD frequency was lowered to 44 HZ on November 19, 2014. Following approximately one-half hour of operation, post-treatment effluent samples were collected in accordance with the Work Plan (see Section 3.2.1). Based on a review of post-treatment effluent sample data from November 19, 2014, 1,1,1 TCA and toluene were detected with the air stripper blower operating at 44 HZ, but at concentrations below the corresponding NYSDEC Class GA Standards. The NYSDEC was notified of the VOC detections and the blower motor frequency was subsequently increased to 46 HZ and has been maintained at that level since the December 18, 2014 O&M event.

3.1.2 Treatment Plant Controls

In August 2011, the NYSDEC authorized construction and installation of a new treatment plant controls system. The new control system is designed to provide remote access to treatment plant operating parameters and improve reliability of the groundwater remediation system. The treatment plant was shut down to begin repairs and upgrades on January 30, 2012 by Aztech Technologies, Inc. (Aztech). The upgrades to the treatment system controls were completed and the treatment plant resumed operation on March 22, 2012. The treatment plant functions are controlled and monitored using an EOS Research Ltd. ProControl Programmable Logic Controller (PLC). The interface software allows remote connection to the PLC via analog phone line. The PLC and interface software also allows the treatment system to be started or stopped remotely. The PLC is programmed to send a facsimile with the status of system inputs and

outputs on a daily basis. If input and/or output device values exceed the defined operating parameters, an alarm condition is set and the corresponding alarm information is sent via facsimile to the system user (i.e. Arcadis).

3.1.3 Geothermal Heat Exchanger

The NYSDEC authorized the installation of a geothermal heat exchanger to provide climate control (heating and humidity) for the treatment system building. The treatment plant was shut down to begin installation of the geothermal heat exchanger on May 8, 2012 by Aztech. The geothermal heat exchanger installation and testing was completed on May 10, 2012. The heat-exchanger uses groundwater from the treatment plant as a geo-thermal energy source.

3.2 Treatment Plant Operation

As shown on PLC facsimile reports (Appendix A) and O&M Checklist and Operation Logs (Appendix B), the Gladding Cordage groundwater treatment system operated without interruption for the entire fourth quarter operating period, with only routine maintenance performed.

The average monthly flow rates and total flow volumes for the fourth quarter 2015 operating period are summarized in Table 3-1. As shown in Table 3-1, the monthly flow rates from recovery wells RW-1 and RW-2 averaged approximately 22 gpm. Based on the total flow values, approximately 5.4 million gallons of water were treated and discharged to the Otselic River between October and December 2015.

3.3 Treatment System Sampling

Influent and effluent groundwater samples were collected from the Gladding Cordage treatment system in accordance with the Work Plan and submitted to Contest Analytical following chain-of-custody protocols. Each sample was analyzed for volatile organic compounds (VOCs) by United States Environmental Protection Agency (USEPA) Method 624. Analytical Reporting Forms are provided in Appendix C.

3.3.1 Influent Sample Results

Table 3-2 and Table 3-3 summarize influent VOC sample results from recovery wells RW-1 and RW-2, respectively. Figure 3-1 provides a summary of 1,1,1-TCA concentrations in samples from recovery wells RW-1 and RW-2 since September 2007.

Tables 3-1 and 3-2 and Figure 3-1 show that the concentrations of 1,1,1-TCA in the fourth quarter 2015 samples from recovery well RW-1 ranged from 32 µg/L in December to 41 µg/L in November; the concentrations of 1,1,1-TCA in the fourth quarter 2015 samples from recovery well RW-2 ranged from 26 µg/L in December to 34 µg/L in November. As shown in Tables 3-1 and 3-2, these results are within the range of historic concentrations and exceed the corresponding NYSDEC Class GA Standard of 5 µg/L.

As shown in Tables 3-2 and 3-3, 1,1-dichloroethane (1,1-DCA) and 1,1-dichloroethene (1,1-DCE) were detected in the fourth quarter 2015 samples from recovery wells RW-1 and RW-2. However, consistent with previous results, the concentrations were less than the applicable NYSDEC Class GA Standard of 5 µg/L.

3.3.2 Effluent Sample Results

Table 3-4 summarizes laboratory analytical data for effluent samples collected from the treatment system. As shown in Table 3-4, no VOCs were detected in any of the fourth quarter 2015 effluent samples at the indicated quantitation limits.

Based on influent sample concentrations and total flow volumes from the Gladding Cordage treatment system, approximately 1.6 pounds of VOCs were removed by the treatment system during the third quarter 2015, with a total mass of approximately seven pounds of VOCs removed during 2015.

4 GROUNDWATER MONITORING PROGRAM

Groundwater samples were collected from the site during the second quarter 2015 in accordance with the Work Plan. The results of the sampling event were submitted in the second quarter 2015 Gladding Cordage Site Quarterly Report (Arcadis, 2015). The next groundwater sampling event is scheduled to take place during the third quarter 2016. A map showing the distribution of 1,1,1-TCA during the second quarter 2015 sampling event is provided in Appendix D for reference.

5 RECOMMENDATIONS

Based on the data presented herein, there are no recommended changes to site operations at this time.

6 SUMMARY

The Gladding Cordage groundwater treatment system operated without interruption during the fourth quarter 2015. The average total flow through the treatment system was approximately 43 GPM.

The concentrations of VOCs detected in pre-treatment influent samples from recovery wells RW-1 and RW-2 were consistent with previous results.

The treatment successfully removes VOCs from groundwater extracted from the capture zone at the current VFD setting of 46 Hz. The VFD setting will continue to be evaluated based on system monitoring results. Approximately 1.6 pounds of VOCs were removed by the treatment system during the fourth quarter 2015.

Based on the current five-quarter sampling interval, the next groundwater monitoring event is scheduled to occur during the third quarter 2016.

7 REFERENCES

Arcadis, 2015, Gladding Cordage Site Quarterly Report, Second Quarter 2015, Arcadis CE, Inc., November 2015.

Malcolm Pirnie, 2007, Gladding Cordage Site Work Plan, Site 7-09-009, Malcolm Pirnie, Inc., June, 2007.

TAMS, 1996, Operation and Maintenance Manual, Volume I, Gladding Cordage Site. Site 7-09-009, TAMS Consultants, Inc., March 1996.

TABLES



TABLE 3-1
TREATMENT SYSTEM STATUS AND FLOW SUMMARY
GLADDING CORDAGE SITE
SOUTH OTSELIC, NEW YORK
NYSDEC SITE NO. 7-04-009A

Date	System Operation (days)	System On-time (% of possible days)	Well On-time		Flow Rates		Totalizer	Totalizer	Recovery Well Total Flows		Total System Flow	Quarterly Totals (gallons)
			RW-1 (% possible)	RW-2 (% possible)	RW-1 (gpm)	RW-2 (gpm)	RW-1 (gallons)	RW-2 (gallons)	RW-1 (gallons)	RW-2 (gallons)	(gallons)	
January-15	30	97%	100%	100%	23.8	22.3	27,482,764	25,089,994	1,017,093	940,617	1,957,710	5,839,875
February-15	27	96%	100%	100%	21.3	24.1	28,457,483	25,964,709	974,719	874,715	1,849,434	
March-15	31	100%	100%	100%	21.7	23.9	29,512,439	26,942,484	1,054,956	977,775	2,032,731	
April-15	30	100%	100%	100%	23.9	21.6	30,572,172	27,868,651	1,059,733	926,167	1,985,900	5,125,831
May-15	26	84%	100%	100%	23.6	21.1	31,474,040	28,682,253	901,868	813,602	1,715,470	
June-15	20	67%	100%	100%	25.3	21.8	32,221,714	29,359,040	747,674	676,787	1,424,461	
July-15	31	100%	100%	100%	25.3	22.3	33,390,538	30,373,435	1,168,824	1,014,395	2,183,219	6,202,519
August-15	31	100%	100%	100%	24.8	22.0	34,478,269	31,320,491	1,087,731	947,056	2,034,787	
September-15	30	100%	100%	100%	25.0	21.5	35,532,694	32,250,579	1,054,425	930,088	1,984,513	
October-15	31	100%	100%	100%	21.5	21.1	36,367,830	33,094,600	835,136	844,021	1,679,157	5,374,028
November-15	30	100%	100%	100%	21.6	22.0	37,244,398	33,967,175	876,568	872,575	1,749,143	
December-15	31	100%	100%	100%	21.9	22.0	38,220,025	34,937,276	975,627	970,101	1,945,728	
Total Flow 2015									11,754,354	10,787,899	22,542,253	

Notes:
gpm - Gallons per minute

TABLE 3-2
GROUNDWATER TREATMENT SYSTEM VOCs (INFLUENT - RW-1)
GLADDING CORDAGE
SOUTH OTSELIC, NEW YORK
NYSDEC Site No. 7-09-009

Sample ID Sampling Date Matrix Units	NYSDEC Class GA Standard ug/L	RW-1 12/18/2014 WATER ug/L	RW-1 1/20/2015 WATER ug/L	RW-1 2/25/2015 WATER ug/L	RW-1 3/19/2015 WATER ug/L	RW-1 5/6/2015 WATER ug/L	RW-1 6/22/2015 WATER ug/L	RW-1 7/31/2015 WATER ug/L	RW-1 8/28/2015 WATER ug/L	RW-1 9/23/2015 WATER ug/L	RW-1 10/26/2015 WATER ug/L	RW-1 11/20/2015 WATER ug/L	RW-1 12/21/2015 WATER ug/L
VOCs													
1,1,1-Trichloroethane	5	44	43	40	36	38	41	40	42	32	38	41	32
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	1.5	1.8 J	1.6 J	1.5 J	2.0 U	1.8 J	1.6 J	1.8 J	1.5 J	1.8 J	2.1	1.5 J
1,1-Dichloroethene	5	2.0 U	1.3 J	0.93 J	0.89 J	0.92 J	0.99 J	0.96 J	0.97 J	0.8 J	0.85 J	1.0 J	0.8 J
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10.0 U	10.0 U	10.0 U	10.0 U	10 U	10 U	10.0 U	10 U	10 U	10.0 U	10 U	10 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	0.19 J	2.0 U	2.0 U	2.0 U	2.0 U
Toluene	5	1.0 U	1.0 U	1.0 U	1.0 U	0.13 J	2.0 U	1.0 U	1.0 U	2.0 U	1.0 U	1.0 U	2.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	5.0 U	5.0 U	5.0 U	5.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Total VOCs		45.5	46.1	44.5	38.4	39.1	43.8	42.6	45.0	34.3	40.7	44.1	34.3

- Concentration exceeds corresponding NYSDEC
Class GA Standard.
U - Not detected at the indicated concentration
J - Estimated concentration.

TABLE 3-3
GROUNDWATER TREATMENT SYSTEM VOCs (INFLUENT - RW-2)
GLADDING CORDAGE
SOUTH OTSELIC, NEW YORK
NYSDEC Site No. 7-09-009

Sample ID Sampling Date Matrix Units	NYSDEC Class GA Standard ug/L	RW-2 12/18/2014 WATER ug/L	RW-2 1/20/2015 WATER ug/L	RW-2 2/25/2015 WATER ug/L	RW-2 3/19/2015 WATER ug/L	RW-2 5/6/2015 WATER ug/L	RW-2 6/23/2015 WATER ug/L	RW-2 7/31/2015 WATER ug/L	RW-2 8/28/2015 WATER ug/L	RW-2 9/23/2015 WATER ug/L	RW-2 10/26/2015 WATER ug/L	RW-2 11/20/2015 WATER ug/L	RW-2 12/21/2015 WATER ug/L
VOCs													
1,1,1-Trichloroethane	5	37	15	34	31	33	48	34	36	26	32	34	26
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	0.72 J	2.0 U	0.76 J	0.69 J	2.0 U	1.1 J	0.74 J	0.77 J	0.61 J	0.75 J	0.85 J	0.61 J
1,1-Dichloroethene	5	0.93 J	0.38 J	0.7 J	0.68 J	0.72 J	1 J	0.72 J	0.62 J	0.58 J	0.63 J	0.92 J	0.58 J
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10.0 U	10.0 U	10.0 U	10.0 U	10 U	10 U	10.0 U	10 U	10 U	10 U	10 U	10 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	0.15 J	2.0 U	2.0 U	2.0 U	2.0 U
Toluene	5	1.0 U	1.0 U	1.0 U	1.0 U	0.13 J	2.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	5.0 U	5.0 U	5.0 U	5.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Total VOCs		38.7	15.4	35.4	32.4	33.9	50.1	35.5	37.5	27.2	33.4	35.8	27.2

- Concentration exceeds corresponding NYSDEC
Class GA Standard.
U - Not detected at the indicated concentration
J - Estimated concentration.

TABLE 3-4
GROUNDWATER TREATMENT SYSTEM VOCS (EFFLUENT)
GLADDING CORDAGE
SOUTH OTSELIC, NEW YORK
NYSDEC Site No. 7-09-009

Sample ID Sampling Date Matrix Units	NYSDEC GA Standard ug/L	EFF(46HZ) 12/18/2014 WATER ug/L	EFF(46HZ) 1/20/2015 WATER ug/L	EFF(46HZ) 2/25/2015 WATER ug/L	EFF(46HZ) 3/19/2015 WATER ug/L	EFF(46HZ) 5/6/2015 WATER ug/L	EFF(46HZ) 6/23/2015 WATER ug/L
VOCs							
1,1,1-Trichloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	1.0 U	0.22 J
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10 U	10 U	10 U	10 U	10 U	10 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	2.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Toluene	5	1.0 U	1.0 U	1.0 U	1.0 U	0.12 J	1.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	5.0 U	5.0 U	5.0 U	5.0 U	2.0 U	2.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U

Notes

U - Not detected at the indicated concentration.

J - Estimated concentration.

TABLE 3-4
GROUNDWATER TREATMENT SYSTEM VOCS (EFFLUENT)
GLADDING CORDAGE
SOUTH OTSELIC, NEW YORK
NYSDEC Site No. 7-09-009

Sample ID Sampling Date Matrix Units	NYSDEC GA Standard ug/L	EFF(46HZ) 7/31/2015 WATER ug/L	EFF(46HZ) 8/28/2015 WATER ug/L	EFF(46HZ) 9/23/2015 WATER ug/L	EFF(46HZ) 10/26/2015 WATER ug/L	EFF(46HZ) 11/20/2015 WATER ug/L	EFF(46HZ) 12/21/2015 WATER ug/L
VOCs							
1,1,1-Trichloroethane	5	0.22 J	0.17 J	1.0 U	1.0 U	1.0 U	1.0 U
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10 U	10 U	10 U	10 U	10 U	10 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	0.2 J	2.0 U	2.0 U	2.0 U	2.0 U
Toluene	5	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	5.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U

Notes

U - Not detected at the indicated concentration.


J - Estimated concentration.

FIGURES



Figure 2-1 Site Location


Gladding Cordage Site
South Otselic, New York
NYSDEC Site 7-09-009



0 2,000 ft

Figure 3-1
Treatment System Influent Sample Concentrations (1,1,1-TCA)

Gladding Cordage Site
NYSDEC Site Number 7-09-009



APPENDIX A

PLC Facsimile Reports





ProControl Series II+

ECOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/01/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 22.0	GPM TOTAL FLOW is 35564484	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 32282004	GAL	
ASBPERS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 426490	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.47	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.89	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.87	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 3.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 59.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/02/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 22.0	GPM TOTAL FLOW is 35596122	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 32313406	GAL	
ASBPERS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 426819	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.81	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.64	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 58.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/03/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMP_LL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 22.1	GPM TOTAL FLOW is 35627705	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 32344774	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 427222	GAL	
HP_PRS is 1.1	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.52	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.68	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.45	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTemp is 58.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/04/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.9	GPM TOTAL FLOW is 35659184	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 32376136	GAL	
ASBPRES is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 427566	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.60	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.32	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTemp is 59.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/05/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.4	GPM TOTAL FLOW is 35690542	GAL	
W2_FLO is 21.4	GPM TOTAL FLOW is 32407478	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 427835	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.44	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.28	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 58.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/06/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMP_LL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.5	GPM TOTAL FLOW is 35721732	GAL	
W2_FLO is 21.2	GPM TOTAL FLOW is 32438775	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 428058	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.47	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.21	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.17	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 60.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/07/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMP_L is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM TOTAL FLOW is 35752780	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 32470041	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 428262	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.52	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.08	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.11	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 61.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/08/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.4	GPM TOTAL FLOW is 35783788	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 32501280	GAL	
ASBP RS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 428443	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.19	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.15	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 61.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/09/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMP_LL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 22.0	GPM TOTAL FLOW is 35814767	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 32532480	GAL	
ASBPRS is 10.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 428643	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.91	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.07	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 61.2	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/10/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.4	GPM TOTAL FLOW is 35845822	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 32563692	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 2.38	GPM TOTAL FLOW is 428914	GAL	
HP_PRS is 8.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 4.87	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 33.69	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.70	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTTEMP is 58.4	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/11/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMP_LL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.5	GPM TOTAL FLOW is 35876920	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 32594942	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 429295	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.41	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.45	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTTEMP is 57.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/12/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.4	GPM TOTAL FLOW is 35907895	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 32626172	GAL	
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 429612	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.17	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.41	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 59.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/13/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM TOTAL FLOW is 35938771	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 32657367	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 429826	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.45	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.46	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.77	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.30	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTemp is 59.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/14/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.3	GPM TOTAL FLOW is 35969575	GAL	
W2_FLO is 21.2	GPM TOTAL FLOW is 32688586	GAL	
ASBPRS is 10.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 430074	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.44	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.47	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.86	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.24	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 61.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/15/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VEDRST is OFF	HPMPOGO is ON	

Analog Inputs:

W1_FLO is 21.2	GPM TOTAL FLOW is 36000299	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 32719816	GAL	
ASBP RS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 430393	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.46	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.47	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 33.19	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.26	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTMP is 58.1	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/16/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 21.5	GPM TOTAL FLOW is 36031005	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 32751039	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 2.36	GPM TOTAL FLOW is 430691	GAL	
HP_PRS is 8.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 4.95	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.45	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.15	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.26	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 59.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/17/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.3	GPM TOTAL FLOW is 36061719	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 32782255	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 431072	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.42	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.36	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTTEMP is 58.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/18/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.5	GPM TOTAL FLOW is 36092427	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 32813480	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 431653	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.66	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.34	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 55.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/19/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMP_LL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.4	GPM TOTAL FLOW is 36123126	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 32844685	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 2.33	GPM TOTAL FLOW is 432300	GAL	
HP_PRS is 8.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 4.91	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.42	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.45	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.79	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.32	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 55.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/20/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMP_L is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.3	GPM TOTAL FLOW is 36153814	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 32875885	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 432754	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 33.42	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.26	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 58.8	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/21/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.4	GPM TOTAL FLOW is 36184420	GAL	
W2_FLO is 21.3	GPM TOTAL FLOW is 32907119	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 433027	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.52	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.55	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.24	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 61.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/22/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM TOTAL FLOW is 36215003	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 32938354	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 433254	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.35	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.20	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 61.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/23/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMP_L is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.4	GPM TOTAL FLOW is 36245602	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 32969589	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 433539	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.54	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.26	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 57.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/24/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMP_LLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.2	GPM TOTAL FLOW is 36276186	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 33000824	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 434051	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.52	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.22	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 55.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/25/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM TOTAL FLOW is 36306726	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 33032071	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 434488	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.63	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.37	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.30	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 59.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/26/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.1	GPM TOTAL FLOW is 36337283	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 33063342	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 434939	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.94	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.49	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 56.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/27/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 21.4	GPM TOTAL FLOW is 36367830	GAL	
W2_FLO is 21.8	GPM TOTAL FLOW is 33094600	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 435471	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.98	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.41	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTTEMP is 55.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/02/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P07 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 36370334	GAL		
W2_FLO is 0.0	GPM TOTAL FLOW is 33097153	GAL		
ASBPRS is 9.2	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 435568	GAL		
HP_PRS is 1.0	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.97	AMP LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 35.37	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.91	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTMP is 57.0	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/04/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 22.4	GPM TOTAL FLOW is 36426708	GAL	
W2_FLO is 22.3	GPM TOTAL FLOW is 33152678	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 436114	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.93	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.62	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 57.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/05/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPOGO is ON	

Analog Inputs:

W1_FLO is 22.3	GPM TOTAL FLOW is 36458499	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 33184096	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 436400	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 33.80	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.53	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTMP is 60.7	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/17/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.9	GPM TOTAL FLOW is 36836820	GAL		
W2_FLO is 21.6	GPM TOTAL FLOW is 33560559	GAL		
ASBPRS is 11.0	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 439359	GAL		
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.18	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.74	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTMP is 53.8	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/18/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACEFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.9	GPM TOTAL FLOW is 36868280	GAL	
W2_FLO is 21.4	GPM TOTAL FLOW is 33591862	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 439526	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.52	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.13	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.64	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 56.4	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/20/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.8	GPM TOTAL FLOW is 36931037	GAL		
W2_FLO is 22.1	GPM TOTAL FLOW is 33654472	GAL		
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 439754	GAL		
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.88	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.72	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTMP is 56.9	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/21/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 22.3	GPM TOTAL FLOW is 36962524	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 33685791	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 439910	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.07	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.72	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTMP is 54.9	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/22/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 22.2	GPM TOTAL FLOW is 36993982	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 33717092	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 440055	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 33.57	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.62	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTMP is 57.8	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/23/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM	TOTAL FLOW is 37025451	GAL	
W2_FLO is 21.6	GPM	TOTAL FLOW is 33748387	GAL	
ASBPRS is 10.7	IWC	LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM	TOTAL FLOW is 440235	GAL	
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.51	AMP	LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.51	AMP	LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 33.65	FT	LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.64	FT	LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.3	PSI	LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.6	PSI	LIMITS are L: 0.5	PSI	H: 100.0
INTMP is 54.6	DEG	LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/24/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPOGO is ON	

Analog Inputs:

W1_FLO is 22.2	GPM	TOTAL FLOW is 37056933	GAL		
W2_FLO is 21.7	GPM	TOTAL FLOW is 33779672	GAL		
ASBPRS is 10.8	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 440470	GAL		
HP_PRS is 1.2	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.45	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.46	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.87	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.60	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.2	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.6	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTMP is 52.2	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/25/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.9	GPM TOTAL FLOW is 37088365	GAL		
W2_FLO is 21.8	GPM TOTAL FLOW is 33810955	GAL		
ASBPRS is 11.0	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 440723	GAL		
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.27	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.68	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 52.3	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/26/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPOGO is ON	

Analog Inputs:

W1_FLO is 21.3	GPM	TOTAL FLOW is 37119737	GAL		
W2_FLO is 21.3	GPM	TOTAL FLOW is 33842227	GAL		
ASBPRS is 10.7	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 440913	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.59	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.58	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.38	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.51	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.2	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.5	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTMP is 54.9	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/27/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMP_LL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM TOTAL FLOW is 37150909	GAL		
W2_FLO is 21.2	GPM TOTAL FLOW is 33873502	GAL		
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 441049	GAL		
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.08	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.51	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTMP is 55.8	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/28/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM TOTAL FLOW is 37181994	GAL	
W2_FLO is 21.3	GPM TOTAL FLOW is 33904752	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 441177	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 33.87	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.51	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTMP is 56.3	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/29/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 22.0	GPM TOTAL FLOW is 37213211	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 33935972	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 441344	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.89	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.51	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 52.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT HAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/30/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.5	GPM TOTAL FLOW is 37244398	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 33967175	GAL	
ASBPRS is 11.1	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 441565	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 33.99	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.55	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTMP is 51.0	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/01/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 22.0	GPM TOTAL FLOW is 37275504	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 33998376	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 441775	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.75	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.47	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 56.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/02/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 22.3	GPM TOTAL FLOW is 37306892	GAL	
W2_FLO is 21.8	GPM TOTAL FLOW is 34029567	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 441921	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 33.49	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.51	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTemp is 58.1	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/03/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 22.3	GPM TOTAL FLOW is 37338294	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 34060773	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 442061	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.77	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.93	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 55.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/04/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.7	GPM TOTAL FLOW is 37369823	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 34092024	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 442215	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.44	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.12	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 55.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/05/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM TOTAL FLOW is 37401369	GAL	
W2_FLO is 22.2	GPM TOTAL FLOW is 34123300	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 442375	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.71	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.08	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 56.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/06/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 22.0	GPM TOTAL FLOW is 37432889	GAL	
W2_FLO is 22.1	GPM TOTAL FLOW is 34154570	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 442556	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.58	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.00	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 53.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/07/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM TOTAL FLOW is 37464455	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 34185825	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 442754	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.16	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.93	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 51.7	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/08/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.5	GPM TOTAL FLOW is 37495978	GAL	
W2_FLO is 21.8	GPM TOTAL FLOW is 34217064	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 442943	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.04	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.83	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 53.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/09/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM TOTAL FLOW is 37527460	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 34248298	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 443146	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 33.96	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.81	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTMP is 53.4	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/10/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM TOTAL FLOW is 37558898	GAL	
W2_FLO is 21.4	GPM TOTAL FLOW is 34279500	GAL	
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 443297	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.77	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.77	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTemp is 56.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/11/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.5	GPM TOTAL FLOW is 37590294	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 34310713	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 443433	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 33.68	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.77	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTMP is 56.0	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/12/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM TOTAL FLOW is 37621699	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 34341952	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 443587	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.52	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.94	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.79	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 53.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/13/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.7	GPM TOTAL FLOW is 37653052	GAL		
W2_FLO is 21.7	GPM TOTAL FLOW is 34373185	GAL		
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 443726	GAL		
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.96	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.72	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 57.9	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/14/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 22.0	GPM TOTAL FLOW is 37684369	GAL		
W2_FLO is 21.6	GPM TOTAL FLOW is 34404415	GAL		
ASBPRS is 10.2	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 443847	GAL		
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.61	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.68	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTMP is 59.8	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/15/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.8	GPM TOTAL FLOW is 37715637	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 34435627	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 443951	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 33.44	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.89	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 58.3	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/16/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM TOTAL FLOW is 37747034	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 34466856	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 444097	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.08	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.91	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 57.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/17/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPOGO is ON	

Analog Inputs:

W1_FLO is 21.9	GPM TOTAL FLOW is 37778428	GAL	
W2_FLO is 21.2	GPM TOTAL FLOW is 34498075	GAL	
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 444243	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.81	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.85	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 57.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/18/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 22.1	GPM TOTAL FLOW is 37809782	GAL	
W2_FLO is 22.1	GPM TOTAL FLOW is 34529301	GAL	
ASBP RS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 444382	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 33.93	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.06	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTMP is 56.7	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/19/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 22.1	GPM TOTAL FLOW is 37841204	GAL	
W2_FLO is 21.4	GPM TOTAL FLOW is 34560552	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 444578	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.99	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.08	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 52.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/20/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.7	GPM TOTAL FLOW is 37872604	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 34591806	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 444866	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.41	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.08	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 53.3	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/21/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P09 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 22.0	GPM TOTAL FLOW is 37903974	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 34623044	GAL	
ASBPERS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 445088	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.15	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.91	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 53.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/22/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.7	GPM TOTAL FLOW is 37935591	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 34654301	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 445246	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.88	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.83	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 57.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/23/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 22.0	GPM TOTAL FLOW is 37967352	GAL	
W2_FLO is 22.1	GPM TOTAL FLOW is 34685737	GAL	
ASBPERS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 445387	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.05	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.93	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTemp is 57.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/24/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.9	GPM TOTAL FLOW is 37999012	GAL	
W2_FLO is 22.1	GPM TOTAL FLOW is 34717231	GAL	
ASBPRS is 10.1	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 445507	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.68	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.43	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.55	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 61.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/25/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 22.0	GPM TOTAL FLOW is 38030624	GAL	
W2_FLO is 22.2	GPM TOTAL FLOW is 34748687	GAL	
ASBPFS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 445630	GAL	
HP_PFS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.73	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.57	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PFS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PFS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 55.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/26/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 22.0	GPM TOTAL FLOW is 38062193	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 34780118	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 445782	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.95	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.48	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 53.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/27/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 22.3	GPM TOTAL FLOW is 38093739	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 34811507	GAL	
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 445938	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.46	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.40	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 56.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/28/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.7	GPM TOTAL FLOW is 38125374	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 34842951	GAL	
ASBPERS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 446105	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.37	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.10	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 53.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/29/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.9	GPM TOTAL FLOW is 38156997	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 34874405	GAL	
ASBPFS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 446351	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.80	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.78	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 52.9	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/30/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM TOTAL FLOW is 38188534	GAL	
W2_FLO is 22.4	GPM TOTAL FLOW is 34905845	GAL	
ASBP RS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 446540	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.03	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.80	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 54.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/31/2015
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.8	GPM TOTAL FLOW is 38220025	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 34937276	GAL	
ASBPFR is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 446717	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.12	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.05	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 55.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN

APPENDIX B

O&M Checklists



Date	10/26/2015
Inspector	JRW
Time	12:30

[illegible]

Date	11/20/2015
Inspector	JRW
Time	12:30

Notes:

APPENDIX C

Analytical Reporting Forms



November 10, 2015

Jeremy Wyckoff
Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065

Project Location: S. Otselic, NY
Client Job Number:
Project Number: 00266406.0000
Laboratory Work Order Number: 15J1277

Enclosed are results of analyses for samples received by the laboratory on October 27, 2015. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "Aaron L. Benoit", followed by a horizontal line.

Aaron L. Benoit
Project Manager

Table of Contents

Sample Summary	3
Case Narrative	4
Sample Results	5
15J1277-01	5
15J1277-02	6
15J1277-03	7
15J1277-04	8
Sample Preparation Information	9
QC Data	10
Volatile Organic Compounds by GC/MS	10
B134723	10
Flag/Qualifier Summary	12
Certifications	13
Chain of Custody/Sample Receipt	15

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065
ATTN: Jeremy Wyckoff

REPORT DATE: 11/10/2015

PURCHASE ORDER NUMBER:

PROJECT NUMBER: 00266406.0000

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 15J1277

The results of analyses performed on the following samples submitted to the CON-TEST Analytical Laboratory are found in this report.

PROJECT LOCATION: S. Otselic, NY


FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
RW-1	15J1277-01	Ground Water		EPA 624	
RW-2	15J1277-02	Ground Water		EPA 624	
EFF 46 HZ	15J1277-03	Ground Water		EPA 624	
Trip Blank	15J1277-04	Trip Blank Water		EPA 624	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Con-Test Analytical Laboratory for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.

A handwritten signature in dark ink, appearing to read "Johanna Harrington", is written over a light-colored, slightly textured background.

Johanna K. Harrington
Manager, Laboratory Reporting

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 15J1277

Date Received: 10/27/2015

Field Sample #: RW-1

Sampled: 10/26/2015 12:30

Sample ID: 15J1277-01

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
Bromomethane	ND	5.0	0.94	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
1,2-Dichlorobenzene	ND	2.0	0.10	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
1,1-Dichloroethane	1.8	2.0	0.16	µg/L	1	J	EPA 624	11/5/15	11/5/15 23:33	EEH
1,1-Dichloroethylene	0.85	2.0	0.21	µg/L	1	J	EPA 624	11/5/15	11/5/15 23:33	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.13	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
Toluene	ND	1.0	0.10	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
1,1,1-Trichloroethane	38	2.0	0.094	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	11/5/15	11/5/15 23:33	EEH
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	100	70-130				11/5/15 23:33				
Toluene-d8	100	70-130				11/5/15 23:33				
4-Bromofluorobenzene	95.5	70-130				11/5/15 23:33				

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 15J1277

Date Received: 10/27/2015

Field Sample #: RW-2

Sampled: 10/26/2015 12:35

Sample ID: 15J1277-02

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
Bromomethane	ND	5.0	0.94	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
1,2-Dichlorobenzene	ND	2.0	0.10	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
1,1-Dichloroethane	0.75	2.0	0.16	µg/L	1	J	EPA 624	11/5/15	11/5/15 23:59	EEH
1,1-Dichloroethylene	0.63	2.0	0.21	µg/L	1	J	EPA 624	11/5/15	11/5/15 23:59	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.13	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
Toluene	ND	1.0	0.10	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
1,1,1-Trichloroethane	32	2.0	0.094	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	11/5/15	11/5/15 23:59	EEH
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	100	70-130				11/5/15 23:59				
Toluene-d8	102	70-130				11/5/15 23:59				
4-Bromofluorobenzene	96.2	70-130				11/5/15 23:59				

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 15J1277

Date Received: 10/27/2015

Field Sample #: EFF 46 HZ

Sampled: 10/26/2015 12:40

Sample ID: 15J1277-03

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
Bromomethane	ND	5.0	0.94	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
1,2-Dichlorobenzene	ND	2.0	0.10	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.13	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
Toluene	ND	1.0	0.10	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	11/5/15	11/5/15 23:06	EEH
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	99.3	70-130				11/5/15 23:06				
Toluene-d8	103	70-130				11/5/15 23:06				
4-Bromofluorobenzene	96.0	70-130				11/5/15 23:06				

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 15J1277

Date Received: 10/27/2015

Field Sample #: Trip Blank

Sampled: 10/26/2015 00:00

Sample ID: 15J1277-04

Sample Matrix: Trip Blank Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
Bromomethane	ND	5.0	0.94	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
1,2-Dichlorobenzene	ND	2.0	0.10	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.13	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
Toluene	ND	1.0	0.10	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	11/5/15	11/5/15 22:39	EEH
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	99.2	70-130				11/5/15 22:39				
Toluene-d8	101	70-130				11/5/15 22:39				
4-Bromofluorobenzene	94.8	70-130				11/5/15 22:39				

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Sample Extraction Data

Prep Method: SW-846 5030B-EPA 624

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
15J1277-01 [RW-1]	B134723	5	5.00	11/05/15
15J1277-02 [RW-2]	B134723	5	5.00	11/05/15
15J1277-03 [EFF 46 HZ]	B134723	5	5.00	11/05/15
15J1277-04 [Trip Blank]	B134723	5	5.00	11/05/15

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL
Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

Batch B134723 - SW-846 5030B
Blank (B134723-BLK1)

Prepared & Analyzed: 11/05/15

Benzene	ND	1.0	µg/L							
Bromodichloromethane	ND	2.0	µg/L							
Bromoform	ND	2.0	µg/L							
Bromomethane	ND	2.0	µg/L							
Carbon Tetrachloride	ND	2.0	µg/L							
Chlorobenzene	ND	2.0	µg/L							
Chlorodibromomethane	ND	2.0	µg/L							
Chloroethane	ND	2.0	µg/L							
2-Chloroethyl Vinyl Ether	ND	10	µg/L							
Chloroform	ND	2.0	µg/L							
Chloromethane	ND	2.0	µg/L							
1,2-Dichlorobenzene	ND	2.0	µg/L							
1,3-Dichlorobenzene	ND	2.0	µg/L							
1,4-Dichlorobenzene	ND	2.0	µg/L							
1,2-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethylene	ND	2.0	µg/L							
trans-1,2-Dichloroethylene	ND	2.0	µg/L							
1,2-Dichloropropane	ND	2.0	µg/L							
cis-1,3-Dichloropropene	ND	2.0	µg/L							
trans-1,3-Dichloropropene	ND	2.0	µg/L							
Ethylbenzene	ND	2.0	µg/L							
Methyl tert-Butyl Ether (MTBE)	ND	2.0	µg/L							
Methylene Chloride	ND	5.0	µg/L							
1,1,2,2-Tetrachloroethane	ND	2.0	µg/L							
Tetrachloroethylene	ND	2.0	µg/L							
Toluene	ND	1.0	µg/L							
1,1,1-Trichloroethane	ND	2.0	µg/L							
1,1,2-Trichloroethane	ND	2.0	µg/L							
Trichloroethylene	ND	2.0	µg/L							
Trichlorofluoromethane (Freon 11)	ND	2.0	µg/L							
Vinyl Chloride	ND	2.0	µg/L							
m+p Xylene	ND	2.0	µg/L							
o-Xylene	ND	2.0	µg/L							
Surrogate: 1,2-Dichloroethane-d4	25.0		µg/L	25.0		99.9	70-130			
Surrogate: Toluene-d8	25.5		µg/L	25.0		102	70-130			
Surrogate: 4-Bromofluorobenzene	23.7		µg/L	25.0		94.7	70-130			

LCS (B134723-BS1)

Prepared & Analyzed: 11/05/15

Benzene	10.4	1.0	µg/L	10.0		104	37-151			
Bromodichloromethane	9.34	2.0	µg/L	10.0		93.4	35-155			
Bromoform	8.59	2.0	µg/L	10.0		85.9	45-169			
Bromomethane	5.00	2.0	µg/L	10.0		50.0	20-242			
Carbon Tetrachloride	9.76	2.0	µg/L	10.0		97.6	70-140			
Chlorobenzene	9.51	2.0	µg/L	10.0		95.1	37-160			
Chlorodibromomethane	9.21	2.0	µg/L	10.0		92.1	53-149			
Chloroethane	11.7	2.0	µg/L	10.0		117	70-130			
2-Chloroethyl Vinyl Ether	106	10	µg/L	100		106	10-305			
Chloroform	9.52	2.0	µg/L	10.0		95.2	51-138			
Chloromethane	8.48	2.0	µg/L	10.0		84.8	20-273			
1,2-Dichlorobenzene	9.16	2.0	µg/L	10.0		91.6	18-190			
1,3-Dichlorobenzene	9.56	2.0	µg/L	10.0		95.6	59-156			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL
Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch B134723 - SW-846 5030B										
LCS (B134723-BS1)				Prepared & Analyzed: 11/05/15						
1,4-Dichlorobenzene	9.49	2.0	µg/L	10.0		94.9	18-190			
1,2-Dichloroethane	9.05	2.0	µg/L	10.0		90.5	49-155			
1,1-Dichloroethane	10.9	2.0	µg/L	10.0		109	59-155			
1,1-Dichloroethylene	10.2	2.0	µg/L	10.0		102	20-234			
trans-1,2-Dichloroethylene	10.7	2.0	µg/L	10.0		107	54-156			
1,2-Dichloropropane	10.8	2.0	µg/L	10.0		108	20-210			
cis-1,3-Dichloropropene	11.4	2.0	µg/L	10.0		114	20-227			
trans-1,3-Dichloropropene	11.3	2.0	µg/L	10.0		113	17-183			
Ethylbenzene	9.41	2.0	µg/L	10.0		94.1	37-162			
Methyl tert-Butyl Ether (MTBE)	10.4	2.0	µg/L	10.0		104	70-130			
Methylene Chloride	11.2	5.0	µg/L	10.0		112	50-221			
1,1,2,2-Tetrachloroethane	10.5	2.0	µg/L	10.0		105	46-157			
Tetrachloroethylene	9.83	2.0	µg/L	10.0		98.3	64-148			
Toluene	9.40	1.0	µg/L	10.0		94.0	47-150			
1,1,1-Trichloroethane	9.47	2.0	µg/L	10.0		94.7	52-162			
1,1,2-Trichloroethane	10.2	2.0	µg/L	10.0		102	52-150			
Trichloroethylene	9.90	2.0	µg/L	10.0		99.0	71-157			
Trichlorofluoromethane (Freon 11)	7.63	2.0	µg/L	10.0		76.3	17-181			
Vinyl Chloride	7.89	2.0	µg/L	10.0		78.9	20-251			
m+p Xylene	19.1	2.0	µg/L	20.0		95.6	70-130			
o-Xylene	9.68	2.0	µg/L	10.0		96.8	70-130			
Surrogate: 1,2-Dichloroethane-d4	25.3		µg/L	25.0		101	70-130			
Surrogate: Toluene-d8	24.9		µg/L	25.0		99.4	70-130			
Surrogate: 4-Bromofluorobenzene	23.9		µg/L	25.0		95.7	70-130			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
	Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
	No results have been blank subtracted unless specified in the case narrative section.
J	Detected but below the Reporting Limit (lowest calibration standard); therefore, result is an estimated concentration (CLP J-Flag).

CERTIFICATIONS
Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 624 in Water</i>	
Benzene	CT,MA,NH,NY,RI,NC,ME,VA
Bromodichloromethane	CT,MA,NH,NY,RI,NC,ME,VA
Bromoform	CT,MA,NH,NY,RI,NC,ME,VA
Bromomethane	CT,MA,NH,NY,RI,NC,ME,VA
Carbon Tetrachloride	CT,MA,NH,NY,RI,NC,ME,VA
Chlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
Chlorodibromomethane	CT,MA,NH,NY,RI,NC,ME,VA
Chloroethane	CT,MA,NH,NY,RI,NC,ME,VA
2-Chloroethyl Vinyl Ether	CT,MA,NH,NY,RI,NC,ME,VA
Chloroform	CT,MA,NH,NY,RI,NC,ME,VA
Chloromethane	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,3-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,4-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
trans-1,2-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichloropropane	CT,MA,NH,NY,RI,NC,ME,VA
cis-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA
trans-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA
Ethylbenzene	CT,MA,NH,NY,RI,NC,ME,VA
Methyl tert-Butyl Ether (MTBE)	NC
Methylene Chloride	CT,MA,NH,NY,RI,NC,ME,VA
1,1,2,2-Tetrachloroethane	CT,MA,NH,NY,RI,NC,ME,VA
Tetrachloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
Toluene	CT,MA,NH,NY,RI,NC,ME,VA
1,1,1-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1,2-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
Trichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
Trichlorofluoromethane (Freon 11)	CT,MA,NH,NY,RI,NC,ME,VA
Vinyl Chloride	CT,MA,NH,NY,RI,NC,ME,VA
m+p Xylene	CT,MA,NH,NY,RI,NC,VA
o-Xylene	CT,MA,NH,NY,RI,NC,VA

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

The CON-TEST Environmental Laboratory operates under the following certifications and accreditations:

Code	Description	Number	Expires
AIHA	AIHA-LAP, LLC	100033	02/1/2016
MA	Massachusetts DEP	M-MA100	06/30/2016
CT	Connecticut Department of Public Health	PH-0567	09/30/2017
NY	New York State Department of Health	10899 NELAP	04/1/2016
NH-S	New Hampshire Environmental Lab	2516 NELAP	02/5/2016
RI	Rhode Island Department of Health	LAO00112	12/30/2015
NC	North Carolina Div. of Water Quality	652	12/31/2015
NJ	New Jersey DEP	MA007 NELAP	06/30/2016
FL	Florida Department of Health	E871027 NELAP	06/30/2016
VT	Vermont Department of Health Lead Laboratory	LL015036	07/30/2016
WA	State of Washington Department of Ecology	C2065	02/23/2016
ME	State of Maine	2011028	06/9/2017
VA	Commonwealth of Virginia	460217	12/14/2015
NH-P	New Hampshire Environmental Lab	2557 NELAP	09/6/2016



con-test[®]
ANALYTICAL LABORATORY

Phone: 413-525-2332
Fax: 413-525-6405
Email: info@contestlabs.com
www.contestlabs.com

CHAIN OF CUSTODY RECORD

39 Spruce Street
East Longmeadow, MA 01028

Page 1 of 1

Company Name: ARCADIS

Telephone: 518-250-7300

Address: 855 RT 416, SR 210

Project #

Attention: Jeremy Wyckoff

Client PO# 0026440610000

Project Location: S. Otisville, NY

DATA DELIVERY (check all that apply)
☐ FAX ☒ EMAIL ☐ WEBSITE

Sampled By: J. Wyckoff

Email: jeremy.wyckoff@arcadis.com

O Project Proposal Provided? (for billing purposes)

Format: ☐ PDF ☒ EXCEL ☐ GIS ☐ OTHER

Collection

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Date

Time

Notes

Comments

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

Beginning Date/Time



Ship

Track

Manage

Learn

FedEx Office®

Login

FedEx® Tracking

806663907103

Ship date:

Mon 10/26/2015

CLIUS

**Delivered**

Signed for by: P.BLAKE

Actual delivery:

Tue 10/27/2015 9:40 am

MA US

Travel History

▲ Date/Time	Activity	Location
10/27/2015 - Tuesday		
9:40 am	Delivered	MA
7:30 am	On FedEx vehicle for delivery	WINDSOR LOCKS, CT
7:24 am	At local FedEx facility	WINDSOR LOCKS, CT
3:30 am	Departed FedEx location	NEWARK, NJ
10/26/2015 - Monday		
11:41 pm	Arrived at FedEx location	NEWARK, NJ
7:15 pm	Left FedEx origin facility	BINGHAMTON, NY
4:36 pm	Picked up	BINGHAMTON, NY

Shipment Facts

Tracking number	806663907103	Service	FedEx Priority Overnight
Weight	9 lbs / 4.08 kgs	Signature services	Direct signature required
Delivered To	Shipping/Receiving	Total pieces	1
Total shipment weight	9 lbs / 4.08 kgs	Shipper reference	00266406 0000
Packaging	Your Packaging	Special handling section	Deliver Weekday, Direct Signature Required



Search

Customer Focus

New Customer Center
Small Business Center
Service Guide
Customer Support

Company Information

About FedEx
Careers
Investor Relations

Featured Services

FedEx One Rate
FedEx SameDay
FedEx Home Delivery
Healthcare Solutions
Online Retail Solutions
Packaging Services
Ancillary Clearance Services

Other Resources

FedEx Compatible
Developer Resource Center
FedEx Ship Manager Software
FedEx Mobile

Companies

FedEx Express
FedEx Ground
FedEx Office
FedEx Freight
FedEx Custom Critical
FedEx Trade Networks
FedEx SupplyChain
FedEx TechConnect

Follow FedEx

United States - English

Login Sample Receipt Checklist

(Rejection Criteria Listing - Using Sample Acceptance Policy)

Any False statement will be brought to the attention of Client

Question	Answer (True/False)		Comment
	T/F/NA		
1) The cooler's custody seal, if present, is intact.	NA		
2) The cooler or samples do not appear to have been compromised or tampered with.	T		
3) Samples were received on ice.	T		
4) Cooler Temperature is acceptable.	T		
5) Cooler Temperature is recorded.	T		
6) COC is filled out in ink and legible.	T		
7) COC is filled out with all pertinent information.	T		
8) Field Sampler's name present on COC.	T		
9) There are no discrepancies between the sample IDs on the container and the COC.	T		
10) Samples are received within Holding Time.	T		
11) Sample containers have legible labels.	T		
12) Containers are not broken or leaking.	T		
13) Air Cassettes are not broken/open.	NA		
14) Sample collection date/times are provided.	T		
15) Appropriate sample containers are used.	T		
16) Proper collection media used.	T		
17) No headspace sample bottles are completely filled.	T		
18) There is sufficient volume for all requested analyses, including any requested MS/MSDs.	T		
19) Trip blanks provided if applicable.	T		
20) VOA sample vials do not have head space or bubble is <6mm (1/4") in diameter.	T		
21) Samples do not require splitting or compositing.	T		

Doc #277 Rev. 4 August 2013

Who notified of False statements?

Log-In Technician Initials: PB


Date/Time:

Date/Time: 10-27-15
9:40

39 Spruce St.
East Longmeadow, MA. 01028
P: 413-525-2332
F: 413-525-6405
www.contestlabs.com



Page 1 of 2



Sample Receipt Checklist

CLIENT NAME: Arcadis RECEIVED BY: PB DATE: 10-27-15

1) Was the chain(s) of custody relinquished and signed? Yes No No CoC Included

2) Does the chain agree with the samples? Yes No

If not, explain:

3) Are all the samples in good condition? Yes No

If not, explain:

4) How were the samples received:

On Ice ☒ Direct from Sampling ☐ Ambient ☐ In Cooler(s) ☒

Were the samples received in Temperature Compliance of (2-6°C)? Yes No N/A

Temperature °C by Temp blank 3.0 Temperature °C by Temp gun _____

5) Are there Dissolved samples for the lab to filter? Yes No

Who was notified _____ Date _____ Time _____

6) Are there any RUSH or SHORT HOLDING TIME samples? Yes No

Who was notified _____ Date _____ Time _____

7) Location where samples are stored:

begin

Permission to subcontract samples? Yes No
(Walk-in clients only) if not already approved
Client Signature: _____

8) Do all samples have the proper Acid pH: Yes No N/A

9) Do all samples have the proper Base pH: Yes No N/A

10) Was the PC notified of any discrepancies with the CoC vs the samples: Yes No N/A

Containers received at Con-Test

	# of containers		# of containers
1 Liter Amber		8 oz amber/clear jar	
500 mL Amber		4 oz amber/clear jar	
250 mL Amber (8oz amber)		2 oz amber/clear jar	
1 Liter Plastic		Plastic Bag / Ziploc	
500 mL Plastic		SOC Kit	
250 mL plastic		Non-ConTest Container	
40 mL Vial - type listed below	<u>10</u>	Perchlorate Kit	
Colisure / bacteria bottle		Flashpoint bottle	
Dissolved Oxygen bottle		Other glass jar	
Encore		Other	

Laboratory Comments:

40 mL vials: # HCl 10

Methanol _____

Doc# 277

Bisulfate _____

DI Water _____

Rev. 4 August 2013

Thiosulfate _____

Unpreserved _____

Time and Date Frozen:

December 4, 2015

Jeremy Wyckoff
Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065

Project Location: S. Otselic, NY
Client Job Number:
Project Number: 00266406.0000
Laboratory Work Order Number: 15K1088

Enclosed are results of analyses for samples received by the laboratory on November 23, 2015. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "Aaron L. Benoit", with a horizontal line extending to the right.

Aaron L. Benoit
Project Manager

Table of Contents

Sample Summary	3
Case Narrative	4
Sample Results	5
15K1088-01	5
15K1088-02	6
15K1088-03	7
15K1088-04	8
Sample Preparation Information	9
QC Data	10
Volatile Organic Compounds by GC/MS	10
B136769	10
Flag/Qualifier Summary	12
Certifications	13
Chain of Custody/Sample Receipt	15

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065
ATTN: Jeremy Wyckoff

REPORT DATE: 12/4/2015

PURCHASE ORDER NUMBER:

PROJECT NUMBER: 00266406.0000

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 15K1088

The results of analyses performed on the following samples submitted to the CON-TEST Analytical Laboratory are found in this report.

PROJECT LOCATION: S. Otselic, NY


FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
RW-1	15K1088-01	Ground Water		EPA 624	
RW-2	15K1088-02	Ground Water		EPA 624	
Eff 46 HA	15K1088-03	Ground Water		EPA 624	
Trip Blank	15K1088-04	Trip Blank Water		EPA 624	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Con-Test Analytical Laboratory for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.

A handwritten signature in dark ink, appearing to read "Johanna Harrington", is written over a light-colored, slightly textured background.

Johanna K. Harrington

Manager, Laboratory Reporting

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 15K1088

Date Received: 11/23/2015

Field Sample #: RW-1

Sampled: 11/20/2015 12:40

Sample ID: 15K1088-01

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
Bromomethane	ND	5.0	0.94	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
1,2-Dichlorobenzene	ND	2.0	0.10	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
1,1-Dichloroethane	2.1	2.0	0.16	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
1,1-Dichloroethylene	1.0	2.0	0.21	µg/L	1	J	EPA 624	12/3/15	12/3/15 22:23	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.13	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
Toluene	ND	1.0	0.10	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
1,1,1-Trichloroethane	41	2.0	0.094	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	12/3/15	12/3/15 22:23	MFF
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	117	70-130				12/3/15 22:23				
Toluene-d8	100	70-130				12/3/15 22:23				
4-Bromofluorobenzene	81.6	70-130				12/3/15 22:23				

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 15K1088

Date Received: 11/23/2015

Field Sample #: RW-2

Sampled: 11/20/2015 12:45

Sample ID: 15K1088-02

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
Bromomethane	ND	5.0	0.94	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
1,2-Dichlorobenzene	ND	2.0	0.10	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
1,1-Dichloroethane	0.85	2.0	0.16	µg/L	1	J	EPA 624	12/3/15	12/3/15 22:49	MFF
1,1-Dichloroethylene	0.92	2.0	0.21	µg/L	1	J	EPA 624	12/3/15	12/3/15 22:49	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.13	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
Toluene	ND	1.0	0.10	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
1,1,1-Trichloroethane	34	2.0	0.094	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	12/3/15	12/3/15 22:49	MFF
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	113	70-130				12/3/15 22:49				
Toluene-d8	99.6	70-130				12/3/15 22:49				
4-Bromofluorobenzene	80.7	70-130				12/3/15 22:49				

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 15K1088

Date Received: 11/23/2015

Field Sample #: Eff 46 HA

Sampled: 11/20/2015 12:50

Sample ID: 15K1088-03

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
Bromomethane	ND	5.0	0.94	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
1,2-Dichlorobenzene	ND	2.0	0.10	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.13	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
Toluene	ND	1.0	0.10	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	12/3/15	12/3/15 21:57	MFF
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	120	70-130				12/3/15 21:57				
Toluene-d8	99.7	70-130				12/3/15 21:57				
4-Bromofluorobenzene	78.2	70-130				12/3/15 21:57				

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 15K1088

Date Received: 11/23/2015

Field Sample #: Trip Blank

Sampled: 11/20/2015 00:00

Sample ID: 15K1088-04

Sample Matrix: Trip Blank Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
Bromomethane	ND	5.0	0.94	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
1,2-Dichlorobenzene	ND	2.0	0.10	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.13	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
Tetrachloroethylene	0.47	2.0	0.17	µg/L	1	J	EPA 624	12/3/15	12/3/15 21:32	MFF
Toluene	0.47	1.0	0.10	µg/L	1	J	EPA 624	12/3/15	12/3/15 21:32	MFF
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	12/3/15	12/3/15 21:32	MFF
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	117	70-130								
Toluene-d8	102	70-130								
4-Bromofluorobenzene	81.3	70-130								

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Sample Extraction Data

Prep Method: SW-846 5030B-EPA 624

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
15K1088-01 [RW-1]	B136769	5	5.00	12/03/15
15K1088-02 [RW-2]	B136769	5	5.00	12/03/15
15K1088-03 [Eff 46 HA]	B136769	5	5.00	12/03/15
15K1088-04 [Trip Blank]	B136769	5	5.00	12/03/15

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL
Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

Batch B136769 - SW-846 5030B
Blank (B136769-BLK1)

Prepared & Analyzed: 12/03/15

Benzene	ND	1.0	µg/L							
Bromodichloromethane	ND	2.0	µg/L							
Bromoform	ND	2.0	µg/L							
Bromomethane	ND	2.0	µg/L							
Carbon Tetrachloride	ND	2.0	µg/L							
Chlorobenzene	ND	2.0	µg/L							
Chlorodibromomethane	ND	2.0	µg/L							
Chloroethane	ND	2.0	µg/L							
2-Chloroethyl Vinyl Ether	ND	10	µg/L							
Chloroform	ND	2.0	µg/L							
Chloromethane	ND	2.0	µg/L							
1,2-Dichlorobenzene	ND	2.0	µg/L							
1,3-Dichlorobenzene	ND	2.0	µg/L							
1,4-Dichlorobenzene	ND	2.0	µg/L							
1,2-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethylene	ND	2.0	µg/L							
trans-1,2-Dichloroethylene	ND	2.0	µg/L							
1,2-Dichloropropane	ND	2.0	µg/L							
cis-1,3-Dichloropropene	ND	2.0	µg/L							
trans-1,3-Dichloropropene	ND	2.0	µg/L							
Ethylbenzene	ND	2.0	µg/L							
Methyl tert-Butyl Ether (MTBE)	ND	2.0	µg/L							
Methylene Chloride	ND	5.0	µg/L							
1,1,2,2-Tetrachloroethane	ND	2.0	µg/L							
Tetrachloroethylene	ND	2.0	µg/L							
Toluene	ND	1.0	µg/L							
1,1,1-Trichloroethane	ND	2.0	µg/L							
1,1,2-Trichloroethane	ND	2.0	µg/L							
Trichloroethylene	ND	2.0	µg/L							
Trichlorofluoromethane (Freon 11)	ND	2.0	µg/L							
Vinyl Chloride	ND	2.0	µg/L							
m+p Xylene	ND	2.0	µg/L							
o-Xylene	ND	2.0	µg/L							
Surrogate: 1,2-Dichloroethane-d4	28.0		µg/L	25.0		112	70-130			
Surrogate: Toluene-d8	25.1		µg/L	25.0		100	70-130			
Surrogate: 4-Bromofluorobenzene	20.4		µg/L	25.0		81.6	70-130			

LCS (B136769-BS1)

Prepared & Analyzed: 12/03/15

Benzene	10.1	1.0	µg/L	10.0		101	37-151			
Bromodichloromethane	9.35	2.0	µg/L	10.0		93.5	35-155			
Bromoform	7.29	2.0	µg/L	10.0		72.9	45-169			
Bromomethane	10.3	2.0	µg/L	10.0		103	20-242			
Carbon Tetrachloride	9.95	2.0	µg/L	10.0		99.5	70-140			
Chlorobenzene	9.62	2.0	µg/L	10.0		96.2	37-160			
Chlorodibromomethane	8.68	2.0	µg/L	10.0		86.8	53-149			
Chloroethane	9.74	2.0	µg/L	10.0		97.4	70-130			
2-Chloroethyl Vinyl Ether	82.6	10	µg/L	100		82.6	10-305			
Chloroform	9.84	2.0	µg/L	10.0		98.4	51-138			
Chloromethane	12.1	2.0	µg/L	10.0		121	20-273			
1,2-Dichlorobenzene	8.99	2.0	µg/L	10.0		89.9	18-190			
1,3-Dichlorobenzene	9.31	2.0	µg/L	10.0		93.1	59-156			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL
Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch B136769 - SW-846 5030B										
LCS (B136769-BS1)				Prepared & Analyzed: 12/03/15						
1,4-Dichlorobenzene	9.12	2.0	µg/L	10.0		91.2	18-190			
1,2-Dichloroethane	10.7	2.0	µg/L	10.0		107	49-155			
1,1-Dichloroethane	10.3	2.0	µg/L	10.0		103	59-155			
1,1-Dichloroethylene	10.3	2.0	µg/L	10.0		103	20-234			
trans-1,2-Dichloroethylene	11.0	2.0	µg/L	10.0		110	54-156			
1,2-Dichloropropane	10.5	2.0	µg/L	10.0		105	20-210			
cis-1,3-Dichloropropene	10.4	2.0	µg/L	10.0		104	20-227			
trans-1,3-Dichloropropene	10.0	2.0	µg/L	10.0		100	17-183			
Ethylbenzene	9.05	2.0	µg/L	10.0		90.5	37-162			
Methyl tert-Butyl Ether (MTBE)	8.25	2.0	µg/L	10.0		82.5	70-130			
Methylene Chloride	10.7	5.0	µg/L	10.0		107	50-221			
1,1,2,2-Tetrachloroethane	8.02	2.0	µg/L	10.0		80.2	46-157			
Tetrachloroethylene	9.84	2.0	µg/L	10.0		98.4	64-148			
Toluene	10.0	1.0	µg/L	10.0		100	47-150			
1,1,1-Trichloroethane	9.77	2.0	µg/L	10.0		97.7	52-162			
1,1,2-Trichloroethane	9.29	2.0	µg/L	10.0		92.9	52-150			
Trichloroethylene	10.0	2.0	µg/L	10.0		100	71-157			
Trichlorofluoromethane (Freon 11)	11.0	2.0	µg/L	10.0		110	17-181			
Vinyl Chloride	11.4	2.0	µg/L	10.0		114	20-251			
m+p Xylene	17.7	2.0	µg/L	20.0		88.6	70-130			
o-Xylene	8.67	2.0	µg/L	10.0		86.7	70-130			
Surrogate: 1,2-Dichloroethane-d4	27.2		µg/L	25.0		109	70-130			
Surrogate: Toluene-d8	26.8		µg/L	25.0		107	70-130			
Surrogate: 4-Bromofluorobenzene	22.5		µg/L	25.0		90.0	70-130			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
	Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
	No results have been blank subtracted unless specified in the case narrative section.
J	Detected but below the Reporting Limit (lowest calibration standard); therefore, result is an estimated concentration (CLP J-Flag).

CERTIFICATIONS
Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 624 in Water</i>	
Benzene	CT,MA,NH,NY,RI,NC,ME,VA
Bromodichloromethane	CT,MA,NH,NY,RI,NC,ME,VA
Bromoform	CT,MA,NH,NY,RI,NC,ME,VA
Bromomethane	CT,MA,NH,NY,RI,NC,ME,VA
Carbon Tetrachloride	CT,MA,NH,NY,RI,NC,ME,VA
Chlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
Chlorodibromomethane	CT,MA,NH,NY,RI,NC,ME,VA
Chloroethane	CT,MA,NH,NY,RI,NC,ME,VA
2-Chloroethyl Vinyl Ether	CT,MA,NH,NY,RI,NC,ME,VA
Chloroform	CT,MA,NH,NY,RI,NC,ME,VA
Chloromethane	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,3-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,4-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
trans-1,2-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichloropropane	CT,MA,NH,NY,RI,NC,ME,VA
cis-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA
trans-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA
Ethylbenzene	CT,MA,NH,NY,RI,NC,ME,VA
Methyl tert-Butyl Ether (MTBE)	NC
Methylene Chloride	CT,MA,NH,NY,RI,NC,ME,VA
1,1,2,2-Tetrachloroethane	CT,MA,NH,NY,RI,NC,ME,VA
Tetrachloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
Toluene	CT,MA,NH,NY,RI,NC,ME,VA
1,1,1-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1,2-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
Trichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
Trichlorofluoromethane (Freon 11)	CT,MA,NH,NY,RI,NC,ME,VA
Vinyl Chloride	CT,MA,NH,NY,RI,NC,ME,VA
m+p Xylene	CT,MA,NH,NY,RI,NC,VA
o-Xylene	CT,MA,NH,NY,RI,NC,VA

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

The CON-TEST Environmental Laboratory operates under the following certifications and accreditations:

Code	Description	Number	Expires
AIHA	AIHA-LAP, LLC	100033	02/1/2016
MA	Massachusetts DEP	M-MA100	06/30/2016
CT	Connecticut Department of Public Health	PH-0567	09/30/2017
NY	New York State Department of Health	10899 NELAP	04/1/2016
NH-S	New Hampshire Environmental Lab	2516 NELAP	02/5/2016
RI	Rhode Island Department of Health	LAO00112	12/30/2015
NC	North Carolina Div. of Water Quality	652	12/31/2015
NJ	New Jersey DEP	MA007 NELAP	06/30/2016
FL	Florida Department of Health	E871027 NELAP	06/30/2016
VT	Vermont Department of Health Lead Laboratory	LL015036	07/30/2016
WA	State of Washington Department of Ecology	C2065	02/23/2016
ME	State of Maine	2011028	06/9/2017
VA	Commonwealth of Virginia	460217	12/14/2015
NH-P	New Hampshire Environmental Lab	2557 NELAP	09/6/2016



Phone: 413-525-2332
Fax: 413-525-6405
Email: info@contestlabs.com
www.contestlabs.com

CHAIN OF CUSTODY RECORD

39 Spruce Street
East Longmeadow, MA 01028

Page 1 of 1

Company Name: ARCADIS

Address: 855 RT 146, STE 210

Attention: J. W. Zickert

Project Location: S. O. Eselie, NY

Sampled By: J. W. Zickert

Telephone: 518-250-7380

Project # 00264426 0000

Client PO#

DATA DELIVERY (check all that apply)

Fax #

Format: PDF EXCEL GIS OTHER

Email: j.zickert@arcadis.com

O Project Proposal Provided? (for billing purposes)

Collection

Beginning Date/Time

Ending Date/Time

Composite

Grab

Matrix Code

Conc Code

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

01 RW-1

02 RW-2

03 EFF 46 HZ

04 TEIP Blank

11/23/15

12/45

12/45

12/45

12/45

12/45

12/45

12/45

12/45

12/45

12/45

12/45

12/45

12/45

12/45

12/45

12/45

12/45

12/45

12/45

12/45

12/45

12/45

12/45

12/45

12/45

12/45

12/45

12/45

12/45

12/45

Comments:

Relinquished by: (signature)

Date/Time: 11/23/15 0830

Received by: (signature)

Date/Time: 11/23/15 1245 PM

Relinquished by: (signature)

Date/Time: 11/23/15 5:15 PM

Received by: (signature)

Date/Time: 11/23/15 1715

Relinquished by: (signature)


Date/Time: 11/23/15 1715

URNAROUND TIME (business days) STARTS AT 9:00 A.M. THE DAY AFTER SAMPLE RECEIPT UNLESS THERE ARE QUESTIONS ON YOUR CHAIN. IF THIS FORM IS NOT FILLED OUT COMPLETELY OR IS INCORRECT, TURNAROUND TIME WILL NOT START UNTIL ALL QUESTIONS ARE ANSWERED. PLEASE BE CAREFUL TO NOT CONTAMINATE THIS DOCUMENT

39 Spruce St.
East Longmeadow, MA. 01028
P: 413-525-2332
F: 413-525-6405
www.contestlabs.com



Page 1 of 2



Sample Receipt Checklist

CLIENT NAME: Arcadis RECEIVED BY: JDL DATE: 11/23/15

- 1) Was the chain(s) of custody relinquished and signed? Yes No No CoC Included
 2) Does the chain agree with the samples? Yes No
 If not, explain:
 3) Are all the samples in good condition? Yes No
 If not, explain:

4) How were the samples received:

On Ice ☒ Direct from Sampling ☐ Ambient ☐ In Cooler(s) ☒

Were the samples received in Temperature Compliance of (2-6°C)? Yes No N/A

Temperature °C by Temp blank _____ Temperature °C by Temp gun 5.8

5) Are there Dissolved samples for the lab to filter? Yes No

Who was notified _____ Date _____ Time _____

6) Are there any RUSH or SHORT HOLDING TIME samples? Yes No

Who was notified _____ Date _____ Time _____

7) Location where samples are stored:

19

Permission to subcontract samples? Yes No
(Walk-in clients only) if not already approved
Client Signature: _____

8) Do all samples have the proper Acid pH: Yes No N/A

9) Do all samples have the proper Base pH: Yes No N/A

10) Was the PC notified of any discrepancies with the CoC vs the samples: Yes No N/A

Containers received at Con-Test

	# of containers		# of containers
1 Liter Amber		8 oz amber/clear jar	
500 mL Amber		4 oz amber/clear jar	
250 mL Amber (8oz amber)		2 oz amber/clear jar	
1 Liter Plastic		Plastic Bag / Ziploc	
500 mL Plastic		SOC Kit	
250 mL plastic		Non-ConTest Container	
40 mL Vial - type listed below	<u>//</u>	Perchlorate Kit	
Colisure / bacteria bottle		Flashpoint bottle	
Dissolved Oxygen bottle		Other glass jar	
Encore		Other	

Laboratory Comments:

40 mL vials: # HCl // # Methanol _____
 Doc# 277 # Bisulfate _____ # DI Water _____
 Rev. 4 August 2013 # Thiosulfate _____ Unpreserved _____

Time and Date Frozen:

Page 2 of 2

Login Sample Receipt Checklist

(Rejection Criteria Listing - Using Sample Acceptance Policy)
Any False statement will be brought to the attention of Client

Question	Answer (True/False)		Comment
	T/F/NA		
1) The cooler's custody seal, if present, is intact.	NA		
2) The cooler or samples do not appear to have been compromised or tampered with.	T		
3) Samples were received on ice.	T		
4) Cooler Temperature is acceptable.	T		
5) Cooler Temperature is recorded.	T		
6) COC is filled out in ink and legible.	T		
7) COC is filled out with all pertinent information.	T		
8) Field Sampler's name present on COC.	T		
9) There are no discrepancies between the sample IDs on the container and the COC.	T		
10) Samples are received within Holding Time.	T		
11) Sample containers have legible labels.	T		
12) Containers are not broken or leaking.	T		
13) Air Cassettes are not broken/open.	NA		
14) Sample collection date/times are provided.	T		
15) Appropriate sample containers are used.	T		
16) Proper collection media used.	T		
17) No headspace sample bottles are completely filled.	T		
18) There is sufficient volume for all requested analyses, including any requested MS/MSDs.	T		
19) Trip blanks provided if applicable.	T		
20) VOA sample vials do not have head space or bubble is <6mm (1/4") in diameter.	T		
21) Samples do not require splitting or compositing.	T		

Doc #277 Rev. 4 August 2013

Who notified of False statements?

Log-In Technician Initials:

JDL

Date/Time:

Date/Time:

11/23/15 1716

January 4, 2016

Jeremy Wyckoff
Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065

Project Location: South Otselic, NY
Client Job Number:
Project Number: 00266406.0000
Laboratory Work Order Number: 15L1228

Enclosed are results of analyses for samples received by the laboratory on December 23, 2015. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "Aaron L. Benoit", with a horizontal line extending to the right.

Aaron L. Benoit
Project Manager

Table of Contents

Sample Summary	3
Case Narrative	4
Sample Results	5
15L1228-01	5
15L1228-02	6
15L1228-03	7
15L1228-04	8
Sample Preparation Information	9
QC Data	10
Volatile Organic Compounds by GC/MS	10
B138929	10
Flag/Qualifier Summary	12
Certifications	13
Chain of Custody/Sample Receipt	15

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065
ATTN: Jeremy Wyckoff

REPORT DATE: 1/4/2016

PURCHASE ORDER NUMBER:

PROJECT NUMBER: 00266406.0000

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 15L1228

The results of analyses performed on the following samples submitted to the CON-TEST Analytical Laboratory are found in this report.

PROJECT LOCATION: South Otselic, NY

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
RW-1	15L1228-01	Ground Water		EPA 624	
RW-2	15L1228-02	Ground Water		EPA 624	
EFF 46 HZ	15L1228-03	Ground Water		EPA 624	
Trip Blank	15L1228-04	Trip Blank Water		EPA 624	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Con-Test Analytical Laboratory for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.

A handwritten signature in black ink, appearing to read "Tod Kopyscinski". The signature is fluid and cursive, with the first name "Tod" being more prominent.

Tod E. Kopyscinski
Laboratory Director

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: South Otselic, NY

Sample Description:

Work Order: 15L1228

Date Received: 12/23/2015

Field Sample #: RW-1

Sampled: 12/21/2015 11:57

Sample ID: 15L1228-01

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
1,1-Dichloroethane	1.5	2.0	0.16	µg/L	1	J	EPA 624	12/31/15	1/1/16 0:29	WSD
1,1-Dichloroethylene	0.80	2.0	0.21	µg/L	1	J	EPA 624	12/31/15	1/1/16 0:29	WSD
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
1,1,1-Trichloroethane	32	2.0	0.094	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	12/31/15	1/1/16 0:29	WSD
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	94.5	70-130								
Toluene-d8	103	70-130								
4-Bromofluorobenzene	101	70-130								

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: South Otselic, NY

Sample Description:

Work Order: 15L1228

Date Received: 12/23/2015

Field Sample #: RW-2

Sampled: 12/21/2015 12:05

Sample ID: 15L1228-02

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
1,1-Dichloroethane	0.61	2.0	0.16	µg/L	1	J	EPA 624	12/31/15	1/1/16 0:56	WSD
1,1-Dichloroethylene	0.58	2.0	0.21	µg/L	1	J	EPA 624	12/31/15	1/1/16 0:56	WSD
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
1,1,1-Trichloroethane	26	2.0	0.094	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	12/31/15	1/1/16 0:56	WSD
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	96.1	70-130								
Toluene-d8	102	70-130								
4-Bromofluorobenzene	101	70-130								

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: South Otselic, NY

Sample Description:

Work Order: 15L1228

Date Received: 12/23/2015

Field Sample #: EFF 46 HZ

Sampled: 12/21/2015 12:10

Sample ID: 15L1228-03

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	12/31/15	1/1/16 0:02	WSD
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	94.1	70-130								
Toluene-d8	103	70-130								
4-Bromofluorobenzene	99.4	70-130								

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: South Otselic, NY

Sample Description:

Work Order: 15L1228

Date Received: 12/23/2015

Field Sample #: Trip Blank

Sampled: 12/21/2015 00:00

Sample ID: 15L1228-04

Sample Matrix: Trip Blank Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
Toluene	0.41	1.0	0.17	µg/L	1	J	EPA 624	12/31/15	12/31/15 23:36	WSD
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	12/31/15	12/31/15 23:36	WSD
m+p Xylene	0.34	2.0	0.25	µg/L	1	J	EPA 624	12/31/15	12/31/15 23:36	WSD
o-Xylene	0.14	2.0	0.13	µg/L	1	J	EPA 624	12/31/15	12/31/15 23:36	WSD
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	95.8	70-130				12/31/15 23:36				
Toluene-d8	102	70-130				12/31/15 23:36				
4-Bromofluorobenzene	101	70-130				12/31/15 23:36				

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Sample Extraction Data

Prep Method: SW-846 5030B-EPA 624

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
15L1228-01 [RW-1]	B138929	5	5.00	12/31/15
15L1228-02 [RW-2]	B138929	5	5.00	12/31/15
15L1228-03 [EFF 46 HZ]	B138929	5	5.00	12/31/15
15L1228-04 [Trip Blank]	B138929	5	5.00	12/31/15

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL
Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

Batch B138929 - SW-846 5030B
Blank (B138929-BLK1)

Prepared & Analyzed: 12/31/15

Benzene	ND	1.0	µg/L							
Bromodichloromethane	ND	2.0	µg/L							
Bromoform	ND	2.0	µg/L							
Bromomethane	ND	2.0	µg/L							
Carbon Tetrachloride	ND	2.0	µg/L							
Chlorobenzene	ND	2.0	µg/L							
Chlorodibromomethane	ND	2.0	µg/L							
Chloroethane	ND	2.0	µg/L							
2-Chloroethyl Vinyl Ether	ND	10	µg/L							
Chloroform	ND	2.0	µg/L							
Chloromethane	ND	2.0	µg/L							
1,2-Dichlorobenzene	ND	2.0	µg/L							
1,3-Dichlorobenzene	ND	2.0	µg/L							
1,4-Dichlorobenzene	ND	2.0	µg/L							
1,2-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethylene	ND	2.0	µg/L							
trans-1,2-Dichloroethylene	ND	2.0	µg/L							
1,2-Dichloropropane	ND	2.0	µg/L							
cis-1,3-Dichloropropene	ND	2.0	µg/L							
trans-1,3-Dichloropropene	ND	2.0	µg/L							
Ethylbenzene	ND	2.0	µg/L							
Methyl tert-Butyl Ether (MTBE)	ND	2.0	µg/L							
Methylene Chloride	ND	5.0	µg/L							
1,1,2,2-Tetrachloroethane	ND	2.0	µg/L							
Tetrachloroethylene	ND	2.0	µg/L							
Toluene	ND	1.0	µg/L							
1,1,1-Trichloroethane	ND	2.0	µg/L							
1,1,2-Trichloroethane	ND	2.0	µg/L							
Trichloroethylene	ND	2.0	µg/L							
Trichlorofluoromethane (Freon 11)	ND	2.0	µg/L							
Vinyl Chloride	ND	2.0	µg/L							
m+p Xylene	ND	2.0	µg/L							
o-Xylene	ND	2.0	µg/L							
Surrogate: 1,2-Dichloroethane-d4	24.2		µg/L	25.0		96.9	70-130			
Surrogate: Toluene-d8	25.6		µg/L	25.0		102	70-130			
Surrogate: 4-Bromofluorobenzene	25.1		µg/L	25.0		101	70-130			

LCS (B138929-BS1)

Prepared & Analyzed: 12/31/15

Benzene	10.0	1.0	µg/L	10.0		100	37-151			
Bromodichloromethane	9.23	2.0	µg/L	10.0		92.3	35-155			
Bromoform	8.56	2.0	µg/L	10.0		85.6	45-169			
Bromomethane	11.3	2.0	µg/L	10.0		113	20-242			
Carbon Tetrachloride	8.93	2.0	µg/L	10.0		89.3	70-140			
Chlorobenzene	9.92	2.0	µg/L	10.0		99.2	37-160			
Chlorodibromomethane	8.66	2.0	µg/L	10.0		86.6	53-149			
Chloroethane	10.6	2.0	µg/L	10.0		106	70-130			
2-Chloroethyl Vinyl Ether	63.2	10	µg/L	100		63.2	10-305			
Chloroform	9.23	2.0	µg/L	10.0		92.3	51-138			
Chloromethane	11.8	2.0	µg/L	10.0		118	20-273			
1,2-Dichlorobenzene	9.41	2.0	µg/L	10.0		94.1	18-190			
1,3-Dichlorobenzene	9.72	2.0	µg/L	10.0		97.2	59-156			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL
Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch B138929 - SW-846 5030B										
LCS (B138929-BS1)				Prepared & Analyzed: 12/31/15						
1,4-Dichlorobenzene	9.30	2.0	µg/L	10.0		93.0	18-190			
1,2-Dichloroethane	8.86	2.0	µg/L	10.0		88.6	49-155			
1,1-Dichloroethane	9.66	2.0	µg/L	10.0		96.6	59-155			
1,1-Dichloroethylene	10.0	2.0	µg/L	10.0		100	20-234			
trans-1,2-Dichloroethylene	9.89	2.0	µg/L	10.0		98.9	54-156			
1,2-Dichloropropane	10.0	2.0	µg/L	10.0		100	20-210			
cis-1,3-Dichloropropene	9.45	2.0	µg/L	10.0		94.5	20-227			
trans-1,3-Dichloropropene	9.11	2.0	µg/L	10.0		91.1	17-183			
Ethylbenzene	10.2	2.0	µg/L	10.0		102	37-162			
Methyl tert-Butyl Ether (MTBE)	9.21	2.0	µg/L	10.0		92.1	70-130			
Methylene Chloride	9.54	5.0	µg/L	10.0		95.4	50-221			
1,1,2,2-Tetrachloroethane	10.4	2.0	µg/L	10.0		104	46-157			
Tetrachloroethylene	9.74	2.0	µg/L	10.0		97.4	64-148			
Toluene	9.81	1.0	µg/L	10.0		98.1	47-150			
1,1,1-Trichloroethane	8.82	2.0	µg/L	10.0		88.2	52-162			
1,1,2-Trichloroethane	9.47	2.0	µg/L	10.0		94.7	52-150			
Trichloroethylene	10.2	2.0	µg/L	10.0		102	71-157			
Trichlorofluoromethane (Freon 11)	8.96	2.0	µg/L	10.0		89.6	17-181			
Vinyl Chloride	9.47	2.0	µg/L	10.0		94.7	20-251			
m+p Xylene	20.6	2.0	µg/L	20.0		103	70-130			
o-Xylene	10.3	2.0	µg/L	10.0		103	70-130			
Surrogate: 1,2-Dichloroethane-d4	24.7		µg/L	25.0		98.6	70-130			
Surrogate: Toluene-d8	25.4		µg/L	25.0		102	70-130			
Surrogate: 4-Bromofluorobenzene	25.2		µg/L	25.0		101	70-130			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
RL	Reporting Limit
DL	Method Detection Limit
MCL	Maximum Contaminant Level
	Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
	No results have been blank subtracted unless specified in the case narrative section.
J	Detected but below the Reporting Limit (lowest calibration standard); therefore, result is an estimated concentration (CLP J-Flag).

CERTIFICATIONS

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 624 in Water</i>	
Benzene	CT,MA,NH,NY,RI,NC,ME,VA
Bromodichloromethane	CT,MA,NH,NY,RI,NC,ME,VA
Bromoform	CT,MA,NH,NY,RI,NC,ME,VA
Bromomethane	CT,MA,NH,NY,RI,NC,ME,VA
Carbon Tetrachloride	CT,MA,NH,NY,RI,NC,ME,VA
Chlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
Chlorodibromomethane	CT,MA,NH,NY,RI,NC,ME,VA
Chloroethane	CT,MA,NH,NY,RI,NC,ME,VA
2-Chloroethyl Vinyl Ether	CT,MA,NH,NY,RI,NC,ME,VA
Chloroform	CT,MA,NH,NY,RI,NC,ME,VA
Chloromethane	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,3-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,4-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
trans-1,2-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichloropropane	CT,MA,NH,NY,RI,NC,ME,VA
cis-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA
trans-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA
Ethylbenzene	CT,MA,NH,NY,RI,NC,ME,VA
Methyl tert-Butyl Ether (MTBE)	NC
Methylene Chloride	CT,MA,NH,NY,RI,NC,ME,VA
1,1,2,2-Tetrachloroethane	CT,MA,NH,NY,RI,NC,ME,VA
Tetrachloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
Toluene	CT,MA,NH,NY,RI,NC,ME,VA
1,1,1-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1,2-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
Trichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
Trichlorofluoromethane (Freon 11)	CT,MA,NH,NY,RI,NC,ME,VA
Vinyl Chloride	CT,MA,NH,NY,RI,NC,ME,VA
m+p Xylene	CT,MA,NH,NY,RI,NC,VA
o-Xylene	CT,MA,NH,NY,RI,NC,VA

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

The CON-TEST Environmental Laboratory operates under the following certifications and accreditations:

Code	Description	Number	Expires
AIHA	AIHA-LAP, LLC	100033	02/1/2016
MA	Massachusetts DEP	M-MA100	06/30/2016
CT	Connecticut Department of Public Health	PH-0567	09/30/2017
NY	New York State Department of Health	10899 NELAP	04/1/2016
NH-S	New Hampshire Environmental Lab	2516 NELAP	02/5/2016
RI	Rhode Island Department of Health	LAO00112	12/30/2015
NC	North Carolina Div. of Water Quality	652	12/31/2016
NJ	New Jersey DEP	MA007 NELAP	06/30/2016
FL	Florida Department of Health	E871027 NELAP	06/30/2016
VT	Vermont Department of Health Lead Laboratory	LL015036	07/30/2016
WA	State of Washington Department of Ecology	C2065	02/23/2016
ME	State of Maine	2011028	06/9/2017
VA	Commonwealth of Virginia	460217	12/14/2016
NH-P	New Hampshire Environmental Lab	2557 NELAP	09/6/2016

[Ship](#)[Track](#)[Manage](#)[Learn](#)[FedEx Office®](#)[My Profile](#)[Support](#)[Locations](#)[English](#)[Search](#)[Login](#)

FedEx® Tracking

545255675863

Ship date:

Tue 12/22/2015

SYRACUSE, NY US

**Delivered**

Signed for by: P.BLAKE

Actual delivery:

Wed 12/23/2015 12:04 pm

EAST LONGMEADOW, MA US

Travel History

▲ Date/Time	Activity	Location
■ 12/23/2015 - Wednesday		
12:04 pm	Delivered	EAST LONGMEADOW, MA
9:56 am	On FedEx vehicle for delivery	WINDSOR LOCKS, CT
9:50 am	At local FedEx facility	WINDSOR LOCKS, CT
7:22 am	At destination sort facility	EAST GRANBY, CT
5:48 am	Departed FedEx location	INDIANAPOLIS, IN
12:02 am	Arrived at FedEx location	INDIANAPOLIS, IN
■ 12/22/2015 - Tuesday		
8:40 pm	Left FedEx origin facility	NORTH SYRACUSE, NY
5:27 pm	Picked up	NORTH SYRACUSE, NY
1:05 pm	Shipment information sent to FedEx	

Shipment Facts

Tracking number	545255675863	Service	FedEx Priority Overnight
Weight	9 lbs / 4.08 kgs	Dimensions	13x6x8 in.
Delivered To	Shipping/Receiving	Total pieces	1
Total shipment weight	9 lbs / 4.08 kgs	Shipper reference	00266406.0000.00003
Packaging	Your Packaging	Special handling section	Deliver Weekday, Additional Handling Surcharge

[Search](#)

Customer Focus

[New Customer Center](#)
[Small Business Center](#)
[Service Guide](#)
[Customer Support](#)

Company Information

[About FedEx](#)
[Careers](#)
[Investor Relations](#)

Featured Services

[FedEx One Rate](#)
[FedEx SameDay](#)
[FedEx Home Delivery](#)
[Healthcare Solutions](#)
[Online Retail Solutions](#)
[Packaging Services](#)
[Ancillary Clearance Services](#)

Other Resources

[FedEx Compatible](#)
[Developer Resource Center](#)
[FedEx Ship Manager Software](#)
[FedEx Mobile](#)

Companies

[FedEx Express](#)
[FedEx Ground](#)
[FedEx Office](#)
[FedEx Freight](#)
[FedEx Custom Critical](#)
[FedEx Trade Networks](#)
[FedEx SupplyChain](#)
[FedEx TechConnect](#)

Follow FedEx


[United States - English](#)

39 Spruce St.
East Longmeadow, MA. 01028
P: 413-525-2332
F: 413-525-6405
www.contestlabs.com



Page 1 of 2

Sample Receipt Checklist



CLIENT NAME: Aracdis RECEIVED BY: RLF DATE: 12/23/15

1) Was the chain(s) of custody relinquished and signed? Yes No No CoC Included

2) Does the chain agree with the samples? Yes No

If not, explain:

3) Are all the samples in good condition? Yes No

If not, explain:

4) How were the samples received:

On Ice ☒ Direct from Sampling ☐ Ambient ☐ In Cooler(s) ☒

Were the samples received in Temperature Compliance of (2-6°C)? Yes No N/A

Temperature °C by Temp blank _____ Temperature °C by Temp gun 4.7°C


5) Are there Dissolved samples for the lab to filter? Yes No

Who was notified _____ Date _____ Time _____

6) Are there any RUSH or SHORT HOLDING TIME samples? Yes No

Who was notified _____ Date _____ Time _____

7) Location where samples are stored:



Permission to subcontract samples? Yes No
(Walk-in clients only) if not already approved
Client Signature: _____

8) Do all samples have the proper Acid pH: Yes No N/A

9) Do all samples have the proper Base pH: Yes No N/A

10) Was the PC notified of any discrepancies with the CoC vs the samples: Yes No N/A

Containers received at Con-Test

	# of containers		# of containers
1 Liter Amber		8 oz amber/clear jar	
500 mL Amber		4 oz amber/clear jar	
250 mL Amber (8oz amber)		2 oz amber/clear jar	
1 Liter Plastic		Plastic Bag / Ziploc	
500 mL Plastic		SOC Kit	
250 mL plastic		Non-ConTest Container	
40 mL Vial - type listed below	11	Perchlorate Kit	
Colisure / bacteria bottle		Flashpoint bottle	
Dissolved Oxygen bottle		Other glass jar	
Encore		Other	

Laboratory Comments:

40 mL vials: # HCl <u>11</u>	# Methanol _____	Time and Date Frozen:
Doc# 277 # Bisulfate _____	# DI Water _____	
Rev. 4 August 2013 # Thiosulfate _____	Unpreserved _____	

Login Sample Receipt Checklist

(Rejection Criteria Listing - Using Sample Acceptance Policy)

Any False statement will be brought to the attention of Client

<u>Question</u>	<u>Answer (True/False)</u>	<u>Comment</u>
	<u>T/F/NA</u>	
1) The cooler's custody seal, if present, is intact.	T	
2) The cooler or samples do not appear to have been compromised or tampered with.	T	
3) Samples were received on ice.	T	
4) Cooler Temperature is acceptable.	T	
5) Cooler Temperature is recorded.	T	
6) COC is filled out in ink and legible.	T	
7) COC is filled out with all pertinent information.	T	
8) Field Sampler's name present on COC.	T	
9) There are no discrepancies between the sample IDs on the container and the COC.	T	
10) Samples are received within Holding Time.	T	
11) Sample containers have legible labels.	T	
12) Containers are not broken or leaking.	T	
13) Air Cassettes are not broken/open.	NA	
14) Sample collection date/times are provided.	T	
15) Appropriate sample containers are used.	T	
16) Proper collection media used.	T	
17) No headspace sample bottles are completely filled.	T	
18) There is sufficient volume for all requested analyses, including any requested MS/MSDs.	T	
19) Trip blanks provided if applicable.	T	
20) VOA sample vials do not have head space or bubble is <6mm (1/4") in diameter.	T	
21) Samples do not require splitting or compositing.	T	

Who notified of False statements?

Date/Time:

Doc #277 Rev. 4 August 2013

Log-In Technician Initials:

Date/Time:

RLF 8/23/15 1204


APPENDIX D

Groundwater 1,1,1-TCA Concentrations – May 2015







SHALLOW WELLS



INTERMEDIATE WELLS




DEEP WELLS



LEGEND

1,1,1-Trichloroethane Concentrations (ug/L)



GLADDING CORDAGE SITE NUMBER 7-09-009
SOUTH OTSELIC, NEW YORK

**GROUNDWATER 1,1,1-TRICHLOROETHANE
CONCENTRATIONS**

MAY 6, 2015



FIGURE

4-5

Arcadis CE, Inc.

855 Route 146

Suite 210

Clifton Park, New York 12065

Tel 518 250 7300

Fax 518 250 7301

www.arcadis.com