

New York State Department of Environmental  
Conservation

## **GLADDING CORDAGE SITE QUARTERLY REPORT**

Third Quarter 2015

January 2016

GLADDING CORDAGE SITE QUARTERLY REPORT – THIRD QUARTER 2015

**GLADDING CORDAGE  
SITE QUARTERLY  
REPORT**

Third Quarter 2015



---

Andy Vitolins, PG  
Associate Vice President

Prepared for:

New York State Department of  
Environmental Conservation – Division of  
Environmental Remediation  
625 Broadway  
Albany, NY 12233-7011



---

Jeremy Wyckoff  
Project Geologist

Prepared by:

Arcadis CE, Inc.  
855 Route 146  
Suite 210  
Clifton Park  
New York 12065  
Tel 518 250 7300  
Fax 518 250 7301

Our Ref.:

00266406.0000

Date:

January 2016

*This document is intended only for the use of  
the individual or entity for which it was  
prepared and may contain information that is  
privileged, confidential and exempt from  
disclosure under applicable law. Any  
dissemination, distribution or copying of this  
document is strictly prohibited.*

## CONTENTS

Acronyms and Abbreviations.....	iii
1 introduction.....	1
2 SITE DESCRIPTION .....	2
3 OPERATION AND MAINTENANCE .....	3
3.1 Treatment Plant Upgrades.....	3
3.1.1 Variable Frequency Drive.....	3
3.1.2 Treatment Plant Controls .....	3
3.1.3 Geothermal Heat Exchanger.....	4
3.2 Treatment Plant Operation .....	4
3.3 Treatment System Sampling .....	4
3.3.1 Influent Sample Results .....	4
3.3.2 Effluent Sample Results .....	5
4 GROUNDWATER MONITORING PROGRAM.....	6
5 RECOMMENDATIONS.....	7
6 SUMMARY.....	8
7 REFERENCES.....	9

## TABLES

Table 3-1	Treatment System Status and Flow Summary
Table 3-2	Groundwater Treatment System VOCs (RW-1)
Table 3-3	Groundwater Treatment System VOCs (RW-2)
Table 3-4	Groundwater Treatment System VOCs (Effluent)

## FIGURES

Figure 2-1	Site Location
Figure 3-1	Treatment System Influent Sample Concentration (1,1,1-TCA)

## APPENDICES

- A PLC Facsimile Reports
- B O&M Checklists
- C Analytical Reporting Forms

## ACRONYMS AND ABBREVIATIONS

Amsl	above mean sea level
BTEX	Benzene, toluene, ethylbenzene, and xylene.
Ft	feet
GAP	generally accepted procedure
Hz	hertz
µg/L	micrograms per liter
NYSDEC	New York State Department of Environmental Conservation
O&M	operation and maintenance
PDB	passive diffusion bag
PLC	programmable logic controller
PCE	Tetrachloroethene
USEPA	United States Environmental Protection Agency
VFD	variable frequency drive
VOC	volatile organic compound
1,1-DCA	1,2-dichloroethane
1,1-DCE	1,2-dichloroethene
1,1,1-TCA	1,1,1-trichloroethane

## GLADDING CORDAGE SITE QUARTERLY REPORT – THIRD QUARTER 2015

### 1 INTRODUCTION

The New York State Department of Environmental Conservation (NYSDEC) has issued a Work Assignment (# D007618-9) to ARCADIS CE, Inc. (Arcadis) for Operation, Maintenance, and Monitoring at the Gladding Cordage Site (Site # 7-09-009). This Quarterly Report has been prepared in accordance with the NYSDEC-approved Work Plan to summarize third quarter 2015 site activities.

## 2 SITE DESCRIPTION

The Gladding Cordage Site is located on Ridge Road, South Otselic, Chenango County, New York (Figure 2-1), along the western bank of the Otselic River. The site contains an active braided wire and rope manufacturing facility that has been in operation since 1892.

## 3 OPERATION AND MAINTENANCE

On August 23, 2007, the NYSDEC provided a training session to Arcadis personnel on the operation and maintenance (O&M) of the groundwater treatment plant at the Gladding Cordage Site. Since then, Arcadis has maintained operation of the groundwater treatment plant. This includes the operation, maintenance, and influent/effluent sampling in accordance with the NYSDEC O&M manual (Operation and Maintenance Manual, Volume I, Gladding Cordage Site, Site 7-09-009, TAMS Consultants, Inc., 1996) (O&M Manual).

### 3.1 Treatment Plant Upgrades

#### 3.1.1 Variable Frequency Drive

A variable frequency drive (VFD) was installed on January 9, 2008 to regulate the speed of the air stripper blower motor for reduced energy usage. Following the installation of the VFD, effluent samples were collected at various blower motor frequencies (speeds) including 40 HZ, 50 HZ, and 60 HZ. The analyte 1,1,1-trichloroethane (1,1,1-TCA) was detected at 6 µg/l in the 40 HZ effluent sample but was not detected in the 50 HZ and 60 HZ samples. Following the completion of the January 9, 2008 sampling event the VFD was set to 50 HZ. Additional sampling was conducted in February 2008 to further optimize the treatment system blower speed. Based on the results, the VFD setting was reduced to 42 HZ beginning in March 2008. Based on the detection of low-level VOCs in effluent samples from the treatment system, the VFD setting was subsequently increased to 46 HZ in September 2010 and was maintained at that frequency until November 19, 2014.

Based on a general trend of lower concentrations of VOCs in influent treatment system samples since September 2010, the NYSDEC authorized a reduction of the VFD frequency to 44 HZ in an attempt to further optimize treatment plant operations and reduce electric usage. The VFD frequency was lowered to 44 HZ on November 19, 2014. Following approximately one-half hour of operation, post-treatment effluent samples were collected in accordance with the Work Plan (see Section 3.2.1). Based on a review of post-treatment effluent sample data from November 19, 2014, 1,1,1 TCA and toluene were detected with the air stripper blower operating at 44 HZ, but at concentrations below the corresponding NYSDEC Class GA Standards. The NYSDEC was notified of the VOC detections and the blower motor frequency was subsequently increased to 46 HZ during the next (December 18, 2014) O&M event.

#### 3.1.2 Treatment Plant Controls

In August 2011, the NYSDEC authorized construction and installation of a new treatment plant controls system. The new control system is designed to provide remote access to treatment plant operating parameters and improve reliability of the groundwater remediation system. The treatment plant was shut down to begin repairs and upgrades on January 30, 2012 by Aztech Technologies, Inc. (Aztech). The upgrades to the treatment system controls were completed and the treatment plant resumed operation on March 22, 2012. The treatment plant functions are controlled and monitored using an EOS Research Ltd. ProControl Programmable Logic Controller (PLC). The interface software allows remote connection to the PLC via analog phone line. The PLC and interface software also allows the treatment system to be started or stopped remotely. The PLC is programmed to send a facsimile with the status of system inputs and outputs on a daily basis. If input and/or output device values exceed the defined operating parameters, an

alarm condition is set and the corresponding alarm information is sent via facsimile to the system user (i.e. Arcadis).

### **3.1.3 Geothermal Heat Exchanger**

The NYSDEC authorized the installation of a geothermal heat exchanger to provide climate control (heating and humidity) for the treatment system building. The treatment plant was shut down to begin installation of the geothermal heat exchanger on May 8, 2012 by Aztech. The geothermal heat exchanger installation and testing was completed on May 10, 2012. The heat-exchanger uses groundwater from the treatment plant as a geo-thermal energy source.

## **3.2 Treatment Plant Operation**

As shown on PLC facsimile reports (Appendix A) and O&M Checklist and Operation Logs (Appendix B), the Gladding Cordage groundwater treatment system was restarted on July 31, 2015 to reset the PLC so facsimile service could be restored. The treatment system operated without interruption for the remainder of the third quarter with the exception of a planned shutdown for air stripper maintenance.

Based on low-level detections of VOCs (approximately 0.2 µg/L) in effluent groundwater samples from the treatment plant since May 2015, the system was shut down on September 23, 2015 for approximately four hours so that the air stripper trays could be inspected and cleaned. Arcadis technicians found that the air passages in the trays were partially restricted with calcium carbonate and used an acidic solution to remove the scaling. The system was restarted and operated without interruption through the remainder of the third quarter.

The average monthly flow rates and total flow volumes for the third quarter 2015 operating period are summarized in Table 3-1. As shown in Table 3-1, the monthly flow rates from recovery wells RW-1 and RW-2 averaged approximately 25 gpm and 22 gpm, respectively. Based on the total flow values, approximately 6.2 million gallons of water were treated between July and September, 2015.

## **3.3 Treatment System Sampling**

Influent and effluent groundwater samples were collected from the Gladding Cordage treatment system in accordance with the Work Plan and submitted to Contest Analytical following chain-of-custody protocols. Each sample was analyzed for volatile organic compounds (VOCs) by United States Environmental Protection Agency (USEPA) Method 624. Analytical Reporting Forms are provided in Appendix C.

### **3.3.1 Influent Sample Results**

Table 3-2 and Table 3-3 summarize influent VOC sample results from recovery wells RW-1 and RW-2, respectively. Figure 3-1 provides a summary of 1,1,1-TCA concentrations in samples from recovery wells RW-1 and RW-2 since September 2007.

Tables 3-1 and 3-2 and Figure 3-1 show that the concentrations of 1,1,1-TCA in the July and August 2015 samples from recovery well RW-1 were 40 µg/L and 42 µg/L, respectively. The concentrations of 1,1,1-TCA decreased to 36 µg/L in the September 2015 samples; the lowest level since May 2014. The concentrations of 1,1,1-TCA in the samples from RW-2 were 34 µg/L in July and 36 µg/L August 2015.

## GLADDING CORDAGE SITE QUARTERLY REPORT – THIRD QUARTER 2015

The 1,1,1-TCA concentration in the September 2015 sample decreased to 26 µg/L. These results are within the range of historic concentrations and exceed the corresponding NYSDEC Class GA Standard of 5 µg/L.

As shown in Tables 3-2 and 3-3, 1,1-dichloroethane (1,1-DCA) and 1,1-dichloroethene (1,1-DCE) were detected in the second quarter 2015 samples from recovery wells RW-1 and RW-2. However, consistent with previous results, the concentrations were less than the applicable NYSDEC Class GA Standard of 5 µg/L.

Tetrachloroethene (PCE) was detected in the August 2015 samples from RW-1 and RW-2 at the estimated (based on the “J” qualifier) concentrations of 0.19 µg/L and 0.15 µg/L, respectively. As shown in the analytical reporting forms (Appendix C), benzene (0.16 µg/L), toluene (0.27 µg/L) ethylbenzene (0.14 µg/L), m+p xylene (0.47µg/L), o-xylene (0.18 µg/L) (BTEX) and PCE (0.23 µg/L) were detected at estimated concentrations in the August 2015 trip blank. Therefore, it is believed that the PCE detections in the samples from RW-1 and RW-2 are not related to the site and are likely laboratory contaminants.

### 3.3.2 Effluent Sample Results

Table 3-4 summarizes laboratory analytical data for effluent samples collected from the treatment system. As shown in Table 3-4, 1,1,1-TCA was detected in the July and August 2015 effluent sample at the estimated concentrations of 0.22 µg/L and 0.17 µg/L, respectively, which are less than the corresponding NYSDEC Class GA Standard of 5 µg/L. PCE was also detected at an estimated concentration of 0.2 µg/L in the August 2015 effluent sample; however, as indicated in Section 3.3.1, it is surmised that this compound is a laboratory contaminant.

As shown in Table 3-4, no VOCs were detected in the September 2015 effluent samples following cleaning of the air stripper.

Based on influent sample concentrations and total flow volumes from the Gladding Cordage treatment system, approximately 1.9 pounds of VOCs were removed by the treatment system during the third quarter 2015.

## 4 GROUNDWATER MONITORING PROGRAM

Groundwater samples were collected from the site during the second quarter 2015 in accordance with the Work Plan. The results of the sampling event were submitted in the second quarter 2015 Gladding Cordage Site Quarterly Report (Arcadis, 2015). The next groundwater sampling event is scheduled to take place during the third quarter 2016.

## 5 RECOMMENDATIONS

Based on the data presented herein, there are no recommended changes to site operations at this time.

## 6 SUMMARY

The Gladding Cordage groundwater treatment system was shut down temporarily on July 31, 2015 to re-establish communications with the PLC. The system was re-started on the same day after the communications problem had been rectified. The groundwater treatment system was shut down on September 23, 2015 to inspect and perform maintenance on the air stripper. The average total flow through the treatment system was approximately 47 GPM. BTEX and PCE were detected in the August 2015 Trip Blank. The presence of PCE in the August 2015 sample from RW-1 and RW-2 is likely related to laboratory contamination. 1,1,1-TCA, was detected in the July and August 2015 effluent samples, but at a concentration less than the respective NYSDEC Class GA Standard. No VOCs were detected in the September 2015 effluent samples following cleaning of the air stripper.

The treatment successfully removes VOCs from groundwater extracted from the capture zone at the current VFD setting of 46 Hz. The VFD setting will continue to be evaluated based on system monitoring results. Approximately 1.9 pounds of VOCs were removed by the treatment system during the third quarter 2015.


Based on the current five-quarter sampling interval, the next groundwater monitoring event is scheduled to occur during the third quarter 2016.

## 7 REFERENCES

Malcolm Pirnie, 2007, Gladding Cordage Site Work Plan, Site 7-09-009, June, 2007.

TAMS Consultants, 1996, Operation and Maintenance Manual, Volume I, Gladding Cordage Site. Site 7-09-009

# TABLES



**TABLE 3-1**  
**TREATMENT SYSTEM STATUS AND FLOW SUMMARY**  
**GLADDING CORDAGE SITE**  
**SOUTH OTSELIC, NEW YORK**  
**NYSDEC SITE NO. 7-04-009A**

Date	System Operation (days)	System On-time (% of possible days)	Well On-time		Flow Rates		Totalizer	Totalizer	Recovery Well Total Flows		Total System Flow (gallons)	Quarterly Totals (gallons)
			RW-1 (% possible )	RW-2 (% possible )	RW-1 (gpm)	RW-2 (gpm)	RW-1 (gallons)	RW-2 (gallons)	RW-1 (gallons)	RW-2 (gallons)		
January-15	30	97%	100%	100%	23.8	22.3	27,482,764	25,089,994	1,017,093	940,617	1,957,710	
February-15	27	96%	100%	100%	21.3	24.1	28,457,483	25,964,709	974,719	874,715	1,849,434	
March-15	31	100%	100%	100%	21.7	23.9	29,512,439	26,942,484	1,054,956	977,775	2,032,731	
April-15	30	100%	100%	100%	23.9	21.6	30,572,172	27,868,651	1,059,733	926,167	1,985,900	
May-15	26	84%	100%	100%	23.6	21.1	31,474,040	28,682,253	901,868	813,602	1,715,470	5,125,831
June-15	20	67%	100%	100%	25.3	21.8	32,221,714	29,359,040	747,674	676,787	1,424,461	
July-15	31	100%	100%	100%	25.3	22.3	33,390,538	30,373,435	1,168,824	1,014,395	2,183,219	
August-15	31	100%	100%	100%	24.8	22.0	34,478,269	31,320,491	1,087,731	947,056	2,034,787	
September-15	30	100%	100%	100%	25.0	21.5	35,532,694	32,250,579	1,054,425	930,088	1,984,513	
<b>Total Flow 2015</b>									<b>9,067,023</b>	<b>8,101,202</b>	<b>17,168,225</b>	

Notes:

gpm - Gallons per minute

**TABLE 3-2**  
**GROUNDWATER TREATMENT SYSTEM VOCs (INFLUENT - RW-1)**  
**GLADDING CORDAGE**  
**SOUTH OTSELIC, NEW YORK**  
**NYSDEC Site No. 7-09-009**

Sample ID Sampling Date Matrix Units	NYSDEC Class GA Standard ug/L	RW-1 9/30/2014 WATER ug/L	RW-1 10/21/2014 WATER ug/L	RW-1 11/19/2014 WATER ug/L	RW-1 12/18/2014 WATER ug/L	RW-1 1/20/2015 WATER ug/L	RW-1 2/25/2015 WATER ug/L	RW-1 3/19/2015 WATER ug/L	RW-1 5/6/2015 WATER ug/L	RW-1 6/22/2015 WATER ug/L	RW-1 7/31/2015 WATER ug/L	RW-1 8/28/2015 WATER ug/L	RW-1 9/23/2015 WATER ug/L
<b>VOCs</b>													
1,1,1-Trichloroethane	5	36	43	51	44	43	40	36	38	41	40	42	32
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	0.16	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
1,1-Dichloroethane	5	1.5	1.6	1.8	1.5	1.8 J	1.6 J	1.5 J	2 U	1.8 J	1.6 J	1.8 J	1.5 J
1,1-Dichloroethene	5	0.87	1.2	2.4	2.0 U	1.3 J	0.93 J	0.89 J	0.92 J	0.99 J	0.96 J	0.97 J	0.8 J
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
2-Chloroethyl Vinyl Ether		10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10 U	10 U	10.0 U	10 U	10 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1 U	1 U	1.0 U	1 U	1 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Chloromethane		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5 U	5 U	5.0 U	5 U	5 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	0.19 J	2 U
Toluene	5	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	0.13 J	2 U	1.0 U	1 U	2 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
trans-1,3-Dichloropropene	0.4	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	2 U	2 U	5.0 U	2 U	2 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Total VOCs		38.4	45.8	55.4	45.5	46.1	44.5	38.4	39.1	43.8	42.6	45.0	34.3

- Concentration exceeds corresponding NYSDEC Class GA Standard.

U - Not detected at the indicated concentration

J - Estimated concentration.

**TABLE 3-3**  
**GROUNDWATER TREATMENT SYSTEM VOCs (INFLUENT - RW-2)**  
**GLADDING CORDAGE**  
**SOUTH OTSELIC, NEW YORK**  
**NYSDEC Site No. 7-09-009**

Sample ID Sampling Date Matrix Units	NYSDEC Class GA Standard ug/L	RW-2 9/29/2014 WATER ug/L	RW-2 10/21/2014 WATER ug/L	RW-2 11/19/2014 WATER ug/L	RW-2 12/18/2014 WATER ug/L	RW-2 1/20/2015 WATER ug/L	RW-2 2/25/2015 WATER ug/L	RW-2 3/19/2015 WATER ug/L	RW-2 5/6/2015 WATER ug/L	RW-2 6/23/2015 WATER ug/L	RW-2 7/31/2015 WATER ug/L	RW-2 8/28/2015 WATER ug/L	RW-2 9/23/2015 WATER ug/L
<b>VOCs</b>													
1,1,1-Trichloroethane	5	32	37	45	37	15	34	31	33	48	34	36	26
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	0.66 J	0.82 J	0.99 J	0.72 J	2.0 U	0.76 J	0.69 J	2.0 U	1.1 J	0.74 J	0.77 J	0.61 J
1,1-Dichloroethene	5	0.76 J	1.3 J	1.4 J	0.93 J	0.38 J	0.7 J	0.68 J	0.72 J	1 J	0.72 J	0.62 J	0.58 J
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10 U	10 U	10.0 U	10 U	10 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	0.15 J
Toluene	5	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	0.13 J	2.0 U	1.0 U	1.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	2.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Total VOCs		33.4	39.1	47.4	38.7	15.4	35.4	32.4	33.9	50.1	35.5	37.5	27.2

- Concentration exceeds corresponding NYSDEC

Class GA Standard.

U - Not detected at the indicated concentration

J - Estimated concentration.

TABLE 3-4

## GROUNDWATER TREATMENT SYSTEM VOCs (EFFLUENT)

GLADDING CORDAGE

SOUTH OTSELIC, NEW YORK

NYSDEC Site No. 7-09-009

Sample ID Sampling Date Matrix Units	NYSDEC GA Standard ug/L	EFF(46HZ) 9/30/2014 WATER ug/L	EFF(46HZ) 10/21/2014 WATER ug/L	EFF(44HZ) 11/19/2014 WATER ug/L	EFF(46HZ) 12/18/2014 WATER ug/L	EFF(46HZ) 1/20/2015 WATER ug/L	EFF(46HZ) 2/25/2015 WATER ug/L
<b>VOCs</b>							
1,1,1-Trichloroethane	5	2.0 U	2.0 U	<b>0.16 J</b>	2.0 U	2.0 U	2.0 U
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Toluene	5	1.0 U	1.0 U	<b>0.19 J</b>	1.0 U	1.0 U	1.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U

## Notes

U - Not detected at the indicated concentration.

J - Estimated concentration.

TABLE 3-4

## GROUNDWATER TREATMENT SYSTEM VOCs (EFFLUENT)

GLADDING CORDAGE

SOUTH OTSELIC, NEW YORK

NYSDEC Site No. 7-09-009

Sample ID Sampling Date Matrix Units	NYSDEC GA Standard ug/L	EFF(46HZ) 3/19/2015 WATER ug/L	EFF(46HZ) 5/6/2015 WATER ug/L	EFF(46HZ) 6/23/2015 WATER ug/L	EFF(46HZ) 7/31/2015 WATER ug/L	EFF(46HZ) 8/28/2015 WATER ug/L	EFF(46HZ) 9/23/2015 WATER ug/L
<b>VOCs</b>							
1,1,1-Trichloroethane	5	2.0 U	1.0 U	<b>0.22 J</b>	<b>0.22 J</b>	<b>0.17</b>	1.0 U
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U
Benzene	1	1.0 U	2.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	<b>0.2</b>	2.0 U
Toluene	5	1.0 U	<b>0.12 J</b>	1.0 U	1.0 U	1.0 U	1.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	5.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U

## Notes

U - Not detected at the indicated concentration.

J - Estimated concentration.

TABLE 3-4

## GROUNDWATER TREATMENT SYSTEM VOCs (EFFLUENT)

GLADDING CORDAGE

SOUTH OTSELIC, NEW YORK

NYSDEC Site No. 7-09-009

Sample ID Sampling Date Matrix Units	NYSDEC GA Standard ug/L	EFF(46HZ) 9/30/2014 WATER ug/L	EFF(46HZ) 10/21/2014 WATER ug/L	EFF(44HZ) 11/19/2014 WATER ug/L	EFF(46HZ) 12/18/2014 WATER ug/L	EFF(46HZ) 1/20/2015 WATER ug/L	EFF(46HZ) 2/25/2015 WATER ug/L
<b>VOCs</b>							
1,1,1-Trichloroethane	5	2.0 U	2.0 U	<b>0.16 J</b>	2.0 U	2.0 U	2.0 U
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Toluene	5	1.0 U	1.0 U	<b>0.19 J</b>	1.0 U	1.0 U	1.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U

## Notes

U - Not detected at the indicated concentration.

J - Estimated concentration.

TABLE 3-4

## GROUNDWATER TREATMENT SYSTEM VOCs (EFFLUENT)

GLADDING CORDAGE

SOUTH OTSELIC, NEW YORK

NYSDEC Site No. 7-09-009

Sample ID Sampling Date Matrix Units	NYSDEC GA Standard ug/L	EFF(46HZ) 3/19/2015 WATER ug/L	EFF(46HZ) 5/6/2015 WATER ug/L	EFF(46HZ) 6/23/2015 WATER ug/L	EFF(46HZ) 7/31/2015 WATER ug/L	EFF(46HZ) 8/28/2015 WATER ug/L	EFF(46HZ) 9/23/2015 WATER ug/L
<b>VOCs</b>							
1,1,1-Trichloroethane	5	2.0 U	1.0 U	<b>0.22 J</b>	<b>0.22 J</b>	<b>0.17 J</b>	1.0 U
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U
Benzene	1	1.0 U	2.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	<b>0.2 J</b>	2.0 U
Toluene	5	1.0 U	<b>0.12 J</b>	1.0 U	1.0 U	1.0 U	1.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	5.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U

## Notes

U - Not detected at the indicated concentration.

J - Estimated concentration.

**TABLE 3-3**  
**GROUNDWATER TREATMENT SYSTEM VOCs (INFLUENT - RW-2)**  
**GLADDING CORDAGE**  
**SOUTH OTSELIC, NEW YORK**  
**NYSDEC Site No. 7-09-009**

Sample ID Sampling Date Matrix Units	NYSDEC Class GA Standard ug/L	RW-2 9/29/2014 WATER ug/L	RW-2 10/21/2014 WATER ug/L	RW-2 11/19/2014 WATER ug/L	RW-2 12/18/2014 WATER ug/L	RW-2 1/20/2015 WATER ug/L	RW-2 2/25/2015 WATER ug/L	RW-2 3/19/2015 WATER ug/L	RW-2 5/6/2015 WATER ug/L	RW-2 6/23/2015 WATER ug/L	RW-2 7/31/2015 WATER ug/L	RW-2 8/28/2015 WATER ug/L	RW-2 9/23/2015 WATER ug/L
<b>VOCs</b>													
1,1,1-Trichloroethane	5	32	37	45	37	15	34	31	33	48	34	36	26
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	0.66 J	0.82 J	0.99 J	0.72 J	2.0 U	0.76 J	0.69 J	2.0 U	1.1 J	0.74 J	0.77 J	0.61 J
1,1-Dichloroethene	5	0.76 J	1.3 J	1.4 J	0.93 J	0.38 J	0.7 J	0.68 J	0.72 J	1 J	0.72 J	0.62 J	0.58 J
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10 U	10 U	10.0 U	10 U	10 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	0.15 J
Toluene	5	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	0.13 J	2.0 U	1.0 U	1.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	2.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Total VOCs		33.4	39.1	47.4	38.7	15.4	35.4	32.4	33.9	50.1	35.5	37.5	27.2

- Concentration exceeds corresponding NYSDEC

Class GA Standard.

U - Not detected at the indicated concentration

J - Estimated concentration.

**TABLE 3-2**  
**GROUNDWATER TREATMENT SYSTEM VOCs (INFLUENT - RW-1)**  
**GLADDING CORDAGE**  
**SOUTH OTSELIC, NEW YORK**  
**NYSDEC Site No. 7-09-009**


Sample ID Sampling Date Matrix Units	NYSDEC Class GA Standard ug/L	RW-1 9/30/2014 WATER ug/L	RW-1 10/21/2014 WATER ug/L	RW-1 11/19/2014 WATER ug/L	RW-1 12/18/2014 WATER ug/L	RW-1 1/20/2015 WATER ug/L	RW-1 2/25/2015 WATER ug/L	RW-1 3/19/2015 WATER ug/L	RW-1 5/6/2015 WATER ug/L	RW-1 6/22/2015 WATER ug/L	RW-1 7/31/2015 WATER ug/L	RW-1 8/28/2015 WATER ug/L	RW-1 9/23/2015 WATER ug/L
<b>VOCs</b>													
1,1,1-Trichloroethane	5	36	43	51	44	43	40	36	38	41	40	42	32
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	0.16	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
1,1-Dichloroethane	5	1.5	1.6	1.8	1.5	1.8 J	1.6 J	1.5 J	2 U	1.8 J	1.6 J	1.8 J	1.5 J
1,1-Dichloroethene	5	0.87	1.2	2.4	2.0 U	1.3 J	0.93 J	0.89 J	0.92 J	0.99 J	0.96 J	0.97 J	0.8 J
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
2-Chloroethyl Vinyl Ether		10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10.0 U	10 U	10 U	10.0 U	10 U	10 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1 U	1 U	1.0 U	1 U	1 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Chloromethane		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5 U	5 U	5.0 U	5 U	5 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	0.19 J	2 U
Toluene	5	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	0.13 J	2 U	1.0 U	1 U	2 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
trans-1,3-Dichloropropene	0.4	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	2 U	2 U	5.0 U	2 U	2 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2 U	2 U	2.0 U	2 U	2 U
Total VOCs		38.4	45.8	55.4	45.5	46.1	44.5	38.4	39.1	43.8	42.6	45.0	34.3

- Concentration exceeds corresponding NYSDEC Class GA Standard.

U - Not detected at the indicated concentration


J - Estimated concentration.

# FIGURES




**Figure 2-1**  
**Site Location**

Gladding Cordage Site  
South Otselic, New York  
NYSDEC Site 7-09-009




**Figure 3-1**  
**Treatment System Influent Sample Concentrations (1,1,1-TCA)**

Gladding Cordage Site  
 NYSDEC Site Number 7-09-009



# **APPENDIX A**

## **PLC Facsimile Reports**





EOS Research Ltd.

Fax Report

**To:**

JEREMY WYCKOFF

**From:**THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 07/01/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2**System Status:**

AUTO P35 : LAST SHUTDOWN @ 19:31:38 ON 06/12/2015 BY ACFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

**Analog Inputs:**

W1_FLO is 25.4	GPM TOTAL FLOW is 32258543	GAL		
W2_FLO is 21.5	GPM TOTAL FLOW is 29390910	GAL		
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 424589	GAL		
HP_PRS is 1.4	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . .	AMP
W1_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.47	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.71	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 57.20	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.8	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 63.0	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 07/02/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:38 ON 06/12/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPILL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

Analog Inputs:

W1_FLO is 26.0	GPM TOTAL FLOW is 32295450	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 29422913	GAL	
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 424796	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: ....
W1_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.46	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 35.18	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 57.50	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 3.8	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 62.0	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 07/03/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:38 ON 06/12/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

Analog Inputs:

W1_FLO is 25.4	GPM TOTAL FLOW is 32332308	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 29454949	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425022	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: .... AMP
W1_AMP is 4.64	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.74	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.93	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 57.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 07/04/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:38 ON 06/12/2015 BY ACEFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.6	GPM TOTAL FLOW is 32369043	GAL	
W2_FLO is 22.2	GPM TOTAL FLOW is 29486923	GAL	
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425106	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: .... AMP
W1_AMP is 4.68	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.36	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.61	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 60.2	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 07/05/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:38 ON 06/12/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VFDRST is OFF	HMPGO is ON	

Analog Inputs:

W1_FLO is 25.3	GPM TOTAL FLOW is 32405738	GAL		
W2_FLO is 22.0	GPM TOTAL FLOW is 29518868	GAL		
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: .....	AMP
W1_AMP is 4.65	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.38	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.48	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.9	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 60.9	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 07/06/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:38 ON 06/12/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.8	GPM TOTAL FLOW is 32442384	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 29550780	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: ....
W1_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.43	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.25	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.34	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 3.9	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 59.1	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

ECS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 07/07/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:38 ON 06/12/2015 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 25.3	GPM	TOTAL FLOW is 32478950	GAL		
W2_FLO is 22.2	GPM	TOTAL FLOW is 29582643	GAL		
ASBPRS is 10.2	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: ...	AMP
W1_AMP is 4.58	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.44	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.96	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.12	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.6	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 63.9	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 07/08/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:38 ON 06/12/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.3	GPM TOTAL FLOW is 32515505	GAL	
W2_FLO is 22.5	GPM TOTAL FLOW is 29614486	GAL	
ASBPRS is 10.2	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: .....
W1_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.39	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.00	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.27	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 3.3	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 3.7	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 64.1	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 07/09/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:38 ON 06/12/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.5	GPM TOTAL FLOW is 32552080	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 29646350	GAL	
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: .... AMP
W1_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.46	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.92	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.12	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 3.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 3.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 60.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 07/10/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:38 ON 06/12/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.8	GPM TOTAL FLOW is 32588701	GAL		
W2_FLO is 22.7	GPM TOTAL FLOW is 29678215	GAL		
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: ....	AMP
W1_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.43	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.48	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.67	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.3	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.7	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 60.6	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 07/11/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:38 ON 06/12/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

Analog Inputs:

W1_FLO is 25.5	GPM	TOTAL FLOW is 32625338	GAL		
W2_FLO is 22.1	GPM	TOTAL FLOW is 29710047	GAL		
ASBPRS is 10.5	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: .....	AMP
W1_AMP is 4.64	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.50	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.20	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.36	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.6	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.9	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 58.4	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 07/12/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:38 ON 06/12/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

Analog Inputs:

W1_FLO is 25.3	GPM TOTAL FLOW is 32661947	GAL		
W2_FLO is 22.3	GPM TOTAL FLOW is 29741807	GAL		
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: .....	AMP
W1_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.96	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.12	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.7	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.0	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 59.7	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 07/13/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:38 ON 06/12/2015 BY ACEFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.6	GPM	TOTAL FLOW is 32698519	GAL		
W2_FLO is 21.4	GPM	TOTAL FLOW is 29773485	GAL		
ASBPRS is 10.3	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: ....	AMP
W1_AMP is 4.53	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.39	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.65	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.00	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.5	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.8	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 61.8	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 07/14/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:38 ON 06/12/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.3	GPM TOTAL FLOW is 32735024	GAL		
W2_FLO is 21.7	GPM TOTAL FLOW is 29805128	GAL		
ASBPRS is 10.2	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL		
HP_PRS is 1.5	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: .....	AMP
W1_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.43	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.27	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.91	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.4	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.7	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 63.4	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 07/15/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:38 ON 06/12/2015 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFRUN is OFF	VFRST is OFF	HMPGO is ON	

## Analog Inputs:

W1_FLO is 25.2	GPM	TOTAL FLOW is 32771581	GAL		
W2_FLO is 21.6	GPM	TOTAL FLOW is 29836801	GAL		
ASBPRS is 10.2	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: .....	AMP
W1_AMP is 4.57	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.41	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.52	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.29	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.2	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.4	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 63.7	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



EOS Research Ltd.

Fax Report

**To:**

JEREMY WYCKOFF

**From:**THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 07/17/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2**System Status:**

AUTO P35 : LAST SHUTDOWN @ 19:31:38 ON 06/12/2015 BY ACFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

**Analog Inputs:**

W1_FLO is 25.2	GPM TOTAL FLOW is 32844676	GAL		
W2_FLO is 22.3	GPM TOTAL FLOW is 29900149	GAL		
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . .	AMP
W1_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.47	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.66	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.04	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.8	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.0	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 57.9	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 07/18/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:38 ON 06/12/2015 BY ACEFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

## Analog Inputs:

W1_FLO is 24.7	GPM TOTAL FLOW is 32881206	GAL		
W2_FLO is 22.1	GPM TOTAL FLOW is 29931812	GAL		
ASBPRS is 10.2	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: .....	AMP
W1_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.46	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.37	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.89	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.4	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.7	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 64.0	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 07/19/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:38 ON 06/12/2015 BY ACEFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

Analog Inputs:

W1_FLO is 25.3	GPM	TOTAL FLOW is 32917668	GAL		
W2_FLO is 21.6	GPM	TOTAL FLOW is 29963437	GAL		
ASBPRS is 10.2	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: ....	AMP
W1_AMP is 4.66	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.50	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.30	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.87	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.3	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.5	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 64.1	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 07/20/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:38 ON 06/12/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

Analog Inputs:

W1_FLO is 25.2	GPM TOTAL FLOW is 32954129	GAL		
W2_FLO is 22.2	GPM TOTAL FLOW is 29995051	GAL		
ASBPRES is 10.1	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: .....	AMP
W1_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.39	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.14	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.87	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.1	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.3	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 64.3	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 07/21/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:38 ON 06/12/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

Analog Inputs:

W1_FLO is 25.2	GPM TOTAL FLOW is 32990548	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 30026643	GAL	
ASBPTRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: ....
W1_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.40	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 33.00	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.79	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 3.3	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 3.4	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 61.5	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 07/22/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:38 ON 06/12/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.4	GPM	TOTAL FLOW is	33026989	GAL		
W2_FLO is 22.3	GPM	TOTAL FLOW is	30058245	GAL		
ASBPRTS is 10.4	IWC	LIMITS are L:	5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is	425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L:	-2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L:	0.00	AMP	H: ....	AMP
W1_AMP is 4.56	AMP	LIMITS are L:	0.00	AMP	H: 10.00	AMP
W2_AMP is 4.42	AMP	LIMITS are L:	0.00	AMP	H: 10.00	AMP
W1_LVL is 33.05	FT	LIMITS are L:	8.00	FT	H: 28.00	FT
W2_LVL is 55.72	FT	LIMITS are L:	9.00	FT	H: 52.00	FT
W1_PRS is 3.5	PSI	LIMITS are L:	0.5	PSI	H: 100.0	PSI
W2_PRS is 3.5	PSI	LIMITS are L:	0.5	PSI	H: 100.0	PSI
INTEMP is 58.9	DEG	LIMITS are L:	42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 07/23/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:38 ON 06/12/2015 BY ACFAIL

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 25.1	GPM TOTAL FLOW is 33063428	GAL	
W2_FLO is 21.8	GPM TOTAL FLOW is 30089849	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: .....
W1_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.44	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 33.20	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.70	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 3.7	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 3.8	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 58.7	DEG LIMITS are L: 42.0	DEG	H: 130.0

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 07/24/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:38 ON 06/12/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

Analog Inputs:

W1_FLO is 25.6	GPM TOTAL FLOW is 33099839	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 30121458	GAL	
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: .... AMP
W1_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.44	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.20	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.62	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 3.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 57.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 07/25/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:38 ON 06/12/2015 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.0	GPM	TOTAL FLOW is 33136224	GAL		
W2_FLO is 21.6	GPM	TOTAL FLOW is 30153055	GAL		
ASBPRS is 10.5	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: ....	AMP
W1_AMP is 4.63	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.47	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.17	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.55	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.9	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 59.2	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 07/26/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO P35 : LAST SHUTDOWN @ 19:31:38 ON 06/12/2015 BY ACFAIL

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

**Analog Inputs:**

W1_FLO is 25.5	GPM	TOTAL FLOW is 33172618	GAL		
W2_FLO is 22.0	GPM	TOTAL FLOW is 30184593	GAL		
ASBPRS is 10.3	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: ....	AMP
W1_AMP is 4.66	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.52	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.22	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.70	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.7	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.8	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 63.2	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 08/01/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.5	GPM	TOTAL FLOW is 33390538	GAL		
W2_FLO is 22.1	GPM	TOTAL FLOW is 30373435	GAL		
ASBPRS is 10.2	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: .....	AMP
W1_AMP is 4.64	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.48	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.81	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.45	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.7	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.6	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 63.0	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 08/02/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.2	GPM	TOTAL FLOW is 33427061	GAL		
W2_FLO is 22.0	GPM	TOTAL FLOW is 30405068	GAL		
ASBPRS is 10.5	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: ....	AMP
W1_AMP is 4.66	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.51	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.88	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.43	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.8	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.8	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 59.9	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 08/03/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

Analog Inputs:

W1_FLO is 25.4	GPM	TOTAL FLOW is 33463457	GAL		
W2_FLO is 21.7	GPM	TOTAL FLOW is 30436689	GAL		
ASBPRS is 10.2	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: ....	AMP
W1_AMP is 4.57	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.42	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.71	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.36	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.8	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.8	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 62.3	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 08/04/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.1	GPM	TOTAL FLOW is 33499789	GAL		
W2_FLO is 21.7	GPM	TOTAL FLOW is 30468273	GAL		
ASBPRS is 10.3	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: .....	AMP
W1_AMP is 4.57	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.44	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.78	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.39	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.7	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.7	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 62.5	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 08/05/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.4	GPM TOTAL FLOW is 33536118	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 30499876	GAL	
ASBPRES is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: .....
W1_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.44	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 32.91	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.36	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 3.7	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 3.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 61.8	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 08/06/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.8	GPM	TOTAL FLOW is 33572459	GAL		
W2_FLO is 22.1	GPM	TOTAL FLOW is 30531482	GAL		
ASBPRES is 10.4	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: ....	AMP
W1_AMP is 4.56	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.41	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.93	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.34	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.9	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.8	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 58.6	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

ECS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 08/07/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 ; MODEL A2

## System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

## Analog Inputs:

W1_FLO is 25.5	GPM	TOTAL FLOW is 33608782	GAL	
W2_FLO is 22.0	GPM	TOTAL FLOW is 30563088	GAL	
ASBPRS is 10.6	IWC	LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL	IWC
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: ....
W1_AMP is 4.61	AMP	LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.48	AMP	LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 32.88	FT	LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.30	FT	LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 57.9	DEG	LIMITS are L: 42.0	DEG	H: 130.0
				DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 08/08/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.9	GPM TOTAL FLOW is 33645051	GAL		
W2_FLO is 21.7	GPM TOTAL FLOW is 30594681	GAL		
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: ....	AMP
W1_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.88	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.28	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.9	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.9	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 59.1	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 08/09/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

Analog Inputs:

W1_FLO is 25.1	GPM TOTAL FLOW is 33681314	GAL	
W2_FLO is 22.1	GPM TOTAL FLOW is 30626246	GAL	
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: ....
W1_AMP is 4.65	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 32.92	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.26	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 3.9	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 3.9	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 60.1	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 08/10/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 25.3	GPM TOTAL FLOW is 33717564	GAL	
W2_FLO is 22.2	GPM TOTAL FLOW is 30657793	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . . .
W1_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.44	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 32.84	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.20	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 3.9	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 3.9	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 61.1	DEG LIMITS are L: 42.0	DEG	H: 130.0

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 08/11/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.2	GPM TOTAL FLOW is 33753810	GAL		
W2_FLO is 21.7	GPM TOTAL FLOW is 30689318	GAL		
ASBPRS is 10.2	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: ....	AMP
W1_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.39	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.71	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.34	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.7	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.7	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 63.6	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 08/12/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFRUN is OFF	VFRDST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.8	GPM	TOTAL FLOW is 33790062	GAL		
W2_FLO is 21.8	GPM	TOTAL FLOW is 30720862	GAL		
ASBPRES is 10.2	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: ....	AMP
W1_AMP is 4.52	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.38	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.80	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.32	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.7	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.6	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 62.3	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 08/13/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

Analog Inputs:

W1_FLO is 25.6	GPM TOTAL FLOW is 33826313	GAL	
W2_FLO is 22.3	GPM TOTAL FLOW is 30752421	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: ....
W1_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.40	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 32.93	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.30	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 3.7	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 3.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 59.7	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 08/14/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

Analog Inputs:

W1_FLO is 25.2	GPM	TOTAL FLOW is 33862543	GAL		
W2_FLO is 21.7	GPM	TOTAL FLOW is 30783964	GAL		
ASBPRS is 10.5	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: ....	AMP
W1_AMP is 4.59	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.45	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.98	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.24	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.9	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.8	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 60.0	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

*EOS Research Ltd.*

*Fax Report*

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 08/15/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

**Analog Inputs:**

W1_FLO is 25.1	GPM TOTAL FLOW is 33898726	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 30815539	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: .....
W1_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 32.92	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.20	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 3.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 3.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 62.7	DEG LIMITS are L: 42.0	DEG	H: 130.0

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 08/16/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.7	GPM TOTAL FLOW is 33934852	GAL	
W2_FLO is 22.1	GPM TOTAL FLOW is 30847115	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: .... AMP
W1_AMP is 4.67	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.92	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.15	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 3.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 3.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 63.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series III+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELCIC NY @ 06:00:00 ON 08/17/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFRUN is OFF	VFRDST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 25.1	GPM	TOTAL FLOW is 33970980	GAL		
W2_FLO is 21.9	GPM	TOTAL FLOW is 30878696	GAL		
ASBPRS is 10.3	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: .....	AMP
W1_AMP is 4.53	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.40	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.82	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.15	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.5	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.2	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 62.6	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 08/18/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASHPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.5	GPM	TOTAL FLOW is 34007063	GAL		
W2_FLO is 21.9	GPM	TOTAL FLOW is 30910220	GAL		
ASBPRS is 10.3	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: . . .	AMP
W1_AMP is 4.56	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.44	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.66	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.07	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.4	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.1	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 63.5	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 08/19/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 25.1	GPM TOTAL FLOW is 34043228	GAL	
W2_FLO is 22.2	GPM TOTAL FLOW is 30941775	GAL	
ASBPRS is 10.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: .... AMP
W1_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.45	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.65	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.15	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 3.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 2.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 64.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 08/20/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.1	GPM	TOTAL FLOW is 34079412	GAL		
W2_FLO is 21.7	GPM	TOTAL FLOW is 30973352	GAL		
ASBPRS is 10.1	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: .....	AMP
W1_AMP is 4.65	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.50	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.55	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.09	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.4	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 2.7	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 65.8	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

ECS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 08/21/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.2	GPM	TOTAL FLOW is 34115673	GAL		
W2_FLO is 22.1	GPM	TOTAL FLOW is 31004953	GAL		
ASBPRS is 10.3	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: ...	AMP
W1_AMP is 4.64	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.49	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.46	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.85	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.3	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 2.4	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 63.0	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 08/22/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

Analog Inputs:

W1_FLO is 25.1	GPM TOTAL FLOW is 34152055	GAL		
W2_FLO is 22.7	GPM TOTAL FLOW is 31036610	GAL		
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: ....	AMP
W1_AMP is 4.74	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.30	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.53	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.6	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 2.5	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 60.5	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 08/23/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.1	GPM	TOTAL FLOW is 34188382	GAL		
W2_FLO is 21.7	GPM	TOTAL FLOW is 31068225	GAL		
ASBPRS is 10.4	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: . . . .	AMP
W1_AMP is 4.77	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.61	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.05	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.39	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.7	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 2.8	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 59.5	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 08/24/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPILL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.2	GPM TOTAL FLOW is 34224652	GAL		
W2_FLO is 21.7	GPM TOTAL FLOW is 31099798	GAL		
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: ....	AMP
W1_AMP is 4.72	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.80	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.26	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.8	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.1	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 60.1	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 08/25/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.0	GPM	TOTAL FLOW is 34260887	GAL		
W2_FLO is 21.6	GPM	TOTAL FLOW is 31131357	GAL		
ASBPRS is 10.3	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: ....	AMP
W1_AMP is 4.64	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.50	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.74	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.22	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.7	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 2.9	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 61.1	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 08/26/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.1	GPM TOTAL FLOW is 34297103	GAL		
W2_FLO is 22.0	GPM TOTAL FLOW is 31162916	GAL		
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: .....	AMP
W1_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.81	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.17	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.8	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.1	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 60.9	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 08/27/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

Analog Inputs:

W1_FLO is 25.2	GPM	TOTAL FLOW is	34333344	GAL		
W2_FLO is 21.9	GPM	TOTAL FLOW is	31194470	GAL		
ASBPRS is 10.4	IWC	LIMITS are L:	5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is	425107	GAL		
HP_PRS is 1.2	PSI	LIMITS are L:	-2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L:	0.00	AMP	H: ....	AMP
W1_AMP is 4.61	AMP	LIMITS are L:	0.00	AMP	H: 10.00	AMP
W2_AMP is 4.46	AMP	LIMITS are L:	0.00	AMP	H: 10.00	AMP
W1_LVL is 32.87	FT	LIMITS are L:	8.00	FT	H: 28.00	FT
W2_LVL is 55.15	FT	LIMITS are L:	9.00	FT	H: 52.00	FT
W1_PRS is 3.8	PSI	LIMITS are L:	0.5	PSI	H: 100.0	PSI
W2_PRS is 3.2	PSI	LIMITS are L:	0.5	PSI	H: 100.0	PSI
INTEMP is 60.5	DEG	LIMITS are L:	42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 08/28/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.0	GPM TOTAL FLOW is 34369620	GAL		
W2_FLO is 22.0	GPM TOTAL FLOW is 31226012	GAL		
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: ....	AMP
W1_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.00	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.07	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.0	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.5	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 58.1	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 08/29/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

Analog Inputs:

W1_FLO is 25.0	GPM	TOTAL FLOW is 34405870	GAL		
W2_FLO is 21.7	GPM	TOTAL FLOW is 31257540	GAL		
ASBPRS is 10.5	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: ....	AMP
W1_AMP is 4.69	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.54	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.02	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.07	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.6	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 58.3	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

*Fax Report*

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 08/30/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

**Analog Inputs:**

W1_FLO is 25.4	GPM TOTAL FLOW is 34442099	GAL		
W2_FLO is 22.2	GPM TOTAL FLOW is 31289017	GAL		
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL		
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: ....	AMP
W1_AMP is 4.72	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.87	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.05	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.0	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.5	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 61.8	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 08/31/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.3	GPM TOTAL FLOW is 34478269	GAL	
W2_FLO is 21.8	GPM TOTAL FLOW is 31320491	GAL	
ASBPRS is 10.2	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: ....
W1_AMP is 4.67	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 32.81	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.03	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 3.8	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 3.2	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 62.8	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 09/01/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.1	GPM TOTAL FLOW is 34514417	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 31351779	GAL	
ASBPRTS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: .....
W1_AMP is 4.64	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 32.82	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.05	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 3.8	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 2.9	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 63.0	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 09/02/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 25.1	GPM TOTAL FLOW is 34550563	GAL	
W2_FLO is 21.4	GPM TOTAL FLOW is 31382960	GAL	
ASBPRES is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: .... AMP
W1_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.52	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.78	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 54.98	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 3.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 2.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 63.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 09/03/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

Analog Inputs:

W1_FLO is 25.2	GPM TOTAL FLOW is 34586683	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 31414131	GAL	
ASBPRS is 10.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: .... AMP
W1_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.63	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 54.98	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 3.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 2.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 63.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 09/04/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HMPGO is ON	

Analog Inputs:

W1_FLO is 24.7	GPM	TOTAL FLOW is 34622794	GAL		
W2_FLO is 21.4	GPM	TOTAL FLOW is 31445279	GAL		
ASBPRS is 10.3	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: ....	AMP
W1_AMP is 4.69	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.55	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.72	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 54.96	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.5	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 2.3	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 63.8	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 09/05/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.2	GPM	TOTAL FLOW is 34658910	GAL		
W2_FLO is 21.8	GPM	TOTAL FLOW is 31476422	GAL		
ASBPRS is 10.3	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: .....	AMP
W1_AMP is 4.77	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.62	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.91	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 54.96	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.7	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 2.3	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 63.6	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 09/06/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

## Analog Inputs:

W1_FLO is 25.4	GPM TOTAL FLOW is 34695037	GAL	
W2_FLO is 21.3	GPM TOTAL FLOW is 31507572	GAL	
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: ..... AMP
W1_AMP is 4.77	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.86	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 54.94	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 3.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 2.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 62.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 09/07/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.3	GPM TOTAL FLOW is 34731143	GAL		
W2_FLO is 21.6	GPM TOTAL FLOW is 31538718	GAL		
ASBPRES is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: ....	AMP
W1_AMP is 4.78	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.64	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.67	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 54.94	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.6	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 2.2	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 63.2	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

ECS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 09/08/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPILL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

Analog Inputs:

W1_FLO is 24.6	GPM TOTAL FLOW is 34767182	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 31569838	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: .....
W1_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 32.58	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 54.90	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 3.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 2.0	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 64.3	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 09/09/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

**Analog Inputs:**

W1_FLO is 24.9	GPM	TOTAL FLOW is 34803221	GAL		
W2_FLO is 21.5	GPM	TOTAL FLOW is 31600929	GAL		
ASBPRS is 10.3	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: .....	AMP
W1_AMP is 4.66	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.52	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.41	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 54.88	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.7	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 1.9	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 64.2	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 09/10/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

**Analog Inputs:**

W1_FLO is 25.3	GPM TOTAL FLOW is 34839295	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 31632039	GAL	
ASBPRS is 10.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: .... AMP
W1_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.59	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 54.98	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 3.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 1.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 63.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 09/11/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.0	GPM TOTAL FLOW is 34875450	GAL	
W2_FLO is 22.1	GPM TOTAL FLOW is 31663157	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: .....
W1_AMP is 4.68	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 32.44	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 54.92	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 3.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 1.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 62.1	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 09/12/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

Analog Inputs:

W1_FLO is 25.2	GPM TOTAL FLOW is 34911566	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 31694261	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL	
HP_PRS is 1.4	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: .....
W1_AMP is 4.76	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 32.39	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 54.90	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 3.9	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 2.0	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 60.1	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 09/13/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

Analog Inputs:

W1_FLO is 25.8	GPM	TOTAL FLOW is 34947721	GAL		
W2_FLO is 21.7	GPM	TOTAL FLOW is 31725373	GAL		
ASBPRS is 10.2	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.2	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: .....	AMP
W1_AMP is 4.74	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.58	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.25	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 54.90	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 3.8	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 2.2	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 63.0	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 09/14/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

Analog Inputs:

W1_FLO is 24.8	GPM	TOTAL FLOW is 34983891	GAL		
W2_FLO is 21.7	GPM	TOTAL FLOW is 31756497	GAL		
ASBPRS is 10.3	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.2	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: . . .	AMP
W1_AMP is 4.73	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.56	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.58	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 54.92	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 2.7	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 59.5	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 09/15/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

Analog Inputs:

W1_FLO is 24.8	GPM	TOTAL FLOW is 35020026	GAL		
W2_FLO is 21.4	GPM	TOTAL FLOW is 31787589	GAL		
ASBPRS is 10.6	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: ....	AMP
W1_AMP is 4.70	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.55	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.05	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.01	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.1	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.7	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 57.3	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELCIC NY @ 06:00:00 ON 09/16/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPILL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.3	GPM TOTAL FLOW is 35056141	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 31818672	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: .....
W1_AMP is 4.67	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 33.04	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 54.96	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 3.8	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 58.3	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 09/17/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 24.7	GPM	TOTAL FLOW is 35092213	GAL		
W2_FLO is 21.2	GPM	TOTAL FLOW is 31849736	GAL		
ASBPTRS is 10.4	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: .....	AMP
W1_AMP is 4.69	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.55	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.88	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 54.94	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.2	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.6	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 60.8	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 09/18/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 25.4	GPM	TOTAL FLOW is 35128285	GAL		
W2_FLO is 21.5	GPM	TOTAL FLOW is 31880794	GAL		
ASBPRS is 10.5	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.2	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: .....	AMP
W1_AMP is 4.75	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.59	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.66	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 54.94	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.1	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.5	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 59.6	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

ECS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 09/19/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

## Analog Inputs:

W1_FLO is 25.2	GPM	TOTAL FLOW is 35164342	GAL		
W2_FLO is 21.5	GPM	TOTAL FLOW is 31911854	GAL		
ASBPRS is 10.3	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: .....	AMP
W1_AMP is 4.70	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.55	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.47	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 54.92	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.1	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 3.6	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 61.2	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 09/20/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

Analog Inputs:

W1_FLO is 24.9	GPM TOTAL FLOW is 35200377	GAL	
W2_FLO is 21.2	GPM TOTAL FLOW is 31942932	GAL	
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: .... AMP
W1_AMP is 4.71	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.76	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.09	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 3.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 60.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 09/21/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

Analog Inputs:

W1_FLO is 25.1	GPM TOTAL FLOW is 35236491	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 31974040	GAL	
ASBPRES is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: . . .
W1_AMP is 4.67	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.52	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 32.93	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.07	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 55.7	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 09/22/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.2	GPM TOTAL FLOW is 35272602	GAL	
W2_FLO is 21.0	GPM TOTAL FLOW is 32005124	GAL	
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 425107	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: .....
W1_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 32.95	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.03	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 58.9	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

Front

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 09/23/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 19:31:48 ON 07/31/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.7	GPM	TOTAL FLOW is 35308715	GAL	
W2_FLO is 21.5	GPM	TOTAL FLOW is 32036213	GAL	
ASBPRS is 10.7	IWC	LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM	TOTAL FLOW is 425107	GAL	
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: .....
W1_AMP is 4.68	AMP	LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.51	AMP	LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 32.93	FT	LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 55.01	FT	LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.2	PSI	LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.3	PSI	LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 55.8	DEG	LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd. Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 09/24/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPILL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFRUN is OFF	VFRDST is OFF	HMPGO is ON	

**Analog Inputs:**

W1_FLO is 23.3	GPM TOTAL FLOW is 35338522	GAL	
W2_FLO is 21.2	GPM TOTAL FLOW is 32062619	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425329	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: ..... AMP
W1_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.52	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.14	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.03	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 59.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 09/25/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 23.0	GPM TOTAL FLOW is 35371934	GAL	
W2_FLO is 21.4	GPM TOTAL FLOW is 32093936	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425494	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: .... AMP
W1_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.19	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 54.96	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 60.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

Fax Report

**To:**

JEREMY WYCKOFF

**From:**

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 09/26/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

**System Status:**

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

**Discrete Inputs:**

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

**Discrete Outputs:**


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

**Analog Inputs:**

W1_FLO is 22.9	GPM	TOTAL FLOW is 35404544	GAL		
W2_FLO is 22.0	GPM	TOTAL FLOW is 32125273	GAL		
ASBPRS is 10.5	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 425658	GAL		
HP_PRS is 1.2	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H: .....	AMP
W1_AMP is 4.62	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.59	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.19	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.01	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.1	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 60.0	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

**Analog Outputs:**

ASBSPD 0.0 PCT MAN



# ProControl Series II+

ECS Research Ltd.

Fax Report

## To:

JEREMY WYCKOFF

## From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 09/27/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

## System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

## Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

## Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

## Analog Inputs:

W1_FLO is 22.3	GPM TOTAL FLOW is 35436840	GAL		
W2_FLO is 22.0	GPM TOTAL FLOW is 32156605	GAL		
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 425847	GAL		
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: .....	AMP
W1_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.17	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 54.96	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.0	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.0	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 59.1	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

## Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 09/28/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 22.1	GPM	TOTAL FLOW is 35468949	GAL		
W2_FLO is 21.5	GPM	TOTAL FLOW is 32187921	GAL		
ASBPRS is 10.2	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 426002	GAL		
HP_PRS is 1.2	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.05	AMP	LIMITS are L: 0.00	AMP	H: .....	AMP
W1_AMP is 4.54	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.51	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.94	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 54.92	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.1	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.1	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 63.6	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 09/29/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFD_RST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 22.1	GPM	TOTAL FLOW is	35500870	GAL		
W2_FLO is 22.0	GPM	TOTAL FLOW is	32219212	GAL		
ASBPRS is 10.1	IWC	LIMITS are L:	5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is	426113	GAL		
HP_PRS is 1.3	PSI	LIMITS are L:	-2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L:	0.00	AMP	H: .....	AMP
W1_AMP is 4.48	AMP	LIMITS are L:	0.00	AMP	H: 10.00	AMP
W2_AMP is 4.47	AMP	LIMITS are L:	0.00	AMP	H: 10.00	AMP
W1_LVL is 32.72	FT	LIMITS are L:	8.00	FT	H: 28.00	FT
W2_LVL is 54.92	FT	LIMITS are L:	9.00	FT	H: 52.00	FT
W1_PRS is 4.0	PSI	LIMITS are L:	0.5	PSI	H: 100.0	PSI
W2_PRS is 3.8	PSI	LIMITS are L:	0.5	PSI	H: 100.0	PSI
INTEMP is 64.7	DEG	LIMITS are L:	42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



# ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELC NY @ 06:00:00 ON 09/30/2015  
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HMPGO is ON	

Analog Inputs:


W1_FLO is 21.9	GPM	TOTAL FLOW is 35532694	GAL	
W2_FLO is 22.1	GPM	TOTAL FLOW is 32250579	GAL	
ASBPRS is 10.0	IWC	LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 426224	GAL	
HP_PRS is 1.2	PSI	LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP	LIMITS are L: 0.00	AMP	H: .... AMP
W1_AMP is 4.55	AMP	LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.53	AMP	LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.49	FT	LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.91	FT	LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 3.9	PSI	LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 3.5	PSI	LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 63.8	DEG	LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN

## **APPENDIX B**

### O&M Checklists



**Gladding Cordage  
South Otselic, New York  
NYSDEC Site #709009**

Date 7/31/2015  
Inspector J. Wyckoff  
Time 19:00

<b>Treatment System Operation</b>		<b>Alarms</b>	
System On (Y/N)	<u>Yes</u>	A/C Fail (Y/N)	<u>No</u>
RW-1 On (Y/N)	<u>Yes</u>	RW-1 (Y/N)	<u>No</u>
RW-2 On (Y/N)	<u>Yes</u>	RW-2 (Y/N)	<u>No</u>
Blower On (Y/N)	<u>Yes</u>	Blower Pressure (Y/N)	<u>No</u>
Sump Pump On (Y/N)	<u>No</u>	Sump Level (Y/N)	<u>No</u>

<b>Recovery Wells</b>	<b>RW-1</b>	<b>RW-2</b>
Flow Rate (GPM)	25.3	22.3
Total Flow (Gallons)	NR	NR
Water Level (Feet Above Probe)	32.86	55.53
Probe Depth (Feet BTOC)	40.00	65.00

<b>Air Stripper</b>			
Blower VFD Setting (Hertz)	46	Intake/Exhaust Piping OK? (Y/N)	Yes
System Pressure (inches water)	10.1	Water Leaks (Y/N)	No
Influent/Effluent Piping OK? (Y/N)	Yes	Water Temperature (°F)	50

<b>Heat Exchanger</b>			
Heat (On/Off)	Off	Building Temperature (°F)	76
Heat Exchanger Flow (GPM)	0.0	Heat Exchanger Pressure (PSI)	1.4

<b>General Building/Site</b>			
Building Condition OK? (Y/N)	Yes	Circuit Breakers Checked (Y/N)	Yes
Grass Mowed (Y/N)	No	Outfall Condition OK? (Y/N)	Yes
Monitoring Wells OK? (Y/N)	Yes	Samples Collected (Y/N)	Yes

## Notes:

Reboot PLC due to no fax alerts since 7/26/15.

---

**NR - Not recorded**

**Gladding Cordage**  
**South Otselic, New York**  
**NYSDEC Site #709009**

Date 8/28/2015  
Inspector J. Wyckoff  
Time 9:00

**Treatment System Operation**

System On (Y/N)	<u>Yes</u>
RW-1 On (Y/N)	<u>Yes</u>
RW-2 On (Y/N)	<u>Yes</u>
Blower On (Y/N)	<u>Yes</u>
Sump Pump On (Y/N)	<u>No</u>

**Alarms**

A/C Fail (Y/N)	<u>No</u>
RW-1 (Y/N)	<u>No</u>
RW-2 (Y/N)	<u>No</u>
Blower Pressure (Y/N)	<u>No</u>
Sump Level (Y/N)	<u>No</u>

**Recovery Wells**

	<b>RW-1</b>	<b>RW-2</b>
Flow Rate (GPM)	<u>24.8</u>	<u>22.0</u>
Total Flow (Gallons)	<u>34369620</u>	<u>31226012</u>
Water Level (Feet Above Probe)	<u>33.05</u>	<u>55.01</u>
Probe Depth (Feet BTOC)	<u>40.00</u>	<u>65.00</u>

**Air Stripper**

Blower VFD Setting (Hertz)	<u>46</u>	Intake/Exhaust Piping OK? (Y/N)	<u>Yes</u>
System Pressure (inches water)	<u>10.3</u>	Water Leaks (Y/N)	<u>No</u>
Influent/Effluent Piping OK? (Y/N)	<u>Yes</u>	Water Temperature (°F)	<u>50</u>

**Heat Exchanger**

Heat (On/Off)	<u>Off</u>	Building Temperature (°F)	<u>60</u>
Heat Exchanger Flow (GPM)	<u>0.0</u>	Heat Exchanger Pressure (PSI)	<u>1.3</u>

**General Building/Site**

Building Condition OK? (Y/N)	<u>Yes</u>	Circuit Breakers Checked (Y/N)	<u>Yes</u>
Grass Mowed (Y/N)	<u>No</u>	Outfall Condition OK? (Y/N)	<u>Yes</u>
Monitoring Wells OK? (Y/N)	<u>Yes</u>	Samples Collected (Y/N)	<u>Yes</u>

**Notes:**

Trim grass  
Perform routine O&M

---

---

---

---

---

---

---

---

---

---

---

---

---

**Gladding Cordage**  
**South Otselic, New York**  
**NYSDEC Site #709009**

Date 9/23/2015  
Inspector JRW / L. Whalen  
Time 7:30

**Treatment System Operation**

System On (Y/N)	<u>Yes</u>
RW-1 On (Y/N)	<u>Yes</u>
RW-2 On (Y/N)	<u>Yes</u>
Blower On (Y/N)	<u>Yes</u>
Sump Pump On (Y/N)	<u>No</u>

**Alarms**

A/C Fail (Y/N)	<u>No</u>
RW-1 (Y/N)	<u>No</u>
RW-2 (Y/N)	<u>No</u>
Blower Pressure (Y/N)	<u>No</u>
Sump Level (Y/N)	<u>No</u>

**Recovery Wells**

	<b>RW-1</b>	<b>RW-2</b>
Flow Rate (GPM)	<u>25</u>	<u>21.5</u>
Total Flow (Gallons)	<u>35308715</u>	<u>32036213</u>
Water Level (Feet Above Probe)	<u>32.95</u>	<u>54.98</u>
Probe Depth (Feet BTOC)	<u>40.00</u>	<u>65.00</u>

**Air Stripper**

Blower VFD Setting (Hertz)	<u>46</u>	Intake/Exhaust Piping OK? (Y/N)	<u>Yes</u>
System Pressure (inches water)	<u>10.7</u>	Water Leaks (Y/N)	<u>No</u>
Influent/Effluent Piping OK? (Y/N)	<u>Yes</u>	Water Temperature (°F)	<u>50</u>

**Heat Exchanger**

Heat (On/Off)	<u>Off</u>	Building Temperature (°F)	<u>54</u>
Heat Exchanger Flow (GPM)	<u>0.0</u>	Heat Exchanger Pressure (PSI)	<u>1.3</u>

**General Building/Site**

Building Condition OK? (Y/N)	<u>Yes</u>	Circuit Breakers Checked (Y/N)	<u>Yes</u>
Grass Mowed (Y/N)	<u>Yes</u>	Outfall Condition OK? (Y/N)	<u>Yes</u>
Monitoring Wells OK? (Y/N)	<u>Yes</u>	Samples Collected (Y/N)	<u>Yes</u>


**Notes:**

08:00 - Shut system down to clean air stripper.  
12:50 - Restart system and collect system samples.

Trim grass.

# **APPENDIX C**

## Analytical Reporting Forms





---

39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

August 12, 2015

Jeremy Wyckoff  
Arcadis US, Inc. - Clifton Park-NY  
855 Route 146, Suite 210  
Clifton Park, NY 12065

Project Location: S. Otselic, NY

Client Job Number:

Project Number: 00266406.0000

Laboratory Work Order Number: 15H0031

Enclosed are results of analyses for samples received by the laboratory on August 3, 2015. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "Aaron L. Benoit". It is written in a cursive, flowing style.

Aaron L. Benoit  
Project Manager

## Table of Contents

Sample Summary	3
Case Narrative	4
Sample Results	5
15H0031-01	5
15H0031-02	6
15H0031-03	7
15H0031-04	8
Sample Preparation Information	9
QC Data	10
Volatile Organic Compounds by GC/MS	10
B128318	10
Flag/Qualifier Summary	12
Certifications	13
Chain of Custody/Sample Receipt	15



39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

Arcadis US, Inc. - Clifton Park-NY  
 855 Route 146, Suite 210  
 Clifton Park, NY 12065  
 ATTN: Jeremy Wyckoff

REPORT DATE: 8/12/2015

PURCHASE ORDER NUMBER:

PROJECT NUMBER: 00266406.0000

#### ANALYTICAL SUMMARY

WORK ORDER NUMBER: 15H0031

The results of analyses performed on the following samples submitted to the CON-TEST Analytical Laboratory are found in this report.

PROJECT LOCATION: S. Otselic, NY

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
RW-1	15H0031-01	Ground Water		EPA 624	
RW-2	15H0031-02	Ground Water		EPA 624	
Eff 46 HZ	15H0031-03	Ground Water		EPA 624	
Trip Blank	15H0031-04	Trip Blank Water		EPA 624	



---

39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

#### CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Con-Test Analytical Laboratory for testing.  
I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.

A handwritten signature in black ink that reads "Tod E. Kopyscinski". The signature is fluid and cursive, with a distinct "T" at the beginning.

Tod E. Kopyscinski  
Laboratory Director



39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 15H0031

Date Received: 8/3/2015

Field Sample #: RW-1

Sampled: 7/31/2015 19:05

Sample ID: 15H0031-01

Sample Matrix: Ground Water

## Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
1,1-Dichloroethane	1.6	2.0	0.16	µg/L	1	J	EPA 624	8/11/15	8/11/15 15:13	EEH
1,1-Dichloroethylene	0.96	2.0	0.21	µg/L	1	J	EPA 624	8/11/15	8/11/15 15:13	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
1,1,1-Trichloroethane	40	2.0	0.094	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	8/11/15	8/11/15 15:13	EEH

Surrogates	% Recovery	Recovery Limits	Flag/Qual	
1,2-Dichloroethane-d4	104	70-130		8/11/15 15:13
Toluene-d8	101	70-130		8/11/15 15:13
4-Bromofluorobenzene	99.4	70-130		8/11/15 15:13



39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 15H0031

Date Received: 8/3/2015

Field Sample #: RW-2

Sampled: 7/31/2015 19:10

Sample ID: 15H0031-02

Sample Matrix: Ground Water

## Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
1,1-Dichloroethane	0.74	2.0	0.16	µg/L	1	J	EPA 624	8/11/15	8/11/15 15:39	EEH
1,1-Dichloroethylene	0.72	2.0	0.21	µg/L	1	J	EPA 624	8/11/15	8/11/15 15:39	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
1,1,1-Trichloroethane	34	2.0	0.094	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	8/11/15	8/11/15 15:39	EEH
Surrogates	% Recovery	Recovery Limits			Flag/Qual					
1,2-Dichloroethane-d4	102	70-130						8/11/15 15:39		
Toluene-d8	100	70-130						8/11/15 15:39		
4-Bromofluorobenzene	102	70-130						8/11/15 15:39		



39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 15H0031

Date Received: 8/3/2015

**Field Sample #:** Eff 46 HZ

Sampled: 7/31/2015 19:15

**Sample ID:** 15H0031-03Sample Matrix: Ground Water**Volatile Organic Compounds by GC/MS**

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
1,1,1-Trichloroethane	0.22	2.0	0.094	µg/L	1	J	EPA 624	8/11/15	8/11/15 14:20	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	8/11/15	8/11/15 14:20	EEH
Surrogates	% Recovery	Recovery Limits			Flag/Qual					
1,2-Dichloroethane-d4	101	70-130								8/11/15 14:20
Toluene-d8	101	70-130								8/11/15 14:20
4-Bromofluorobenzene	101	70-130								8/11/15 14:20



39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 15H0031

Date Received: 8/3/2015

**Field Sample #:** Trip Blank

Sampled: 7/31/2015 00:00

**Sample ID:** 15H0031-04

Sample Matrix: Trip Blank Water

**Volatile Organic Compounds by GC/MS**

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	8/11/15	8/11/15 13:53	EEH

Surrogates	% Recovery	Recovery Limits	Flag/Qual
1,2-Dichloroethane-d4	103	70-130	8/11/15 13:53
Toluene-d8	101	70-130	8/11/15 13:53
4-Bromofluorobenzene	101	70-130	8/11/15 13:53

39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

**Sample Extraction Data****Prep Method: SW-846 5030B-EPA 624**

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
15H0031-01 [RW-1]	B128318	5	5.00	08/11/15
15H0031-02 [RW-2]	B128318	5	5.00	08/11/15
15H0031-03 [Eff 46 HZ]	B128318	5	5.00	08/11/15
15H0031-04 [Trip Blank]	B128318	5	5.00	08/11/15

39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

**QUALITY CONTROL****Volatile Organic Compounds by GC/MS - Quality Control**

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

**Batch B128318 - SW-846 5030B**

<b>Blank (B128318-BLK1)</b>	Prepared: 08/10/15 Analyzed: 08/11/15					
Benzene	ND	1.0	µg/L			
Bromodichloromethane	ND	2.0	µg/L			
Bromoform	ND	2.0	µg/L			
Bromomethane	ND	2.0	µg/L			
Carbon Tetrachloride	ND	2.0	µg/L			
Chlorobenzene	ND	2.0	µg/L			
Chlorodibromomethane	ND	2.0	µg/L			
Chloroethane	ND	2.0	µg/L			
2-Chloroethyl Vinyl Ether	ND	10	µg/L			
Chloroform	ND	2.0	µg/L			
Chloromethane	ND	2.0	µg/L			
1,2-Dichlorobenzene	ND	2.0	µg/L			
1,3-Dichlorobenzene	ND	2.0	µg/L			
1,4-Dichlorobenzene	ND	2.0	µg/L			
1,2-Dichloroethane	ND	2.0	µg/L			
cis-1,2-Dichloroethylene	ND	1.0	µg/L			
1,1-Dichloroethane	ND	2.0	µg/L			
1,1-Dichloroethylene	ND	2.0	µg/L			
trans-1,2-Dichloroethylene	ND	2.0	µg/L			
1,2-Dichloropropane	ND	2.0	µg/L			
cis-1,3-Dichloropropene	ND	2.0	µg/L			
trans-1,3-Dichloropropene	ND	2.0	µg/L			
Ethylbenzene	ND	2.0	µg/L			
Methyl tert-Butyl Ether (MTBE)	ND	2.0	µg/L			
Methylene Chloride	ND	5.0	µg/L			
1,1,2,2-Tetrachloroethane	ND	2.0	µg/L			
Tetrachloroethylene	ND	2.0	µg/L			
Toluene	ND	1.0	µg/L			
1,1,1-Trichloroethane	ND	2.0	µg/L			
1,1,2-Trichloroethane	ND	2.0	µg/L			
Trichloroethylene	ND	2.0	µg/L			
Trichlorofluoromethane (Freon 11)	ND	2.0	µg/L			
Vinyl Chloride	ND	2.0	µg/L			
m+p Xylene	ND	2.0	µg/L			
o-Xylene	ND	2.0	µg/L			
Surrogate: 1,2-Dichloroethane-d4	25.6		µg/L	25.0	102	70-130
Surrogate: Toluene-d8	25.3		µg/L	25.0	101	70-130
Surrogate: 4-Bromofluorobenzene	25.1		µg/L	25.0	101	70-130

<b>LCS (B128318-BS1)</b>	Prepared: 08/10/15 Analyzed: 08/11/15					
Benzene	10.4	1.0	µg/L	10.0	104	37-151
Bromodichloromethane	10.6	2.0	µg/L	10.0	106	35-155
Bromoform	10.0	2.0	µg/L	10.0	100	45-169
Bromomethane	9.44	2.0	µg/L	10.0	94.4	20-242
Carbon Tetrachloride	10.3	2.0	µg/L	10.0	103	70-140
Chlorobenzene	10.3	2.0	µg/L	10.0	103	37-160
Chlorodibromomethane	10.6	2.0	µg/L	10.0	106	53-149
Chloroethane	9.66	2.0	µg/L	10.0	96.6	70-130
2-Chloroethyl Vinyl Ether	97.3	10	µg/L	100	97.3	10-305
Chloroform	9.94	2.0	µg/L	10.0	99.4	51-138
Chloromethane	8.20	2.0	µg/L	10.0	82.0	20-273
1,2-Dichlorobenzene	10.5	2.0	µg/L	10.0	105	18-190



39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

### QUALITY CONTROL

#### Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD RPD	Limit Notes
<b>Batch B128318 - SW-846 5030B</b>									
<b>LCS (B128318-BS1)</b>									
Prepared: 08/10/15 Analyzed: 08/11/15									
1,3-Dichlorobenzene	10.2	2.0	µg/L	10.0	102	59-156			
1,4-Dichlorobenzene	10.2	2.0	µg/L	10.0	102	18-190			
1,2-Dichloroethane	10.5	2.0	µg/L	10.0	105	49-155			
cis-1,2-Dichloroethylene	10.8	1.0	µg/L	10.0	108	70-130			
1,1-Dichloroethane	10.8	2.0	µg/L	10.0	108	59-155			
1,1-Dichloroethylene	10.8	2.0	µg/L	10.0	108	20-234			
trans-1,2-Dichloroethylene	10.8	2.0	µg/L	10.0	108	54-156			
1,2-Dichloropropane	10.3	2.0	µg/L	10.0	103	20-210			
cis-1,3-Dichloropropene	10.5	2.0	µg/L	10.0	105	20-227			
trans-1,3-Dichloropropene	10.8	2.0	µg/L	10.0	108	17-183			
Ethylbenzene	10.4	2.0	µg/L	10.0	104	37-162			
Methyl tert-Butyl Ether (MTBE)	11.0	2.0	µg/L	10.0	110	70-130			
Methylene Chloride	11.1	5.0	µg/L	10.0	111	50-221			
1,1,2,2-Tetrachloroethane	11.2	2.0	µg/L	10.0	112	46-157			
Tetrachloroethylene	10.2	2.0	µg/L	10.0	102	64-148			
Toluene	10.3	1.0	µg/L	10.0	103	47-150			
1,1,1-Trichloroethane	10.6	2.0	µg/L	10.0	106	52-162			
1,1,2-Trichloroethane	10.9	2.0	µg/L	10.0	109	52-150			
Trichloroethylene	10.7	2.0	µg/L	10.0	107	71-157			
Trichlorofluoromethane (Freon 11)	10.2	2.0	µg/L	10.0	102	17-181			
Vinyl Chloride	9.00	2.0	µg/L	10.0	90.0	20-251			
m+p Xylene	20.6	2.0	µg/L	20.0	103	70-130			
o-Xylene	10.4	2.0	µg/L	10.0	104	70-130			
Surrogate: 1,2-Dichloroethane-d4	25.8		µg/L	25.0	103	70-130			
Surrogate: Toluene-d8	24.8		µg/L	25.0	99.2	70-130			
Surrogate: 4-Bromofluorobenzene	25.2		µg/L	25.0	101	70-130			

**FLAG/QUALIFIER SUMMARY**

- \* QC result is outside of established limits.
  - † Wide recovery limits established for difficult compound.
  - ‡ Wide RPD limits established for difficult compound.
  - # Data exceeded client recommended or regulatory level
- Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
- No results have been blank subtracted unless specified in the case narrative section.
- J Detected but below the Reporting Limit (lowest calibration standard); therefore, result is an estimated concentration (CLP J-Flag).



39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

#### CERTIFICATIONS

##### Certified Analyses included in this Report

Analyte	Certifications
<b>EPA 624 in Water</b>	
Benzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromodichloromethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromoform	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromomethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Carbon Tetrachloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chlorodibromomethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
2-Chloroethyl Vinyl Ether	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloroform	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloromethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,3-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,4-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
trans-1,2-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichloropropane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
cis-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
trans-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Ethylbenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Methyl tert-Butyl Ether (MTBE)	NC
Methylene Chloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,2,2-Tetrachloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Tetrachloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Toluene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,1-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,2-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Trichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Trichlorofluoromethane (Freon 11)	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Vinyl Chloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
m+p Xylene	CT,MA,NH,NY,RI,NC,VA,NJ
o-Xylene	CT,MA,NH,NY,RI,NC,VA,NJ



39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

The CON-TEST Environmental Laboratory operates under the following certifications and accreditations:

Code	Description	Number	Expires
AIHA	AIHA-LAP, LLC	100033	02/1/2016
MA	Massachusetts DEP	M-MA100	06/30/2016
CT	Connecticut Department of Public Health	PH-0567	09/30/2015
NY	New York State Department of Health	10899 NELAP	04/1/2016
NH-S	New Hampshire Environmental Lab	2516 NELAP	02/5/2016
RI	Rhode Island Department of Health	LAO00112	12/30/2015
NC	North Carolina Div. of Water Quality	652	12/31/2015
NJ	New Jersey DEP	MA007 NELAP	09/30/2015
FL	Florida Department of Health	E871027 NELAP	06/30/2016
VT	Vermont Department of Health Lead Laboratory	LL015036	07/30/2016
WA	State of Washington Department of Ecology	C2065	02/23/2016
ME	State of Maine	2011028	06/9/2017
VA	Commonwealth of Virginia	460217	12/14/2015
NH-P	New Hampshire Environmental Lab	2557 NELAP	09/6/2015



# CHAIN OF CUSTODY RECORD

Phone: 413-525-2332

Fax: 413-525-6405

Email: info@contestlabs.com  
ANALYTICAL LABORATORY

Company Name: ARCADES

Address: 855 Route 146, RR 2/10

Lifton Park, NY 12065

Client PO#

Project # 00266406; 00220

DATA DELIVERY (check all that apply)

 FAX EMAIL WEBSITE

Fax #

Email: Jeremy.Walkoff@arcades.us

Format: PDF EXCEL GIS OTHER

Collection

 Enhanced Data Package

Beginning Date/Time

Ending Date/Time

Composite Grab

Macro Grade

Const Grade

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate


O = Other

I = Iced

39 Spruce St.  
East Longmeadow, MA. 01028  
P: 413-525-2332  
F: 413-525-6405  
www.contestlabs.com



Page 1 of 2

**Sample Receipt Checklist**CLIENT NAME: ArcadisRECEIVED BY: KKMDATE: 8/3/15

1) Was the chain(s) of custody relinquished and signed?

 Yes No

No CoC Included

2) Does the chain agree with the samples?

 Yes No

If not, explain:

3) Are all the samples in good condition?

 Yes No

If not, explain:

4) How were the samples received:

On Ice Direct from Sampling Ambient In Cooler(s) 

Were the samples received in Temperature Compliance of (2-6°C)?

 Yes No

N/A

Temperature °C by Temp blank

3.0

Temperature °C by Temp gun

5) Are there Dissolved samples for the lab to filter?

 Yes No

Who was notified \_\_\_\_\_ Date \_\_\_\_\_ Time \_\_\_\_\_

6) Are there any RUSH or SHORT HOLDING TIME samples?

 Yes No

Who was notified \_\_\_\_\_ Date \_\_\_\_\_ Time \_\_\_\_\_

7) Location where samples are stored:

 Permission to subcontract samples? Yes  No 

(Walk-in clients only) if not already approved

Client Signature: \_\_\_\_\_

8) Do all samples have the proper Acid pH: Yes  No  N/A9) Do all samples have the proper Base pH: Yes  No  N/A10) Was the PC notified of any discrepancies with the CoC vs the samples: Yes  No  N/A**Containers received at Con-Test**

	# of containers		# of containers
1 Liter Amber		8 oz amber/clear jar	
500 mL Amber		4 oz amber/clear jar	
250 mL Amber (8oz amber)		2 oz amber/clear jar	
1 Liter Plastic		Plastic Bag / Ziploc	
500 mL Plastic		SOC Kit	
250 mL plastic		Non-ConTest Container	
40 mL Vial - type listed below	//	Perchlorate Kit	
Colisure / bacteria bottle		Flashpoint bottle	
Dissolved Oxygen bottle		Other glass jar	
Encore		Other	

Laboratory Comments:

40 mL vials: # HCl	//	# Methanol	Time and Date Frozen:
Doc# 277	# Bisulfate	# DI Water	
Rev. 4 August 2013	# Thiosulfate		

**Page 2 of 2**  
**Login Sample Receipt Checklist**  
**(Rejection Criteria Listing - Using Sample Acceptance Policy)**  
**Any False statement will be brought to the attention of Client**

<u>Question</u>	<u>Answer (True/False)</u>		<u>Comment</u>
	T/F/NA		
1) The cooler's custody seal, if present, is intact.	N/A		
2) The cooler or samples do not appear to have been compromised or tampered with.	T		
3) Samples were received on ice.	T		
4) Cooler Temperature is acceptable.	T		
5) Cooler Temperature is recorded.	T		
6) COC is filled out in ink and legible.	T		
7) COC is filled out with all pertinent information.	T		
8) Field Sampler's name present on COC.	T		
9) There are no discrepancies between the sample IDs on the container and the COC.	T		
10) Samples are received within Holding Time.	T		
11) Sample containers have legible labels.	T		
12) Containers are not broken or leaking.	T		
13) Air Cassettes are not broken/open.	N/A		
14) Sample collection date/times are provided.	T		
15) Appropriate sample containers are used.	T		
16) Proper collection media used.	T		
17) No headspace sample bottles are completely filled.	T		
18) There is sufficient volume for all requested analyses, including any requested MS/MSDs.	T		
19) Trip blanks provided if applicable.	T		
20) VOA sample vials do not have head space or bubble is <6mm (1/4") in diameter.	T		
21) Samples do not require splitting or compositing.	T		

Who notified of False statements?

Date/Time:

Doc #277 Rev. 4 August 2013

Log-In Technician Initials:

Date/Time:

KKM

8/3/15  
1325



---

39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

September 11, 2015

Jeremy Wyckoff  
Arcadis US, Inc. - Clifton Park-NY  
855 Route 146, Suite 210  
Clifton Park, NY 12065

Project Location: S. Ostelic, NY  
Client Job Number:  
Project Number: 00266406.0000  
Laboratory Work Order Number: 15I0002

Enclosed are results of analyses for samples received by the laboratory on September 1, 2015. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "Aaron L. Benoit". It is written in a cursive, flowing style with some variations in line thickness.

Aaron L. Benoit  
Project Manager

## Table of Contents

Sample Summary	3
Case Narrative	4
Sample Results	5
15I0002-01	5
15I0002-02	6
15I0002-03	7
15I0002-04	8
Sample Preparation Information	9
QC Data	10
Volatile Organic Compounds by GC/MS	10
B130150	10
Flag/Qualifier Summary	12
Certifications	13
Chain of Custody/Sample Receipt	15



39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

Arcadis US, Inc. - Clifton Park-NY  
 855 Route 146, Suite 210  
 Clifton Park, NY 12065  
 ATTN: Jeremy Wyckoff

REPORT DATE: 9/11/2015

PURCHASE ORDER NUMBER:

PROJECT NUMBER: 00266406.0000

#### **ANALYTICAL SUMMARY**

WORK ORDER NUMBER: 15I0002

The results of analyses performed on the following samples submitted to the CON-TEST Analytical Laboratory are found in this report.

PROJECT LOCATION: S. Ostelic, NY

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
RW-1	15I0002-01	Ground Water		EPA 624	
RW-2	15I0002-02	Ground Water		EPA 624	
EFF 46 HZ	15I0002-03	Ground Water		EPA 624	
Trip Blank	15I0002-04	Trip Blank Water		EPA 624	



---

39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

#### CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Con-Test Analytical Laboratory for testing.  
I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.

A handwritten signature in black ink, appearing to read "Tod E. Kopyscinski".

Tod E. Kopyscinski  
Laboratory Director



39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

Project Location: S. Ostelic, NY

Sample Description:

Work Order: 15I0002

Date Received: 9/1/2015

Field Sample #: RW-1

Sampled: 8/28/2015 09:40

Sample ID: 15I0002-01

Sample Matrix: Ground Water

## Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
1,1-Dichloroethane	1.8	2.0	0.16	µg/L	1	J	EPA 624	9/10/15	9/10/15 16:42	LBD
1,1-Dichloroethylene	0.97	2.0	0.21	µg/L	1	J	EPA 624	9/10/15	9/10/15 16:42	LBD
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
Tetrachloroethylene	0.19	2.0	0.080	µg/L	1	J	EPA 624	9/10/15	9/10/15 16:42	LBD
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
1,1,1-Trichloroethane	42	2.0	0.094	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
1,1,2-Trichloroethane	0.22	2.0	0.12	µg/L	1	J	EPA 624	9/10/15	9/10/15 16:42	LBD
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	9/10/15	9/10/15 16:42	LBD

Surrogates	% Recovery	Recovery Limits	Flag/Qual
1,2-Dichloroethane-d4	102	70-130	9/10/15 16:42
Toluene-d8	101	70-130	9/10/15 16:42
4-Bromofluorobenzene	89.1	70-130	9/10/15 16:42



39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

Project Location: S. Ostelic, NY

Sample Description:

Work Order: 15I0002

Date Received: 9/1/2015

Field Sample #: RW-2

Sampled: 8/28/2015 09:45

Sample ID: 15I0002-02

Sample Matrix: Ground Water

## Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
1,1-Dichloroethane	0.77	2.0	0.16	µg/L	1	J	EPA 624	9/10/15	9/10/15 17:13	LBD
1,1-Dichloroethylene	0.62	2.0	0.21	µg/L	1	J	EPA 624	9/10/15	9/10/15 17:13	LBD
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
Tetrachloroethylene	0.15	2.0	0.080	µg/L	1	J	EPA 624	9/10/15	9/10/15 17:13	LBD
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
1,1,1-Trichloroethane	36	2.0	0.094	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	9/10/15	9/10/15 17:13	LBD

Surrogates	% Recovery	Recovery Limits	Flag/Qual
1,2-Dichloroethane-d4	102	70-130	9/10/15 17:13
Toluene-d8	100	70-130	9/10/15 17:13
4-Bromofluorobenzene	89.4	70-130	9/10/15 17:13



39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

Project Location: S. Ostelic, NY

Sample Description:

Work Order: 15I0002

Date Received: 9/1/2015

Field Sample #: EFF 46 HZ

Sampled: 8/28/2015 09:50

Sample ID: 15I0002-03

Sample Matrix: Ground Water

## Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
Tetrachloroethylene	0.20	2.0	0.080	µg/L	1	J	EPA 624	9/10/15	9/10/15 16:11	LBD
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
1,1,1-Trichloroethane	0.17	2.0	0.094	µg/L	1	J	EPA 624	9/10/15	9/10/15 16:11	LBD
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	9/10/15	9/10/15 16:11	LBD

Surrogates	% Recovery	Recovery Limits	Flag/Qual
1,2-Dichloroethane-d4	103	70-130	9/10/15 16:11
Toluene-d8	102	70-130	9/10/15 16:11
4-Bromofluorobenzene	71.8	70-130	9/10/15 16:11



39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

Project Location: S. Ostelic, NY

Sample Description:

Work Order: 15I0002

Date Received: 9/1/2015

**Field Sample #:** Trip Blank

Sampled: 8/28/2015 00:00

**Sample ID:** 15I0002-04Sample Matrix: Trip Blank Water**Volatile Organic Compounds by GC/MS**

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	0.16	1.0	0.079	µg/L	1	J	EPA 624	9/10/15	9/10/15 15:40	LBD
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
Ethylbenzene	0.14	2.0	0.092	µg/L	1	J	EPA 624	9/10/15	9/10/15 15:40	LBD
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
Tetrachloroethylene	0.23	2.0	0.080	µg/L	1	J	EPA 624	9/10/15	9/10/15 15:40	LBD
Toluene	0.27	1.0	0.090	µg/L	1	J	EPA 624	9/10/15	9/10/15 15:40	LBD
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	9/10/15	9/10/15 15:40	LBD
m+p Xylene	0.47	2.0	0.18	µg/L	1	J	EPA 624	9/10/15	9/10/15 15:40	LBD
o-Xylene	0.18	2.0	0.11	µg/L	1	J	EPA 624	9/10/15	9/10/15 15:40	LBD

Surrogates	% Recovery	Recovery Limits	Flag/Qual
1,2-Dichloroethane-d4	101	70-130	
Toluene-d8	101	70-130	
4-Bromofluorobenzene	89.9	70-130	



39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

### Sample Extraction Data

Prep Method: SW-846 5030B-EPA 624

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
15I0002-01 [RW-1]	B130150	5	5.00	09/10/15
15I0002-02 [RW-2]	B130150	5	5.00	09/10/15
15I0002-03 [EFF 46 HZ]	B130150	5	5.00	09/10/15
15I0002-04 [Trip Blank]	B130150	5	5.00	09/10/15

39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

**QUALITY CONTROL****Volatile Organic Compounds by GC/MS - Quality Control**

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	---------	-----------	-------

**Batch B130150 - SW-846 5030B****Blank (B130150-BLK1)**

Prepared: 09/04/15 Analyzed: 09/10/15

Benzene	ND	1.0	µg/L							
Bromodichloromethane	ND	2.0	µg/L							
Bromoform	ND	2.0	µg/L							
Bromomethane	ND	2.0	µg/L							
Carbon Tetrachloride	ND	2.0	µg/L							
Chlorobenzene	ND	2.0	µg/L							
Chlorodibromomethane	ND	2.0	µg/L							
Chloroethane	ND	2.0	µg/L							
2-Chloroethyl Vinyl Ether	ND	10	µg/L							
Chloroform	ND	2.0	µg/L							
Chloromethane	ND	2.0	µg/L							
1,2-Dichlorobenzene	ND	2.0	µg/L							
1,3-Dichlorobenzene	ND	2.0	µg/L							
1,4-Dichlorobenzene	ND	2.0	µg/L							
1,2-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethylene	ND	2.0	µg/L							
trans-1,2-Dichloroethylene	ND	2.0	µg/L							
1,2-Dichloropropane	ND	2.0	µg/L							
cis-1,3-Dichloropropene	ND	2.0	µg/L							
trans-1,3-Dichloropropene	ND	2.0	µg/L							
Ethylbenzene	ND	2.0	µg/L							
Methyl tert-Butyl Ether (MTBE)	ND	2.0	µg/L							
Methylene Chloride	ND	5.0	µg/L							
1,1,2,2-Tetrachloroethane	ND	2.0	µg/L							
Tetrachloroethylene	0.22	2.0	µg/L							J
Toluene	ND	1.0	µg/L							
1,1,1-Trichloroethane	ND	2.0	µg/L							
1,1,2-Trichloroethane	ND	2.0	µg/L							
Trichloroethylene	ND	2.0	µg/L							
Trichlorofluoromethane (Freon 11)	ND	2.0	µg/L							
Vinyl Chloride	ND	2.0	µg/L							
m+p Xylene	ND	2.0	µg/L							
o-Xylene	ND	2.0	µg/L							
Surrogate: 1,2-Dichloroethane-d4	24.0		µg/L	25.0		96.2		70-130		
Surrogate: Toluene-d8	25.4		µg/L	25.0		102		70-130		
Surrogate: 4-Bromofluorobenzene	22.5		µg/L	25.0		90.2		70-130		

**LCS (B130150-BS1)**

Prepared: 09/04/15 Analyzed: 09/10/15

Benzene	11.6	1.0	µg/L	10.0		116		37-151		
Bromodichloromethane	9.88	2.0	µg/L	10.0		98.8		35-155		
Bromoform	9.39	2.0	µg/L	10.0		93.9		45-169		
Bromomethane	11.8	2.0	µg/L	10.0		118		20-242		
Carbon Tetrachloride	10.1	2.0	µg/L	10.0		101		70-140		
Chlorobenzene	9.95	2.0	µg/L	10.0		99.5		37-160		
Chlorodibromomethane	9.46	2.0	µg/L	10.0		94.6		53-149		
Chloroethane	11.7	2.0	µg/L	10.0		117		70-130		
2-Chloroethyl Vinyl Ether	114	10	µg/L	100		114		10-305		
Chloroform	10.3	2.0	µg/L	10.0		103		51-138		
Chloromethane	14.1	2.0	µg/L	10.0		141		20-273		
1,2-Dichlorobenzene	9.98	2.0	µg/L	10.0		99.8		18-190		
1,3-Dichlorobenzene	9.42	2.0	µg/L	10.0		94.2		59-156		

39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

**QUALITY CONTROL****Volatile Organic Compounds by GC/MS - Quality Control**

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD RPD	Limit Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	---------	-------------

**Batch B130150 - SW-846 5030B**

<b>LCS (B130150-BS1)</b>					Prepared: 09/04/15 Analyzed: 09/10/15				
1,4-Dichlorobenzene	9.31	2.0	µg/L	10.0	93.1	18-190			
1,2-Dichloroethane	9.30	2.0	µg/L	10.0	93.0	49-155			
1,1-Dichloroethane	10.9	2.0	µg/L	10.0	109	59-155			
1,1-Dichloroethylene	11.4	2.0	µg/L	10.0	114	20-234			
trans-1,2-Dichloroethylene	11.1	2.0	µg/L	10.0	111	54-156			
1,2-Dichloropropane	11.0	2.0	µg/L	10.0	110	20-210			
cis-1,3-Dichloropropene	10.2	2.0	µg/L	10.0	102	20-227			
trans-1,3-Dichloropropene	8.99	2.0	µg/L	10.0	89.9	17-183			
Ethylbenzene	10.1	2.0	µg/L	10.0	101	37-162			
Methyl tert-Butyl Ether (MTBE)	10.6	2.0	µg/L	10.0	106	70-130			
Methylene Chloride	12.4	5.0	µg/L	10.0	124	50-221			
1,1,2,2-Tetrachloroethane	9.67	2.0	µg/L	10.0	96.7	46-157			
Tetrachloroethylene	10.3	2.0	µg/L	10.0	103	64-148			
Toluene	10.5	1.0	µg/L	10.0	105	47-150			
1,1,1-Trichloroethane	10.2	2.0	µg/L	10.0	102	52-162			
1,1,2-Trichloroethane	10.3	2.0	µg/L	10.0	103	52-150			
Trichloroethylene	11.1	2.0	µg/L	10.0	111	71-157			
Trichlorofluoromethane (Freon 11)	10.2	2.0	µg/L	10.0	102	17-181			
Vinyl Chloride	11.8	2.0	µg/L	10.0	118	20-251			
m+p Xylene	20.2	2.0	µg/L	20.0	101	70-130			
o-Xylene	9.86	2.0	µg/L	10.0	98.6	70-130			
Surrogate: 1,2-Dichloroethane-d4	23.2		µg/L	25.0	93.0	70-130			
Surrogate: Toluene-d8	25.4		µg/L	25.0	102	70-130			
Surrogate: 4-Bromofluorobenzene	25.2		µg/L	25.0	101	70-130			



---

39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

**FLAG/QUALIFIER SUMMARY**

- \* QC result is outside of established limits.
- † Wide recovery limits established for difficult compound.
- ‡ Wide RPD limits established for difficult compound.
- # Data exceeded client recommended or regulatory level
  
- Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
- No results have been blank subtracted unless specified in the case narrative section.
  
- J Detected but below the Reporting Limit (lowest calibration standard); therefore, result is an estimated concentration (CLP J-Flag).



39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

### CERTIFICATIONS

#### Certified Analyses included in this Report

Analyte	Certifications
<b>EPA 624 in Water</b>	
Benzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromodichloromethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromoform	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromomethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Carbon Tetrachloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chlorodibromomethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
2-Chloroethyl Vinyl Ether	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloroform	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloromethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,3-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,4-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
trans-1,2-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichloropropane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
cis-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
trans-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Ethylbenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Methyl tert-Butyl Ether (MTBE)	NC
Methylene Chloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,2,2-Tetrachloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Tetrachloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Toluene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,1-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,2-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Trichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Trichlorofluoromethane (Freon 11)	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Vinyl Chloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
m+p Xylene	CT,MA,NH,NY,RI,NC,VA,NJ
o-Xylene	CT,MA,NH,NY,RI,NC,VA,NJ



39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

The CON-TEST Environmental Laboratory operates under the following certifications and accreditations:

Code	Description	Number	Expires
AIHA	AIHA-LAP, LLC	100033	02/1/2016
MA	Massachusetts DEP	M-MA100	06/30/2016
CT	Connecticut Department of Public Health	PH-0567	09/30/2015
NY	New York State Department of Health	10899 NELAP	04/1/2016
NH-S	New Hampshire Environmental Lab	2516 NELAP	02/5/2016
RI	Rhode Island Department of Health	LAO00112	12/30/2015
NC	North Carolina Div. of Water Quality	652	12/31/2015
NJ	New Jersey DEP	MA007 NELAP	09/30/2015
FL	Florida Department of Health	E871027 NELAP	06/30/2016
VT	Vermont Department of Health Lead Laboratory	LL015036	07/30/2016
WA	State of Washington Department of Ecology	C2065	02/23/2016
ME	State of Maine	2011028	06/9/2017
VA	Commonwealth of Virginia	460217	12/14/2015
NH-P	New Hampshire Environmental Lab	2557 NELAP	09/6/2016

**CHAIN OF CUSTODY RECORD**

NEW YORK STATE

Phone: 413-525-2332

Fax: 413-525-6405

Email: info@contestlabs.com

www.contestlabs.com

Project Location: S. Otsego, NY

Sampled By: J. W. Eckoff

Company Name: Acapdjs

Address: 855 RT 146, STE 210

Attention: Jimmy Eckoff

Project Proposal Provided? (for billing purposes)

Project #

PO#

DATA DELIVERY (check all that apply)

 FAX EMAIL WEBSITE

Fax #

Email: jerry.eckoff@acapdjs.com

Format: PDF EXCEL GIS OTHER Collection "Enhanced Data Package" 

Beginning Date/Time

Ending Date/Time

Composite

Grab

Date/Time

Matrix Code

Conc. Code

Telephone: 518-250-7300

Project #: 00266 4060000

Client PO#

DATA DELIVERY (check all that apply)

 FAX EMAIL WEBSITE

Fax #

Email: jerry.eckoff@acapdjs.com

Format: PDF EXCEL GIS OTHER Collection "Enhanced Data Package" 

Beginning Date/Time

Ending Date/Time

Composite

Grab

Date/Time

Matrix Code

Conc. Code

V

U

W

X

Y

Z

AA

BB

CC

DD

EE

FF

GG

HH

II

JJ

KK

LL

MM

NN

OO

PP

QQ

RR

SS

TT

UU

VV

WW

XX

YY

ZZ

AA

BB

CC

DD

EE

FF

GG

HH

II

JJ

KK

LL

MM

NN

OO

PP

QQ

RR

SS

TT

UU

VV

WW

XX

YY

ZZ

ANALYSIS REQUESTED

H

I

J

K

L

M

N

O

P

Q

R

S

T

U

V

W

X

Y

Z

AA

BB

CC

DD

EE

FF

GG

HH

II

JJ

KK

LL

MM

NN

OO

PP

QQ

RR

SS

TT

UU

VV

WW

XX

YY

ZZ

AA

BB

CC

DD

EE

FF

GG

HH

II

JJ

KK

LL

Comments:

Please use the following codes to let Con-Test know if a specific sample

may be high in concentration in Matrix/Conc. Code Box:

O = other \_\_\_\_\_

D W H = drinking water

G W = groundwater

A = air

S = soil/solid

S L = sludge

O = other \_\_\_\_\_

Turnaround Time:

Date/Time:

Relinquished by:

Received by:

Comments:

Please use the following codes to let Con-Test know if a specific sample

may be high in concentration in Matrix/Conc. Code Box:

O = other \_\_\_\_\_

D W H = drinking water

G W = groundwater

A = air

S = soil/solid

S L = sludge

O = other \_\_\_\_\_

NY TOGS

AWQ STDS

NY Unrestricted Use

NYC Sewer Discharge

Part 360 GW (Landfill)

RUSH<sup>†</sup>

24 hr

48 hr

72 hr

4 day

O

ASP-A

Equis (1 file)

ASP-B

Equis (4 file)

O

Other

9/1/2015

## Track your package or shipment with FedEx Tracking

[My Profile](#) [My FedEx Rewards](#) [Support](#) [Locations](#)  [English](#) [Search](#)[Ship](#) [Track](#) [Manage](#) [Learn](#) [FedEx Office ®](#)[Login](#)**IMPORTANT!**

FedEx is closely monitoring Hurricane Ignacio and Hurricane Jimena. Learn More

## FedEx® Tracking

**774405778136**Ship date :  
Mon 8/31/2015Actual delivery :  
Tues 9/01/2015 9:44 am

ALBANY, NY US

EAST LONGMEADOW, MA US

**Delivered**

Signed for by: P.BLAKE

## Travel History

Date/Time	Activity	Location
- 9/01/2015 - Tuesday		
9:44 am	Delivered	EAST LONGMEADOW, MA
7:19 am	On FedEx vehicle for delivery	WINDSOR LOCKS, CT
7:12 am	At local FedEx facility	WINDSOR LOCKS, CT
3:53 am	Departed FedEx location	NEWARK, NJ
12:31 am	Arrived at FedEx location	NEWARK, NJ
- 8/31/2015 - Monday		
9:00 pm	Left FedEx origin facility	MENANDS, NY
4:42 pm	Picked up	MENANDS, NY
3:36 pm	Shipment information sent to FedEx	

## Shipment Facts

Tracking number	774405778136	Service	FedEx Priority Overnight
Weight	17 lbs / 7.71 kgs	Dimensions	16x10x16 in.
Delivered To	Shipping/Receiving	Total pieces	1
Total shipment weight	17 lbs / 7.71 kgs	Shipper reference	85
Packaging	Your Packaging	Special handling section	Deliver Weekday

[Search](#)

**Customer Focus**  
[New Customer Center](#)  
[Small Business Center](#)  
[Service Guide](#)  
[Customer Support](#)

**Company Information**  
[About FedEx](#)  
[Careers](#)  
[Investor Relations](#)

**Featured Services**  
[FedEx One Rate](#)  
[FedEx SameDay](#)  
[FedEx Home Delivery](#)  
[Healthcare Solutions](#)  
[Online Retail Solutions](#)  
[Packaging Services](#)  
[Ancillary Clearance Services](#)

**Other Resources**  
[FedEx Compatible](#)  
[Developer Resource Center](#)  
[FedEx Ship Manager Software](#)  
[FedEx Mobile](#)

**Companies**  
[FedEx Express](#)  
[FedEx Ground](#)  
[FedEx Office](#)  
[FedEx Freight](#)  
[FedEx Custom Critical](#)  
[FedEx Trade Networks](#)  
[FedEx SupplyChain](#)  
[FedEx TechConnect](#)

## Follow FedEx

 [United States - English](#)

Page 2 of 2

Login Sample Receipt Checklist

(Rejection Criteria Listing - Using Sample Acceptance Policy)  
 Any False statement will be brought to the attention of Client

<u>Question</u>	<u>Answer (True/False)</u>	<u>Comment</u>
	T/F/NA	
1) The cooler's custody seal, if present, is intact.	N/A	
2) The cooler or samples do not appear to have been compromised or tampered with.	T	
3) Samples were received on ice.	T	
4) Cooler Temperature is acceptable.	T	
5) Cooler Temperature is recorded.	T	
6) COC is filled out in ink and legible.	T	
7) COC is filled out with all pertinent information.	T	
8) Field Sampler's name present on COC.	T	
9) There are no discrepancies between the sample IDs on the container and the COC.	T	
10) Samples are received within Holding Time.	T	
11) Sample containers have legible labels.	T	
12) Containers are not broken or leaking.	T	
13) Air Cassettes are not broken/open.	N/A	
14) Sample collection date/times are provided.	T	
15) Appropriate sample containers are used.	T	
16) Proper collection media used.	T	
17) No headspace sample bottles are completely filled.	T	
18) There is sufficient volume for all requested analyses, including any requested MS/MSDs.	T	
19) Trip blanks provided if applicable.	T	
20) VOA sample vials do not have head space or bubble is <6mm (1/4") in diameter.	T	
21) Samples do not require splitting or compositing.	T	

Who notified of False statements?

Log-In Technician Initials: PB

Date/Time:

Date/Time: 9.1.15

8:44

39 Spruce St.  
East Longmeadow, MA. 01028  
P: 413-525-2332  
F: 413-525-6405  
www.contestlabs.com



Page 1 of 2

Sample Receipt ChecklistCLIENT NAME: ArcadisRECEIVED BY: PBDATE: 9-1-151) Was the chain(s) of custody relinquished and signed?  Yes  No  No CoC Included2) Does the chain agree with the samples?  Yes  No

If not, explain:

3) Are all the samples in good condition?  Yes  No

If not, explain:

4) How were the samples received:

On Ice  Direct from Sampling  Ambient  In Cooler(s) Were the samples received in Temperature Compliance of (2-6°C)?  Yes  No  N/ATemperature °C by Temp blank 3.0 Temperature °C by Temp gun \_\_\_\_\_5) Are there Dissolved samples for the lab to filter?  Yes  No

Who was notified \_\_\_\_\_ Date \_\_\_\_\_ Time \_\_\_\_\_

6) Are there any RUSH or SHORT HOLDING TIME samples?  Yes  No

Who was notified \_\_\_\_\_ Date \_\_\_\_\_ Time \_\_\_\_\_

Permission to subcontract samples? Yes  No 7) Location where samples are stored: log in  
(Walk-in clients only) if not already approved  
Client Signature: \_\_\_\_\_8) Do all samples have the proper Acid pH:  Yes  No  N/A \_\_\_\_\_9) Do all samples have the proper Base pH:  Yes  No  N/A \_\_\_\_\_10) Was the PC notified of any discrepancies with the CoC vs the samples:  Yes  No  N/A \_\_\_\_\_**Containers received at Con-Test**

	# of containers		# of containers
1 Liter Amber		8 oz amber/clear jar	
500 mL Amber		4 oz amber/clear jar	
250 mL Amber (8oz amber)		2 oz amber/clear jar	
1 Liter Plastic		Plastic Bag / Ziploc	
500 mL Plastic		SOC Kit	
250 mL plastic		Non-ConTest Container	
40 mL Vial - type listed below	11	Perchlorate Kit	
Colisure / bacteria bottle		Flashpoint bottle	
Dissolved Oxygen bottle		Other glass jar	
Encore		Other	

Laboratory Comments:

40 mL vials: # HCl	11	# Methanol	Time and Date Frozen:
Doc# 277	# Bisulfate	# DI Water	
Rev. 4 August 2013	# Thiosulfate	Unpreserved	



---

39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

October 5, 2015

Jeremy Wyckoff  
Arcadis US, Inc. - Clifton Park-NY  
855 Route 146, Suite 210  
Clifton Park, NY 12065

Project Location: S. Ostelic, NY  
Client Job Number:  
Project Number: 00266406.0000  
Laboratory Work Order Number: 15I1183

Enclosed are results of analyses for samples received by the laboratory on September 26, 2015. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "Aaron L. Benoit". It is written in a cursive style with some variations in line thickness.

Aaron L. Benoit  
Project Manager

## Table of Contents

Sample Summary	3
Case Narrative	4
Sample Results	5
15I1183-01	5
15I1183-02	6
15I1183-03	7
15I1183-04	8
Sample Preparation Information	9
QC Data	10
Volatile Organic Compounds by GC/MS	10
B132003	10
Flag/Qualifier Summary	12
Certifications	13
Chain of Custody/Sample Receipt	15




---

39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

Arcadis US, Inc. - Clifton Park-NY  
 855 Route 146, Suite 210  
 Clifton Park, NY 12065  
 ATTN: Jeremy Wyckoff

REPORT DATE: 10/5/2015

PURCHASE ORDER NUMBER:

PROJECT NUMBER: 00266406.0000

**ANALYTICAL SUMMARY**

---

WORK ORDER NUMBER: 15I1183

The results of analyses performed on the following samples submitted to the CON-TEST Analytical Laboratory are found in this report.

PROJECT LOCATION: S. Ostelic, NY

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
RW-1	15I1183-01	Ground Water		EPA 624	
RW-2	15I1183-02	Ground Water		EPA 624	
EFF46HZ	15I1183-03	Ground Water		EPA 624	
Trip Blank	15I1183-04	Trip Blank Water		EPA 624	



---

39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

#### CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

#### EPA 624

---

**Qualifications:****L-01**

Laboratory fortified blank /laboratory control sample recovery outside of control limits. Data validation is not affected since all results are "not detected" for all samples in this batch for this compound and bias is on the high side.

**Analyte & Samples(s) Qualified:****Chloroethane**

B132003-BS1

The results of analyses reported only relate to samples submitted to the Con-Test Analytical Laboratory for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.

A handwritten signature in black ink, appearing to read "Johanna K. Harrington".

Johanna K. Harrington

Manager, Laboratory Reporting



39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

Project Location: S. Ostelic, NY

Sample Description:

Work Order: 15I1183

Date Received: 9/26/2015

Field Sample #: RW-1

Sampled: 9/23/2015 10:40

Sample ID: 15I1183-01

Sample Matrix: Ground Water

**Volatile Organic Compounds by GC/MS**

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
1,1-Dichloroethane	1.7	2.0	0.16	µg/L	1	J	EPA 624	10/1/15	10/3/15 0:39	EEH
1,1-Dichloroethylene	0.92	2.0	0.21	µg/L	1	J	EPA 624	10/1/15	10/3/15 0:39	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
1,1,1-Trichloroethane	38	2.0	0.094	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	10/1/15	10/3/15 0:39	EEH

Surrogates	% Recovery	Recovery Limits	Flag/Qual	
1,2-Dichloroethane-d4	109	70-130		10/3/15 0:39
Toluene-d8	102	70-130		10/3/15 0:39
4-Bromofluorobenzene	95.5	70-130		10/3/15 0:39



39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

Project Location: S. Ostelic, NY

Sample Description:

Work Order: 15I1183

Date Received: 9/26/2015

Field Sample #: RW-2

Sampled: 9/23/2015 10:45

Sample ID: 15I1183-02

Sample Matrix: Ground Water

**Volatile Organic Compounds by GC/MS**

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
1,1-Dichloroethane	0.70	2.0	0.16	µg/L	1	J	EPA 624	10/1/15	10/3/15 1:06	EEH
1,1-Dichloroethylene	0.69	2.0	0.21	µg/L	1	J	EPA 624	10/1/15	10/3/15 1:06	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
1,1,1-Trichloroethane	31	2.0	0.094	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	10/1/15	10/3/15 1:06	EEH

Surrogates	% Recovery	Recovery Limits	Flag/Qual	
1,2-Dichloroethane-d4	106	70-130		10/3/15 1:06
Toluene-d8	100	70-130		10/3/15 1:06
4-Bromofluorobenzene	97.4	70-130		10/3/15 1:06



39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

Project Location: S. Ostelic, NY

Sample Description:

Work Order: 15I1183

Date Received: 9/26/2015

Field Sample #: EFF46HZ

Sampled: 9/23/2015 10:50

Sample ID: 15I1183-03

Sample Matrix: Ground Water

## Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	10/1/15	10/3/15 0:12	EEH

Surrogates	% Recovery	Recovery Limits	Flag/Qual
1,2-Dichloroethane-d4	110	70-130	10/3/15 0:12
Toluene-d8	100	70-130	10/3/15 0:12
4-Bromofluorobenzene	96.5	70-130	10/3/15 0:12



39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

Project Location: S. Ostelic, NY

Sample Description:

Work Order: 15I1183

Date Received: 9/26/2015

**Field Sample #:** Trip Blank

Sampled: 9/23/2015 00:00

**Sample ID:** 15I1183-04Sample Matrix: Trip Blank Water**Volatile Organic Compounds by GC/MS**

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.079	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
Carbon Tetrachloride	ND	2.0	0.10	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
Chlorobenzene	ND	2.0	0.12	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
Chlorodibromomethane	ND	2.0	0.054	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
Chloroethane	ND	2.0	0.16	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
Chloroform	ND	2.0	0.14	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
1,2-Dichlorobenzene	ND	2.0	0.076	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
1,3-Dichlorobenzene	ND	2.0	0.079	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
1,4-Dichlorobenzene	ND	2.0	0.046	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
1,2-Dichloropropane	ND	2.0	0.11	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
cis-1,3-Dichloropropene	ND	2.0	0.062	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
trans-1,3-Dichloropropene	ND	2.0	0.056	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
Ethylbenzene	ND	2.0	0.092	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.12	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
Tetrachloroethylene	ND	2.0	0.080	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
Toluene	ND	1.0	0.090	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
Trichloroethylene	ND	2.0	0.077	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
m+p Xylene	ND	2.0	0.18	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH
o-Xylene	ND	2.0	0.11	µg/L	1		EPA 624	10/1/15	10/2/15 23:46	EEH

Surrogates	% Recovery	Recovery Limits	Flag/Qual
1,2-Dichloroethane-d4	107	70-130	10/2/15 23:46
Toluene-d8	101	70-130	10/2/15 23:46
4-Bromofluorobenzene	97.4	70-130	10/2/15 23:46



---

39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

### Sample Extraction Data

Prep Method: SW-846 5030B-EPA 624

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
15I1183-01 [RW-1]	B132003	5	5.00	10/01/15
15I1183-02 [RW-2]	B132003	5	5.00	10/01/15
15I1183-03 [EFF46HZ]	B132003	5	5.00	10/01/15
15I1183-04 [Trip Blank]	B132003	5	5.00	10/01/15



39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

**QUALITY CONTROL****Volatile Organic Compounds by GC/MS - Quality Control**

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD RPD	Limit Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	---------	-------------

**Batch B132003 - SW-846 5030B**

<b>Blank (B132003-BLK1)</b>					Prepared: 10/01/15 Analyzed: 10/02/15				
Benzene	ND	1.0	µg/L						
Bromodichloromethane	ND	2.0	µg/L						
Bromoform	ND	2.0	µg/L						
Bromomethane	ND	2.0	µg/L						
Carbon Tetrachloride	ND	2.0	µg/L						
Chlorobenzene	ND	2.0	µg/L						
Chlorodibromomethane	ND	2.0	µg/L						
Chloroethane	ND	2.0	µg/L						
2-Chloroethyl Vinyl Ether	ND	10	µg/L						
Chloroform	ND	2.0	µg/L						
Chloromethane	ND	2.0	µg/L						
1,2-Dichlorobenzene	ND	2.0	µg/L						
1,3-Dichlorobenzene	ND	2.0	µg/L						
1,4-Dichlorobenzene	ND	2.0	µg/L						
1,2-Dichloroethane	ND	2.0	µg/L						
1,1-Dichloroethane	ND	2.0	µg/L						
1,1-Dichloroethylene	ND	2.0	µg/L						
trans-1,2-Dichloroethylene	ND	2.0	µg/L						
1,2-Dichloropropane	ND	2.0	µg/L						
cis-1,3-Dichloropropene	ND	2.0	µg/L						
trans-1,3-Dichloropropene	ND	2.0	µg/L						
Ethylbenzene	ND	2.0	µg/L						
Methyl tert-Butyl Ether (MTBE)	ND	2.0	µg/L						
Methylene Chloride	ND	5.0	µg/L						
1,1,2,2-Tetrachloroethane	ND	2.0	µg/L						
Tetrachloroethylene	ND	2.0	µg/L						
Toluene	ND	1.0	µg/L						
1,1,1-Trichloroethane	ND	2.0	µg/L						
1,1,2-Trichloroethane	ND	2.0	µg/L						
Trichloroethylene	ND	2.0	µg/L						
Trichlorofluoromethane (Freon 11)	ND	2.0	µg/L						
Vinyl Chloride	ND	2.0	µg/L						
m+p Xylene	ND	2.0	µg/L						
o-Xylene	ND	2.0	µg/L						
Surrogate: 1,2-Dichloroethane-d4	27.1		µg/L	25.0		108	70-130		
Surrogate: Toluene-d8	25.4		µg/L	25.0		102	70-130		
Surrogate: 4-Bromofluorobenzene	24.0		µg/L	25.0		96.2	70-130		

<b>LCS (B132003-BS1)</b>					Prepared: 10/01/15 Analyzed: 10/02/15				
Benzene	9.32	1.0	µg/L	10.0		93.2	37-151		
Bromodichloromethane	9.42	2.0	µg/L	10.0		94.2	35-155		
Bromoform	7.58	2.0	µg/L	10.0		75.8	45-169		
Bromomethane	9.54	2.0	µg/L	10.0		95.4	20-242		
Carbon Tetrachloride	9.13	2.0	µg/L	10.0		91.3	70-140		
Chlorobenzene	8.84	2.0	µg/L	10.0		88.4	37-160		
Chlorodibromomethane	8.63	2.0	µg/L	10.0		86.3	53-149		
<b>Chloroethane</b>	16.1	2.0	µg/L	10.0		<b>161</b> *	70-130		L-01
2-Chloroethyl Vinyl Ether	107	10	µg/L	100		107	10-305		
Chloroform	9.39	2.0	µg/L	10.0		93.9	51-138		
Chloromethane	10.5	2.0	µg/L	10.0		105	20-273		
1,2-Dichlorobenzene	8.54	2.0	µg/L	10.0		85.4	18-190		
1,3-Dichlorobenzene	9.05	2.0	µg/L	10.0		90.5	59-156		



39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

**QUALITY CONTROL****Volatile Organic Compounds by GC/MS - Quality Control**

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD RPD	Limit Notes
<b>Batch B132003 - SW-846 5030B</b>									
<b>LCS (B132003-BS1)</b>									
Prepared: 10/01/15 Analyzed: 10/02/15									
1,4-Dichlorobenzene	8.94	2.0	µg/L	10.0	89.4	18-190			
1,2-Dichloroethane	9.64	2.0	µg/L	10.0	96.4	49-155			
1,1-Dichloroethane	9.87	2.0	µg/L	10.0	98.7	59-155			
1,1-Dichloroethylene	9.42	2.0	µg/L	10.0	94.2	20-234			
trans-1,2-Dichloroethylene	9.85	2.0	µg/L	10.0	98.5	54-156			
1,2-Dichloropropane	9.48	2.0	µg/L	10.0	94.8	20-210			
cis-1,3-Dichloropropene	9.87	2.0	µg/L	10.0	98.7	20-227			
trans-1,3-Dichloropropene	9.78	2.0	µg/L	10.0	97.8	17-183			
Ethylbenzene	9.05	2.0	µg/L	10.0	90.5	37-162			
Methyl tert-Butyl Ether (MTBE)	9.65	2.0	µg/L	10.0	96.5	70-130			
Methylene Chloride	8.74	5.0	µg/L	10.0	87.4	50-221			
1,1,2,2-Tetrachloroethane	9.48	2.0	µg/L	10.0	94.8	46-157			
Tetrachloroethylene	9.76	2.0	µg/L	10.0	97.6	64-148			
Toluene	9.31	1.0	µg/L	10.0	93.1	47-150			
1,1,1-Trichloroethane	9.36	2.0	µg/L	10.0	93.6	52-162			
1,1,2-Trichloroethane	9.56	2.0	µg/L	10.0	95.6	52-150			
Trichloroethylene	9.61	2.0	µg/L	10.0	96.1	71-157			
Trichlorofluoromethane (Freon 11)	8.42	2.0	µg/L	10.0	84.2	17-181			
Vinyl Chloride	8.04	2.0	µg/L	10.0	80.4	20-251			
m+p Xylene	18.2	2.0	µg/L	20.0	90.8	70-130			
o-Xylene	9.14	2.0	µg/L	10.0	91.4	70-130			
Surrogate: 1,2-Dichloroethane-d4	26.7		µg/L	25.0	107	70-130			
Surrogate: Toluene-d8	25.2		µg/L	25.0	101	70-130			
Surrogate: 4-Bromofluorobenzene	24.4		µg/L	25.0	97.8	70-130			



---

39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

**FLAG/QUALIFIER SUMMARY**

\* QC result is outside of established limits.

† Wide recovery limits established for difficult compound.

‡ Wide RPD limits established for difficult compound.

# Data exceeded client recommended or regulatory level

Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.

No results have been blank subtracted unless specified in the case narrative section.

J Detected but below the Reporting Limit (lowest calibration standard); therefore, result is an estimated concentration (CLP J-Flag).

L-01 Laboratory fortified blank /laboratory control sample recovery outside of control limits. Data validation is not affected since all results are "not detected" for all samples in this batch for this compound and bias is on the high side.



39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

#### CERTIFICATIONS

##### Certified Analyses included in this Report

Analyte	Certifications
<b>EPA 624 in Water</b>	
Benzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromodichloromethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromoform	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Bromomethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Carbon Tetrachloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chlorodibromomethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
2-Chloroethyl Vinyl Ether	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloroform	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Chloromethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,3-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,4-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
trans-1,2-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,2-Dichloropropane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
cis-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
trans-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Ethylbenzene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Methyl tert-Butyl Ether (MTBE)	NC
Methylene Chloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,2,2-Tetrachloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Tetrachloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Toluene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,1-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
1,1,2-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Trichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Trichlorofluoromethane (Freon 11)	CT,MA,NH,NY,RI,NC,ME,VA,NJ
Vinyl Chloride	CT,MA,NH,NY,RI,NC,ME,VA,NJ
m+p Xylene	CT,MA,NH,NY,RI,NC,VA,NJ
o-Xylene	CT,MA,NH,NY,RI,NC,VA,NJ




---

39 Spruce Street \* East Longmeadow, MA 01028 \* FAX 413/525-6405 \* TEL. 413/525-2332

The CON-TEST Environmental Laboratory operates under the following certifications and accreditations:

Code	Description	Number	Expires
AIHA	AIHA-LAP, LLC	100033	02/1/2016
MA	Massachusetts DEP	M-MA100	06/30/2016
CT	Connecticut Department of Public Health	PH-0567	09/30/2015
NY	New York State Department of Health	10899 NELAP	04/1/2016
NH-S	New Hampshire Environmental Lab	2516 NELAP	02/5/2016
RI	Rhode Island Department of Health	LAO00112	12/30/2015
NC	North Carolina Div. of Water Quality	652	12/31/2015
NJ	New Jersey DEP	MA007 NELAP	10/30/2015
FL	Florida Department of Health	E871027 NELAP	06/30/2016
VT	Vermont Department of Health Lead Laboratory	LL015036	07/30/2016
WA	State of Washington Department of Ecology	C2065	02/23/2016
ME	State of Maine	2011028	06/9/2017
VA	Commonwealth of Virginia	460217	12/14/2015
NH-P	New Hampshire Environmental Lab	2557 NELAP	09/6/2016

**CHAIN OF CUSTODY RECORD**

Phone: 413-525-2332

Fax: 413-525-6405

Email: info@contestlabs.com  
www.contestlabs.com

NEW YORK STATE

ANALYTICAL LABORATORY

15 E 1183

Company Name: ARCADTS

Address: 855 Route 146, Ste 210

Project # 00266406.0000

Client PO#

Fax #

Attention: J. W. Cutoff

Project Location: S. Otsego, NY

Sampled By: J. W. Cutoff

Project Proposal Provided? (for billing purposes)

39 Spruce Street

East Longmeadow, MA 01028

Page \_\_\_\_\_ of \_\_\_\_\_

		ANALYSIS REQUESTED											
Con-Test Lab ID (laboratory use only)	Client Sample ID / Description	Beginning Date/Time	Ending Date/Time	Composite	Grab	*Matrix	Date	Conc.	Code	Comments:	Turnaround	Program Information/Regulatory	
		9/23/15	10:40	X	X	Gel	M	X					
02	RW-2	10:45	X	X	I	M	X			5-Day	<input checked="" type="radio"/> NY TOGS		
03	EFF 46 H2	10:50	X	X	L	X				7 Day	<input type="radio"/> AWQ STDS		
04	TRIP Blank	-	X	X	V	-	X			10-Day or —	<input type="radio"/> NYC Sewer Discharge		
										RUSH <sup>†</sup>	<input checked="" type="radio"/> Part 360 GW (Landfill)		
										24 hr	<input type="radio"/> 48 hr		
										72 hr	<input type="radio"/> 4 day		
											<sup>†</sup> require lab approval		
											<input type="radio"/> Other: _____		
Please use the following codes to let Con-Test know if a specific sample may be high in concentration in Matrix/Conc. Code Box: H - High; M - Medium; L - Low; C - Clean; U - Unknown													
Comments: _____													
Relinquished by: (signature) <i>James W. Cutoff</i>	Date/Time: 9/23/15 14:00	Relinquished by: _____	Date/Time: _____										
Received by: (signature) <i>James W. Cutoff</i>	Date/Time: 9/25/15 16:00pm	Received by: _____	Date/Time: _____										
Relinquished by: (signature) <i>James W. Cutoff</i>	Date/Time: 9/25/15 17:00pm	Relinquished by: _____	Date/Time: _____										
Received by: (signature) <i>James W. Cutoff</i>	Date/Time: 9/26/15 10:50	Received by: _____	Date/Time: _____										
Turnaround													
Program Information/Regulatory													
<input type="radio"/> NY Part 375 <input checked="" type="radio"/> NY Restricted Use <input type="radio"/> NY TOGS <input type="radio"/> NY Unrestricted Use <input type="radio"/> AWQ STDS <input type="radio"/> NYC Sewer Discharge <input type="radio"/> Other: _____													
Deliverables													
<input type="radio"/> Equis (1 file) <input type="radio"/> Equis (4 file) <input type="radio"/> ASP-A <input type="radio"/> ASP-B <input checked="" type="radio"/> Other: _____													

9/26/2015

Track your package or shipment with FedEx Tracking

[My Profile](#) [My FedEx Rewards](#) [Support](#) [Locations](#) [English](#) [Search](#)[Ship](#)[Track](#)[Manage](#)[Learn](#)[FedEx Office®](#)[Login](#)**IMPORTANT!**FedEx anticipates delays and disruptions in the Washington, D.C., New York, and Philadelphia metro areas because of the papal visit. [Learn More](#)**FedEx® Tracking****774599448061**Ship date :  
Fri 9/25/2015Actual delivery :  
Sat 9/26/2015 10:52 am

ALBANY, NY US

EAST LONGMEADOW, MA US

**Delivered**

Signed for by: P.BLAKE

**Travel History**

Date/Time	Activity	Location
= 9/26/2015 - Saturday		
10:52 am	Delivered	EAST LONGMEADOW, MA
8:26 am	On FedEx vehicle for delivery	WINDSOR LOCKS, CT
8:21 am	At local FedEx facility	WINDSOR LOCKS, CT
6:45 am	At destination sort facility	EAST GRANBY, CT
3:28 am	Departed FedEx location	MEMPHIS, TN
= 9/25/2015 - Friday		
11:08 pm	Arrived at FedEx location	MEMPHIS, TN
8:09 pm	Left FedEx origin facility	MENANDS, NY
6:53 pm	Picked up	MENANDS, NY
2:14 pm	Shipment information sent to FedEx	

**Shipment Facts**


Tracking number	774599448061	Service	FedEx Priority Overnight
Weight	18 lbs / 8.16 kgs	Dimensions	18x11x17 in.
Delivered To	Shipping/Receiving	Total pieces	1
Total shipment weight	18 lbs / 8.16 kgs	Shipper reference	85
Packaging	Your Packaging	Special handling section	For Saturday Delivery

[Search](#)**Customer Focus**[New Customer Center](#)[Small Business Center](#)[Service Guide](#)[Customer Support](#)**Company Information**[About FedEx](#)[Careers](#)[Investor Relations](#)**Featured Services**[FedEx One Rate](#)[FedEx SameDay](#)[FedEx Home Delivery](#)[Healthcare Solutions](#)[Online Retail Solutions](#)[Packaging Services](#)[Ancillary Clearance Services](#)**Other Resources**[FedEx Compatible](#)[Developer Resource Center](#)[FedEx Ship Manager Software](#)[FedEx Mobile](#)**Follow FedEx**[United States - English](#)

39 Spruce St.  
East Longmeadow, MA. 01028  
P: 413-525-2332  
F: 413-525-6405  
www.contestlabs.com



Page 1 of 2



## Sample Receipt Checklist

CLIENT NAME: ArcadisRECEIVED BY: PBDATE: 9.26.15

1) Was the chain(s) of custody relinquished and signed?

 Yes No

No CoC Included

2) Does the chain agree with the samples?

 Yes No

If not, explain:

3) Are all the samples in good condition?

 Yes No

If not, explain:

4) How were the samples received:

On Ice Direct from Sampling Ambient In Cooler(s) Were the samples received in Temperature Compliance of (2-6°C)?  Yes  No  N/A

Temperature °C by Temp blank

3.0

Temperature °C by Temp gun

5) Are there Dissolved samples for the lab to filter?

 Yes No

Who was notified \_\_\_\_\_ Date \_\_\_\_\_ Time \_\_\_\_\_

6) Are there any RUSH or SHORT HOLDING TIME samples?

 Yes No

Who was notified \_\_\_\_\_ Date \_\_\_\_\_ Time \_\_\_\_\_

7) Location where samples are stored:

LoganPermission to subcontract samples? Yes  No 

(Walk-in clients only) if not already approved

Client Signature: \_\_\_\_\_

8) Do all samples have the proper Acid pH: Yes  No  N/A9) Do all samples have the proper Base pH: Yes  No  N/A10) Was the PC notified of any discrepancies with the CoC vs the samples: Yes  No  N/A

### Containers received at Con-Test

	# of containers		# of containers
1 Liter Amber		8 oz amber/clear jar	
500 mL Amber		4 oz amber/clear jar	
250 mL Amber (8oz amber)		2 oz amber/clear jar	
1 Liter Plastic		Plastic Bag / Ziploc	
500 mL Plastic		SOC Kit	
250 mL plastic		Non-ConTest Container	
40 mL Vial - type listed below	<u>11</u>	Perchlorate Kit	
Colisure / bacteria bottle		Flashpoint bottle	
Dissolved Oxygen bottle		Other glass jar	
Encore		Other	

Laboratory Comments:

40 mL vials: # HCl	<u>11</u>	# Methanol	Time and Date Frozen:
Doc# 277	# Bisulfate	# DI Water	
Rev. 4 August 2013	# Thiosulfate	Unpreserved	

Page 2 of 2

Login Sample Receipt Checklist

(Rejection Criteria Listing - Using Sample Acceptance Policy)  
 Any False statement will be brought to the attention of Client

<u>Question</u>	<u>Answer (True/False)</u>	<u>Comment</u>
	T/F/NA	
1) The cooler's custody seal, if present, is intact.	N/A	
2) The cooler or samples do not appear to have been compromised or tampered with.	T	
3) Samples were received on ice.	T	
4) Cooler Temperature is acceptable.	T	
5) Cooler Temperature is recorded.	T	
6) COC is filled out in ink and legible.	T	
7) COC is filled out with all pertinent information.	T	
8) Field Sampler's name present on COC.	T	
9) There are no discrepancies between the sample IDs on the container and the COC.	T	
10) Samples are received within Holding Time.	T	
11) Sample containers have legible labels.	T	
12) Containers are not broken or leaking.	T	
13) Air Cassettes are not broken/open.	N/A	
14) Sample collection date/times are provided.	T	
15) Appropriate sample containers are used.	T	
16) Proper collection media used.	T	
17) No headspace sample bottles are completely filled.	T	
18) There is sufficient volume for all requested analyses, including any requested MS/MSDs.	T	
19) Trip blanks provided if applicable.	T	
20) VOA sample vials do not have head space or bubble is <6mm (1/4") in diameter.	T	
21) Samples do not require splitting or compositing.	T	

Who notified of False statements?

Date/Time:

Date/Time: 9-26-15

10:52

Doc #277 Rev. 4 August 2013

Log-In Technician Initials: PR

Arcadis CE, Inc.

855 Route 146

Suite 210

Clifton Park, New York 12065

Tel 518 250 7300

Fax 518 250 7301

[www.arcadis.com](http://www.arcadis.com)