

New York State Department of Environmental
Conservation

GLADDING CORDAGE SITE QUARTERLY REPORT

SITE 7-09-009

Fourth Quarter 2016

March 2017

GLADDING CORDAGE SITE QUARTERLY REPORT

Fourth Quarter 2016



Andy Vitolins, PG
Associate Vice President

Prepared for:

New York State Department of
Environmental Conservation – Division of
Environmental Remediation

625 Broadway
Albany, NY 12233-7011



Jeremy Wyckoff
Project Geologist

Prepared by:

Arcadis CE, Inc.
855 Route 146
Suite 210
Clifton Park
New York 12065
Tel 518 250 7300
Fax 518 250 7301

Our Ref.:

00266406.0000

Date:

March 2017

This document is intended only for the use of the individual or entity for which it was prepared and may contain information that is privileged, confidential and exempt from disclosure under applicable law. Any dissemination, distribution or copying of this document is strictly prohibited.

CONTENTS

Acronyms and Abbreviations.....	iii
1 introduction.....	1
2 SITE DESCRIPTION	2
3 OPERATION AND MAINTENANCE	3
3.1 Treatment Plant Upgrades.....	3
3.1.1 Variable Frequency Drive.....	3
3.1.2 Treatment Plant Controls	3
3.1.3 Geothermal Heat Exchanger.....	4
3.2 Treatment Plant Operation	4
3.3 Treatment System Sampling	4
3.3.1 Influent Sample Results	4
3.3.2 Effluent Sample Results	5
4 GROUNDWATER MONITORING PROGRAM.....	6
5 RECOMMENDATIONS.....	7
6 SUMMARY	8
7 REFERENCES.....	9

TABLES

Table 3-1	Treatment System Status and Flow Summary
Table 3-2	Groundwater Treatment System VOCs (RW-1)
Table 3-3	Groundwater Treatment System VOCs (RW-2)
Table 3-4	Groundwater Treatment System VOCs (Effluent)

FIGURES

Figure 2-1	Site Location
Figure 3-1	Treatment System Influent Sample Concentration (1,1,1-TCA)

APPENDICES

- A PLC Facsimile Reports
- B O&M Checklists
- C Analytical Reporting Forms

ACRONYMS AND ABBREVIATIONS

Amsl	above mean sea level
BTEX	Benzene, toluene, ethylbenzene, and xylene.
Ft	feet
GAP	generally accepted procedure
HZ	hertz
µg/L	micrograms per liter
NYSDEC	New York State Department of Environmental Conservation
O&M	operation and maintenance
PDB	passive diffusion bag
PLC	programmable logic controller
PCE	Tetrachloroethene
USEPA	United States Environmental Protection Agency
VFD	variable frequency drive
VOC	volatile organic compound
1,1-DCA	1,2-dichloroethane
1,1-DCE	1,2-dichloroethene
1,1,1-TCA	1,1,1-trichloroethane

1 INTRODUCTION

The New York State Department of Environmental Conservation (NYSDEC) has issued a Work Assignment (# D007618-9) to ARCADIS CE, Inc. (Arcadis) for Operation, Maintenance, and Monitoring at the Gladding Cordage Site (Site # 7-09-009). This Quarterly Report has been prepared in accordance with the NYSDEC-approved Work Plan to summarize fourth quarter 2016 site activities.

2 SITE DESCRIPTION

The Gladding Cordage Site is located on Ridge Road, South Otselic, Chenango County, New York (Figure 2-1), along the western bank of the Otselic River. The site contains an active braided wire and rope manufacturing facility that has been in operation since 1892.

3 OPERATION AND MAINTENANCE

On August 23, 2007, the NYSDEC provided a training session to Arcadis personnel on the operation and maintenance (O&M) of the groundwater treatment plant at the Gladding Cordage Site. Since then, Arcadis has maintained operation of the groundwater treatment plant. This includes the operation, maintenance, and influent/effluent sampling in accordance with the NYSDEC O&M manual (Operation and Maintenance Manual, Volume I, Gladding Cordage Site, Site 7-09-009, TAMS Consultants, Inc., 1996) (O&M Manual).

3.1 Treatment Plant Upgrades

3.1.1 Variable Frequency Drive

A variable frequency drive (VFD) was installed on January 9, 2008 to regulate the speed of the air stripper blower motor for reduced energy usage. Following the installation of the VFD, effluent samples were collected at various blower motor frequencies (speeds) to evaluate the minimum blower frequency required for the treatment plant to effectively treat groundwater extracted from the source area. Additional sampling was conducted again in February 2008 to further optimize the treatment system blower speed. Based on the results, the VFD setting was reduced to 42 hertz (HZ) beginning in March 2008. However, based on the detection of low-level VOCs in effluent samples from the treatment system, the VFD setting was subsequently increased to 46 HZ in September 2010 and was maintained at that frequency until November 19, 2014.

Based on a general trend of lower concentrations of VOCs in influent treatment system samples since September 2010, the NYSDEC authorized a reduction of the VFD frequency to 44 HZ in an attempt to further optimize treatment plant operations and reduce electric usage. The VFD frequency was lowered to 44 HZ on November 19, 2014. Following approximately one-half hour of operation, post-treatment effluent samples were collected in accordance with the Work Plan (see Section 3.2.1). Based on a review of post-treatment effluent sample data from November 19, 2014, 1,1,1 TCA and toluene were detected with the air stripper blower operating at 44 HZ, but at concentrations below the corresponding NYSDEC Class GA Standards. The NYSDEC was notified of the VOC detections and the blower motor frequency was subsequently increased to 46 HZ and has been maintained at that level since the December 18, 2014 O&M event.

3.1.2 Treatment Plant Controls

In August 2011, the NYSDEC authorized construction and installation of a new treatment plant controls system. The new control system is designed to provide remote access to treatment plant operating parameters and improve reliability of the groundwater remediation system. The treatment plant was shut down to begin repairs and upgrades on January 30, 2012 by Aztech Technologies, Inc. (Aztech). The upgrades to the treatment system controls were completed and the treatment plant resumed operation on March 22, 2012. The treatment plant functions are controlled and monitored using an EOS Research Ltd. ProControl Programmable Logic Controller (PLC). The interface software allows remote connection to the PLC via analog phone line. The PLC and interface software also allows the treatment system to be started or stopped remotely. The PLC is programmed to send a facsimile with the status of system inputs and outputs on a daily basis. If input and/or output device values exceed the defined operating parameters, an

alarm condition is set and the corresponding alarm information is sent via facsimile to the system user (i.e. Arcadis).

3.1.3 Geothermal Heat Exchanger

The NYSDEC authorized the installation of a geothermal heat exchanger to provide climate control (heating and humidity) for the treatment system building. The treatment plant was shut down to begin installation of the system on May 8, 2012 by Aztech. The geothermal heat exchanger installation and testing was completed on May 10, 2012. The heat-exchanger uses groundwater from the treatment plant as a geo-thermal energy source.

3.2 Treatment Plant Operation

As shown on PLC facsimile reports (Appendix A) and O&M Checklist and Operation Logs (Appendix B), the Gladding Cordage groundwater treatment system shut down on October 5th, 2016 due to a power interruption (AC Fail). The system was restarted remotely on October 7th, 2016. In November 2016, the treatment plant shut down on three occasions due to power interruptions on November 1st, November 15th, and November 29th. The treatment system was restarted remotely on November 6th, 2016 following the November 1st power outage; restarted remotely on November 17th following the November 15th power outage; and restarted manually on December 4th following the November 29th power outage. The system could not be restarted remotely following the November 29th power outage due to a lack of communication with the PLC. After this power outage, the PLC was rebooted and the system was restarted from the site.

The average monthly flow rates and total flow volumes for the fourth quarter 2016 operating period are summarized in Table 3-1. As shown in Table 3-1, the monthly flow rates from recovery wells RW-1 and RW-2 averaged approximately 25.6 gpm and 23.8 gpm, respectively. Based on the total flow values, approximately 5.4 million gallons of water were treated and discharged to the Otselic River between October and December 2016.

3.3 Treatment System Sampling

Influent and effluent groundwater samples were collected from the Gladding Cordage treatment system in accordance with the Work Plan and submitted to Contest Analytical following chain-of-custody protocols. Each sample was analyzed for volatile organic compounds (VOCs) by United States Environmental Protection Agency (USEPA) Method 624. Analytical Reporting Forms are provided in Appendix C.

3.3.1 Influent Sample Results

Table 3-2 and Table 3-3 summarize influent VOC sample results from recovery wells RW-1 and RW-2, respectively. Figure 3-1 provides a summary of 1,1,1-TCA concentrations in samples from recovery wells RW-1 and RW-2 since September 2007.

Table 3-2 and Figure 3-1 show that the concentrations of 1,1,1-TCA in samples from recovery well RW-1 ranged between 39 µg/L in October and 42 µg/L in November. Table 3-3 and Figure 3-1 show that the concentrations of 1,1,1-TCA in the samples from recovery well RW-2 were similar to the previous month, (35 µg/L in November and 32 µg/L in December). As shown in Tables 3-2 and 3-3, these results are

within the range of historic concentrations and exceed the corresponding NYSDEC Class GA Standard of 5 µg/L.

As shown in Tables 3-2 and 3-3, 1,1-dichloroethane (1,1-DCA) and 1,1-dichloroethene (1,1-DCE) were detected in the fourth quarter 2016 samples from recovery wells RW-1 and RW-2. As shown in Table 3-2, 1,1,2-trichloroethane was detected in recovery well RW-1 at a level that is lower than the NYSDEC Class GA Standard of 1 µg/L. As shown in Table 3-3, chloromethane (methyl chloride), a common laboratory contaminant, was also detected in the fourth quarter 2016 samples from recovery well RW-2. However, consistent with previous results, the detected concentrations were less than the applicable NYSDEC Class GA Standard of 5 µg/L.

3.3.2 Effluent Sample Results

Table 3-4 summarizes laboratory analytical data for effluent samples collected from the treatment system. As shown in Table 3-4, concentrations of both 1,1,1- TCA and chloromethane were detected in the fourth quarter 2016 effluent samples. However, the concentrations were less than the applicable NYSDEC Class GA Standard of 5 µg/L.

Based on influent sample concentrations and total flow volumes from the Gladding Cordage treatment system, approximately 1.8 pounds of VOCs were removed by the treatment system during the fourth quarter 2016. The total VOC mass removed in 2016 was approximately 6.4 pounds.

4 GROUNDWATER MONITORING PROGRAM

Groundwater samples were collected from the site during the third quarter 2016 in accordance with the Work Plan. The results of the sampling event were submitted in the third quarter 2016 Gladding Cordage Site Quarterly Report (Arcadis, 2017). The next groundwater sampling event is scheduled to take place during the fourth quarter 2017.

5 RECOMMENDATIONS

If low-level detections of 1,1,1-TCA persist in post-treatment effluent samples during the first quarter 2017, it is recommended that the air stripper be disassembled and cleaned.

6 SUMMARY

The Gladding Cordage groundwater treatment system had several interruptions during the fourth quarter 2016 due to power outages. With the exception of the one event, the system was restarted remotely following each power interruption. The average total flow through the treatment system was approximately 49 GPM.

The concentrations of VOCs detected in pre-treatment influent samples from recovery wells RW-1 and RW-2 were consistent with previous results.

The treatment successfully removes VOCs from groundwater extracted from the capture zone at the current VFD setting of 46 Hz. However, low-level detections of 1,1,1-TCA in the December effluent samples may indicate that the air stripper needs to be cleaned. The VFD setting will continue to be evaluated based on system monitoring results. Approximately 1.8 pounds of VOCs were removed by the treatment system during the fourth quarter 2016. The total VOC mass removed in 2016 was approximately 6.4 pounds.

Based on the current five-quarter sampling interval, the next groundwater monitoring event is scheduled to occur during the fourth quarter 2017.

7 REFERENCES

Arcadis, 2017, Gladding Cordage Site Quarterly Report, Third Quarter 2016, Arcadis CE, Inc., November February, 2017.

Malcolm Pirnie, 2007, Gladding Cordage Site Work Plan, Site 7-09-009, Malcolm Pirnie, Inc., June, 2007.

TAMS, 1996, Operation and Maintenance Manual, Volume I, Gladding Cordage Site. Site 7-09-009, TAMS Consultants, Inc., March 1996.

TABLES



**TABLE 3-1
TREATMENT SYSTEM STATUS AND FLOW SUMMARY
GLADDING CORDAGE SITE
SOUTH OTSELIC, NEW YORK
NYSDEC SITE NO. 7-04-009A**

Date	System Operation (days)	System On-time (% of possible days)	Well On-time		Flow Rates		Totalizer		Recovery Well Total Flows		Total System Flow (gallons)	Quarterly Totals (gallons)
			RW-1 (% possible)	RW-2 (% possible)	RW-1 (gpm)	RW-2 (gpm)	RW-1 (gallons)	RW-2 (gallons)	RW-1 (gallons)	RW-2 (gallons)		
January-16	29	94%	100%	100%	20.7	22.1	39,095,592	35,850,122	875,567	912,846	1,788,413	5,501,623
February-16	29	100%	100%	100%	21.9	22.2	39,988,542	36,759,764	892,950	909,642	1,802,592	
March-16	31	100%	100%	100%	20.6	21.4	40,931,049	37,727,875	942,507	968,111	1,910,618	
April-16	29	97%	100%	100%	21.1	21.2	41,816,850	38,633,091	885,801	905,216	1,791,017	5,088,795
May-16	29	94%	100%	100%	21.9	21.1	42,727,616	39,534,066	910,766	900,975	1,811,741	
June-16	23	77%	100%	100%	24.9	21.6	43,515,441	40,232,278	787,825	698,212	1,486,037	
July-16	26	84%	100%	100%	25.1	22.6	44,489,448	41,120,013	974,007	887,735	1,861,742	5,592,798
August-16	25	81%	100%	100%	25.8	23.2	45,398,795	41,958,714	909,347	838,701	1,748,048	
September-16	28	93%	100%	100%	25.6	23.7	46,429,587	42,910,930	1,030,792	952,216	1,983,008	
October-16	28	90%	100%	100%	25.2	23.8	47,490,153	43,894,225	1,060,566	983,295	2,043,861	5,348,351
November-16	19	63%	100%	100%	25.8	23.6	48,297,839	44,642,649	807,686	748,424	1,556,110	
December-16	26	84%	100%	100%	25.7	24.0	49,198,978	45,489,890	901,139 *	847,241 *	1,748,380	
Total Flow 2016									10,978,953	10,552,614	21,531,567	

Notes:

* - Estimated flow rate based on operational time

gpm - Gallons per minute

TABLE 3-2
GROUNDWATER TREATMENT SYSTEM VOCS (INFLUENT - RW-1)
GLADDING CORDAGE
SOUTH OTSELIC, NEW YORK
NYSDEC Site No. 7-09-009

Sample ID Sampling Date Matrix Units	NYSDEC Class GA Standard ug/L	RW-1 1/25/2016 WATER ug/L	RW-1 2/26/2016 WATER ug/L	RW-1 3/18/2016 WATER ug/L	RW-1 4/22/2016 WATER ug/L	RW-1 5/23/2016 WATER ug/L	RW-1 6/24/2016 WATER ug/L	RW-1 7/25/2016 WATER ug/L	RW-1 8/18/2016 WATER ug/L	RW-1 9/16/2016 WATER ug/L	RW-1 10/31/2016 WATER ug/L	RW-1 11/28/2016 WATER ug/L	RW-1 12/4/2016 WATER ug/L
VOCs													
1,1,1-Trichloroethane	5	38	36	36	31	34	32	35	34	36	39	42	41
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	0.25 J
1,1-Dichloroethane	5	1.8 J	1.5 J	1.4 J	1.2 J	1.3 J	1.1 J	1.5 J	1.6 J	1.6 J	1.7 J	2.1	2 J
1,1-Dichloroethene	5	0.84 J	0.79 J	0.86 J	0.84 J	0.77 J	0.69 J	0.68 J	0.89 J	0.75 J	0.91 J	1.0 J	1.2 J
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10.0 U	10 U	10 U	10.0 U	10 U	10 U	10 U	10 U	10 U	10.0 U	10 U	10 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane (Methyl Chloride)	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	0.77 J	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Toluene	5	1.0 U	1.0 U	2.0 U	1.0 U	1.0 U	2.0 U	2.0 U	2.0 U	2.0 U	1.0 U	1.0 U	2.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	5.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Total VOCs		40.6	38.3	38.3	33.0	36.1	33.8	38.0	36.5	38.4	41.6	45.1	44.5

- Concentration exceeds corresponding NYSD
Class GA Standard.
U - Not detected at the indicated concentration
J - Estimated concentration.

TABLE 3-3
GROUNDWATER TREATMENT SYSTEM VOCS (INFLUENT - RW-2)
GLADDING CORDAGE
SOUTH OTSELIC, NEW YORK
NYSDEC Site No. 7-09-009

Sample ID Sampling Date Matrix Units	NYSDEC Class GA Standard ug/L	RW-2 1/25/2016 WATER ug/L	RW-2 2/26/2016 WATER ug/L	RW-2 3/18/2016 WATER ug/L	RW-2 4/22/2016 WATER ug/L	RW-2 5/23/2016 WATER ug/L	RW-2 6/24/2016 WATER ug/L	RW-2 7/25/2016 WATER ug/L	RW-2 8/18/2016 WATER ug/L	RW-2 9/16/2016 WATER ug/L	RW-2 10/31/2016 WATER ug/L	RW-2 11/28/2016 WATER ug/L	RW-2 12/4/2016 WATER ug/L
VOCs													
1,1,1-Trichloroethane	5	32	29	29	25	28	33	28	29	35	33	35	32
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	0.86 J	0.62 J	0.62 J	0.53 J	0.56 J	0.58 J	0.66 J	0.70 J	0.77 J	0.78 J	0.89 J	0.82 J
1,1-Dichloroethene	5	0.64 J	0.56 J	0.66 J	0.60 J	0.62 J	0.58 J	0.48 J	0.72 J	0.82 J	0.78 J	0.87 J	0.86 J
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane (Methyl Chloride)	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	0.59 J	2.0 U	2.0 U	2.0 U	2.4	0.57 J
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Toluene	5	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	5.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Total VOCs		33.5	30.2	30.3	26.1	29.2	34.2	29.7	30.4	36.6	34.6	39.2	34.3

- Concentration exceeds corresponding NYSDEC
Class GA Standard.
U - Not detected at the indicated concentration
J - Estimated concentration.

TABLE 3-4
GROUNDWATER TREATMENT SYSTEM VOCS (EFFLUENT)
GLADDING CORDAGE
SOUTH OTSELIC, NEW YORK
NYSDEC Site No. 7-09-009

Sample ID Sampling Date Matrix Units	NYSDEC GA Standard ug/L	EFF(46HZ) 1/25/2016 WATER ug/L	EFF(46HZ) 2/26/2016 WATER ug/L	EFF(46HZ) 3/18/2016 WATER ug/L	EFF(46HZ) 4/22/2016 WATER ug/L	EFF(46HZ) 5/23/2016 WATER ug/L	EFF(46HZ) 6/24/2016 WATER ug/L	EFF(46HZ) 7/25/2016 WATER ug/L	EFF(46HZ) 8/18/2016 WATER ug/L	EFF(46HZ) 9/16/2016 WATER ug/L	EFF(46HZ) 10/31/2016 WATER ug/L	EFF(46HZ) 11/28/2016 WATER ug/L	EFF(46HZ) 12/4/2016 WATER ug/L
VOCs													
1,1,1-Trichloroethane	5	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	0.15 J
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane (Methyl Chloride)	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	1.0 J	2.0 U	2.0 U	2.0 U	2.3	0.73 J
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Toluene	5	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	5.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Total VOCs													


Notes
U - Not detected at the indicated concentration.
J - Estimated concentration.

FIGURES



Figure 2-1 Site Location


Gladding Cordage Site
South Otselic, New York
NYSDEC Site 7-09-009



0 2,000 ft

Figure 3-1
Treatment System Influent Sample Concentrations (1,1,1-TCA)

Gladding Cordage Site
NYSDEC Site Number 7-09-009



APPENDIX A

PLC Facsimile Reports





ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/01/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 15:02:21 ON 09/14/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 24.9	GPM TOTAL FLOW is 46466033	GAL	
W2_FLO is 23.1	GPM TOTAL FLOW is 42944584	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 467289	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.84	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.78	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 31.07	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.07	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 61.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/02/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 15:02:21 ON 09/14/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.3	GPM TOTAL FLOW is 46502440	GAL	
W2_FLO is 23.5	GPM TOTAL FLOW is 42978279	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 467368	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.91	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.84	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 31.07	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.17	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 62.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/03/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 15:02:21 ON 09/14/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.4	GPM TOTAL FLOW is 46538827	GAL	
W2_FLO is 23.3	GPM TOTAL FLOW is 43011970	GAL	
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 467434	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.82	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.74	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 30.95	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.17	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 63.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/04/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 15:02:21 ON 09/14/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.4	GPM TOTAL FLOW is 46575189	GAL	
W2_FLO is 23.5	GPM TOTAL FLOW is 43045646	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 467505	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.79	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.71	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 31.22	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.15	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 62.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/05/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 15:02:21 ON 09/14/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.1	GPM TOTAL FLOW is 46611531	GAL	
W2_FLO is 23.2	GPM TOTAL FLOW is 43079310	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 467574	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.72	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 31.36	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.20	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 60.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ALARM Fax Report

EOS Research Ltd.

ProControl Series II+

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 09:34:31 ON 10/05/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P19 : LAST SHUTDOWN @ 15:02:21 ON 09/14/2016 BY ASBVFD
FAX REPORT INITIATED BY PROCESS 18

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is ON	E_STOP is OFF		

Discrete Outputs:


W1_GO is OFF	W2_GO is OFF	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 46616928	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 43084310	GAL	
ASBPRS is 0.0	IWC LIMITS are L: 5.0	IWC H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 467586	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI H: 20.0	PSI
HP_AMP is 0.00	AMP LIMITS are L: 0.00	AMP H:	AMP
W1_AMP is 0.00	AMP LIMITS are L: 0.00	AMP H: 10.00	AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP H: 10.00	AMP
W1_LVL is 0.00	FT LIMITS are L: 8.00	FT H: 28.00	FT
W2_LVL is 0.00	FT LIMITS are L: 9.00	FT H: 52.00	FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI H: 100.0	PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI H: 100.0	PSI
INTEMP is 0.0	DEG LIMITS are L: 42.0	DEG H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ALARM Fax Report

EOS Research Ltd.

ProControl Series II+

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 09:41:00 ON 10/05/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

SHUTD P02 : LAST SHUTDOWN @ 15:02:21 ON 09/14/2016 BY ASBVFD
FAX REPORT INITIATED BY PROCESS 19

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is ON	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 46616928	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 43084310	GAL	
ASBPRS is 0.0	IWC LIMITS are L: 5.0	IWC H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 467586	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI H: 20.0	PSI
HP_AMP is 0.00	AMP LIMITS are L: 0.00	AMP H:	AMP
W1_AMP is 0.00	AMP LIMITS are L: 0.00	AMP H: 10.00	AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP H: 10.00	AMP
W1_LVL is 0.00	FT LIMITS are L: 8.00	FT H: 28.00	FT
W2_LVL is 0.00	FT LIMITS are L: 9.00	FT H: 52.00	FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI H: 100.0	PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI H: 100.0	PSI
INTEMP is 0.0	DEG LIMITS are L: 42.0	DEG H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/06/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

MANUAL : LAST SHUTDOWN @ 09:44:32 ON 10/05/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is OFF	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 46616928	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 43084310	GAL	
ASBPRS is 0.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 467586	GAL	
HP_PRS is 0.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.07	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 0.01	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.22	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.59	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 60.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/07/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

MANUAL : LAST SHUTDOWN @ 09:44:32 ON 10/05/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is OFF	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 46616928	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 43084310	GAL	
ASBPRS is 0.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 467586	GAL	
HP_PRS is 0.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 0.01	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.15	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.55	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 60.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/08/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 09:44:32 ON 10/05/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.5	GPM TOTAL FLOW is 46646064	GAL	
W2_FLO is 23.6	GPM TOTAL FLOW is 43111352	GAL	
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 467639	GAL	
HP_PRS is 1.5	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.80	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.73	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 30.89	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.07	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 62.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/09/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 09:44:32 ON 10/05/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.6	GPM TOTAL FLOW is 46682776	GAL	
W2_FLO is 24.0	GPM TOTAL FLOW is 43145459	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 467716	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.79	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.73	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 30.94	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.09	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 61.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/15/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 09:44:32 ON 10/05/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.2	GPM TOTAL FLOW is 46902362	GAL	
W2_FLO is 23.8	GPM TOTAL FLOW is 43349393	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 468362	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.90	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.83	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 31.05	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.01	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 55.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/16/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 09:44:32 ON 10/05/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.5	GPM	TOTAL FLOW is 46938972	GAL		
W2_FLO is 23.5	GPM	TOTAL FLOW is 43383400	GAL		
ASBPRS is 10.5	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 468458	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.05	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.98	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.90	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 30.81	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 54.94	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.5	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.7	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 62.0	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/17/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 09:44:32 ON 10/05/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.5	GPM TOTAL FLOW is 46975560	GAL	
W2_FLO is 23.6	GPM TOTAL FLOW is 43417383	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 468524	GAL	
HP_PRS is 1.4	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.84	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.76	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 30.66	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 54.96	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 63.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/18/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 09:44:32 ON 10/05/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.7	GPM TOTAL FLOW is 47012111	GAL	
W2_FLO is 23.5	GPM TOTAL FLOW is 43451345	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 2.37	GPM TOTAL FLOW is 468594	GAL	
HP_PRS is 8.6	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 5.47	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.75	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.68	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 30.54	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.03	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 61.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/19/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 09:44:32 ON 10/05/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.3	GPM TOTAL FLOW is 47048623	GAL	
W2_FLO is 23.3	GPM TOTAL FLOW is 43485275	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 468639	GAL	
HP_PRS is 1.4	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.81	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.75	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 30.67	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.09	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 63.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/20/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 09:44:32 ON 10/05/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.3	GPM	TOTAL FLOW is 47085187	GAL		
W2_FLO is 22.9	GPM	TOTAL FLOW is 43519235	GAL		
ASBPRS is 10.5	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 468727	GAL		
HP_PRS is 1.4	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.05	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.84	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.78	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 30.88	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.11	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.7	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.6	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTMP is 61.6	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/20/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 09:44:32 ON 10/05/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 25.3	GPM TOTAL FLOW is 47085187	GAL	
W2_FLO is 22.9	GPM TOTAL FLOW is 43519235	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 468727	GAL	
HP_PRS is 1.4	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.84	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.78	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 30.88	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.11	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 61.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/20/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 09:44:32 ON 10/05/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.3	GPM TOTAL FLOW is 47085187	GAL	
W2_FLO is 22.9	GPM TOTAL FLOW is 43519235	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 468727	GAL	
HP_PRS is 1.4	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.84	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.78	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 30.88	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.11	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 61.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/21/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 09:44:32 ON 10/05/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.6	GPM TOTAL FLOW is 47121798	GAL	
W2_FLO is 23.9	GPM TOTAL FLOW is 43553203	GAL	
ASBPRS is 10.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 468805	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.78	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.72	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 31.94	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.50	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 63.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/22/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 09:44:32 ON 10/05/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.5	GPM TOTAL FLOW is 47158732	GAL	
W2_FLO is 23.8	GPM TOTAL FLOW is 43587415	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 468912	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.76	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.71	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.50	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.29	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 59.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/23/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 09:44:32 ON 10/05/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.3	GPM TOTAL FLOW is 47195709	GAL	
W2_FLO is 23.6	GPM TOTAL FLOW is 43621643	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 469045	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.81	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.76	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.39	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.96	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 57.2	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/24/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 09:44:32 ON 10/05/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.4	GPM TOTAL FLOW is 47232724	GAL	
W2_FLO is 23.8	GPM TOTAL FLOW is 43655904	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 469155	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.72	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.65	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.81	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.16	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 58.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/25/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 09:44:32 ON 10/05/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.5	GPM TOTAL FLOW is 47269586	GAL	
W2_FLO is 23.3	GPM TOTAL FLOW is 43690023	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 469291	GAL	
HP_PRS is 1.4	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 1.13	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.70	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.78	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 58.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/27/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 09:44:32 ON 10/05/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 24.9	GPM TOTAL FLOW is 47343127	GAL	
W2_FLO is 23.4	GPM TOTAL FLOW is 43758093	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	CPM TOTAL FLOW is 469568	CAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.50	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.31	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 56.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/28/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 09:44:32 ON 10/05/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.8	GPM TOTAL FLOW is 47379885	GAL	
W2_FLO is 23.5	GPM TOTAL FLOW is 43792109	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 469726	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.65	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.87	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.82	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 56.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II

EOS Research Ltd. Fax Report

J
JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 10/31/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPEGO is ON	

Analog Inputs:

ASBPRS is 00.1	IWC LIMITS are L: 50.0	IWC H: 50.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 470149	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP H:	AMP
W1_AMP is 4.62	AMP LIMITS are L: 0.00	AMP H: 10.00	AMP
W2_AMP is 4.58	AMP LIMITS are L: 0.00	AMP H: 10.00	AMP
W1_TVT is 32.65	FT LIMITS are L: 8.00	FT H: 28.00	FT
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI H: 100.0	PSI
INTEMP is 57.4	DEG LIMITS are L: 42.0	DEG H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/01/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 09:44:32 ON 10/05/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.3	GPM TOTAL FLOW is 47526881	GAL	
W2_FLO is 23.8	GPM TOTAL FLOW is 43928249	GAL	
ASBP RS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 470406	GAL	
HP_PRS is 1.5	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.69	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.40	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 50.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN




ALARM Fax Report

EOS Research Ltd.

ProControl Series 11+

To:

JEREMY WYCKOFF



SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

SHUTD : LAST SHUTDOWN @ 09:44:32 ON 10/05/2016 BY ACFAIL
FAX REPORT INITIATED BY PROCESS 29

W1_CTR is OFF	W2_CTR is OFF	ASBVED is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is OFF	W2_GO is OFF	ASB_GO is ON	SMP_GO is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 0.0	GPM	TOTAL FLOW is 47537650	GAL		
W2_FLO is 0.0	GPM	TOTAL FLOW is 43938228	GAL		
ASPRS is 0.5	AMP	LIMITS are L: 5.0	AMP	H: 30.0	AMP
W1_AMP is 0.01	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 0.00	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.38	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 57.37	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 0.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W1_PRS is 0.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI

Analog Outputs:

ASBSPD 0.0 PCT MAN



ALARM Fax Report

EOS Research Ltd.

ProControl Series II+

*****W*****

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 13:02:58 ON 11/01/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E STOP is OFF		
W1_GO is OFF	W2_GO is OFF	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is ON	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMGO is ON	

Analog Inputs:

W2_FLO is 0.0	GPM TOTAL FLOW is 43730220	GAL	
ASBPRS is 0.5	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 470475	GAL	
HP_PRS is 0.8	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.06	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 0.01	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTMP is 58.4	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

FCS Research Ltd

Fox Report

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/02/2016

MANUAL : LAST SHUTDOWN @ 13:12:58 ON 11/01/2016 BY ASBVFD

Discrete Inputs:


W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
000 000 000	000 000 000	000 000 000	000 000 000

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is ON	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPEGO is OFF	

W1_FLO is 0.0	GPM TOTAL FLOW is 47537650	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 43938228	GAL	
ASBPRS is 0.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 470475	GAL	
HP_PRS is 0.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.07	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_LIM is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_LVL is 57.67	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 53.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/02/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

MANUAL : LAST SHUTDOWN @ 13:12:58 ON 11/01/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_IO is OFF	FTRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is ON	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is OFF	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 47537650	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 43938228	GAL	
ASBPRS is 0.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 470475	GAL	
HP_PRS is 0.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.07	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.38	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.67	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 53.8	DEC LIMITS are L: 42.0	DEC	H: 130.0 DEC

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II

EOS Research Ltd. Fax Report



JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/03/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is ON	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is OFF	

Analog Inputs:

ASBPRS is 0.2	LWC LIMITS are L: 5.0	LWC H: 30.0	LWC
HP_FLO is 0.00	GPM TOTAL FLOW is 470475	GAL	
HP_PRS is 0.9	PSI LIMITS are L: -2.0	PSI H: 20.0	PSI
HP_AMP is 0.07	AMP LIMITS are L: 0.00	AMP H:	AMP
W1_AMP is 0.01	AMP LIMITS are L: 0.00	AMP H: 10.00	AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP H: 10.00	AMP
W1_LYL is 34.16	FT LIMITS are L: 0.00	FT H: 20.00	FT
W2_PRS is 0.0	PSI LIMITS are L: 0.00	PSI H: 10.00	PSI
INTEMP is 57.3	DEG LIMITS are L: 42.0	DEG H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/04/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

MANUAL : LAST SHUTDOWN @ 13:12:58 ON 11/01/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is ON	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is OFF	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 47537650	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 43938228	GAL	
ASBPRS is 0.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 470475	GAL	
HP_PRS is 0.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.07	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 0.01	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.15	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 58.43	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 54.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/05/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

MANUAL : LAST SHUTDOWN @ 13:12:58 ON 11/01/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is ON	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is OFF	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 47537650	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 43938228	GAL	
ASBPRS is 0.1	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 470475	GAL	
HP_PRS is 0.9	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 1.11	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 0.01	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.95	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 58.15	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 51.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/06/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

MANUAL : LAST SHUTDOWN @ 13:12:58 ON 11/01/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is ON	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is OFF	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 47537650	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 43938228	GAL	
ASBPRS is 0.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 470475	GAL	
HP_PRS is 0.9	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 1.12	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 0.01	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.84	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.98	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 53.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/07/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 13:12:58 ON 11/01/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.8	GPM TOTAL FLOW is 47554584	GAL	
W2_FLO is 23.6	GPM TOTAL FLOW is 43953776	GAL	
ASBPRS is 11.0	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 470481	GAL	
HP_PRS is 1.4	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.06	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.69	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.02	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.53	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 50.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/08/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 13:12:58 ON 11/01/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.6	GPM TOTAL FLOW is 47591594	GAL	
W2_FLO is 23.5	GPM TOTAL FLOW is 43987759	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 470644	GAL	
HP_PRS is 1.4	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.67	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.70	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.36	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 51.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/09/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 13:12:58 ON 11/01/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.7	GPM	TOTAL FLOW is 47628491	GAL		
W2_FLO is 23.6	GPM	TOTAL FLOW is 44021699	GAL		
ASBPRS is 10.5	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 470814	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.68	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.61	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.25	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.23	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.5	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.8	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 56.9	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/10/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 13:12:58 ON 11/01/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.8	GPM	TOTAL FLOW is 47665411	GAL		
W2_FLO is 23.9	GPM	TOTAL FLOW is 44055611	GAL		
ASBPRS is 10.8	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 471038	GAL		
HP_PRS is 1.4	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.68	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.60	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.37	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.23	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.7	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.9	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 51.3	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/11/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 13:12:58 ON 11/01/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.0	GPM TOTAL FLOW is 47702256	GAL	
W2_FLO is 24.0	GPM TOTAL FLOW is 44089504	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 471250	GAL	
HP_PRS is 1.4	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.69	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.63	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 31.84	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.00	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 55.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/12/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 13:12:58 ON 11/01/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.5	GPM TOTAL FLOW is 47739045	GAL	
W2_FLO is 23.7	GPM TOTAL FLOW is 44123393	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 471473	GAL	
HP_PRS is 1.5	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.67	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.48	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.08	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 51.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/13/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 13:12:58 ON 11/01/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.2	GPM TOTAL FLOW is 47775829	GAL	
W2_FLO is 23.5	GPM TOTAL FLOW is 44157280	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 471733	GAL	
HP_PRS is 1.4	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.72	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.27	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.04	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 50.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/14/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 13:12:58 ON 11/01/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.9	GPM	TOTAL FLOW is 47812591	GAL		
W2_FLO is 23.2	GPM	TOTAL FLOW is 44191174	GAL		
ASBPRS is 10.7	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 2.16	GPM	TOTAL FLOW is 471989	GAL		
HP_PRS is 1.6	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.07	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.69	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.64	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.16	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.98	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.7	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.9	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 48.6	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/15/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO : LAST SHUTDOWN @ 13:12:58 ON 11/01/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.4	GPM TOTAL FLOW is 47849282	GAL	
W2_FLO is 23.0	GPM TOTAL FLOW is 44225024	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 472217	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.64	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.08	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.87	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 52.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ALARM Fax Report

EOS Research Ltd.

ProControl Series II+

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 21:48:11 ON 11/15/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P19 : LAST SHUTDOWN @ 13:12:58 ON 11/01/2016 BY ASBVFD
FAX REPORT INITIATED BY PROCESS 18

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is ON	E_STOP is OFF		

Discrete Outputs:


W1_GO is OFF	W2_GO is OFF	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 47873402	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 44247273	GAL	
ASBPRS is 0.0	IWC LIMITS are L: 5.0	IWC H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 472330	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI H: 20.0	PSI
HP_AMP is 0.00	AMP LIMITS are L: 0.00	AMP H:	AMP
W1_AMP is 0.00	AMP LIMITS are L: 0.00	AMP H: 10.00	AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP H: 10.00	AMP
W1_LVL is 0.00	FT LIMITS are L: 8.00	FT H: 28.00	FT
W2_LVL is 0.00	FT LIMITS are L: 9.00	FT H: 52.00	FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI H: 100.0	PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI H: 100.0	PSI
INTEMP is 0.0	DEG LIMITS are L: 42.0	DEG H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ALARM Fax Report

EOS Research Ltd.

ProControl Series II+

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 21:54:00 ON 11/15/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

SHUTD P02 : LAST SHUTDOWN @ 13:12:58 ON 11/01/2016 BY ASBVFD
FAX REPORT INITIATED BY PROCESS 19

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 0.0	GPM	TOTAL FLOW is 47873402	GAL		
W2_FLO is 0.0	GPM	TOTAL FLOW is 44247273	GAL		
ASBPRS is 0.2	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 472330	GAL		
HP_PRS is 0.9	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.06	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 0.01	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 0.00	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.89	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 57.20	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 0.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 0.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 55.2	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/16/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

MANUAL : LAST SHUTDOWN @ 21:58:11 ON 11/15/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is OFF	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 47873402	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 44247273	GAL	
ASBPRS is 0.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 472330	GAL	
HP_PRS is 0.9	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.07	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 0.01	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.74	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.27	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 53.2	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/17/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

MANUAL : LAST SHUTDOWN @ 21:58:11 ON 11/15/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is OFF	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 47873402	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 44247273	GAL	
ASBPRS is 0.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 472330	GAL	
HP_PRS is 0.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.07	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 0.01	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.88	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.24	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 53.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/18/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 21:58:11 ON 11/15/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.3	GPM TOTAL FLOW is 47895249	GAL	
W2_FLO is 24.0	GPM TOTAL FLOW is 44267595	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 472489	GAL	
HP_PRS is 1.5	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.11	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.85	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 51.2	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/19/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 21:58:11 ON 11/15/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.7	GPM TOTAL FLOW is 47932083	GAL	
W2_FLO is 23.8	GPM TOTAL FLOW is 44301895	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 472707	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.69	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.64	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 31.89	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.77	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 52.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/20/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 21:58:11 ON 11/15/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.6	GPM TOTAL FLOW is 47968883	GAL	
W2_FLO is 24.3	GPM TOTAL FLOW is 44336179	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 472911	GAL	
HP_PRS is 1.4	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.69	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.65	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 31.51	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.79	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 52.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/21/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 21:58:11 ON 11/15/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.5	GPM TOTAL FLOW is 48005710	GAL	
W2_FLO is 23.7	GPM TOTAL FLOW is 44370466	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 2.32	GPM TOTAL FLOW is 473232	GAL	
HP_PRS is 8.5	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 7.99	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.65	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 31.58	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.87	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 48.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/22/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 21:58:11 ON 11/15/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.6	GPM TOTAL FLOW is 48042513	GAL	
W2_FLO is 24.0	GPM TOTAL FLOW is 44404753	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 473561	GAL	
HP_PRS is 5.1	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 4.71	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.68	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.63	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.00	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.91	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 49.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/23/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 21:58:11 ON 11/15/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.5	GPM	TOTAL FLOW is 48079329	GAL		
W2_FLO is 23.9	GPM	TOTAL FLOW is 44439050	GAL		
ASBPRS is 11.0	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 473885	GAL		
HP_PRS is 1.4	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.65	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.61	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.36	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.93	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.8	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 5.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTMP is 50.5	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/24/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 21:58:11 ON 11/15/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.7	GPM	TOTAL FLOW is 48116120	GAL	
W2_FLO is 23.6	GPM	TOTAL FLOW is 44473362	GAL	
ASBPRS is 10.8	IWC	LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 2.34	GPM	TOTAL FLOW is 474188	GAL	
HP_PRS is 8.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 7.31	AMP	LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.66	AMP	LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.62	AMP	LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.28	FT	LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.85	FT	LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.8	PSI	LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 51.2	DEG	LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/25/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 21:58:11 ON 11/15/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.1	GPM TOTAL FLOW is 48152895	GAL	
W2_FLO is 23.8	GPM TOTAL FLOW is 44507662	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 474470	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.71	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.65	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.30	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.87	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 52.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/26/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 21:58:11 ON 11/15/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.5	GPM TOTAL FLOW is 48189674	GAL	
W2_FLO is 23.8	GPM TOTAL FLOW is 44541931	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 474726	GAL	
HP_PRS is 1.4	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.77	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.72	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.43	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.06	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 53.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/27/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 21:58:11 ON 11/15/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.7	GPM TOTAL FLOW is 48226516	GAL	
W2_FLO is 23.9	GPM TOTAL FLOW is 44576223	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 475000	GAL	
HP_PRS is 1.4	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.74	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.68	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.61	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.27	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 52.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/28/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 21:58:11 ON 11/15/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.1	GPM TOTAL FLOW is 48263423	GAL	
W2_FLO is 23.9	GPM TOTAL FLOW is 44610524	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 475278	GAL	
HP_PRS is 1.6	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.71	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.65	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.80	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.42	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 52.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ALARM Fax Report

EOS Research Ltd.

ProControl Series II+

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 04:31:05 ON 11/29/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P12 : LAST SHUTDOWN @ 21:58:11 ON 11/15/2016 BY ACFAIL
FAX REPORT INITIATED BY PROCESS 11

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is ON	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 0.0	GPM	TOTAL FLOW is 48297839	GAL		
W2_FLO is 0.0	GPM	TOTAL FLOW is 44642649	GAL		
ASBPRS is 0.7	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 475300	GAL		
HP_PRS is 0.5	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.07	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 0.01	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 0.00	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.51	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 57.69	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 0.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 0.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 68.3	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ALARM Fax Report

EOS Research Ltd.

ProControl Series II+

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 04:38:00 ON 11/29/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

SHUTD P02 : LAST SHUTDOWN @ 21:58:11 ON 11/15/2016 BY ACFAIL
FAX REPORT INITIATED BY PROCESS 12

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is OFF	W2_GO is OFF	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is ON	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 0.0	GPM	TOTAL FLOW is 48297839	GAL		
W2_FLO is 0.0	GPM	TOTAL FLOW is 44642649	GAL		
ASBPRS is 0.2	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 475300	GAL		
HP_PRS is 0.5	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.06	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 0.01	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 0.00	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.75	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 57.84	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 0.2	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 0.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 67.2	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/29/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

MANUAL : LAST SHUTDOWN @ 04:41:07 ON 11/29/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is ON	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is OFF	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 48297839	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 44642649	GAL	
ASBPRS is 0.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 475300	GAL	
HP_PRS is 0.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 0.01	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.69	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.86	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 67.2	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 11/30/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

MANUAL : LAST SHUTDOWN @ 04:41:07 ON 11/29/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is ON	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is OFF	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 48297839	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 44642649	GAL	
ASBPRS is 0.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 475300	GAL	
HP_PRS is 0.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 0.01	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.43	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 58.74	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 71.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/01/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

MANUAL : LAST SHUTDOWN @ 04:41:07 ON 11/29/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is ON	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is OFF	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 48297839	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 44642649	GAL	
ASBPRS is 0.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 475300	GAL	
HP_PRS is 0.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 0.01	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.75	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 59.44	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 71.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/02/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

MANUAL : LAST SHUTDOWN @ 04:41:07 ON 11/29/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is ON	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is OFF	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 48297839	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 44642649	GAL	
ASBPRS is 0.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 475300	GAL	
HP_PRS is 0.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 0.01	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 36.04	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 59.44	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 67.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/03/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

MANUAL : LAST SHUTDOWN @ 04:41:07 ON 11/29/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is ON	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is OFF	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 48297839	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 44642649	GAL	
ASBPRS is 0.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 475300	GAL	
HP_PRS is 0.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 0.01	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.73	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 58.89	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 66.2	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/04/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

MANUAL : LAST SHUTDOWN @ 04:41:07 ON 11/29/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is ON	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is OFF	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 48297839	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 44642649	GAL	
ASBPRS is 0.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 475300	GAL	
HP_PRS is 0.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 0.01	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.67	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 58.60	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 65.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/05/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 04:41:07 ON 11/29/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.4	GPM TOTAL FLOW is 48325268	GAL	
W2_FLO is 24.1	GPM TOTAL FLOW is 44668452	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 475300	GAL	
HP_PRS is 1.4	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.83	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.79	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.02	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.91	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 67.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/06/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 04:41:07 ON 11/29/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.9	GPM TOTAL FLOW is 48362049	GAL	
W2_FLO is 24.1	GPM TOTAL FLOW is 44703042	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 475300	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.72	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.67	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.11	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.84	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 67.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/07/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 04:41:07 ON 11/29/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.1	GPM TOTAL FLOW is 48398753	GAL	
W2_FLO is 24.0	GPM TOTAL FLOW is 44737572	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 475300	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.72	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.68	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.80	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.67	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 68.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/08/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 04:41:07 ON 11/29/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.6	GPM TOTAL FLOW is 48435449	GAL	
W2_FLO is 24.2	GPM TOTAL FLOW is 44772114	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 475300	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.73	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.68	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.84	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.72	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 67.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/09/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 04:41:07 ON 11/29/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.7	GPM TOTAL FLOW is 48472139	GAL	
W2_FLO is 24.2	GPM TOTAL FLOW is 44806585	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 475301	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.68	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.65	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.88	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.63	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 64.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/10/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 04:41:07 ON 11/29/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.5	GPM TOTAL FLOW is 48508836	GAL	
W2_FLO is 23.5	GPM TOTAL FLOW is 44841054	GAL	
ASBPRS is 11.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 475301	GAL	
HP_PRS is 1.4	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.68	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.64	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.06	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.61	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 62.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/11/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 04:41:07 ON 11/29/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.6	GPM TOTAL FLOW is 48545545	GAL	
W2_FLO is 23.7	GPM TOTAL FLOW is 44875536	GAL	
ASBPRS is 11.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 475327	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.71	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.15	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.55	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 58.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/12/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 04:41:07 ON 11/29/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.8	GPM TOTAL FLOW is 48582265	GAL	
W2_FLO is 23.9	GPM TOTAL FLOW is 44909989	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 475327	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.72	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.68	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.39	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.21	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 65.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/13/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 04:41:07 ON 11/29/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.5	GPM TOTAL FLOW is 48618904	GAL	
W2_FLO is 23.4	GPM TOTAL FLOW is 44944381	GAL	
ASBPRS is 11.1	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 475327	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.70	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.75	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.44	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 62.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/14/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 04:41:07 ON 11/29/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.7	GPM TOTAL FLOW is 48655431	GAL	
W2_FLO is 24.0	GPM TOTAL FLOW is 44978757	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 475327	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.68	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.59	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.27	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 65.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/15/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 04:41:07 ON 11/29/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.5	GPM TOTAL FLOW is 48691951	GAL	
W2_FLO is 23.8	GPM TOTAL FLOW is 45013144	GAL	
ASBPRS is 11.1	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 475354	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.68	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.30	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.29	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 58.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/16/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 04:41:07 ON 11/29/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.3	GPM TOTAL FLOW is 48728537	GAL	
W2_FLO is 24.1	GPM TOTAL FLOW is 45047541	GAL	
ASBPRS is 11.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 475451	GAL	
HP_PRS is 1.5	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.64	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.66	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.40	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 54.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 12/17/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 04:41:07 ON 11/29/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.3	GPM TOTAL FLOW is 48765096	GAL	
W2_FLO is 23.5	GPM TOTAL FLOW is 45081959	GAL	
ASBPRS is 11.1	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 475524	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.64	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.60	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.25	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 60.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/10/2017
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 04:41:07 ON 11/29/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.6	GPM TOTAL FLOW is 49641925	GAL	
W2_FLO is 23.3	GPM TOTAL FLOW is 45908059	GAL	
ASBPRS is 11.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 476342	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.68	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.63	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.39	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.67	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 55.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN

APPENDIX B

O&M Checklists



Gladding Cordage
South Otselic, New York
NYSDEC Site #709009

Date 10/31/2016
Inspector L. Whalen
Time 7:30

Treatment System Operation		Alarms	
System On (Y/N)	Yes	A/C Fail (Y/N)	No
RW-1 On (Y/N)	Yes	RW-1 (Y/N)	No
RW-2 On (Y/N)	Yes	RW-2 (Y/N)	No
Blower On (Y/N)	Yes	Blower Pressure (Y/N)	No
Sump Pump On (Y/N)	No	Sump Level (Y/N)	No

Recovery Wells	RW-1	RW-2
Flow Rate (GPM)	25.2	23.8
Total Flow (Gallons)	47490153	43894225
Water Level (Feet Above Probe)	32.67	56.48
Probe Depth (Feet BTOC)	40.00	65.00

Air Stripper			
Blower VFD Setting (Hertz)	46	Intake/Exhaust Piping OK? (Y/N)	Yes
System Pressure (inches water)	10.7	Water Leaks (Y/N)	No
Influent/Effluent Piping OK? (Y/N)	Yes	Water Temperature (°F)	53

Heat Exchanger			
Heat (On/Off)	On	Building Temperature (°F)	70
Heat Exchanger Flow (GPM)	0.0	Heat Exchanger Pressure (PSI)	1.3

General Building/Site			
Building Condition OK? (Y/N)	Yes	Circuit Breakers Checked (Y/N)	Yes
Grass Mowed (Y/N)	Yes	Outfall Condition OK? (Y/N)	Yes
Monitoring Wells OK? (Y/N)	Yes	Samples Collected (Y/N)	Yes

Notes:			
Sampled:	RW-1	705	
	RW-2	710	
	EFF 46 HZ	715	
System Chec	745		
Trimmed gra	800		
(last time for the season)			
Turned ceiling heater on Low			

Gladding Cordage
South Otselic, New York
NYSDEC Site #709009

Date 11/28/2016
Inspector L. Whalen
Time 6:20

Treatment System Operation		Alarms	
System On (Y/N)	Yes	A/C Fail (Y/N)	No
RW-1 On (Y/N)	Yes	RW-1 (Y/N)	No
RW-2 On (Y/N)	Yes	RW-2 (Y/N)	No
Blower On (Y/N)	Yes	Blower Pressure (Y/N)	No
Sump Pump On (Y/N)	No	Sump Level (Y/N)	No

Recovery Wells	RW-1	RW-2
Flow Rate (GPM)	25.8	23.6
Total Flow (Gallons)	48297839	44642649
Water Level (Feet Above Probe)	32.82	56.42
Probe Depth (Feet BTOC)	40.00	65.00

Air Stripper			
Blower VFD Setting (Hertz)	46	Intake/Exhaust Piping OK? (Y/N)	Yes
System Pressure (inches water)	10.7	Water Leaks (Y/N)	No
Influent/Effluent Piping OK? (Y/N)	Yes	Water Temperature (°F)	52

Heat Exchanger			
Heat (On/Off)	On	Building Temperature (°F)	67
Heat Exchanger Flow (GPM)	0.0	Heat Exchanger Pressure (PSI)	1.4

General Building/Site			
Building Condition OK? (Y/N)	Yes	Circuit Breakers Checked (Y/N)	Yes
Grass Mowed (Y/N)	Snow	Outfall Condition OK? (Y/N)	Yes
Monitoring Wells OK? (Y/N)	Yes	Samples Collected (Y/N)	Yes

Notes:			
Sampled:	RW-1	605	
	RW-2	610	
	EFF 46 HZ	615	
System Check:	620		
(Turned ceiling heater up to Med.)	28 ° out today		

Gladding Cordage
South Otselic, New York
NYSDEC Site #709009

Date 12/4/2016
Inspector LDW/DSW
Time 11:25

Treatment System Operation		Alarms	
System On (Y/N)	<u>Yes</u>	A/C Fail (Y/N)	<u>No</u>
RW-1 On (Y/N)	<u>Yes</u>	RW-1 (Y/N)	<u>No</u>
RW-2 On (Y/N)	<u>Yes</u>	RW-2 (Y/N)	<u>No</u>
Blower On (Y/N)	<u>Yes</u>	Blower Pressure (Y/N)	<u>No</u>
Sump Pump On (Y/N)	<u>No</u>	Sump Level (Y/N)	<u>No</u>

Recovery Wells	RW-1	RW-2
Flow Rate (GPM)	<u>25.7</u>	<u>24.0</u>
Total Flow (Gallons)	<u>Not reported</u>	<u>Not reported</u>
Water Level (Feet Above Probe)	<u>33.60</u>	<u>57.08</u>
Probe Depth (Feet BTOC)	<u>40.00</u>	<u>65.00</u>

Air Stripper			
Blower VFD Setting (Hertz)	<u>46</u>	Intake/Exhaust Piping OK? (Y/N)	<u>Yes</u>
System Pressure (inches water)	<u>10.8</u>	Water Leaks (Y/N)	<u>No</u>
Influent/Effluent Piping OK? (Y/N)	<u>Yes</u>	Water Temperature (°F)	<u></u>

Heat Exchanger			
Heat (On/Off)	<u>On</u>	Building Temperature (°F)	<u>74</u>
Heat Exchanger Flow (GPM)	<u>0.0</u>	Heat Exchanger Pressure (PSI)	<u>1.4</u>

General Building/Site			
Building Condition OK? (Y/N)	<u>Yes</u>	Circuit Breakers Checked (Y/N)	<u>Yes</u>
Grass Mowed (Y/N)	<u>N/A</u>	Outfall Condition OK? (Y/N)	<u>Yes</u>
Monitoring Wells OK? (Y/N)	<u>Yes</u>	Samples Collected (Y/N)	<u>No</u>

Notes:	
<u>System down on arrival.</u>	
<u>System restarted at 11:19AM (12-4-16)</u>	
<u></u>	
<u></u>	
System check:	<u>11:30</u>
<u></u>	
<u></u>	

Gladding Cordage
South Otselic, New York
NYSDEC Site #709009

Date 12/29/2016
Inspector L. Whalen
Time 7:30

Treatment System Operation		Alarms	
System On (Y/N)	Yes	A/C Fail (Y/N)	No
RW-1 On (Y/N)	Yes	RW-1 (Y/N)	No
RW-2 On (Y/N)	Yes	RW-2 (Y/N)	No
Blower On (Y/N)	Yes	Blower Pressure (Y/N)	No
Sump Pump On (Y/N)	No	Sump Level (Y/N)	No

Recovery Wells	RW-1	RW-2
Flow Rate (GPM)	25.5	23.7
Total Flow (Gallons)	NR	NR
Water Level (Feet Above Probe)	33.02	56.65
Probe Depth (Feet BTOC)	40.00	65.00

Air Stripper			
Blower VFD Setting (Hertz)	46	Intake/Exhaust Piping OK? (Y/N)	Yes
System Pressure (inches water)	10.8	Water Leaks (Y/N)	No
Influent/Effluent Piping OK? (Y/N)	Yes	Water Temperature (°F)	54.2

Heat Exchanger			
Heat (On/Off)	On	Building Temperature (°F)	67
Heat Exchanger Flow (GPM)	0.0	Heat Exchanger Pressure (PSI)	1.4

General Building/Site			
Building Condition OK? (Y/N)	Yes	Circuit Breakers Checked (Y/N)	Yes
Grass Mowed (Y/N)	N/A	Outfall Condition OK? (Y/N)	Yes
Monitoring Wells OK? (Y/N)	Yes	Samples Collected (Y/N)	Yes

Notes:			
Sampled:	RW-1	6:05	
	RW-2	6:10	
	EFF 46 HZ	6:15	

Shut down and and restart system to reset PLC

APPENDIX C

Analytical Reporting Forms



November 11, 2016

Jeremy Wyckoff
Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065

Project Location: S. Otselic, N.Y.
Client Job Number:
Project Number: 00266406.0000
Laboratory Work Order Number: 16K0007

Enclosed are results of analyses for samples received by the laboratory on November 1, 2016. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "Aaron L. Benoit", with a long horizontal line extending to the right.

Aaron L. Benoit
Project Manager

Table of Contents

Sample Summary	3
Case Narrative	4
Sample Results	5
16K0007-01	5
16K0007-02	6
16K0007-03	7
16K0007-04	8
Sample Preparation Information	9
QC Data	10
Volatile Organic Compounds by GC/MS	10
B162482	10
Flag/Qualifier Summary	12
Certifications	13
Chain of Custody/Sample Receipt	15

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065
ATTN: Jeremy Wyckoff

REPORT DATE: 11/11/2016

PURCHASE ORDER NUMBER:

PROJECT NUMBER: 00266406.0000

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 16K0007

The results of analyses performed on the following samples submitted to the CON-TEST Analytical Laboratory are found in this report.

PROJECT LOCATION: S. Otselic, N.Y.

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
RW-1	16K0007-01	Ground Water		EPA 624	
RW-2	16K0007-02	Ground Water		EPA 624	
EFF 46 HZ	16K0007-03	Ground Water		EPA 624	
Trip Blank	16K0007-04	Trip Blank Water		EPA 624	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Con-Test Analytical Laboratory for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.

A handwritten signature in black ink, appearing to read "Lisa Worthington", is written over a light pink rectangular background.

Lisa A. Worthington
Project Manager

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, N.Y.

Sample Description:

Work Order: 16K0007

Date Received: 11/1/2016

Field Sample #: RW-1

Sampled: 10/31/2016 07:05

Sample ID: 16K0007-01

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
Bromodichloromethane	ND	2.0	0.30	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
Carbon Tetrachloride	ND	2.0	0.25	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
Chloromethane	ND	2.0	0.55	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
1,1-Dichloroethane	1.7	2.0	0.16	µg/L	1	J	EPA 624	11/4/16	11/5/16 3:52	EEH
1,1-Dichloroethylene	0.91	2.0	0.21	µg/L	1	J	EPA 624	11/4/16	11/5/16 3:52	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
Tetrachloroethylene	ND	2.0	0.27	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
1,1,1-Trichloroethane	39	2.0	0.13	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
1,1,2-Trichloroethane	ND	2.0	0.24	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
m+p Xylene	ND	2.0	0.26	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	11/4/16	11/5/16 3:52	EEH
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	105	70-130				11/5/16 3:52				
Toluene-d8	103	70-130				11/5/16 3:52				
4-Bromofluorobenzene	101	70-130				11/5/16 3:52				

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, N.Y.

Sample Description:

Work Order: 16K0007

Date Received: 11/1/2016

Field Sample #: RW-2

Sampled: 10/31/2016 07:10

Sample ID: 16K0007-02

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
Bromodichloromethane	ND	2.0	0.30	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
Carbon Tetrachloride	ND	2.0	0.25	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
Chloromethane	ND	2.0	0.55	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
1,1-Dichloroethane	0.78	2.0	0.16	µg/L	1	J	EPA 624	11/4/16	11/5/16 4:19	EEH
1,1-Dichloroethylene	0.78	2.0	0.21	µg/L	1	J	EPA 624	11/4/16	11/5/16 4:19	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
Tetrachloroethylene	ND	2.0	0.27	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
1,1,1-Trichloroethane	33	2.0	0.13	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
1,1,2-Trichloroethane	ND	2.0	0.24	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
m+p Xylene	ND	2.0	0.26	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	11/4/16	11/5/16 4:19	EEH
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	102	70-130				11/5/16 4:19				
Toluene-d8	99.3	70-130				11/5/16 4:19				
4-Bromofluorobenzene	99.6	70-130				11/5/16 4:19				

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, N.Y.

Sample Description:

Work Order: 16K0007

Date Received: 11/1/2016

Field Sample #: EFF 46 HZ

Sampled: 10/31/2016 07:15

Sample ID: 16K0007-03

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
Bromodichloromethane	ND	2.0	0.30	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
Carbon Tetrachloride	ND	2.0	0.25	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
Chloromethane	ND	2.0	0.55	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
Tetrachloroethylene	ND	2.0	0.27	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
1,1,1-Trichloroethane	ND	2.0	0.13	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
1,1,2-Trichloroethane	ND	2.0	0.24	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
m+p Xylene	ND	2.0	0.26	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	11/4/16	11/5/16 3:25	EEH
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	103	70-130				11/5/16 3:25				
Toluene-d8	102	70-130				11/5/16 3:25				
4-Bromofluorobenzene	102	70-130				11/5/16 3:25				

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, N.Y.

Sample Description:

Work Order: 16K0007

Date Received: 11/1/2016

Field Sample #: Trip Blank

Sampled: 10/31/2016 00:00

Sample ID: 16K0007-04

Sample Matrix: Trip Blank Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	0.18	1.0	0.12	µg/L	1	J	EPA 624	11/4/16	11/5/16 2:58	EEH
Bromodichloromethane	ND	2.0	0.30	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
Carbon Tetrachloride	ND	2.0	0.25	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
Chloromethane	ND	2.0	0.55	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
Tetrachloroethylene	ND	2.0	0.27	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
Toluene	0.48	1.0	0.17	µg/L	1	J	EPA 624	11/4/16	11/5/16 2:58	EEH
1,1,1-Trichloroethane	ND	2.0	0.13	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
1,1,2-Trichloroethane	ND	2.0	0.24	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	11/4/16	11/5/16 2:58	EEH
m+p Xylene	0.26	2.0	0.26	µg/L	1	J	EPA 624	11/4/16	11/5/16 2:58	EEH
o-Xylene	0.14	2.0	0.13	µg/L	1	J	EPA 624	11/4/16	11/5/16 2:58	EEH
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	105	70-130								
Toluene-d8	101	70-130								
4-Bromofluorobenzene	99.3	70-130								

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Sample Extraction Data

Prep Method: SW-846 5030B-EPA 624

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
16K0007-01 [RW-1]	B162482	5	5.00	11/04/16
16K0007-02 [RW-2]	B162482	5	5.00	11/04/16
16K0007-03 [EFF 46 HZ]	B162482	5	5.00	11/04/16
16K0007-04 [Trip Blank]	B162482	5	5.00	11/04/16

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL
Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

Batch B162482 - SW-846 5030B
Blank (B162482-BLK1)

Prepared & Analyzed: 11/04/16

Benzene	ND	1.0	µg/L							
Bromodichloromethane	ND	2.0	µg/L							
Bromoform	ND	2.0	µg/L							
Bromomethane	ND	2.0	µg/L							
Carbon Tetrachloride	ND	2.0	µg/L							
Chlorobenzene	ND	2.0	µg/L							
Chlorodibromomethane	ND	2.0	µg/L							
Chloroethane	ND	2.0	µg/L							
2-Chloroethyl Vinyl Ether	ND	10	µg/L							
Chloroform	ND	2.0	µg/L							
Chloromethane	ND	2.0	µg/L							
1,2-Dichlorobenzene	ND	2.0	µg/L							
1,3-Dichlorobenzene	ND	2.0	µg/L							
1,4-Dichlorobenzene	ND	2.0	µg/L							
1,2-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethylene	ND	2.0	µg/L							
trans-1,2-Dichloroethylene	ND	2.0	µg/L							
1,2-Dichloropropane	ND	2.0	µg/L							
cis-1,3-Dichloropropene	ND	2.0	µg/L							
trans-1,3-Dichloropropene	ND	2.0	µg/L							
Ethylbenzene	ND	2.0	µg/L							
Methyl tert-Butyl Ether (MTBE)	ND	2.0	µg/L							
Methylene Chloride	ND	5.0	µg/L							
1,1,2,2-Tetrachloroethane	ND	2.0	µg/L							
Tetrachloroethylene	ND	2.0	µg/L							
Toluene	ND	1.0	µg/L							
1,1,1-Trichloroethane	ND	2.0	µg/L							
1,1,2-Trichloroethane	ND	2.0	µg/L							
Trichloroethylene	ND	2.0	µg/L							
Trichlorofluoromethane (Freon 11)	ND	2.0	µg/L							
Vinyl Chloride	ND	2.0	µg/L							
m+p Xylene	ND	2.0	µg/L							
o-Xylene	ND	2.0	µg/L							
Surrogate: 1,2-Dichloroethane-d4	25.6		µg/L	25.0		102	70-130			
Surrogate: Toluene-d8	25.0		µg/L	25.0		99.9	70-130			
Surrogate: 4-Bromofluorobenzene	24.9		µg/L	25.0		99.5	70-130			

LCS (B162482-BS1)

Prepared & Analyzed: 11/04/16

Benzene	10.8	1.0	µg/L	10.0		108	37-151			
Bromodichloromethane	10.8	2.0	µg/L	10.0		108	35-155			
Bromoform	10.0	2.0	µg/L	10.0		100	45-169			
Bromomethane	11.9	2.0	µg/L	10.0		119	20-242			
Carbon Tetrachloride	11.4	2.0	µg/L	10.0		114	70-140			
Chlorobenzene	10.8	2.0	µg/L	10.0		108	37-160			
Chlorodibromomethane	9.65	2.0	µg/L	10.0		96.5	53-149			
Chloroethane	11.1	2.0	µg/L	10.0		111	70-130			
2-Chloroethyl Vinyl Ether	83.8	10	µg/L	100		83.8	10-305			
Chloroform	11.4	2.0	µg/L	10.0		114	51-138			
Chloromethane	9.61	2.0	µg/L	10.0		96.1	20-273			
1,2-Dichlorobenzene	11.2	2.0	µg/L	10.0		112	18-190			
1,3-Dichlorobenzene	11.0	2.0	µg/L	10.0		110	59-156			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL
Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch B162482 - SW-846 5030B										
LCS (B162482-BS1)				Prepared & Analyzed: 11/04/16						
1,4-Dichlorobenzene	10.9	2.0	µg/L	10.0		109	18-190			
1,2-Dichloroethane	10.7	2.0	µg/L	10.0		107	49-155			
1,1-Dichloroethane	11.3	2.0	µg/L	10.0		113	59-155			
1,1-Dichloroethylene	10.9	2.0	µg/L	10.0		109	20-234			
trans-1,2-Dichloroethylene	9.85	2.0	µg/L	10.0		98.5	54-156			
1,2-Dichloropropane	10.8	2.0	µg/L	10.0		108	20-210			
cis-1,3-Dichloropropene	10.8	2.0	µg/L	10.0		108	20-227			
trans-1,3-Dichloropropene	11.7	2.0	µg/L	10.0		117	17-183			
Ethylbenzene	11.2	2.0	µg/L	10.0		112	37-162			
Methyl tert-Butyl Ether (MTBE)	10.7	2.0	µg/L	10.0		107	70-130			
Methylene Chloride	10.4	5.0	µg/L	10.0		104	50-221			
1,1,2,2-Tetrachloroethane	11.5	2.0	µg/L	10.0		115	46-157			
Tetrachloroethylene	11.4	2.0	µg/L	10.0		114	64-148			
Toluene	10.7	1.0	µg/L	10.0		107	47-150			
1,1,1-Trichloroethane	11.1	2.0	µg/L	10.0		111	52-162			
1,1,2-Trichloroethane	10.8	2.0	µg/L	10.0		108	52-150			
Trichloroethylene	11.5	2.0	µg/L	10.0		115	71-157			
Trichlorofluoromethane (Freon 11)	11.2	2.0	µg/L	10.0		112	17-181			
Vinyl Chloride	11.6	2.0	µg/L	10.0		116	20-251			
m+p Xylene	22.3	2.0	µg/L	20.0		112	70-130			
o-Xylene	11.0	2.0	µg/L	10.0		110	70-130			
Surrogate: 1,2-Dichloroethane-d4	26.2		µg/L	25.0		105	70-130			
Surrogate: Toluene-d8	25.0		µg/L	25.0		100	70-130			
Surrogate: 4-Bromofluorobenzene	25.1		µg/L	25.0		100	70-130			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
ND	Not Detected
RL	Reporting Limit
DL	Method Detection Limit
MCL	Maximum Contaminant Level
	Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
	No results have been blank subtracted unless specified in the case narrative section.
J	Detected but below the Reporting Limit (lowest calibration standard); therefore, result is an estimated concentration (CLP J-Flag).

CERTIFICATIONS
Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 624 in Water</i>	
Benzene	CT,MA,NH,NY,RI,NC,ME,VA
Bromodichloromethane	CT,MA,NH,NY,RI,NC,ME,VA
Bromoform	CT,MA,NH,NY,RI,NC,ME,VA
Bromomethane	CT,MA,NH,NY,RI,NC,ME,VA
Carbon Tetrachloride	CT,MA,NH,NY,RI,NC,ME,VA
Chlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
Chlorodibromomethane	CT,MA,NH,NY,RI,NC,ME,VA
Chloroethane	CT,MA,NH,NY,RI,NC,ME,VA
2-Chloroethyl Vinyl Ether	CT,MA,NH,NY,RI,NC,ME,VA
Chloroform	CT,MA,NH,NY,RI,NC,ME,VA
Chloromethane	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,3-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,4-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
trans-1,2-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichloropropane	CT,MA,NH,NY,RI,NC,ME,VA
cis-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA
trans-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA
Ethylbenzene	CT,MA,NH,NY,RI,NC,ME,VA
Methyl tert-Butyl Ether (MTBE)	NY,NC
Methylene Chloride	CT,MA,NH,NY,RI,NC,ME,VA
1,1,2,2-Tetrachloroethane	CT,MA,NH,NY,RI,NC,ME,VA
Tetrachloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
Toluene	CT,MA,NH,NY,RI,NC,ME,VA
1,1,1-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1,2-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
Trichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
Trichlorofluoromethane (Freon 11)	CT,MA,NH,NY,RI,NC,ME,VA
Vinyl Chloride	CT,MA,NH,NY,RI,NC,ME,VA
m+p Xylene	CT,MA,NH,NY,RI,NC,VA
o-Xylene	CT,MA,NH,NY,RI,NC,VA

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

The CON-TEST Environmental Laboratory operates under the following certifications and accreditations:

Code	Description	Number	Expires
AIHA	AIHA-LAP, LLC - ISO17025:2005	100033	02/1/2018
MA	Massachusetts DEP	M-MA100	06/30/2017
CT	Connecticut Department of Public Health	PH-0567	09/30/2017
NY	New York State Department of Health	10899 NELAP	04/1/2017
NH-S	New Hampshire Environmental Lab	2516 NELAP	02/5/2017
RI	Rhode Island Department of Health	LAO00112	12/30/2016
NC	North Carolina Div. of Water Quality	652	12/31/2016
NJ	New Jersey DEP	MA007 NELAP	06/30/2017
FL	Florida Department of Health	E871027 NELAP	06/30/2017
VT	Vermont Department of Health Lead Laboratory	LL015036	07/30/2017
ME	State of Maine	2011028	06/9/2017
VA	Commonwealth of Virginia	460217	12/14/2016
NH-P	New Hampshire Environmental Lab	2557 NELAP	09/6/2017

39 Spruce St.
East Longmeadow, MA. 01028
P: 413-525-2332
F: 413-525-6405
www.contestlabs.com



Page 1 of 2

Sample Receipt Checklist

CLIENT NAME: Arcadis RECEIVED BY: PB DATE: 11-1-16

1) Was the chain(s) of custody relinquished and signed? Yes ☒ No ☐ No COC Incl.

2) Does the chain agree with the samples? Yes ☒ No ☐

If not, explain:

3) Are all the samples in good condition? Yes ☒ No ☐

If not, explain:

4) How were the samples received:

On Ice ☒ Direct from Sampling ☐ Ambient ☐ In Cooler(s) ☒

Were the samples received in Temperature Compliance of (2-6°C)? Yes ☒ No ☐ N/A ☐

Temperature °C by Temp blank Temperature °C by Temp gun 3.9

5) Are there Dissolved samples for the lab to filter? Yes ☐ No ☒

Who was notified Date Time

6) Are there any RUSH or SHORT HOLDING TIME samples? Yes ☐ No ☒

Who was notified Date Time

7) Location where samples are stored:

Log in

Permission to subcontract samples? Yes No
(Walk-in clients only) if not already approved
Client Signature:

8) Do all samples have the proper Acid pH: Yes ☐ No ☐ N/A ☒

9) Do all samples have the proper Base pH: Yes ☐ No ☐ N/A ☒

10) Was the PC notified of any discrepancies with the CoC vs the samples: Yes ☐ N/A ☒

Containers received at Con-Test

	# of containers		# of containers
1 Liter Amber		16 oz amber	
500 mL Amber		8 oz amber/clear jar	
250 mL Amber (8oz amber)		4 oz amber/clear jar	
1 Liter Plastic		2 oz amber/clear jar	
500 mL Plastic		Plastic Bag / Ziploc	
250 mL plastic		SOC Kit	
40 mL Vial - type listed below	<u>11</u>	Perchlorate Kit	
Colisure / bacteria bottle		Flashpoint bottle	
Dissolved Oxygen bottle		Other glass jar	
Encore		Other	

40 mL vials: # HCl 11 # Methanol

Doc# 277 # Bisulfate # DI Water

Rev. 4 August 2013 # Thiosulfate Unpreserved

Time and Date Frozen:

Login Sample Receipt Checklist

(Rejection Criteria Listing - Using Sample Acceptance Policy)

Any False statement will be brought to the attention of Client

Question	Answer (True/False)	Comment
	T/F/NA	
1) The cooler's custody seal, if present, is intact.	NA	
2) The cooler or samples do not appear to have been compromised or tampered with.	T	
3) Samples were received on ice.	T	
4) Cooler Temperature is acceptable.	T	
5) Cooler Temperature is recorded.	T	
6) COC is filled out in ink and legible.	T	
7) COC is filled out with all pertinent information.	T	
8) Field Sampler's name present on COC.	T	
9) There are no discrepancies between the sample IDs on the container and the COC.	T	
10) Samples are received within Holding Time.	T	
11) Sample containers have legible labels.	T	
12) Containers are not broken or leaking.	T	
13) Air Cassettes are not broken/open.	NA	
14) Sample collection date/times are provided.	T	
15) Appropriate sample containers are used.	T	
16) Proper collection media used.	T	
17) No headspace sample bottles are completely filled.	T	
18) There is sufficient volume for all requested analyses, including any requested MS/MSDs.	T	
19) Trip blanks provided if applicable.	T	
20) VOA sample vials do not have head space or bubble is <6mm (1/4") in diameter.	T	
21) Samples do not require splitting or compositing.	NA	

Doc #277 Rev. 4 August 2013

Who notified of False statements?

Log-In Technician Initials: PB

Date/Time:

Date/Time: 11-1-16
9:11

December 14, 2016

Jeremy Wyckoff
Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065

Project Location: S. Otselic, N.Y.
Client Job Number:
Project Number: 00266406.0000
Laboratory Work Order Number: 16K1510

Enclosed are results of analyses for samples received by the laboratory on November 30, 2016. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "Aaron L. Benoit", with a horizontal line extending to the right.

Aaron L. Benoit
Project Manager

Table of Contents

Sample Summary	3
Case Narrative	4
Sample Results	5
16K1510-01	5
16K1510-02	6
16K1510-03	7
16K1510-04	8
Sample Preparation Information	9
QC Data	10
Volatile Organic Compounds by GC/MS	10
B165362	10
Flag/Qualifier Summary	12
Certifications	13
Chain of Custody/Sample Receipt	15

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065
ATTN: Jeremy Wyckoff

REPORT DATE: 12/14/2016

PURCHASE ORDER NUMBER:

PROJECT NUMBER: 00266406.0000

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 16K1510

The results of analyses performed on the following samples submitted to the CON-TEST Analytical Laboratory are found in this report.

PROJECT LOCATION: S. Otselic, N.Y.

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
RW-1	16K1510-01	Ground Water		EPA 624	
RW-2	16K1510-02	Ground Water		EPA 624	
EFF 46 HZ	16K1510-03	Ground Water		EPA 624	
Trip Blank	16K1510-04	Trip Blank Water		EPA 624	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Con-Test Analytical Laboratory for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.

A handwritten signature in black ink, appearing to read "Lisa Worthington", is written over a light pink rectangular background.

Lisa A. Worthington
Project Manager

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, N.Y.

Sample Description:

Work Order: 16K1510

Date Received: 11/30/2016

Field Sample #: RW-1

Sampled: 11/28/2016 06:05

Sample ID: 16K1510-01

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
Bromodichloromethane	ND	2.0	0.30	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
Carbon Tetrachloride	ND	2.0	0.25	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
Chloromethane	1.8	2.0	0.55	µg/L	1	J	EPA 624	12/9/16	12/9/16 22:02	MFF
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
1,1-Dichloroethane	2.1	2.0	0.16	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
1,1-Dichloroethylene	1.0	2.0	0.21	µg/L	1	J	EPA 624	12/9/16	12/9/16 22:02	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
Tetrachloroethylene	ND	2.0	0.27	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
1,1,1-Trichloroethane	42	2.0	0.13	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
1,1,2-Trichloroethane	ND	2.0	0.24	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
m+p Xylene	ND	2.0	0.26	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	12/9/16	12/9/16 22:02	MFF
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	115	70-130				12/9/16 22:02				
Toluene-d8	86.5	70-130				12/9/16 22:02				
4-Bromofluorobenzene	82.2	70-130				12/9/16 22:02				

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, N.Y.

Sample Description:

Work Order: 16K1510

Date Received: 11/30/2016

Field Sample #: RW-2

Sampled: 11/28/2016 06:10

Sample ID: 16K1510-02

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
Bromodichloromethane	ND	2.0	0.30	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
Carbon Tetrachloride	ND	2.0	0.25	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
Chloromethane	2.4	2.0	0.55	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
1,1-Dichloroethane	0.89	2.0	0.16	µg/L	1	J	EPA 624	12/9/16	12/9/16 22:25	MFF
1,1-Dichloroethylene	0.87	2.0	0.21	µg/L	1	J	EPA 624	12/9/16	12/9/16 22:25	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
Tetrachloroethylene	ND	2.0	0.27	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
1,1,1-Trichloroethane	35	2.0	0.13	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
1,1,2-Trichloroethane	ND	2.0	0.24	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
m+p Xylene	ND	2.0	0.26	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	12/9/16	12/9/16 22:25	MFF
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	114	70-130				12/9/16 22:25				
Toluene-d8	86.0	70-130				12/9/16 22:25				
4-Bromofluorobenzene	80.0	70-130				12/9/16 22:25				

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, N.Y.

Sample Description:

Work Order: 16K1510

Date Received: 11/30/2016

Field Sample #: EFF 46 HZ

Sampled: 11/28/2016 06:15

Sample ID: 16K1510-03

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
Bromodichloromethane	ND	2.0	0.30	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
Carbon Tetrachloride	ND	2.0	0.25	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
Chloromethane	2.3	2.0	0.55	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
Tetrachloroethylene	ND	2.0	0.27	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
1,1,1-Trichloroethane	ND	2.0	0.13	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
1,1,2-Trichloroethane	ND	2.0	0.24	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
m+p Xylene	ND	2.0	0.26	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	12/9/16	12/9/16 21:40	MFF
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	119	70-130				12/9/16 21:40				
Toluene-d8	92.4	70-130				12/9/16 21:40				
4-Bromofluorobenzene	84.5	70-130				12/9/16 21:40				

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, N.Y.

Sample Description:

Work Order: 16K1510

Date Received: 11/30/2016

Field Sample #: Trip Blank

Sampled: 11/28/2016 00:00

Sample ID: 16K1510-04

Sample Matrix: Trip Blank Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	0.16	1.0	0.12	µg/L	1	J	EPA 624	12/9/16	12/9/16 21:17	MFF
Bromodichloromethane	ND	2.0	0.30	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
Carbon Tetrachloride	ND	2.0	0.25	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
Chloromethane	1.4	2.0	0.55	µg/L	1	J	EPA 624	12/9/16	12/9/16 21:17	MFF
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
Tetrachloroethylene	ND	2.0	0.27	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
Toluene	0.60	1.0	0.17	µg/L	1	J	EPA 624	12/9/16	12/9/16 21:17	MFF
1,1,1-Trichloroethane	ND	2.0	0.13	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
1,1,2-Trichloroethane	ND	2.0	0.24	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
m+p Xylene	ND	2.0	0.26	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	12/9/16	12/9/16 21:17	MFF
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	114	70-130				12/9/16 21:17				
Toluene-d8	92.2	70-130				12/9/16 21:17				
4-Bromofluorobenzene	83.5	70-130				12/9/16 21:17				

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Sample Extraction Data

Prep Method: SW-846 5030B-EPA 624

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
16K1510-01 [RW-1]	B165362	5	5.00	12/09/16
16K1510-02 [RW-2]	B165362	5	5.00	12/09/16
16K1510-03 [EFF 46 HZ]	B165362	5	5.00	12/09/16
16K1510-04 [Trip Blank]	B165362	5	5.00	12/09/16

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL
Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

Batch B165362 - SW-846 5030B
Blank (B165362-BLK1)

Prepared & Analyzed: 12/09/16

Benzene	ND	1.0	µg/L							
Bromodichloromethane	ND	2.0	µg/L							
Bromoform	ND	2.0	µg/L							
Bromomethane	ND	2.0	µg/L							
Carbon Tetrachloride	ND	2.0	µg/L							
Chlorobenzene	ND	2.0	µg/L							
Chlorodibromomethane	ND	2.0	µg/L							
Chloroethane	ND	2.0	µg/L							
2-Chloroethyl Vinyl Ether	ND	10	µg/L							
Chloroform	ND	2.0	µg/L							
Chloromethane	ND	2.0	µg/L							
1,2-Dichlorobenzene	ND	2.0	µg/L							
1,3-Dichlorobenzene	ND	2.0	µg/L							
1,4-Dichlorobenzene	ND	2.0	µg/L							
1,2-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethylene	ND	2.0	µg/L							
trans-1,2-Dichloroethylene	ND	2.0	µg/L							
1,2-Dichloropropane	ND	2.0	µg/L							
cis-1,3-Dichloropropene	ND	2.0	µg/L							
trans-1,3-Dichloropropene	ND	2.0	µg/L							
Ethylbenzene	ND	2.0	µg/L							
Methyl tert-Butyl Ether (MTBE)	ND	2.0	µg/L							
Methylene Chloride	ND	5.0	µg/L							
1,1,2,2-Tetrachloroethane	ND	2.0	µg/L							
Tetrachloroethylene	ND	2.0	µg/L							
Toluene	ND	1.0	µg/L							
1,1,1-Trichloroethane	ND	2.0	µg/L							
1,1,2-Trichloroethane	ND	2.0	µg/L							
Trichloroethylene	ND	2.0	µg/L							
Trichlorofluoromethane (Freon 11)	ND	2.0	µg/L							
Xylenes (total)	ND	3.0	µg/L							
Vinyl Chloride	ND	2.0	µg/L							
m+p Xylene	ND	2.0	µg/L							
o-Xylene	ND	2.0	µg/L							
Surrogate: 1,2-Dichloroethane-d4	28.4		µg/L	25.0		113	70-130			
Surrogate: Toluene-d8	23.4		µg/L	25.0		93.5	70-130			
Surrogate: 4-Bromofluorobenzene	20.9		µg/L	25.0		83.4	70-130			

LCS (B165362-BS1)

Prepared & Analyzed: 12/09/16

Benzene	10.0	1.0	µg/L	10.0		100	37-151			
Bromodichloromethane	10.3	2.0	µg/L	10.0		103	35-155			
Bromoform	9.56	2.0	µg/L	10.0		95.6	45-169			
Bromomethane	10.8	2.0	µg/L	10.0		108	20-242			
Carbon Tetrachloride	9.98	2.0	µg/L	10.0		99.8	70-140			
Chlorobenzene	9.92	2.0	µg/L	10.0		99.2	37-160			
Chlorodibromomethane	10.2	2.0	µg/L	10.0		102	53-149			
Chloroethane	9.79	2.0	µg/L	10.0		97.9	70-130			
2-Chloroethyl Vinyl Ether	172	10	µg/L	100		172	10-305			
Chloroform	10.4	2.0	µg/L	10.0		104	51-138			
Chloromethane	11.3	2.0	µg/L	10.0		113	20-273			
1,2-Dichlorobenzene	10.2	2.0	µg/L	10.0		102	18-190			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL
Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch B165362 - SW-846 5030B										
LCS (B165362-BS1)				Prepared & Analyzed: 12/09/16						
1,3-Dichlorobenzene	10.2	2.0	µg/L	10.0		102	59-156			
1,4-Dichlorobenzene	10.0	2.0	µg/L	10.0		100	18-190			
1,2-Dichloroethane	10.9	2.0	µg/L	10.0		109	49-155			
1,1-Dichloroethane	10.7	2.0	µg/L	10.0		107	59-155			
1,1-Dichloroethylene	10.0	2.0	µg/L	10.0		100	20-234			
trans-1,2-Dichloroethylene	10.3	2.0	µg/L	10.0		103	54-156			
1,2-Dichloropropane	10.1	2.0	µg/L	10.0		101	20-210			
cis-1,3-Dichloropropene	10.6	2.0	µg/L	10.0		106	20-227			
trans-1,3-Dichloropropene	10.1	2.0	µg/L	10.0		101	17-183			
Ethylbenzene	9.07	2.0	µg/L	10.0		90.7	37-162			
Methyl tert-Butyl Ether (MTBE)	10.2	2.0	µg/L	10.0		102	70-130			
Methylene Chloride	10.4	5.0	µg/L	10.0		104	50-221			
1,1,2,2-Tetrachloroethane	10.6	2.0	µg/L	10.0		106	46-157			
Tetrachloroethylene	10.2	2.0	µg/L	10.0		102	64-148			
Toluene	10.4	1.0	µg/L	10.0		104	47-150			
1,1,1-Trichloroethane	10.2	2.0	µg/L	10.0		102	52-162			
1,1,2-Trichloroethane	10.6	2.0	µg/L	10.0		106	52-150			
Trichloroethylene	10.8	2.0	µg/L	10.0		108	71-157			
Trichlorofluoromethane (Freon 11)	10.3	2.0	µg/L	10.0		103	17-181			
Vinyl Chloride	10.2	2.0	µg/L	10.0		102	20-251			
m+p Xylene	17.5	2.0	µg/L	20.0		87.3	70-130			
o-Xylene	9.38	2.0	µg/L	10.0		93.8	70-130			
Surrogate: 1,2-Dichloroethane-d4	26.1		µg/L	25.0		104	70-130			
Surrogate: Toluene-d8	26.3		µg/L	25.0		105	70-130			
Surrogate: 4-Bromofluorobenzene	24.5		µg/L	25.0		97.9	70-130			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
ND	Not Detected
RL	Reporting Limit
DL	Method Detection Limit
MCL	Maximum Contaminant Level
	Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
	No results have been blank subtracted unless specified in the case narrative section.
J	Detected but below the Reporting Limit (lowest calibration standard); therefore, result is an estimated concentration (CLP J-Flag).

CERTIFICATIONS

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 624 in Water</i>	
Benzene	CT,MA,NH,NY,RI,NC,ME,VA
Bromodichloromethane	CT,MA,NH,NY,RI,NC,ME,VA
Bromoform	CT,MA,NH,NY,RI,NC,ME,VA
Bromomethane	CT,MA,NH,NY,RI,NC,ME,VA
Carbon Tetrachloride	CT,MA,NH,NY,RI,NC,ME,VA
Chlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
Chlorodibromomethane	CT,MA,NH,NY,RI,NC,ME,VA
Chloroethane	CT,MA,NH,NY,RI,NC,ME,VA
2-Chloroethyl Vinyl Ether	CT,MA,NH,NY,RI,NC,ME,VA
Chloroform	CT,MA,NH,NY,RI,NC,ME,VA
Chloromethane	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,3-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,4-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
trans-1,2-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichloropropane	CT,MA,NH,NY,RI,NC,ME,VA
cis-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA
trans-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA
Ethylbenzene	CT,MA,NH,NY,RI,NC,ME,VA
Methyl tert-Butyl Ether (MTBE)	NY,NC
Methylene Chloride	CT,MA,NH,NY,RI,NC,ME,VA
1,1,2,2-Tetrachloroethane	CT,MA,NH,NY,RI,NC,ME,VA
Tetrachloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
Toluene	CT,MA,NH,NY,RI,NC,ME,VA
1,1,1-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1,2-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
Trichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
Trichlorofluoromethane (Freon 11)	CT,MA,NH,NY,RI,NC,ME,VA
Vinyl Chloride	CT,MA,NH,NY,RI,NC,ME,VA
m+p Xylene	CT,MA,NH,NY,RI,NC,VA
o-Xylene	CT,MA,NH,NY,RI,NC,VA

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

The CON-TEST Environmental Laboratory operates under the following certifications and accreditations:

Code	Description	Number	Expires
AIHA	AIHA-LAP, LLC - ISO17025:2005	100033	02/1/2018
MA	Massachusetts DEP	M-MA100	06/30/2017
CT	Connecticut Department of Public Health	PH-0567	09/30/2017
NY	New York State Department of Health	10899 NELAP	04/1/2017
NH-S	New Hampshire Environmental Lab	2516 NELAP	02/5/2017
RI	Rhode Island Department of Health	LAO00112	12/30/2016
NC	North Carolina Div. of Water Quality	652	12/31/2016
NJ	New Jersey DEP	MA007 NELAP	06/30/2017
FL	Florida Department of Health	E871027 NELAP	06/30/2017
VT	Vermont Department of Health Lead Laboratory	LL015036	07/30/2017
ME	State of Maine	2011028	06/9/2017
VA	Commonwealth of Virginia	460217	12/14/2016
NH-P	New Hampshire Environmental Lab	2557 NELAP	09/6/2017



con-test[®]
ANALYTICAL LABORATORY

Phone: 413-525-2332
Fax: 413-525-6405
Email: info@contestlabs.com
www.contestlabs.com

CHAIN OF CUSTODY RECORD

NEW YORK STATE

39 Spruce Street
East Longmeadow, MA 01028

Page 1 of 1

Company Name: Acadia's

Address: 855 Route 146, STE 210

Clifton Park NY 12065

Attention: J. Wyckoff

Project Location: S. Otseclie, N.Y.

Sampled By: L. Whalen

Telephone: 518-250-7300

Project # 00266406-0000

Client PO#

DATA DELIVERY (check all that apply)

☐ FAX ☒ EMAIL ☐ WEBSITE

Format: ☐ PDF ☒ EXCEL ☐ GIS ☐ OTHER

☐ "Enhanced Data Package"

☐ Project Proposal Provided? (for billing purposes)

Collection

Beginning Date/Time

Ending Date/Time

Composite

Grab

Matrix Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Con-Test Lab ID

Client Sample ID / Description

01 RW-1

02 RW-2

03 EFF 46 HZ

04 Trip Blank

Con-Test Lab ID

Client Sample ID / Description

01 RW-1

02 RW-2

03 EFF 46 HZ

04 Trip Blank

Relinquished by: (signature)	Date/Time: 11/28/16 1400	Relinquished by:	Date/Time:
Received by: (signature)	Date/Time: 11/30/16 10:00	Received by:	Date/Time:
Relinquished by: (signature)	Date/Time:	Relinquished by:	Date/Time:
Received by: (signature)	Date/Time:	Received by:	Date/Time:

Turnaround Time (business days) STARTS AT 9:00 A.M. THE DAY AFTER SAMPLE RECEIPT UNLESS THERE ARE QUESTIONS ON YOUR CHAIN. IF THIS FORM IS NOT FILLED OUT COMPLETELY OR IS INCORRECT, TURNAROUND TIME WILL NOT START UNTIL ALL QUESTIONS ARE ANSWERED.	PLEASE BE CAREFUL TO NOT CONTAMINATE THIS DOCUMENT
--	--

39 Spruce St.
East Longmeadow, MA. 01028
P: 413-525-2332
F: 413-525-6405
www.contestlabs.com



Page 1 of 2

Sample Receipt Checklist

CLIENT NAME: Accudis RECEIVED BY: EB DATE: 11/30/16

1) Was the chain(s) of custody relinquished and signed? Yes ☒ No ☐ No COC Incl.

2) Does the chain agree with the samples? Yes ☒ No ☐

If not, explain:

3) Are all the samples in good condition? Yes ☒ No ☐

If not, explain:

4) How were the samples received:

On Ice ☒ Direct from Sampling ☐ Ambient ☐ In Cooler(s) ☒

Were the samples received in Temperature Compliance of (2-6°C)? Yes ☒ No ☐ N/A ☐

Temperature °C by Temp blank Temperature °C by Temp gun 3.8

5) Are there Dissolved samples for the lab to filter? Yes ☐ No ☒

Who was notified Date Time

6) Are there any RUSH or SHORT HOLDING TIME samples? Yes ☐ No ☒

Who was notified Date Time

7) Location where samples are stored:

Log In

Permission to subcontract samples? Yes ☐ No ☐
(Walk-in clients only) if not already approved

Client Signature:

8) Do all samples have the proper Acid pH: Yes ☐ No ☐ N/A ☒

9) Do all samples have the proper Base pH: Yes ☐ No ☐ N/A ☒

10) Was the PC notified of any discrepancies with the CoC vs the samples: Yes ☐ N/A ☒

Containers received at Con-Test

	# of containers		# of containers
1 Liter Amber		16 oz amber	
500 mL Amber		8 oz amber/clear jar	
250 mL Amber (8oz amber)		4 oz amber/clear jar	
1 Liter Plastic		2 oz amber/clear jar	
500 mL Plastic		Plastic Bag / Ziploc	
250 mL plastic		SOC Kit	
40 mL Vial - type listed below	<u>11</u>	Perchlorate Kit	
Colisure / bacteria bottle		Flashpoint bottle	
Dissolved Oxygen bottle		Other glass jar	
Encore		Other	

40 mL vials: # HCl 11 # Methanol

Time and Date Frozen:

Doc# 277 # Bisulfate # DI Water

Rev. 4 August 2013 # Thiosulfate Unpreserved

Login Sample Receipt Checklist
(Rejection Criteria Listing - Using Sample Acceptance Policy)
Any False statement will be brought to the attention of Client

Question	Answer (True/False)	Comment
	T/F/NA	
1) The cooler's custody seal, if present, is intact.	T ^{EB} N/A	
2) The cooler or samples do not appear to have been compromised or tampered with.	T	
3) Samples were received on ice.	T	
4) Cooler Temperature is acceptable.	T	
5) Cooler Temperature is recorded.	T	3.8 with gun
6) COC is filled out in ink and legible.	T	
7) COC is filled out with all pertinent information.	T	
8) Field Sampler's name present on COC.	T	
9) There are no discrepancies between the sample IDs on the container and the COC.	T	
10) Samples are received within Holding Time.	T	
11) Sample containers have legible labels.	T	
12) Containers are not broken or leaking.	T	
13) Air Cassettes are not broken/open.	N/A	
14) Sample collection date/times are provided.	T	
15) Appropriate sample containers are used.	T	
16) Proper collection media used.	T	
17) No headspace sample bottles are completely filled.	T	
18) There is sufficient volume for all requested analyses, including any requested MS/MSDs.	T	
19) Trip blanks provided if applicable.	T	
20) VOA sample vials do not have head space or bubble is <6mm (1/4") in diameter.	T	
21) Samples do not require splitting or compositing.	T	

Doc #277 Rev. 4 August 2013

Who notified of False statements?

Log-In Technician Initials:

EB

Date/Time:

Date/Time: 11/30/16

10:00

January 10, 2017

Jeremy Wyckoff
Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065

Project Location: South Otselic, NY
Client Job Number:
Project Number: 00266406.0000
Laboratory Work Order Number: 16L1387

Enclosed are results of analyses for samples received by the laboratory on December 30, 2016. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "Aaron L. Benoit", with a horizontal line extending to the right.

Aaron L. Benoit
Project Manager

Table of Contents

Sample Summary	3
Case Narrative	4
Sample Results	5
16L1387-01	5
16L1387-02	6
16L1387-03	7
16L1387-04	8
Sample Preparation Information	9
QC Data	10
Volatile Organic Compounds by GC/MS	10
B167143	10
Flag/Qualifier Summary	12
Certifications	13
Chain of Custody/Sample Receipt	15

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065
ATTN: Jeremy Wyckoff

REPORT DATE: 1/10/2017

PURCHASE ORDER NUMBER:

PROJECT NUMBER: 00266406.0000

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 16L1387

The results of analyses performed on the following samples submitted to the CON-TEST Analytical Laboratory are found in this report.

PROJECT LOCATION: South Otselic, NY

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
RW-1	16L1387-01	Ground Water		EPA 624	
RW-2	16L1387-02	Ground Water		EPA 624	
EFF 46 HZ	16L1387-03	Ground Water		EPA 624	
Trip Blank	16L1387-04	Trip Blank Water		EPA 624	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Con-Test Analytical Laboratory for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.

A handwritten signature in black ink, appearing to read "Lisa Worthington", is written over a light pink rectangular background.

Lisa A. Worthington
Project Manager

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: South Otselic, NY

Sample Description:

Work Order: 16L1387

Date Received: 12/30/2016

Field Sample #: RW-1

Sampled: 12/29/2016 06:05

Sample ID: 16L1387-01

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
Bromodichloromethane	ND	2.0	0.30	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
Carbon Tetrachloride	ND	2.0	0.25	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
Chloromethane	ND	2.0	0.55	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
1,1-Dichloroethane	2.0	2.0	0.16	µg/L	1	J	EPA 624	1/4/17	1/6/17 22:23	MFF
1,1-Dichloroethylene	1.2	2.0	0.21	µg/L	1	J	EPA 624	1/4/17	1/6/17 22:23	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
Tetrachloroethylene	ND	2.0	0.27	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
1,1,1-Trichloroethane	41	2.0	0.13	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
1,1,2-Trichloroethane	0.25	2.0	0.24	µg/L	1	J	EPA 624	1/4/17	1/6/17 22:23	MFF
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
m+p Xylene	ND	2.0	0.26	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	1/4/17	1/6/17 22:23	MFF
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	122	70-130								
Toluene-d8	98.8	70-130								
4-Bromofluorobenzene	91.3	70-130								

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: South Otselic, NY

Sample Description:

Work Order: 16L1387

Date Received: 12/30/2016

Field Sample #: RW-2

Sampled: 12/29/2016 06:10

Sample ID: 16L1387-02

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
Bromodichloromethane	ND	2.0	0.30	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
Carbon Tetrachloride	ND	2.0	0.25	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
Chloromethane	0.57	2.0	0.55	µg/L	1	J	EPA 624	1/4/17	1/6/17 22:46	MFF
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
1,1-Dichloroethane	0.82	2.0	0.16	µg/L	1	J	EPA 624	1/4/17	1/6/17 22:46	MFF
1,1-Dichloroethylene	0.86	2.0	0.21	µg/L	1	J	EPA 624	1/4/17	1/6/17 22:46	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
Tetrachloroethylene	ND	2.0	0.27	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
1,1,1-Trichloroethane	32	2.0	0.13	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
1,1,2-Trichloroethane	ND	2.0	0.24	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
m+p Xylene	ND	2.0	0.26	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	1/4/17	1/6/17 22:46	MFF
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	124	70-130								
Toluene-d8	99.6	70-130								
4-Bromofluorobenzene	87.0	70-130								

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: South Otselic, NY

Sample Description:

Work Order: 16L1387

Date Received: 12/30/2016

Field Sample #: EFF 46 HZ

Sampled: 12/29/2016 06:15

Sample ID: 16L1387-03

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
Bromodichloromethane	ND	2.0	0.30	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
Carbon Tetrachloride	ND	2.0	0.25	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
Chloromethane	0.73	2.0	0.55	µg/L	1	J	EPA 624	1/4/17	1/6/17 21:16	MFF
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
Tetrachloroethylene	ND	2.0	0.27	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
1,1,1-Trichloroethane	0.15	2.0	0.13	µg/L	1	J	EPA 624	1/4/17	1/6/17 21:16	MFF
1,1,2-Trichloroethane	ND	2.0	0.24	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
m+p Xylene	ND	2.0	0.26	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	1/4/17	1/6/17 21:16	MFF
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	123	70-130								
Toluene-d8	99.4	70-130								
4-Bromofluorobenzene	88.5	70-130								

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: South Otselic, NY

Sample Description:

Work Order: 16L1387

Date Received: 12/30/2016

Field Sample #: Trip Blank

Sampled: 12/29/2016 00:00

Sample ID: 16L1387-04

Sample Matrix: Trip Blank Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	0.14	1.0	0.12	µg/L	1	J	EPA 624	1/4/17	1/6/17 20:53	MFF
Bromodichloromethane	ND	2.0	0.30	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
Carbon Tetrachloride	ND	2.0	0.25	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
Chloromethane	0.85	2.0	0.55	µg/L	1	J	EPA 624	1/4/17	1/6/17 20:53	MFF
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
Tetrachloroethylene	ND	2.0	0.27	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
Toluene	0.67	1.0	0.17	µg/L	1	J	EPA 624	1/4/17	1/6/17 20:53	MFF
1,1,1-Trichloroethane	ND	2.0	0.13	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
1,1,2-Trichloroethane	ND	2.0	0.24	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
m+p Xylene	0.30	2.0	0.26	µg/L	1	J	EPA 624	1/4/17	1/6/17 20:53	MFF
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	1/4/17	1/6/17 20:53	MFF
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	121	70-130								
Toluene-d8	97.4	70-130								
4-Bromofluorobenzene	92.2	70-130								

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Sample Extraction Data

Prep Method: SW-846 5030B-EPA 624

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
16L1387-01 [RW-1]	B167143	5	5.00	01/04/17
16L1387-02 [RW-2]	B167143	5	5.00	01/04/17
16L1387-03 [EFF 46 HZ]	B167143	5	5.00	01/04/17
16L1387-04 [Trip Blank]	B167143	5	5.00	01/04/17

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL
Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

Batch B167143 - SW-846 5030B
Blank (B167143-BLK1)

Prepared: 01/04/17 Analyzed: 01/06/17

Benzene	ND	1.0	µg/L							
Bromodichloromethane	ND	2.0	µg/L							
Bromoform	ND	2.0	µg/L							
Bromomethane	ND	2.0	µg/L							
Carbon Tetrachloride	ND	2.0	µg/L							
Chlorobenzene	ND	2.0	µg/L							
Chlorodibromomethane	ND	2.0	µg/L							
Chloroethane	ND	2.0	µg/L							
2-Chloroethyl Vinyl Ether	ND	10	µg/L							
Chloroform	ND	2.0	µg/L							
Chloromethane	ND	2.0	µg/L							
1,2-Dichlorobenzene	ND	2.0	µg/L							
1,3-Dichlorobenzene	ND	2.0	µg/L							
1,4-Dichlorobenzene	ND	2.0	µg/L							
1,2-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethylene	ND	2.0	µg/L							
trans-1,2-Dichloroethylene	ND	2.0	µg/L							
1,2-Dichloropropane	ND	2.0	µg/L							
cis-1,3-Dichloropropene	ND	2.0	µg/L							
trans-1,3-Dichloropropene	ND	2.0	µg/L							
Ethylbenzene	ND	2.0	µg/L							
Methyl tert-Butyl Ether (MTBE)	ND	2.0	µg/L							
Methylene Chloride	ND	5.0	µg/L							
1,1,2,2-Tetrachloroethane	ND	2.0	µg/L							
Tetrachloroethylene	ND	2.0	µg/L							
Toluene	ND	1.0	µg/L							
1,1,1-Trichloroethane	ND	2.0	µg/L							
1,1,2-Trichloroethane	ND	2.0	µg/L							
Trichloroethylene	ND	2.0	µg/L							
Trichlorofluoromethane (Freon 11)	ND	2.0	µg/L							
Vinyl Chloride	ND	2.0	µg/L							
m+p Xylene	ND	2.0	µg/L							
o-Xylene	ND	2.0	µg/L							
Surrogate: 1,2-Dichloroethane-d4	30.1		µg/L	25.0		120	70-130			
Surrogate: Toluene-d8	24.9		µg/L	25.0		99.7	70-130			
Surrogate: 4-Bromofluorobenzene	22.2		µg/L	25.0		88.9	70-130			

LCS (B167143-BS1)

Prepared: 01/04/17 Analyzed: 01/06/17

Benzene	10.2	1.0	µg/L	10.0		102	37-151			
Bromodichloromethane	10.7	2.0	µg/L	10.0		107	35-155			
Bromoform	8.98	2.0	µg/L	10.0		89.8	45-169			
Bromomethane	16.9	2.0	µg/L	10.0		169	20-242			
Carbon Tetrachloride	11.7	2.0	µg/L	10.0		117	70-140			
Chlorobenzene	10.0	2.0	µg/L	10.0		100	37-160			
Chlorodibromomethane	9.92	2.0	µg/L	10.0		99.2	53-149			
Chloroethane	11.9	2.0	µg/L	10.0		119	70-130			
2-Chloroethyl Vinyl Ether	106	10	µg/L	100		106	10-305			
Chloroform	10.5	2.0	µg/L	10.0		105	51-138			
Chloromethane	10.6	2.0	µg/L	10.0		106	20-273			
1,2-Dichlorobenzene	10.2	2.0	µg/L	10.0		102	18-190			
1,3-Dichlorobenzene	10.1	2.0	µg/L	10.0		101	59-156			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL
Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch B167143 - SW-846 5030B										
LCS (B167143-BS1)					Prepared: 01/04/17 Analyzed: 01/06/17					
1,4-Dichlorobenzene	10.2	2.0	µg/L	10.0		102	18-190			
1,2-Dichloroethane	11.6	2.0	µg/L	10.0		116	49-155			
1,1-Dichloroethane	10.7	2.0	µg/L	10.0		107	59-155			
1,1-Dichloroethylene	11.3	2.0	µg/L	10.0		113	20-234			
trans-1,2-Dichloroethylene	11.5	2.0	µg/L	10.0		115	54-156			
1,2-Dichloropropane	9.95	2.0	µg/L	10.0		99.5	20-210			
cis-1,3-Dichloropropene	9.00	2.0	µg/L	10.0		90.0	20-227			
trans-1,3-Dichloropropene	8.94	2.0	µg/L	10.0		89.4	17-183			
Ethylbenzene	9.62	2.0	µg/L	10.0		96.2	37-162			
Methyl tert-Butyl Ether (MTBE)	8.63	2.0	µg/L	10.0		86.3	70-130			
Methylene Chloride	12.6	5.0	µg/L	10.0		126	50-221			
1,1,2,2-Tetrachloroethane	9.70	2.0	µg/L	10.0		97.0	46-157			
Tetrachloroethylene	11.1	2.0	µg/L	10.0		111	64-148			
Toluene	10.5	1.0	µg/L	10.0		105	47-150			
1,1,1-Trichloroethane	10.4	2.0	µg/L	10.0		104	52-162			
1,1,2-Trichloroethane	10.3	2.0	µg/L	10.0		103	52-150			
Trichloroethylene	10.1	2.0	µg/L	10.0		101	71-157			
Trichlorofluoromethane (Freon 11)	13.4	2.0	µg/L	10.0		134	17-181			
Vinyl Chloride	10.3	2.0	µg/L	10.0		103	20-251			
m+p Xylene	19.7	2.0	µg/L	20.0		98.4	70-130			
o-Xylene	9.54	2.0	µg/L	10.0		95.4	70-130			
Surrogate: 1,2-Dichloroethane-d4	29.4		µg/L	25.0		118	70-130			
Surrogate: Toluene-d8	26.4		µg/L	25.0		106	70-130			
Surrogate: 4-Bromofluorobenzene	24.1		µg/L	25.0		96.4	70-130			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
ND	Not Detected
RL	Reporting Limit
DL	Method Detection Limit
MCL	Maximum Contaminant Level
	Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
	No results have been blank subtracted unless specified in the case narrative section.
J	Detected but below the Reporting Limit (lowest calibration standard); therefore, result is an estimated concentration (CLP J-Flag).

CERTIFICATIONS
Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 624 in Water</i>	
Benzene	CT,MA,NH,NY,RI,NC,ME,VA
Bromodichloromethane	CT,MA,NH,NY,RI,NC,ME,VA
Bromoform	CT,MA,NH,NY,RI,NC,ME,VA
Bromomethane	CT,MA,NH,NY,RI,NC,ME,VA
Carbon Tetrachloride	CT,MA,NH,NY,RI,NC,ME,VA
Chlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
Chlorodibromomethane	CT,MA,NH,NY,RI,NC,ME,VA
Chloroethane	CT,MA,NH,NY,RI,NC,ME,VA
2-Chloroethyl Vinyl Ether	CT,MA,NH,NY,RI,NC,ME,VA
Chloroform	CT,MA,NH,NY,RI,NC,ME,VA
Chloromethane	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,3-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,4-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
trans-1,2-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichloropropane	CT,MA,NH,NY,RI,NC,ME,VA
cis-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA
trans-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA
Ethylbenzene	CT,MA,NH,NY,RI,NC,ME,VA
Methyl tert-Butyl Ether (MTBE)	NY,NC
Methylene Chloride	CT,MA,NH,NY,RI,NC,ME,VA
1,1,2,2-Tetrachloroethane	CT,MA,NH,NY,RI,NC,ME,VA
Tetrachloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
Toluene	CT,MA,NH,NY,RI,NC,ME,VA
1,1,1-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1,2-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
Trichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
Trichlorofluoromethane (Freon 11)	CT,MA,NH,NY,RI,NC,ME,VA
Vinyl Chloride	CT,MA,NH,NY,RI,NC,ME,VA
m+p Xylene	CT,MA,NH,NY,RI,NC,VA
o-Xylene	CT,MA,NH,NY,RI,NC,VA

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

The CON-TEST Environmental Laboratory operates under the following certifications and accreditations:

Code	Description	Number	Expires
AIHA	AIHA-LAP, LLC - ISO17025:2005	100033	02/1/2018
MA	Massachusetts DEP	M-MA100	06/30/2017
CT	Connecticut Department of Public Health	PH-0567	09/30/2017
NY	New York State Department of Health	10899 NELAP	04/1/2017
NH-S	New Hampshire Environmental Lab	2516 NELAP	02/5/2017
RI	Rhode Island Department of Health	LAO00112	12/30/2016
NC	North Carolina Div. of Water Quality	652	12/31/2017
NJ	New Jersey DEP	MA007 NELAP	06/30/2017
FL	Florida Department of Health	E871027 NELAP	06/30/2017
VT	Vermont Department of Health Lead Laboratory	LL015036	07/30/2017
ME	State of Maine	2011028	06/9/2017
VA	Commonwealth of Virginia	460217	12/14/2017
NH-P	New Hampshire Environmental Lab	2557 NELAP	09/6/2017



Phone: 413-525-2332
Fax: 413-525-6405
Email: info@contestlabs.com
www.contestlabs.com

CHAIN OF CUSTODY RECORD

NEW YORK STATE

39 Spruce Street
East Longmeadow, MA 01028

Page 1 of 1

Company Name: Arcadia's

Address: 855 Route 146, STE 210

Clifton Park, NY 12065

Attention: J. Wyckoff

Project Location: S. Otseque, NY

Sampled By: L. Whalen

Telephone: 518-250-7300

Project # 00266406.0000

Client PO#

DATA DELIVERY (check all that apply)

☐ FAX ☐ EMAIL ☐ WEBSITE

Fax #

Email:

Format:

PDF ☐ EXCEL ☐ GIS ☐

OTHER ☐

☐ "Enhanced Data Package"

☐ Project Proposal Provided? (for billing purposes)

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

☐

Collection

Beginning Date/Time

Ending Date/Time

Client Sample ID / Description

Con-Test Lab ID (laboratory use only)

Composite

Grab

*Matrix Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code

Conc Code


Conc Code

Conc Code</

39 Spruce St.
East Longmeadow, MA. 01028
P: 413-525-2332
F: 413-525-6405
www.contestlabs.com



Page 1 of 2



Sample Receipt Checklist

CLIENT NAME: Accadis RECEIVED BY: PLF DATE: 12/30/16

1) Was the chain(s) of custody relinquished and signed? Yes No No CoC Included

2) Does the chain agree with the samples? Yes No

If not, explain:

3) Are all the samples in good condition? Yes No

If not, explain:

4) How were the samples received:

On Ice ☒ Direct from Sampling ☐ Ambient ☐ In Cooler(s) ☒

Were the samples received in Temperature Compliance of (2-6°C)? Yes No N/A

Temperature °C by Temp blank _____ Temperature °C by Temp gun 5.2°C


5) Are there Dissolved samples for the lab to filter? Yes No

Who was notified _____ Date _____ Time _____

6) Are there any RUSH or SHORT HOLDING TIME samples? Yes No

Who was notified _____ Date _____ Time _____

7) Location where samples are stored:



Permission to subcontract samples? Yes No
(Walk-in clients only) if not already approved
Client Signature: _____

8) Do all samples have the proper Acid pH: Yes No N/A

9) Do all samples have the proper Base pH: Yes No N/A

10) Was the PC notified of any discrepancies with the CoC vs the samples: Yes No N/A

Containers received at Con-Test

	# of containers		# of containers
1 Liter Amber		8 oz amber/clear jar	
500 mL Amber		4 oz amber/clear jar	
250 mL Amber (8oz amber)		2 oz amber/clear jar	
1 Liter Plastic		Plastic Bag / Ziploc	
500 mL Plastic		SOC Kit	
250 mL plastic		Non-ConTest Container	
40 mL Vial - type listed below	<u>11</u>	Perchlorate Kit	
Colisure / bacteria bottle		Flashpoint bottle	
Dissolved Oxygen bottle		Other glass jar	
Encore		Other	

Laboratory Comments:

40 mL vials: # HCl 11 # Methanol _____

Doc# 277 # Bisulfate _____ # DI Water _____

Rev. 4 August 2013 # Thiosulfate _____ Unpreserved _____

Time and Date Frozen:

Login Sample Receipt Checklist

(Rejection Criteria Listing - Using Sample Acceptance Policy)

Any False statement will be brought to the attention of Client

<u>Question</u>	<u>Answer (True/False)</u>	<u>Comment</u>
	T/F/NA	
1) The cooler's custody seal, if present, is intact.	T LA	
2) The cooler or samples do not appear to have been compromised or tampered with.	T	
3) Samples were received on ice.	T	
4) Cooler Temperature is acceptable.	T	
5) Cooler Temperature is recorded.	T	
6) COC is filled out in ink and legible.	T	
7) COC is filled out with all pertinent information.	T	
8) Field Sampler's name present on COC.	T	
9) There are no discrepancies between the sample IDs on the container and the COC.	T	
10) Samples are received within Holding Time.	T	
11) Sample containers have legible labels.	T	
12) Containers are not broken or leaking.	T	
13) Air Cassettes are not broken/open.	LA	
14) Sample collection date/times are provided.	T	
15) Appropriate sample containers are used.	T	
16) Proper collection media used.	T	
17) No headspace sample bottles are completely filled.	T	
18) There is sufficient volume for all requested analyses, including any requested MS/MSDs.	T	
19) Trip blanks provided if applicable.	T	
20) VOA sample vials do not have head space or bubble is <6mm (1/4") in diameter.	T	
21) Samples do not require splitting or compositing.	T	

Doc #277 Rev. 4 August 2013

Who notified of False statements?

Log-In Technician Initials:

Date/Time:

Date/Time:

PLT 12/30/16 915

Arcadis CE, Inc.

855 Route 146

Suite 210

Clifton Park, New York 12065

Tel 518 250 7300

Fax 518 250 7301

www.arcadis.com