

New York State Department of Environmental
Conservation

GLADDING CORDAGE SITE QUARTERLY REPORT

SITE 7-09-009

Second Quarter 2016

October 2016

GLADDING CORDAGE SITE QUARTERLY REPORT

Second Quarter 2016



Andy Vitolins, PG
Associate Vice President

Prepared for:

New York State Department of
Environmental Conservation – Division of
Environmental Remediation

625 Broadway
Albany, NY 12233-7011

Prepared by:

Arcadis CE, Inc.
855 Route 146
Suite 210
Clifton Park
New York 12065
Tel 518 250 7300
Fax 518 250 7301



Jeremy Wyckoff
Project Geologist

Our Ref.:

00266406.0000

Date:

October 2016

This document is intended only for the use of the individual or entity for which it was prepared and may contain information that is privileged, confidential and exempt from disclosure under applicable law. Any dissemination, distribution or copying of this document is strictly prohibited.

CONTENTS

Acronyms and Abbreviations.....	iii
1 introduction.....	1
2 SITE DESCRIPTION	2
3 OPERATION AND MAINTENANCE	3
3.1 Treatment Plant Upgrades.....	3
3.1.1 Variable Frequency Drive.....	3
3.1.2 Treatment Plant Controls	3
3.1.3 Geothermal Heat Exchanger.....	4
3.2 Treatment Plant Operation	4
3.3 Treatment System Sampling	4
3.3.1 Influent Sample Results	4
3.3.2 Effluent Sample Results	5
4 GROUNDWATER MONITORING PROGRAM.....	6
5 RECOMMENDATIONS.....	7
6 SUMMARY	8
7 REFERENCES.....	9

TABLES

Table 3-1	Treatment System Status and Flow Summary
Table 3-2	Groundwater Treatment System VOCs (RW-1)
Table 3-3	Groundwater Treatment System VOCs (RW-2)
Table 3-4	Groundwater Treatment System VOCs (Effluent)

FIGURES

Figure 2-1	Site Location
Figure 3-1	Treatment System Influent Sample Concentration (1,1,1-TCA)

APPENDICES

- A PLC Facsimile Reports
- B O&M Checklists
- C Analytical Reporting Forms
- D Groundwater 1,1,1-TCA Concentrations – May 2015

ACRONYMS AND ABBREVIATIONS

Amsl	above mean sea level
BTEX	Benzene, toluene, ethylbenzene, and xylene.
Ft	feet
GAP	generally accepted procedure
HZ	hertz
µg/L	micrograms per liter
NYSDEC	New York State Department of Environmental Conservation
O&M	operation and maintenance
PDB	passive diffusion bag
PLC	programmable logic controller
PCE	Tetrachloroethene
USEPA	United States Environmental Protection Agency
VFD	variable frequency drive
VOC	volatile organic compound
1,1-DCA	1,2-dichloroethane
1,1-DCE	1,2-dichloroethene
1,1,1-TCA	1,1,1-trichloroethane

1 INTRODUCTION

The New York State Department of Environmental Conservation (NYSDEC) has issued a Work Assignment (# D007618-9) to ARCADIS CE, Inc. (Arcadis) for Operation, Maintenance, and Monitoring at the Gladding Cordage Site (Site # 7-09-009). This Quarterly Report has been prepared in accordance with the NYSDEC-approved Work Plan to summarize second quarter 2016 site activities.

2 SITE DESCRIPTION

The Gladding Cordage Site is located on Ridge Road, South Otselic, Chenango County, New York (Figure 2-1), along the western bank of the Otselic River. The site contains an active braided wire and rope manufacturing facility that has been in operation since 1892.

3 OPERATION AND MAINTENANCE

On August 23, 2007, the NYSDEC provided a training session to Arcadis personnel on the operation and maintenance (O&M) of the groundwater treatment plant at the Gladding Cordage Site. Since then, Arcadis has maintained operation of the groundwater treatment plant. This includes the operation, maintenance, and influent/effluent sampling in accordance with the NYSDEC O&M manual (Operation and Maintenance Manual, Volume I, Gladding Cordage Site, Site 7-09-009, TAMS Consultants, Inc., 1996) (O&M Manual).

3.1 Treatment Plant Upgrades

3.1.1 Variable Frequency Drive

A variable frequency drive (VFD) was installed on January 9, 2008 to regulate the speed of the air stripper blower motor for reduced energy usage. Following the installation of the VFD, effluent samples were collected at various blower motor frequencies (speeds) to evaluate the minimum blower frequency required for the treatment plant to effectively treat groundwater extracted from the source area. Additional sampling was conducted again in February 2008 to further optimize the treatment system blower speed. Based on the results, the VFD setting was reduced to 42 hertz (HZ) beginning in March 2008. However, based on the detection of low-level VOCs in effluent samples from the treatment system, the VFD setting was subsequently increased to 46 HZ in September 2010 and was maintained at that frequency until November 19, 2014.

Based on a general trend of lower concentrations of VOCs in influent treatment system samples since September 2010, the NYSDEC authorized a reduction of the VFD frequency to 44 HZ in an attempt to further optimize treatment plant operations and reduce electric usage. The VFD frequency was lowered to 44 HZ on November 19, 2014. Following approximately one-half hour of operation, post-treatment effluent samples were collected in accordance with the Work Plan (see Section 3.2.1). Based on a review of post-treatment effluent sample data from November 19, 2014, 1,1,1 TCA and toluene were detected with the air stripper blower operating at 44 HZ, but at concentrations below the corresponding NYSDEC Class GA Standards. The NYSDEC was notified of the VOC detections and the blower motor frequency was subsequently increased to 46 HZ and has been maintained at that level since the December 18, 2014 O&M event.

3.1.2 Treatment Plant Controls

In August 2011, the NYSDEC authorized construction and installation of a new treatment plant controls system. The new control system is designed to provide remote access to treatment plant operating parameters and improve reliability of the groundwater remediation system. The treatment plant was shut down to begin repairs and upgrades on January 30, 2012 by Aztech Technologies, Inc. (Aztech). The upgrades to the treatment system controls were completed and the treatment plant resumed operation on March 22, 2012. The treatment plant functions are controlled and monitored using an EOS Research Ltd. ProControl Programmable Logic Controller (PLC). The interface software allows remote connection to the PLC via analog phone line. The PLC and interface software also allows the treatment system to be started or stopped remotely. The PLC is programmed to send a facsimile with the status of system inputs and outputs on a daily basis. If input and/or output device values exceed the defined operating parameters, an

alarm condition is set and the corresponding alarm information is sent via facsimile to the system user (i.e. Arcadis).

3.1.3 Geothermal Heat Exchanger

The NYSDEC authorized the installation of a geothermal heat exchanger to provide climate control (heating and humidity) for the treatment system building. The treatment plant was shut down to begin installation of the system on May 8, 2012 by Aztech. The geothermal heat exchanger installation and testing was completed on May 10, 2012. The heat-exchanger uses groundwater from the treatment plant as a geo-thermal energy source.

3.2 Treatment Plant Operation

As shown on PLC facsimile reports (Appendix A) and O&M Checklist and Operation Logs (Appendix B), the Gladding Cordage groundwater treatment system shut down on April 17, 2016 due to a power interruption. The system was restated remotely on April 18, 2016. The system also shut down on May 7, 2016 and was restarted remotely on May 9, 2016. In June 2016, the treatment plant shut down on three occasions due to power interruptions (June 5, June 7 and June 21). The treatment system was restarted remotely on June 9, 2016 following the June 7 power outage. The system could not be restarted remotely following the June 5, 2016 or June 21, 2016 power outage due to a lack of communication with the PLC. After each of these power outages, the PLC was rebooted and the system was restarted from the site.

The average monthly flow rates and total flow volumes for the second quarter 2016 operating period are summarized in Table 3-1. As shown in Table 3-1, the monthly flow rates from recovery wells RW-1 and RW-2 averaged approximately 23 gpm and 21gpm, respectively. Based on the total flow values, approximately 5.1 million gallons of water were treated and discharged to the Otselic River between April and June 2016.

3.3 Treatment System Sampling

Influent and effluent groundwater samples were collected from the Gladding Cordage treatment system in accordance with the Work Plan and submitted to Contest Analytical following chain-of-custody protocols. Each sample was analyzed for volatile organic compounds (VOCs) by United States Environmental Protection Agency (USEPA) Method 624. Analytical Reporting Forms are provided in Appendix C.

3.3.1 Influent Sample Results

Table 3-2 and Table 3-3 summarize influent VOC sample results from recovery wells RW-1 and RW-2, respectively. Figure 3-1 provides a summary of 1,1,1-TCA concentrations in samples from recovery wells RW-1 and RW-2 since September 2007.

Table 3-2 and Figure 3-1, show that the concentrations of 1,1,1-TCA in samples from recovery well RW-1 ranged between 31µg/L in April and 34 µg/L in May. Table 3-3 and Figure 3-1, show that the concentrations of 1,1,1-TCA in the samples from recovery well RW-2 increased slightly from 25 µg/L in April to 33 µg/L in June. As shown in Tables 3-2 and 3-3, these results are within the range of historic concentrations and exceed the corresponding NYSDEC Class GA Standard of 5 µg/L.

As shown in Tables 3-2 and 3-3, 1,1-dichloroethane (1,1-DCA) and 1,1-dichloroethene (1,1-DCE) were detected in the second quarter 2016 samples from recovery wells RW-1 and RW-2. However, consistent with previous results, the concentrations were less than the applicable NYSDEC Class GA Standard of 5 µg/L.

3.3.2 Effluent Sample Results

Table 3-4 summarizes laboratory analytical data for effluent samples collected from the treatment system. As shown in Table 3-4, no VOCs were detected in any of the second quarter 2016 effluent samples at the indicated quantitation limits.

Based on influent sample concentrations and total flow volumes from the Gladding Cordage treatment system, approximately 1.4 pounds of VOCs were removed by the treatment system during the second quarter 2016.

4 GROUNDWATER MONITORING PROGRAM

Groundwater samples were collected from the site during the second quarter 2015 in accordance with the Work Plan. The results of the sampling event were submitted in the second quarter 2015 Gladding Cordage Site Quarterly Report (Arcadis, 2015). The next groundwater sampling event is scheduled to take place during the third quarter 2016. A map showing the distribution of 1,1,1-TCA during the second quarter 2015 sampling event is provided in Appendix D for reference.

5 RECOMMENDATIONS

Based on the data presented herein, there are no recommended changes to site operations at this time.

6 SUMMARY

The Gladding Cordage groundwater treatment system had several interruptions during the second quarter 2016 due to power outages. With the exception of the one event, the system was restarted remotely following each power interruption. The average total flow through the treatment system was approximately 44 GPM.

The concentrations of VOCs detected in pre-treatment influent samples from recovery wells RW-1 and RW-2 were consistent with previous results.

The treatment successfully removes VOCs from groundwater extracted from the capture zone at the current VFD setting of 46 Hz. The VFD setting will continue to be evaluated based on system monitoring results. Approximately 1.4 pounds of VOCs were removed by the treatment system during the second quarter 2016.

Based on the current five-quarter sampling interval, the next groundwater monitoring event is scheduled to occur during the third quarter 2016.

TABLES



**TABLE 3-1
TREATMENT SYSTEM STATUS AND FLOW SUMMARY
GLADDING CORDAGE SITE
SOUTH OTSELIC, NEW YORK
NYSDEC SITE NO. 7-04-009A**

Date	System Operation (days)	System On-time (% of possible days)	Well On-time		Flow Rates		Totalizer		Recovery Well Total Flows		Total System Flow (gallons)	Quarterly Totals (gallons)
			RW-1 (% possible)	RW-2 (% possible)	RW-1 (gpm)	RW-2 (gpm)	RW-1 (gallons)	RW-2 (gallons)	RW-1 (gallons)	RW-2 (gallons)		
January-16	29	94%	100%	100%	20.7	22.1	39,095,592	35,850,122	875,567	912,846	1,788,413	5,501,623
February-16	29	100%	100%	100%	21.9	22.2	39,988,542	36,759,764	892,950	909,642	1,802,592	
March-15	31	100%	100%	100%	20.6	21.4	40,931,049	37,727,875	942,507	968,111	1,910,618	
April-16	29	97%	100%	100%	21.1	21.2	41,816,850	38,633,091	885,801	905,216	1,791,017	5,088,795
May-16	29	94%	100%	100%	21.9	21.1	42,727,616	39,534,066	910,766	900,975	1,811,741	
June-16	23	77%	100%	100%	24.9	21.6	43,515,441	40,232,278	787,825	698,212	1,486,037	
Total Flow 2016									5,295,416	5,295,002	10,590,418	

Notes:
gpm - Gallons per minute

TABLE 3-2
GROUNDWATER TREATMENT SYSTEM VOCs (INFLUENT - RW-1)
GLADDING CORDAGE
SOUTH OTSELIC, NEW YORK
NYSDEC Site No. 7-09-009

Sample ID Sampling Date Matrix Units	NYSDEC Class GA Standard ug/L	RW-1 7/31/2015 WATER ug/L	RW-1 8/28/2015 WATER ug/L	RW-1 9/23/2015 WATER ug/L	RW-1 10/26/2015 WATER ug/L	RW-1 11/20/2015 WATER ug/L	RW-1 12/21/2015 WATER ug/L	RW-1 1/25/2016 WATER ug/L	RW-1 2/26/2016 WATER ug/L	RW-1 3/18/2016 WATER ug/L	RW-1 4/22/2016 WATER ug/L	RW-1 5/23/2016 WATER ug/L	RW-1 6/24/2016 WATER ug/L
VOCs													
1,1,1-Trichloroethane	5	40	42	32	38	41	32	38	36	36	31	34	32
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	1.6 J	1.8 J	1.5 J	1.8 J	2.1	1.5 J	1.8 J	1.5 J	1.4 J	1.2 J	1.3 J	1.1 J
1,1-Dichloroethene	5	0.96 J	0.97 J	0.8 J	0.85 J	1.0 J	0.8 J	0.84 J	0.79 J	0.86 J	0.84 J	0.77 J	0.69 J
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10.0 U	10 U	10 U	10.0 U	10 U	10 U	10.0 U	10 U	10 U	10.0 U	10 U	10 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane (Methyl Chloride)	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	0.19 J	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Toluene	5	1.0 U	1.0 U	2.0 U	1.0 U	1.0 U	2.0 U	1.0 U	1.0 U	2.0 U	1.0 U	1.0 U	2.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	5.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Total VOCs		42.6	45.0	34.3	40.7	44.1	34.3	40.6	38.3	38.3	33.0	36.1	33.8

- Concentration exceeds corresponding NYSD
Class GA Standard.
U - Not detected at the indicated concentration
J - Estimated concentration.

TABLE 3-3
GROUNDWATER TREATMENT SYSTEM VOCS (INFLUENT - RW-2)
GLADDING CORDAGE
SOUTH OTSELIC, NEW YORK
NYSDEC Site No. 7-09-009

Sample ID Sampling Date Matrix Units	NYSDEC Class GA Standard ug/L	RW-2 7/31/2015 WATER ug/L	RW-2 8/28/2015 WATER ug/L	RW-2 9/23/2015 WATER ug/L	RW-2 10/26/2015 WATER ug/L	RW-2 11/20/2015 WATER ug/L	RW-2 12/21/2015 WATER ug/L	RW-2 1/25/2016 WATER ug/L	RW-2 2/26/2016 WATER ug/L	RW-2 3/18/2016 WATER ug/L	RW-2 4/22/2016 WATER ug/L	RW-2 5/23/2016 WATER ug/L	RW-2 6/24/2016 WATER ug/L
VOCs													
1,1,1-Trichloroethane	5	34	36	26	32	34	26	32	29	29	25	28	33
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	0.74 J	0.77 J	0.61 J	0.75 J	0.85 J	0.61 J	0.86 J	0.62 J	0.62 J	0.53 J	0.56 J	0.58 J
1,1-Dichloroethene	5	0.72 J	0.62 J	0.58 J	0.63 J	0.92 J	0.58 J	0.64 J	0.56 J	0.66 J	0.60 J	0.62 J	0.58 J
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10.0 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane (Methyl Chloride)	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	0.15 J	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Toluene	5	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	5.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Total VOCs		35.5	37.5	27.2	33.4	35.8	27.2	33.5	30.2	30.3	26.1	29.2	34.2


 - Concentration exceeds corresponding NYSDEC
Class GA Standard.
U - Not detected at the indicated concentration
J - Estimated concentration.

TABLE 3-4
GROUNDWATER TREATMENT SYSTEM VOCS (EFFLUENT)
GLADDING CORDAGE
SOUTH OTSELIC, NEW YORK
NYSDEC Site No. 7-09-009

Sample ID Sampling Date Matrix Units	NYSDEC GA Standard ug/L	EFF(46HZ) 7/31/2015 WATER ug/L	EFF(46HZ) 8/28/2015 WATER ug/L	EFF(46HZ) 9/23/2015 WATER ug/L	EFF(46HZ) 10/26/2015 WATER ug/L	EFF(46HZ) 11/20/2015 WATER ug/L	EFF(46HZ) 12/21/2015 WATER ug/L
VOCS							
1,1,1-Trichloroethane	5	0.22 J	0.17 J	1.0 U	1.0 U	1.0 U	1.0 U
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10 U	10 U	10 U	10 U	10 U	10 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane (Methyl Chloride)	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	0.2 J	2.0 U	2.0 U	2.0 U	2.0 U
Toluene	5	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	5.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U

Notes

U - Not detected at the indicated concentration.

J - Estimated concentration.

TABLE 3-4
GROUNDWATER TREATMENT SYSTEM VOCs (EFFLUENT)
GLADDING CORDAGE
SOUTH OTSELIC, NEW YORK
NYSDEC Site No. 7-09-009

Sample ID Sampling Date Matrix Units	NYSDEC GA Standard ug/L	EFF(46HZ) 1/25/2016 WATER ug/L	EFF(46HZ) 2/26/2016 WATER ug/L	EFF(46HZ) 3/18/2016 WATER ug/L	EFF(46HZ) 4/22/2016 WATER ug/L	EFF(46HZ) 5/23/2016 WATER ug/L	EFF(46HZ) 6/24/2016 WATER ug/L
VOCs							
1,1,1-Trichloroethane	5	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10 U	10 U	10 U	10 U	10 U	10 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane (Methyl Chloride)	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	1.0 J
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Toluene	5	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	5.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U

Notes

U - Not detected at the indicated concentration.


J - Estimated concentration.

FIGURES



Figure 2-1
Site Location


Gladding Cordage Site
South Otselic, New York
NYSDEC Site 7-09-009



0 2,000 ft

Figure 3-1
Treatment System Influent Sample Concentrations (1,1,1-TCA)

Gladding Cordage Site
NYSDEC Site Number 7-09-009



APPENDIX A

PLC Facsim ile Reports





ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/01/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.1	GPM TOTAL FLOW is 40961217	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 37758964	GAL	
ASBPRS is 10.1	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 454905	GAL	
HP_PRS is 1.1	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.52	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.98	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.74	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 63.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/02/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 20.8	GPM TOTAL FLOW is 40991425	GAL	
W2_FLO is 21.3	GPM TOTAL FLOW is 37790043	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 455006	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.17	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.06	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 57.2	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/03/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.1	GPM TOTAL FLOW is 41021693	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 37821115	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 455158	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.09	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.06	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 53.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/06/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 20.7	GPM	TOTAL FLOW is 41112535	GAL		
W2_FLO is 21.7	GPM	TOTAL FLOW is 37914517	GAL		
ASBPRS is 11.2	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 455934	GAL		
HP_PRS is 1.2	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.43	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.47	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.68	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.06	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.4	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.7	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTemp is 49.0	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/07/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 20.7	GPM TOTAL FLOW is 41142700	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 37945634	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 456116	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.89	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.87	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 56.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/08/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.1	GPM TOTAL FLOW is 41172901	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 37976845	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 456253	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.89	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.03	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 55.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/09/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.0	GPM TOTAL FLOW is 41203215	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 38008154	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 456453	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.89	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.84	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 51.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/10/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 20.8	GPM TOTAL FLOW is 41233477	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 38039448	GAL	
ASBPRS is 11.1	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 456701	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.47	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.19	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.76	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 50.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/11/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 20.6	GPM TOTAL FLOW is 41263702	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 38070707	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 456888	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.52	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.80	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.46	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 53.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/12/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.2	GPM TOTAL FLOW is 41293918	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 38101971	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 457040	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.52	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.53	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.29	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 55.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/13/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.2	GPM TOTAL FLOW is 41324249	GAL	
W2_FLO is 21.8	GPM TOTAL FLOW is 38133323	GAL	
ASBPRS is 11.0	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 457234	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.88	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.27	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 51.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/14/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 20.9	GPM TOTAL FLOW is 41354533	GAL	
W2_FLO is 21.8	GPM TOTAL FLOW is 38164653	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 457427	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.46	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.55	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.91	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 52.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/15/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 20.8	GPM	TOTAL FLOW is 41384795	GAL		
W2_FLO is 21.5	GPM	TOTAL FLOW is 38195962	GAL		
ASBPRS is 11.0	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 2.34	GPM	TOTAL FLOW is 457579	GAL		
HP_PRS is 8.4	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 6.60	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.47	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.50	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.38	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.67	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.2	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.6	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 53.4	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/16/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.0	GPM TOTAL FLOW is 41415011	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 38227270	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 457729	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.22	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.55	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 55.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/17/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.3	GPM TOTAL FLOW is 41445196	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 38258562	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 457844	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.02	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.42	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 53.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ALARM Fax Report

EOS Research Ltd.

ProControl Series II+

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 11:40:54 ON 04/17/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

SHUTD : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL
FAX REPORT INITIATED BY PROCESS 29

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is ON	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 0.0	GPM	TOTAL FLOW is 41452330	GAL		
W2_FLO is 0.0	GPM	TOTAL FLOW is 38265954	GAL		
ASBPRS is 0.6	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 457871	GAL		
HP_PRS is 0.9	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.06	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 0.01	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 0.00	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 35.48	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 57.27	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 0.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 0.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 62.6	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/18/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

MANUAL : LAST SHUTDOWN @ 11:50:54 ON 04/17/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is ON	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is OFF	

Analog Inputs:

W1_FLO is 0.0	GPM	TOTAL FLOW is 41452330	GAL		
W2_FLO is 0.0	GPM	TOTAL FLOW is 38265954	GAL		
ASBPRS is 0.1	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 457883	GAL		
HP_PRS is 0.9	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.07	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 0.01	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 0.00	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 35.87	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 57.65	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 0.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 0.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 55.5	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/19/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 11:50:54 ON 04/17/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPEGO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM TOTAL FLOW is 41479728	GAL	
W2_FLO is 21.4	GPM TOTAL FLOW is 38293082	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 457970	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.41	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.23	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 59.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/20/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 11:50:54 ON 04/17/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.3	GPM	TOTAL FLOW is 41510837	GAL		
W2_FLO is 21.8	GPM	TOTAL FLOW is 38324033	GAL		
ASBPRS is 10.8	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 458128	GAL		
HP_PRS is 1.2	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 1.14	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.42	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.43	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.48	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.21	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.4	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.7	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 54.6	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/21/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 11:50:54 ON 04/17/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.3	GPM TOTAL FLOW is 41541736	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 38354978	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 458256	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.16	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.12	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 53.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/22/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 11:50:54 ON 04/17/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.3	GPM TOTAL FLOW is 41572548	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 38385903	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 458365	GAL	
HP_PRS is 1.1	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.86	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.00	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 60.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/23/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 11:50:54 ON 04/17/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.4	GPM	TOTAL FLOW is 41603255	GAL		
W2_FLO is 21.6	GPM	TOTAL FLOW is 38416816	GAL		
ASBPRS is 10.5	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 2.34	GPM	TOTAL FLOW is 458476	GAL		
HP_PRS is 8.1	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 8.59	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.48	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.50	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.77	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.98	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.2	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.5	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 57.4	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/24/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 11:50:54 ON 04/17/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.4	GPM TOTAL FLOW is 41633977	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 38447730	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 458615	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.02	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.98	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 53.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/25/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 11:50:54 ON 04/17/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.2	GPM	TOTAL FLOW is 41664635	GAL		
W2_FLO is 21.4	GPM	TOTAL FLOW is 38478646	GAL		
ASBPRS is 10.6	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 2.32	GPM	TOTAL FLOW is 458743	GAL		
HP_PRS is 8.1	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 7.41	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.43	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.45	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.89	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.85	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.3	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.6	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 57.8	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/26/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 11:50:54 ON 04/17/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.0	GPM TOTAL FLOW is 41695146	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 38509522	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 458854	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.47	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.37	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.81	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 59.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/27/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 11:50:54 ON 04/17/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.3	GPM TOTAL FLOW is 41725616	GAL	
W2_FLO is 21.3	GPM TOTAL FLOW is 38540423	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 459001	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.47	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.47	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.92	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.02	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 54.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/28/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 11:50:54 ON 04/17/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 20.7	GPM TOTAL FLOW is 41756037	GAL	
W2_FLO is 21.4	GPM TOTAL FLOW is 38571310	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 459148	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.43	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.45	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.77	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.91	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 54.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/29/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 11:50:54 ON 04/17/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 20.6	GPM	TOTAL FLOW is 41786451	GAL		
W2_FLO is 21.5	GPM	TOTAL FLOW is 38602195	GAL		
ASBPRS is 10.5	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 459270	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.49	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.50	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.71	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.81	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.3	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.6	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 59.0	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 04/30/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 11:50:54 ON 04/17/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 20.9	GPM	TOTAL FLOW is 41816850	GAL		
W2_FLO is 21.5	GPM	TOTAL FLOW is 38633091	GAL		
ASBPRS is 10.5	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 459392	GAL		
HP_PRS is 1.2	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.59	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.61	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.95	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.81	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.2	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.6	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 57.9	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/03/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 11:50:54 ON 04/17/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.1	GPM TOTAL FLOW is 41907842	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 38725866	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 459765	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.44	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.46	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.04	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.25	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 57.2	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/04/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 11:50:54 ON 04/17/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.1	GPM TOTAL FLOW is 41938148	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 38756755	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 459885	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.47	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.82	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.08	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 60.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/05/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 11:50:54 ON 04/17/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 20.8	GPM TOTAL FLOW is 41968416	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 38787623	GAL	
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 459994	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.67	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.04	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 57.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/06/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 11:50:54 ON 04/17/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 20.9	GPM	TOTAL FLOW is 41998631	GAL		
W2_FLO is 21.3	GPM	TOTAL FLOW is 38818484	GAL		
ASBPRS is 10.3	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 460114	GAL		
HP_PRS is 1.2	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.48	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.49	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.64	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.96	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.1	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.4	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 60.6	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/07/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 11:50:54 ON 04/17/2016 BY ASBVFD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 20.8	GPM TOTAL FLOW is 42028834	GAL	
W2_FLO is 21.2	GPM TOTAL FLOW is 38849340	GAL	
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 460224	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.70	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.96	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 58.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ALARM Fax Report

EOS Research Ltd.

ProControl Series II+

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 17:35:52 ON 05/07/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P19 : LAST SHUTDOWN @ 11:50:54 ON 04/17/2016 BY ASBVFD
FAX REPORT INITIATED BY PROCESS 18

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is ON	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 42043431	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 38864226	GAL	
ASBPRS is 0.0	IWC LIMITS are L: 5.0	IWC H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 460272	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI H: 20.0	PSI
HP_AMP is 0.00	AMP LIMITS are L: 0.00	AMP H:	AMP
W1_AMP is 0.00	AMP LIMITS are L: 0.00	AMP H: 10.00	AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP H: 10.00	AMP
W1_LVL is 0.00	FT LIMITS are L: 8.00	FT H: 28.00	FT
W2_LVL is 0.00	FT LIMITS are L: 9.00	FT H: 52.00	FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI H: 100.0	PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI H: 100.0	PSI
INTEMP is 0.0	DEG LIMITS are L: 42.0	DEG H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ALARM Fax Report

EOS Research Ltd.

ProControl Series II+

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 17:42:00 ON 05/07/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

SHUTD P02 : LAST SHUTDOWN @ 11:50:54 ON 04/17/2016 BY ASBVFD
FAX REPORT INITIATED BY PROCESS 19

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is ON	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 42043431	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 38864226	GAL	
ASBPRS is 0.0	IWC LIMITS are L: 5.0	IWC H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 460272	GAL	
HP_PRS is 0.0	PSI LIMITS are L: -2.0	PSI H: 20.0	PSI
HP_AMP is 0.00	AMP LIMITS are L: 0.00	AMP H:	AMP
W1_AMP is 0.00	AMP LIMITS are L: 0.00	AMP H: 10.00	AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP H: 10.00	AMP
W1_LVL is 0.00	FT LIMITS are L: 8.00	FT H: 28.00	FT
W2_LVL is 0.00	FT LIMITS are L: 9.00	FT H: 52.00	FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI H: 100.0	PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI H: 100.0	PSI
INTEMP is 0.0	DEG LIMITS are L: 42.0	DEG H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/08/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

MANUAL : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is OFF	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 42043431	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 38864226	GAL	
ASBPRS is 0.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 460272	GAL	
HP_PRS is 0.9	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.07	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 0.01	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.49	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.18	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 58.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/09/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

MANUAL : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is OFF	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 42043431	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 38864226	GAL	
ASBPRS is 0.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 460272	GAL	
HP_PRS is 0.9	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.07	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 0.01	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.86	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.20	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTemp is 56.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/10/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P36 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.9	GPM TOTAL FLOW is 42070532	GAL	
W2_FLO is 21.0	GPM TOTAL FLOW is 38890366	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 460395	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.46	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.44	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.94	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.93	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 54.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/11/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P36 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 22.3	GPM TOTAL FLOW is 42102229	GAL	
W2_FLO is 21.3	GPM TOTAL FLOW is 38921039	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 460518	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.47	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.46	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.94	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.89	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 54.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/12/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P36 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 22.0	GPM TOTAL FLOW is 42133840	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 38951708	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 460608	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.74	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.85	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 58.2	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/13/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P36 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM TOTAL FLOW is 42165378	GAL	
W2_FLO is 21.0	GPM TOTAL FLOW is 38982365	GAL	
ASBPRS is 10.1	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 460671	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.31	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.72	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 62.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/14/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P36 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.8	GPM TOTAL FLOW is 42196937	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 39013011	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 460767	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.43	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.91	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTemp is 59.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/15/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P36 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.9	GPM TOTAL FLOW is 42228474	GAL	
W2_FLO is 21.8	GPM TOTAL FLOW is 39043673	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 460887	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 1.11	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.31	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.85	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 56.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/16/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P36 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM TOTAL FLOW is 42260037	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 39074364	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 461030	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.52	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.81	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 55.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/17/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P36 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM TOTAL FLOW is 42291491	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 39105028	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 461164	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.45	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.44	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.70	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.81	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 56.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/18/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P36 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.9	GPM TOTAL FLOW is 42322828	GAL	
W2_FLO is 21.0	GPM TOTAL FLOW is 39135702	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 461293	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.43	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.42	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.65	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.74	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 54.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/19/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P36 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 22.0	GPM TOTAL FLOW is 42354097	GAL	
W2_FLO is 21.2	GPM TOTAL FLOW is 39166360	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 461408	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.47	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.63	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.72	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 56.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/21/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P36 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.7	GPM TOTAL FLOW is 42416557	GAL	
W2_FLO is 21.4	GPM TOTAL FLOW is 39227673	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 461603	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.49	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.62	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 59.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/22/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P36 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.7	GPM TOTAL FLOW is 42447777	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 39258380	GAL	
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 461699	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.25	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.58	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 60.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/23/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P36 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.4	GPM TOTAL FLOW is 42478952	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 39289074	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 461774	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.39	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.58	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 59.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/24/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P36 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.9	GPM TOTAL FLOW is 42510129	GAL	
W2_FLO is 21.3	GPM TOTAL FLOW is 39319725	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 461846	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.17	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.51	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 59.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/25/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P36 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM TOTAL FLOW is 42541274	GAL	
W2_FLO is 21.1	GPM TOTAL FLOW is 39350353	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 461928	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.30	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.51	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTemp is 59.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/26/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P36 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM TOTAL FLOW is 42572419	GAL	
W2_FLO is 21.1	GPM TOTAL FLOW is 39380983	GAL	
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 461989	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 1.15	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.47	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.36	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.39	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 60.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/27/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P36 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.9	GPM TOTAL FLOW is 42603533	GAL	
W2_FLO is 21.1	GPM TOTAL FLOW is 39411596	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 462043	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.19	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.43	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 61.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/28/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P36 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM	TOTAL FLOW is 42634617	GAL		
W2_FLO is 21.2	GPM	TOTAL FLOW is 39442208	GAL		
ASBPRS is 10.3	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 462096	GAL		
HP_PRS is 1.2	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.62	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.61	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 32.26	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.43	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.1	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.2	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTMP is 62.4	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/29/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P36 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM TOTAL FLOW is 42665646	GAL	
W2_FLO is 21.2	GPM TOTAL FLOW is 39472820	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 462136	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.21	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.34	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 63.2	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/30/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P36 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM TOTAL FLOW is 42696651	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 39503439	GAL	
ASBPRS is 10.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 462191	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.63	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.11	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.36	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 3.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 63.2	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 05/31/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P36 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.4	GPM TOTAL FLOW is 42727616	GAL	
W2_FLO is 21.4	GPM TOTAL FLOW is 39534066	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 462243	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.05	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.39	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 3.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 61.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/01/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P36 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.5	GPM TOTAL FLOW is 42758567	GAL	
W2_FLO is 21.4	GPM TOTAL FLOW is 39564684	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 462304	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.47	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.12	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.32	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 59.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/02/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P36 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.5	GPM TOTAL FLOW is 42789472	GAL	
W2_FLO is 21.2	GPM TOTAL FLOW is 39595292	GAL	
ASBPRS is 10.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 462343	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 32.00	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.30	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 3.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 63.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/03/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P36 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.4	GPM TOTAL FLOW is 42820382	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 39625926	GAL	
ASBPRS is 10.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 462412	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 31.98	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.30	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 3.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 63.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/04/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P36 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.3	GPM TOTAL FLOW is 42851232	GAL	
W2_FLO is 21.0	GPM TOTAL FLOW is 39656522	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 462464	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 31.95	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.30	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 3.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 3.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTemp is 61.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ALARM Fax Report

EOS Research Ltd.

ProControl Series II+

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 02:09:54 ON 06/05/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P19 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL
FAX REPORT INITIATED BY PROCESS 18

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is ON	E_STOP is OFF		

Discrete Outputs:


W1_GO is OFF	W2_GO is OFF	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 0.0	GPM	TOTAL FLOW is 42877122	GAL		
W2_FLO is 0.0	GPM	TOTAL FLOW is 39682176	GAL		
ASBPRS is 0.0	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 462504	GAL		
HP_PRS is 0.0	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.00	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 0.00	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 0.00	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 0.00	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 0.00	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 0.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 0.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 0.0	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ALARM Fax Report

EOS Research Ltd.

ProControl Series II+

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 02:16:00 ON 06/05/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

SHUTD P02 : LAST SHUTDOWN @ 17:45:53 ON 05/07/2016 BY ACFAIL
FAX REPORT INITIATED BY PROCESS 19

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 0.0	GPM	TOTAL FLOW is 42877122	GAL	
W2_FLO is 0.0	GPM	TOTAL FLOW is 39682176	GAL	
ASBPRS is 0.2	IWC	LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 462504	GAL	
HP_PRS is 0.9	PSI	LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.06	AMP	LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 0.01	AMP	LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP	LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.49	FT	LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.50	FT	LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 63.4	DEG	LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/05/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

MANUAL : LAST SHUTDOWN @ 02:19:55 ON 06/05/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is OFF	

Analog Inputs:

W1_FLO is 0.0	GPM	TOTAL FLOW is 42877122	GAL		
W2_FLO is 0.0	GPM	TOTAL FLOW is 39682176	GAL		
ASBPRS is 0.2	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 462504	GAL		
HP_PRS is 0.9	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.05	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 0.01	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 0.00	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.71	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.57	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 0.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 0.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 64.5	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/06/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

MANUAL : LAST SHUTDOWN @ 02:19:55 ON 06/05/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is OFF	

Analog Inputs:

W1_FLO is 0.0	GPM	TOTAL FLOW is 42877122	GAL		
W2_FLO is 0.0	GPM	TOTAL FLOW is 39682176	GAL		
ASBPRS is 0.2	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 462504	GAL		
HP_PRS is 0.9	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.05	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 0.01	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 0.00	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.60	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 57.62	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 0.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 0.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 63.0	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/07/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 02:19:55 ON 06/05/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 24.1	GPM TOTAL FLOW is 42910504	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 39712088	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 462563	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 31.72	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.93	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 61.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ALARM Fax Report

EOS Research Ltd.

ProControl Series II+

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 13:18:08 ON 06/07/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P19 : LAST SHUTDOWN @ 02:19:55 ON 06/05/2016 BY ACFAIL
FAX REPORT INITIATED BY PROCESS 18

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 0.0	GPM	TOTAL FLOW is 42920986	GAL		
W2_FLO is 0.0	GPM	TOTAL FLOW is 39721490	GAL		
ASBPRS is 9.4	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 462588	GAL		
HP_PRS is 0.9	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.05	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 0.01	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 0.00	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.38	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.86	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 0.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 0.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 65.9	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ALARM Fax Report

EOS Research Ltd.

ProControl Series II+

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 13:24:00 ON 06/07/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

SHUTD P02 : LAST SHUTDOWN @ 02:19:55 ON 06/05/2016 BY ACFAIL
FAX REPORT INITIATED BY PROCESS 19

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is OFF	W2_GO is OFF	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 0.0	GPM	TOTAL FLOW is 42920986	GAL		
W2_FLO is 0.0	GPM	TOTAL FLOW is 39721490	GAL		
ASBPRS is 9.3	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 462588	GAL		
HP_PRS is 0.9	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.05	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 0.01	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 0.00	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.69	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 57.03	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 0.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 0.0	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 65.8	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/08/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

MANUAL : LAST SHUTDOWN @ 13:28:08 ON 06/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is OFF	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 42920986	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 39721490	GAL	
ASBPRS is 0.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 462588	GAL	
HP_PRS is 0.9	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.07	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 0.01	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.02	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.08	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 60.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/10/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

MANUAL : LAST SHUTDOWN @ 13:28:08 ON 06/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is OFF	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 42920986	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 39721490	GAL	
ASBPRS is 0.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 462588	GAL	
HP_PRS is 0.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.07	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 0.01	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.29	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.89	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 59.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/11/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 13:28:08 ON 06/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 24.9	GPM TOTAL FLOW is 42948755	GAL	
W2_FLO is 21.3	GPM TOTAL FLOW is 39745178	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 462656	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.76	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 31.70	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.53	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 57.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/12/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 13:28:08 ON 06/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.1	GPM TOTAL FLOW is 42984912	GAL	
W2_FLO is 21.4	GPM TOTAL FLOW is 39776152	GAL	
ASBPRS is 10.1	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 462726	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.77	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 31.73	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.81	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 62.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/13/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 13:28:08 ON 06/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.2	GPM TOTAL FLOW is 43021040	GAL	
W2_FLO is 21.3	GPM TOTAL FLOW is 39807148	GAL	
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 462831	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.71	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 31.90	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.74	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 59.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/14/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 13:28:08 ON 06/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.2	GPM TOTAL FLOW is 43057052	GAL	
W2_FLO is 21.3	GPM TOTAL FLOW is 39838125	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 462943	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.64	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 31.89	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.68	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 57.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/15/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 13:28:08 ON 06/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 24.7	GPM TOTAL FLOW is 43092977	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 39869066	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 463031	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.64	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 31.77	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.55	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 57.2	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/16/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 13:28:08 ON 06/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 24.5	GPM	TOTAL FLOW is 43128820	GAL		
W2_FLO is 21.4	GPM	TOTAL FLOW is 39899987	GAL		
ASBPRS is 10.3	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 463092	GAL		
HP_PRS is 1.2	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.66	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.51	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 31.47	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.53	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.3	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.4	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 61.4	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/17/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 13:28:08 ON 06/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 24.7	GPM TOTAL FLOW is 43164642	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 39930871	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 463144	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 31.49	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.49	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 61.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/18/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 13:28:08 ON 06/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 24.8	GPM TOTAL FLOW is 43200436	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 39961733	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 463206	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.73	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 31.73	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.41	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 60.2	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/19/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 13:28:08 ON 06/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.0	GPM TOTAL FLOW is 43236208	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 39992558	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 463269	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.77	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 31.79	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.34	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 60.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/20/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 13:28:08 ON 06/07/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 24.7	GPM TOTAL FLOW is 43271964	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 40023375	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 463333	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.64	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 31.56	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.30	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 62.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/29/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 01:16:41 ON 06/21/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 25.1	GPM	TOTAL FLOW is 43479512	GAL		
W2_FLO is 21.3	GPM	TOTAL FLOW is 40201397	GAL		
ASBPRS is 10.3	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 463625	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.05	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.67	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.52	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 31.62	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.87	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.2	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.2	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTemp is 62.4	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

ECOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 06/30/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 01:16:41 ON 06/21/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 24.7	GPM TOTAL FLOW is 43515441	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 40232278	GAL	
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 463702	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.68	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 31.58	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.60	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.1	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTMP is 60.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN

APPENDIX B

O&M Checklists



Date	4/22/2016
Inspector	L. Whalen
Time	7:45

Notes:

Date	5/23/2016
Inspector	L. Whalen
Time	7:00

Notes:

Date	6/6/2016
Inspector	L. Whalen
Time	7:30

Notes:
System shut down on 6/5/16 @ 02:16. Could not be restarted remotely.
Re-boot PLC and restarted system at 07:00. Values above after restart.
Mowed grass.

Date	6/24/2016
Inspector	L. Whalen
Time	6:00

Notes:
System restarted upon arrival. System shut down on 6/21/16 @ 01:16.
Restarted system at 06:30. Values above after restart.
Mowed grass.

APPENDIX C

Analytical Reporting Forms



May 3, 2016

Jeremy Wyckoff
Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065

Project Location: S. Otselic, NY
Client Job Number:
Project Number: 00266406.0000
Laboratory Work Order Number: 16D1100

Enclosed are results of analyses for samples received by the laboratory on April 25, 2016. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "Aaron L. Benoit", with a horizontal line extending to the right.

Aaron L. Benoit
Project Manager

Table of Contents

Sample Summary	3
Case Narrative	4
Sample Results	5
16D1100-01	5
16D1100-02	6
16D1100-03	7
16D1100-04	8
Sample Preparation Information	9
QC Data	10
Volatile Organic Compounds by GC/MS	10
B147970	10
Flag/Qualifier Summary	12
Certifications	13
Chain of Custody/Sample Receipt	15

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065
ATTN: Jeremy Wyckoff

REPORT DATE: 5/3/2016

PURCHASE ORDER NUMBER:

PROJECT NUMBER: 00266406.0000

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 16D1100

The results of analyses performed on the following samples submitted to the CON-TEST Analytical Laboratory are found in this report.

PROJECT LOCATION: S. Otselic, NY

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
RW-1	16D1100-01	Ground Water		EPA 624	
RW-2	16D1100-02	Ground Water		EPA 624	
EFF 46 HZ	16D1100-03	Ground Water		EPA 624	
Trip Blanks	16D1100-04	Trip Blank Water		EPA 624	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Con-Test Analytical Laboratory for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.

A handwritten signature in black ink, appearing to read "Lisa Worthington", is written over a light pink rectangular background.

Lisa A. Worthington
Project Manager

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 16D1100

Date Received: 4/25/2016

Field Sample #: RW-1

Sampled: 4/22/2016 07:00

Sample ID: 16D1100-01

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
1,1-Dichloroethane	1.2	2.0	0.16	µg/L	1	J	EPA 624	4/29/16	5/3/16 0:16	EEH
1,1-Dichloroethylene	0.84	2.0	0.21	µg/L	1	J	EPA 624	4/29/16	5/3/16 0:16	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
1,1,1-Trichloroethane	31	2.0	0.094	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	4/29/16	5/3/16 0:16	EEH
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	102	70-130								
Toluene-d8	99.2	70-130								
4-Bromofluorobenzene	98.2	70-130								

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 16D1100

Date Received: 4/25/2016

Field Sample #: RW-2

Sampled: 4/22/2016 07:10

Sample ID: 16D1100-02

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
1,1-Dichloroethane	0.53	2.0	0.16	µg/L	1	J	EPA 624	4/29/16	5/3/16 0:43	EEH
1,1-Dichloroethylene	0.60	2.0	0.21	µg/L	1	J	EPA 624	4/29/16	5/3/16 0:43	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
1,1,1-Trichloroethane	25	2.0	0.094	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	4/29/16	5/3/16 0:43	EEH
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	104	70-130				5/3/16 0:43				
Toluene-d8	99.6	70-130				5/3/16 0:43				
4-Bromofluorobenzene	97.8	70-130				5/3/16 0:43				

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 16D1100

Date Received: 4/25/2016

Field Sample #: EFF 46 HZ

Sampled: 4/22/2016 07:20

Sample ID: 16D1100-03

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	4/29/16	5/2/16 23:50	EEH
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	105	70-130				5/2/16 23:50				
Toluene-d8	99.4	70-130				5/2/16 23:50				
4-Bromofluorobenzene	97.0	70-130				5/2/16 23:50				

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 16D1100

Date Received: 4/25/2016

Field Sample #: Trip Blanks

Sampled: 4/22/2016 00:00

Sample ID: 16D1100-04

Sample Matrix: Trip Blank Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	4/29/16	5/2/16 23:23	EEH
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	103	70-130								
Toluene-d8	99.2	70-130								
4-Bromofluorobenzene	99.0	70-130								

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Sample Extraction Data

Prep Method: SW-846 5030B-EPA 624

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
16D1100-01 [RW-1]	B147970	5	5.00	04/29/16
16D1100-02 [RW-2]	B147970	5	5.00	04/29/16
16D1100-03 [EFF 46 HZ]	B147970	5	5.00	04/29/16
16D1100-04 [Trip Blanks]	B147970	5	5.00	04/29/16

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL
Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

Batch B147970 - SW-846 5030B
Blank (B147970-BLK1)

Prepared: 04/29/16 Analyzed: 05/02/16

Benzene	ND	1.0	µg/L							
Bromodichloromethane	ND	2.0	µg/L							
Bromoform	ND	2.0	µg/L							
Bromomethane	ND	2.0	µg/L							
Carbon Tetrachloride	ND	2.0	µg/L							
Chlorobenzene	ND	2.0	µg/L							
Chlorodibromomethane	ND	2.0	µg/L							
Chloroethane	ND	2.0	µg/L							
2-Chloroethyl Vinyl Ether	ND	10	µg/L							
Chloroform	ND	2.0	µg/L							
Chloromethane	ND	2.0	µg/L							
1,2-Dichlorobenzene	ND	2.0	µg/L							
1,3-Dichlorobenzene	ND	2.0	µg/L							
1,4-Dichlorobenzene	ND	2.0	µg/L							
1,2-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethylene	ND	2.0	µg/L							
trans-1,2-Dichloroethylene	ND	2.0	µg/L							
1,2-Dichloropropane	ND	2.0	µg/L							
cis-1,3-Dichloropropene	ND	2.0	µg/L							
trans-1,3-Dichloropropene	ND	2.0	µg/L							
Ethylbenzene	ND	2.0	µg/L							
Methyl tert-Butyl Ether (MTBE)	ND	2.0	µg/L							
Methylene Chloride	ND	5.0	µg/L							
1,1,2,2-Tetrachloroethane	ND	2.0	µg/L							
Tetrachloroethylene	ND	2.0	µg/L							
Toluene	ND	1.0	µg/L							
1,1,1-Trichloroethane	ND	2.0	µg/L							
1,1,2-Trichloroethane	ND	2.0	µg/L							
Trichloroethylene	ND	2.0	µg/L							
Trichlorofluoromethane (Freon 11)	ND	2.0	µg/L							
Vinyl Chloride	ND	2.0	µg/L							
m+p Xylene	ND	2.0	µg/L							
o-Xylene	ND	2.0	µg/L							
Surrogate: 1,2-Dichloroethane-d4	25.2		µg/L	25.0		101	70-130			
Surrogate: Toluene-d8	24.6		µg/L	25.0		98.4	70-130			
Surrogate: 4-Bromofluorobenzene	24.4		µg/L	25.0		97.6	70-130			

LCS (B147970-BS1)

Prepared: 04/29/16 Analyzed: 05/02/16

Benzene	7.46	1.0	µg/L	10.0		74.6	37-151			
Bromodichloromethane	8.00	2.0	µg/L	10.0		80.0	35-155			
Bromoform	8.28	2.0	µg/L	10.0		82.8	45-169			
Bromomethane	9.11	2.0	µg/L	10.0		91.1	20-242			
Carbon Tetrachloride	7.88	2.0	µg/L	10.0		78.8	70-140			
Chlorobenzene	7.72	2.0	µg/L	10.0		77.2	37-160			
Chlorodibromomethane	8.06	2.0	µg/L	10.0		80.6	53-149			
Chloroethane	7.97	2.0	µg/L	10.0		79.7	70-130			
2-Chloroethyl Vinyl Ether	77.8	10	µg/L	100		77.8	10-305			
Chloroform	7.62	2.0	µg/L	10.0		76.2	51-138			
Chloromethane	9.85	2.0	µg/L	10.0		98.5	20-273			
1,2-Dichlorobenzene	8.23	2.0	µg/L	10.0		82.3	18-190			
1,3-Dichlorobenzene	8.31	2.0	µg/L	10.0		83.1	59-156			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL
Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch B147970 - SW-846 5030B										
LCS (B147970-BS1)				Prepared: 04/29/16 Analyzed: 05/02/16						
1,4-Dichlorobenzene	8.02	2.0	µg/L	10.0		80.2	18-190			
1,2-Dichloroethane	7.83	2.0	µg/L	10.0		78.3	49-155			
1,1-Dichloroethane	7.66	2.0	µg/L	10.0		76.6	59-155			
1,1-Dichloroethylene	7.40	2.0	µg/L	10.0		74.0	20-234			
trans-1,2-Dichloroethylene	7.76	2.0	µg/L	10.0		77.6	54-156			
1,2-Dichloropropane	7.58	2.0	µg/L	10.0		75.8	20-210			
cis-1,3-Dichloropropene	8.00	2.0	µg/L	10.0		80.0	20-227			
trans-1,3-Dichloropropene	7.70	2.0	µg/L	10.0		77.0	17-183			
Ethylbenzene	7.86	2.0	µg/L	10.0		78.6	37-162			
Methyl tert-Butyl Ether (MTBE)	8.01	2.0	µg/L	10.0		80.1	70-130			
Methylene Chloride	8.21	5.0	µg/L	10.0		82.1	50-221			
1,1,2,2-Tetrachloroethane	8.50	2.0	µg/L	10.0		85.0	46-157			
Tetrachloroethylene	7.91	2.0	µg/L	10.0		79.1	64-148			
Toluene	7.52	1.0	µg/L	10.0		75.2	47-150			
1,1,1-Trichloroethane	7.97	2.0	µg/L	10.0		79.7	52-162			
1,1,2-Trichloroethane	8.23	2.0	µg/L	10.0		82.3	52-150			
Trichloroethylene	7.82	2.0	µg/L	10.0		78.2	71-157			
Trichlorofluoromethane (Freon 11)	7.60	2.0	µg/L	10.0		76.0	17-181			
Vinyl Chloride	7.60	2.0	µg/L	10.0		76.0	20-251			
m+p Xylene	15.9	2.0	µg/L	20.0		79.6	70-130			
o-Xylene	8.04	2.0	µg/L	10.0		80.4	70-130			
Surrogate: 1,2-Dichloroethane-d4	26.2		µg/L	25.0		105	70-130			
Surrogate: Toluene-d8	24.6		µg/L	25.0		98.2	70-130			
Surrogate: 4-Bromofluorobenzene	25.0		µg/L	25.0		99.9	70-130			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
ND	Not Detected
RL	Reporting Limit
DL	Method Detection Limit
MCL	Maximum Contaminant Level
	Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
	No results have been blank subtracted unless specified in the case narrative section.
J	Detected but below the Reporting Limit (lowest calibration standard); therefore, result is an estimated concentration (CLP J-Flag).

CERTIFICATIONS
Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 624 in Water</i>	
Benzene	CT,MA,NH,NY,RI,NC,ME,VA
Bromodichloromethane	CT,MA,NH,NY,RI,NC,ME,VA
Bromoform	CT,MA,NH,NY,RI,NC,ME,VA
Bromomethane	CT,MA,NH,NY,RI,NC,ME,VA
Carbon Tetrachloride	CT,MA,NH,NY,RI,NC,ME,VA
Chlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
Chlorodibromomethane	CT,MA,NH,NY,RI,NC,ME,VA
Chloroethane	CT,MA,NH,NY,RI,NC,ME,VA
2-Chloroethyl Vinyl Ether	CT,MA,NH,NY,RI,NC,ME,VA
Chloroform	CT,MA,NH,NY,RI,NC,ME,VA
Chloromethane	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,3-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,4-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
trans-1,2-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichloropropane	CT,MA,NH,NY,RI,NC,ME,VA
cis-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA
trans-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA
Ethylbenzene	CT,MA,NH,NY,RI,NC,ME,VA
Methyl tert-Butyl Ether (MTBE)	NC
Methylene Chloride	CT,MA,NH,NY,RI,NC,ME,VA
1,1,2,2-Tetrachloroethane	CT,MA,NH,NY,RI,NC,ME,VA
Tetrachloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
Toluene	CT,MA,NH,NY,RI,NC,ME,VA
1,1,1-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1,2-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
Trichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
Trichlorofluoromethane (Freon 11)	CT,MA,NH,NY,RI,NC,ME,VA
Vinyl Chloride	CT,MA,NH,NY,RI,NC,ME,VA
m+p Xylene	CT,MA,NH,NY,RI,NC,VA
o-Xylene	CT,MA,NH,NY,RI,NC,VA

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

The CON-TEST Environmental Laboratory operates under the following certifications and accreditations:

Code	Description	Number	Expires
AIHA	AIHA-LAP, LLC	100033	02/1/2018
MA	Massachusetts DEP	M-MA100	06/30/2016
CT	Connecticut Department of Public Health	PH-0567	09/30/2017
NY	New York State Department of Health	10899 NELAP	04/1/2017
NH-S	New Hampshire Environmental Lab	2516 NELAP	02/5/2017
RI	Rhode Island Department of Health	LAO00112	12/30/2016
NC	North Carolina Div. of Water Quality	652	12/31/2016
NJ	New Jersey DEP	MA007 NELAP	06/30/2016
FL	Florida Department of Health	E871027 NELAP	06/30/2016
VT	Vermont Department of Health Lead Laboratory	LL015036	07/30/2016
ME	State of Maine	2011028	06/9/2017
VA	Commonwealth of Virginia	460217	12/14/2016
NH-P	New Hampshire Environmental Lab	2557 NELAP	09/6/2016

CHAIN OF CUSTODY RECORD

39 Spruce Street
East Longmeadow, MA 01028

Page 1 of 1

Phone: 413-525-2332

Fax: 413-525-6405

Email: info@contestlabs.com

www.contestlabs.com



Telephone: 518-250-7300

Project # 00266406.0000

Client PO#

Company Name: Arcadis

Address: 855 Route 146, STE 210, CLifton Park NY, 12065

Attention: J. Wyckoff

Project Location: S. Otsego, NY

Sampled By: L. Whalen

☐ Project Proposal Provided? (for billing purposes)

DATA DELIVERY (check all that apply)

☐ FAX ☒ EMAIL ☐ WEBSITE

Fax #

Email:

Format:

☐ PDF ☒ EXCEL ☐ GIS ☐ OTHER

☐ "Enhanced Data Package"

Collection

Con-Test Lab ID (laboratory use only)	Client Sample ID / Description	Beginning Date/Time	Ending Date/Time	Composite	Grab	*Matrix Code	Conc Code
01	RW-1	4/22/16	0700		X	GW	M
02	RW-2		0710		X		M
03	EFF 46 HZ		0720		X		L
04	Trip Blank				X		-

Comments:

Please use the following codes to let Con-Test know if a specific sample may be high in concentration in Matrix/Conc. Code Box:

H - High; M - Medium; L - Low; C - Clean; U - Unknown

Turnaround

☐ 5-Day
☐ 7 Day
☒ 10-Day or RUSH

☐ 24 hr
☐ 48 hr
☐ 72 hr
☐ 4 day

☐ Require lab approval

Program Information/Regulatory

☒ NY TOGS ☐ NY Restricted Use ☐ NY Part 375

☐ AWQ STDS ☐ NY Unrestricted Use ☐ NY CP-51

☐ NYC Sewer Discharge ☐ Other:

☐ Part 360 GW (Landfill)

Deliverables

☐ ASP-A ☐ Equis (1 file)

☒ ASP-B ☒ Equis (4 file)

JRNAROUND TIME (business days) STARTS AT 9:00 A.M. THE DAY AFTER SAMPLE RECEIPT UNLESS THERE ARE QUESTIONS ON YOUR CHAIN. IF THIS FORM IS NOT FILLED OUT COMPLETELY OR IS INCORRECT, TURNAROUND TIME WILL NOT START UNTIL ALL QUESTIONS ARE ANSWERED. PLEASE BE CAREFUL TO NOT CONTAMINATE THIS DOCUMENT

39 Spruce St.
East Longmeadow, MA. 01028
P: 413-525-2332
F: 413-525-6405
www.contestlabs.com



Page 1 of 2

Sample Receipt Checklist

CLIENT NAME: Arcadis RECEIVED BY: PB DATE: 4/25/2016

1) Was the chain(s) of custody relinquished and signed? Yes x No No COC Incl.

2) Does the chain agree with the samples? Yes x No

If not, explain:

3) Are all the samples in good condition? Yes x No

If not, explain:

4) How were the samples received:

On Ice x Direct from Sampling Ambient In Cooler(s) x

Were the samples received in Temperature Compliance of (2-6°C)? Yes x No N/A

Temperature °C by Temp blank 3 Temperature °C by Temp gun

5) Are there Dissolved samples for the lab to filter? Yes No x

Who was notified Date Time

6) Are there any RUSH or SHORT HOLDING TIME samples? Yes No x

Who was notified Date Time

Proscience

Permission to subcontract samples? Yes No
(Walk-in clients only) if not already approved

Client Signature:

7) Location where samples are stored:

8) Do all samples have the proper Acid pH: Yes No N/A x

9) Do all samples have the proper Base pH: Yes No N/A x

10) Was the PC notified of any discrepancies with the CoC vs the samples: Yes N/A x

Containers received at Con-Test

	# of containers			# of containers
1 Liter Amber			16 oz amber	
500 mL Amber			8 oz amber/clear jar	
250 mL Amber (8oz amber)			4 oz amber/clear jar	
1 Liter Plastic			2 oz amber/clear jar	
500 mL Plastic			Plastic Bag / Ziploc	
250 mL plastic			SOC Kit	
40 mL Vial - type listed below	14		Perchlorate Kit	
Colisure / bacteria bottle			Flashpoint bottle	
Dissolved Oxygen bottle			Other glass jar	
Encore			Other	

40 mL vials: # HCl 14 # Methanol

Doc# 277: # Bisulfate # DI Water

Rev. 4 August 2013 # Thiosulfate Unpreserved

Time and Date Frozen:

Login Sample Receipt Checklist
(Rejection Criteria Listing - Using Sample Acceptance Policy)
Any False statement will be brought to the attention of Client

<u>Question</u>	<u>Answer (True/False)</u>		<u>Comment</u>
	T/F/NA		
1) The cooler's custody seal, if present, is intact.	NA		
2) The cooler or samples do not appear to have been compromised or tampered with.	T		
3) Samples were received on ice.	T		
4) Cooler Temperature is acceptable.	T		
5) Cooler Temperature is recorded.	T		
6) COC is filled out in ink and legible.	T		
7) COC is filled out with all pertinent information.	T		
8) Field Sampler's name present on COC.	T		
9) There are no discrepancies between the sample IDs on the container and the COC.	T		
10) Samples are received within Holding Time.	T		
11) Sample containers have legible labels.	T		
12) Containers are not broken or leaking.	T		
13) Air Cassettes are not broken/open.	NA		
14) Sample collection date/times are provided.	T		
15) Appropriate sample containers are used.	T		
16) Proper collection media used.	T		
17) No headspace sample bottles are completely filled.	T		
18) There is sufficient volume for all requested analyses, including any requested MS/MSDs.	T		
19) Trip blanks provided if applicable.	T		
20) VOA sample vials do not have head space or bubble is <6mm (1/4") in diameter.	T		
21) Samples do not require splitting or compositing.	T		

Doc #277 Rev. 4 August 2013

Who notified of False statements?

Log-In Technician Initials: PB

Date/Time:

Date/Time: 4/25/16

May 31, 2016

Jeremy Wyckoff
Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065

Project Location: S. Otselic, NY
Client Job Number:
Project Number: 00266406.0000
Laboratory Work Order Number: 16E1189

Enclosed are results of analyses for samples received by the laboratory on May 26, 2016. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "Aaron L. Benoit", with a horizontal line extending to the right.

Aaron L. Benoit
Project Manager

July 12, 2016

Jeremy Wyckoff
Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065

Project Location: S. Otselic, NY
Client Job Number:
Project Number: 00266406.0000
Laboratory Work Order Number: 16F1367

Enclosed are results of analyses for samples received by the laboratory on June 27, 2016. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "Aaron L. Benoit", with a horizontal line extending to the right.

Aaron L. Benoit
Project Manager

Table of Contents

Sample Summary	3
Case Narrative	4
Sample Results	5
16F1367-01	5
16F1367-02	6
16F1367-03	7
16F1367-04	8
Sample Preparation Information	9
QC Data	10
Volatile Organic Compounds by GC/MS	10
B153127	10
Flag/Qualifier Summary	12
Certifications	13
Chain of Custody/Sample Receipt	15

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065
ATTN: Jeremy Wyckoff

REPORT DATE: 7/12/2016

PURCHASE ORDER NUMBER:

PROJECT NUMBER: 00266406.0000

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 16F1367

The results of analyses performed on the following samples submitted to the CON-TEST Analytical Laboratory are found in this report.

PROJECT LOCATION: S. Otselic, NY

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
RW-1	16F1367-01	Ground Water		EPA 624	
RW-2	16F1367-02	Ground Water		EPA 624	
EFF 46 HZ	16F1367-03	Ground Water		EPA 624	
Trip Blank	16F1367-04	Trip Blank Water		EPA 624	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Con-Test Analytical Laboratory for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.

A handwritten signature in black ink, appearing to read "Tod Kopyscinski", written in a cursive style.

Tod E. Kopyscinski
Laboratory Director

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 16F1367

Date Received: 6/27/2016

Field Sample #: RW-1

Sampled: 6/24/2016 07:30

Sample ID: 16F1367-01

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
Bromodichloromethane	ND	2.0	0.30	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
Carbon Tetrachloride	ND	2.0	0.25	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
Chloromethane	ND	2.0	0.55	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
1,1-Dichloroethane	1.1	2.0	0.16	µg/L	1	J	EPA 624	7/7/16	7/8/16 7:52	MFF
1,1-Dichloroethylene	0.69	2.0	0.21	µg/L	1	J	EPA 624	7/7/16	7/8/16 7:52	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
Tetrachloroethylene	ND	2.0	0.27	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
1,1,1-Trichloroethane	32	2.0	0.13	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
1,1,2-Trichloroethane	ND	2.0	0.24	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
m+p Xylene	ND	2.0	0.26	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	7/7/16	7/8/16 7:52	MFF
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	98.4	70-130								
Toluene-d8	97.3	70-130								
4-Bromofluorobenzene	104	70-130								

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 16F1367

Date Received: 6/27/2016

Field Sample #: RW-2

Sampled: 6/24/2016 07:35

Sample ID: 16F1367-02

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
Bromodichloromethane	ND	2.0	0.30	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
Carbon Tetrachloride	ND	2.0	0.25	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
Chloromethane	ND	2.0	0.55	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
1,1-Dichloroethane	0.58	2.0	0.16	µg/L	1	J	EPA 624	7/7/16	7/8/16 8:19	MFF
1,1-Dichloroethylene	0.58	2.0	0.21	µg/L	1	J	EPA 624	7/7/16	7/8/16 8:19	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
Tetrachloroethylene	ND	2.0	0.27	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
1,1,1-Trichloroethane	33	2.0	0.13	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
1,1,2-Trichloroethane	ND	2.0	0.24	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
m+p Xylene	ND	2.0	0.26	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	7/7/16	7/8/16 8:19	MFF
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	99.0	70-130								
Toluene-d8	97.0	70-130								
4-Bromofluorobenzene	102	70-130								

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 16F1367

Date Received: 6/27/2016

Field Sample #: EFF 46 HZ

Sampled: 6/24/2016 07:40

Sample ID: 16F1367-03

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
Bromodichloromethane	ND	2.0	0.30	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
Carbon Tetrachloride	ND	2.0	0.25	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
Chloromethane	ND	2.0	0.55	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
Tetrachloroethylene	ND	2.0	0.27	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
1,1,1-Trichloroethane	ND	2.0	0.13	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
1,1,2-Trichloroethane	ND	2.0	0.24	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
m+p Xylene	ND	2.0	0.26	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	7/7/16	7/8/16 6:58	MFF
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	98.5	70-130								
Toluene-d8	97.4	70-130								
4-Bromofluorobenzene	104	70-130								

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 16F1367

Date Received: 6/27/2016

Field Sample #: Trip Blank

Sampled: 6/24/2016 00:00

Sample ID: 16F1367-04

Sample Matrix: Trip Blank Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
Bromodichloromethane	ND	2.0	0.30	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
Carbon Tetrachloride	ND	2.0	0.25	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
Chloromethane	ND	2.0	0.55	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
Tetrachloroethylene	ND	2.0	0.27	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
Toluene	0.96	1.0	0.17	µg/L	1	J	EPA 624	7/7/16	7/8/16 7:25	MFF
1,1,1-Trichloroethane	ND	2.0	0.13	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
1,1,2-Trichloroethane	ND	2.0	0.24	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	7/7/16	7/8/16 7:25	MFF
m+p Xylene	0.46	2.0	0.26	µg/L	1	J	EPA 624	7/7/16	7/8/16 7:25	MFF
o-Xylene	0.19	2.0	0.13	µg/L	1	J	EPA 624	7/7/16	7/8/16 7:25	MFF
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	96.6	70-130								
Toluene-d8	97.7	70-130								
4-Bromofluorobenzene	104	70-130								

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Sample Extraction Data

Prep Method: SW-846 5030B-EPA 624

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
16F1367-01 [RW-1]	B153127	5	5.00	07/07/16
16F1367-02 [RW-2]	B153127	5	5.00	07/07/16
16F1367-03 [EFF 46 HZ]	B153127	5	5.00	07/07/16
16F1367-04 [Trip Blank]	B153127	5	5.00	07/07/16

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL
Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

Batch B153127 - SW-846 5030B
Blank (B153127-BLK1)

Prepared & Analyzed: 07/07/16

Benzene	ND	1.0	µg/L							
Bromodichloromethane	ND	2.0	µg/L							
Bromoform	ND	2.0	µg/L							
Bromomethane	ND	2.0	µg/L							
Carbon Tetrachloride	ND	2.0	µg/L							
Chlorobenzene	ND	2.0	µg/L							
Chlorodibromomethane	ND	2.0	µg/L							
Chloroethane	ND	2.0	µg/L							
2-Chloroethyl Vinyl Ether	ND	10	µg/L							
Chloroform	ND	2.0	µg/L							
Chloromethane	ND	2.0	µg/L							
1,2-Dichlorobenzene	ND	2.0	µg/L							
1,3-Dichlorobenzene	ND	2.0	µg/L							
1,4-Dichlorobenzene	ND	2.0	µg/L							
1,2-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethylene	ND	2.0	µg/L							
trans-1,2-Dichloroethylene	ND	2.0	µg/L							
1,2-Dichloropropane	ND	2.0	µg/L							
cis-1,3-Dichloropropene	ND	2.0	µg/L							
trans-1,3-Dichloropropene	ND	2.0	µg/L							
Ethylbenzene	ND	2.0	µg/L							
Methyl tert-Butyl Ether (MTBE)	ND	2.0	µg/L							
Methylene Chloride	ND	5.0	µg/L							
1,1,2,2-Tetrachloroethane	ND	2.0	µg/L							
Tetrachloroethylene	ND	2.0	µg/L							
Toluene	ND	1.0	µg/L							
1,1,1-Trichloroethane	ND	2.0	µg/L							
1,1,2-Trichloroethane	ND	2.0	µg/L							
Trichloroethylene	ND	2.0	µg/L							
Trichlorofluoromethane (Freon 11)	ND	2.0	µg/L							
Vinyl Chloride	ND	2.0	µg/L							
m+p Xylene	ND	2.0	µg/L							
o-Xylene	ND	2.0	µg/L							
Surrogate: 1,2-Dichloroethane-d4	25.0		µg/L	25.0		100	70-130			
Surrogate: Toluene-d8	24.3		µg/L	25.0		97.1	70-130			
Surrogate: 4-Bromofluorobenzene	25.8		µg/L	25.0		103	70-130			

LCS (B153127-BS1)

Prepared & Analyzed: 07/07/16

Benzene	8.52	1.0	µg/L	10.0		85.2	37-151			
Bromodichloromethane	8.90	2.0	µg/L	10.0		89.0	35-155			
Bromoform	11.0	2.0	µg/L	10.0		110	45-169			
Bromomethane	10.7	2.0	µg/L	10.0		107	20-242			
Carbon Tetrachloride	10.1	2.0	µg/L	10.0		101	70-140			
Chlorobenzene	8.85	2.0	µg/L	10.0		88.5	37-160			
Chlorodibromomethane	9.46	2.0	µg/L	10.0		94.6	53-149			
Chloroethane	12.5	2.0	µg/L	10.0		125	70-130			
2-Chloroethyl Vinyl Ether	90.8	10	µg/L	100		90.8	10-305			
Chloroform	8.59	2.0	µg/L	10.0		85.9	51-138			
Chloromethane	13.9	2.0	µg/L	10.0		139	20-273			
1,2-Dichlorobenzene	9.09	2.0	µg/L	10.0		90.9	18-190			
1,3-Dichlorobenzene	8.96	2.0	µg/L	10.0		89.6	59-156			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL
Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch B153127 - SW-846 5030B										
LCS (B153127-BS1)				Prepared & Analyzed: 07/07/16						
1,4-Dichlorobenzene	8.81	2.0	µg/L	10.0		88.1	18-190			
1,2-Dichloroethane	8.98	2.0	µg/L	10.0		89.8	49-155			
1,1-Dichloroethane	8.16	2.0	µg/L	10.0		81.6	59-155			
1,1-Dichloroethylene	9.03	2.0	µg/L	10.0		90.3	20-234			
trans-1,2-Dichloroethylene	8.05	2.0	µg/L	10.0		80.5	54-156			
1,2-Dichloropropane	8.22	2.0	µg/L	10.0		82.2	20-210			
cis-1,3-Dichloropropene	9.08	2.0	µg/L	10.0		90.8	20-227			
trans-1,3-Dichloropropene	9.47	2.0	µg/L	10.0		94.7	17-183			
Ethylbenzene	9.92	2.0	µg/L	10.0		99.2	37-162			
Methyl tert-Butyl Ether (MTBE)	9.85	2.0	µg/L	10.0		98.5	70-130			
Methylene Chloride	9.11	5.0	µg/L	10.0		91.1	50-221			
1,1,2,2-Tetrachloroethane	9.69	2.0	µg/L	10.0		96.9	46-157			
Tetrachloroethylene	9.72	2.0	µg/L	10.0		97.2	64-148			
Toluene	9.27	1.0	µg/L	10.0		92.7	47-150			
1,1,1-Trichloroethane	10.0	2.0	µg/L	10.0		100	52-162			
1,1,2-Trichloroethane	9.12	2.0	µg/L	10.0		91.2	52-150			
Trichloroethylene	9.05	2.0	µg/L	10.0		90.5	71-157			
Trichlorofluoromethane (Freon 11)	11.9	2.0	µg/L	10.0		119	17-181			
Vinyl Chloride	16.4	2.0	µg/L	10.0		164	20-251			
m+p Xylene	20.1	2.0	µg/L	20.0		100	70-130			
o-Xylene	9.92	2.0	µg/L	10.0		99.2	70-130			
Surrogate: 1,2-Dichloroethane-d4	26.1		µg/L	25.0		105	70-130			
Surrogate: Toluene-d8	24.5		µg/L	25.0		98.0	70-130			
Surrogate: 4-Bromofluorobenzene	26.0		µg/L	25.0		104	70-130			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
ND	Not Detected
RL	Reporting Limit
DL	Method Detection Limit
MCL	Maximum Contaminant Level
	Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
	No results have been blank subtracted unless specified in the case narrative section.
J	Detected but below the Reporting Limit (lowest calibration standard); therefore, result is an estimated concentration (CLP J-Flag).

CERTIFICATIONS

Certified Analyses included in this Report

Analyte	Certifications
EPA 624 in Water	
Benzene	CT,MA,NH,NY,RI,NC,ME,VA
Bromodichloromethane	CT,MA,NH,NY,RI,NC,ME,VA
Bromoform	CT,MA,NH,NY,RI,NC,ME,VA
Bromomethane	CT,MA,NH,NY,RI,NC,ME,VA
Carbon Tetrachloride	CT,MA,NH,NY,RI,NC,ME,VA
Chlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
Chlorodibromomethane	CT,MA,NH,NY,RI,NC,ME,VA
Chloroethane	CT,MA,NH,NY,RI,NC,ME,VA
2-Chloroethyl Vinyl Ether	CT,MA,NH,NY,RI,NC,ME,VA
Chloroform	CT,MA,NH,NY,RI,NC,ME,VA
Chloromethane	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,3-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,4-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
trans-1,2-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichloropropane	CT,MA,NH,NY,RI,NC,ME,VA
cis-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA
trans-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA
Ethylbenzene	CT,MA,NH,NY,RI,NC,ME,VA
Methyl tert-Butyl Ether (MTBE)	NY,NC
Methylene Chloride	CT,MA,NH,NY,RI,NC,ME,VA
1,1,2,2-Tetrachloroethane	CT,MA,NH,NY,RI,NC,ME,VA
Tetrachloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
Toluene	CT,MA,NH,NY,RI,NC,ME,VA
1,1,1-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1,2-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
Trichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
Trichlorofluoromethane (Freon 11)	CT,MA,NH,NY,RI,NC,ME,VA
Vinyl Chloride	CT,MA,NH,NY,RI,NC,ME,VA
m+p Xylene	CT,MA,NH,NY,RI,NC,VA
o-Xylene	CT,MA,NH,NY,RI,NC,VA

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

The CON-TEST Environmental Laboratory operates under the following certifications and accreditations:

Code	Description	Number	Expires
AIHA	AIHA-LAP, LLC	100033	02/1/2018
MA	Massachusetts DEP	M-MA100	06/30/2016
CT	Connecticut Department of Public Health	PH-0567	09/30/2017
NY	New York State Department of Health	10899 NELAP	04/1/2017
NH-S	New Hampshire Environmental Lab	2516 NELAP	02/5/2017
RI	Rhode Island Department of Health	LAO00112	12/30/2016
NC	North Carolina Div. of Water Quality	652	12/31/2016
NJ	New Jersey DEP	MA007 NELAP	06/30/2017
FL	Florida Department of Health	E871027 NELAP	06/30/2017
VT	Vermont Department of Health Lead Laboratory	LL015036	07/30/2017
ME	State of Maine	2011028	06/9/2017
VA	Commonwealth of Virginia	460217	12/14/2016
NH-P	New Hampshire Environmental Lab	2557 NELAP	09/6/2016



Phone: 413-525-2332
Fax: 413-525-6405
Email: info@contestlabs.com
www.contestlabs.com

Company Name: Arcadi's

Address: 855 Route 146, STE 210

City: Clifton Park NY 12065

Attention: J. Wyckoff

Project Location: S. Otselec, NY.

Sampled By: L. Whalen

Project Proposal Provided? (for billing purposes)

CHAIN OF CUSTODY RECORD

NEW YORK STATE

39 Spruce Street
East Longmeadow, MA 01028

Page 1 of 1

Telephone: 518-250-7300

Project # 00266406.0000

Client PO#

DATA DELIVERY (check all that apply)
☐ FAX ☒ EMAIL ☐ WEBSITE

Fax #

Email:

Format:

PDF ☒ EXCEL ☒ GIS ☐
☐ OTHER

☐ "Enhanced Data Package"

Collection

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Conc. Code

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

6/24/16 0730

6/24/16 0735

6/24/16 0740

-

6/24/16 0730

6/24/16 0735

6/24/16 0740

-

6/24/16 0730

6/24/16 0735

6/24/16 0740

-

6/24/16 0730

6/24/16 0735

6/24/16 0740

-

6/24/16 0730

6/24/16 0735

6/24/16 0740

-

6/24/16 0730

6/24/16 0735

6/24/16 0740

-

6/24/16 0730

6/24/16 0735

6/24/16 0740

-

6/24/16 0730

6/24/16 0735

6/24/16 0740

-

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

Relinquished by: (signature)

Date/Time: 6/24/16

39 Spruce St.
East Longmeadow, MA. 01028
P: 413-525-2332
F: 413-525-6405
www.contestlabs.com



Page 1 of 2

Sample Receipt Checklist

CLIENT NAME: Accadis RECEIVED BY: PB DATE: 6-27-16

1) Was the chain(s) of custody relinquished and signed? Yes ☒ No ☐ No COC Incl.

2) Does the chain agree with the samples?

Yes ☒ No ☐

If not, explain:

3) Are all the samples in good condition?

Yes ☒ No ☐

If not, explain:

4) How were the samples received:

On Ice ☐ Direct from Sampling ☐ Ambient ☐ In Cooler(s) ☒ *See comments

Were the samples received in Temperature Compliance of (2-6°C)? Yes ☐ No ☒ N/A ☐

Temperature °C by Temp blank ☐ Temperature °C by Temp gun 26.3

5) Are there Dissolved samples for the lab to filter?

Yes ☐ No ☒

Who was notified ☐ Date ☐ Time ☐

6) Are there any RUSH or SHORT HOLDING TIME samples?

Yes ☐ No ☒

Who was notified ☐ Date ☐ Time ☐

7) Location where samples are stored:

Log in

Permission to subcontract samples? Yes No

(Walk-in clients only) if not already approved

Client Signature: ☐

8) Do all samples have the proper Acid pH: Yes ☐ No ☐ N/A ☒

9) Do all samples have the proper Base pH: Yes ☐ No ☐ N/A ☒

10) Was the PC notified of any discrepancies with the CoC vs the samples: Yes ☐ N/A ☒

Containers received at Con-Test

	# of containers			# of containers
1 Liter Amber			16 oz amber	
500 mL Amber			8 oz amber/clear jar	
250 mL Amber (8oz amber)			4 oz amber/clear jar	
1 Liter Plastic			2 oz amber/clear jar	
500 mL Plastic			Plastic Bag / Ziploc	
250 mL plastic			SOC Kit	
40 mL Vial - type listed below	<u>11</u>		Perchlorate Kit	
Colisure / bacteria bottle			Flashpoint bottle	
Dissolved Oxygen bottle			Other glass jar	
Encore			Other	

Samples were received in a cooler with 2 bags
of warm water. coolest temp I could find was 26.3

40 mL vials: # HCl 11 # Methanol ☐

Time and Date Frozen: ☐

Doc# 277 # Bisulfate ☐ # DI Water ☐

Rev. 4 August 2013 # Thiosulfate ☐ Unpreserved ☐

Login Sample Receipt Checklist

(Rejection Criteria Listing - Using Sample Acceptance Policy)

Any False statement will be brought to the attention of Client

Question	Answer (True/False)		Comment
	T/F/NA		
1) The cooler's custody seal, if present, is intact.	NA		
2) The cooler or samples do not appear to have been compromised or tampered with.	T		
3) Samples were received on ice.	—		Ice was melted
4) Cooler Temperature is acceptable.	F		
5) Cooler Temperature is recorded.	T		
6) COC is filled out in ink and legible.	T		
7) COC is filled out with all pertinent information.	T		
8) Field Sampler's name present on COC.	T		
9) There are no discrepancies between the sample IDs on the container and the COC.	T		
10) Samples are received within Holding Time.	T		
11) Sample containers have legible labels.	T		
12) Containers are not broken or leaking.	T		
13) Air Cassettes are not broken/open.	NA		
14) Sample collection date/times are provided.	T		
15) Appropriate sample containers are used.	T		
16) Proper collection media used.	T		
17) No headspace sample bottles are completely filled.	T		
18) There is sufficient volume for all requested analyses, including any requested MS/MSDs.	T		
19) Trip blanks provided if applicable.	T		
20) VOA sample vials do not have head space or bubble is <6mm (1/4") in diameter.	T		
21) Samples do not require splitting or compositing.	T		

Doc #277 Rev. 4 August 2013

Who notified of False statements?

Log-In Technician Initials: PRB

Date/Time:

Date/Time: 6.21.16

Table of Contents

Sample Summary	3
Case Narrative	4
Sample Results	5
16E1189-01	5
16E1189-02	6
16E1189-03	7
16E1189-04	8
Sample Preparation Information	9
QC Data	10
Volatile Organic Compounds by GC/MS	10
B150221	10
Flag/Qualifier Summary	12
Certifications	13
Chain of Custody/Sample Receipt	15

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065
ATTN: Jeremy Wyckoff

REPORT DATE: 5/31/2016

PURCHASE ORDER NUMBER:

PROJECT NUMBER: 00266406.0000

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 16E1189

The results of analyses performed on the following samples submitted to the CON-TEST Analytical Laboratory are found in this report.

PROJECT LOCATION: S. Otselic, NY

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
RW-1	16E1189-01	Ground Water		EPA 624	
RW-2	16E1189-02	Ground Water		EPA 624	
EFF 46 HZ	16E1189-03	Ground Water		EPA 624	
Trip Blank	16E1189-04	Ground Water		EPA 624	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Con-Test Analytical Laboratory for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.

A handwritten signature in black ink, appearing to read "Tod Kopyscinski". The signature is fluid and cursive, with the first name "Tod" being more prominent.

Tod E. Kopyscinski
Laboratory Director

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 16E1189

Date Received: 5/26/2016

Field Sample #: RW-1

Sampled: 5/23/2016 06:30

Sample ID: 16E1189-01

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
1,1-Dichloroethane	1.3	2.0	0.16	µg/L	1	J	EPA 624	5/27/16	5/28/16 12:55	EEH
1,1-Dichloroethylene	0.77	2.0	0.21	µg/L	1	J	EPA 624	5/27/16	5/28/16 12:55	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
1,1,1-Trichloroethane	34	2.0	0.094	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	5/27/16	5/28/16 12:55	EEH
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	113	70-130				5/28/16 12:55				
Toluene-d8	98.7	70-130				5/28/16 12:55				
4-Bromofluorobenzene	100	70-130				5/28/16 12:55				

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 16E1189

Date Received: 5/26/2016

Field Sample #: RW-2

Sampled: 5/23/2016 06:40

Sample ID: 16E1189-02

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
1,1-Dichloroethane	0.56	2.0	0.16	µg/L	1	J	EPA 624	5/27/16	5/28/16 13:21	EEH
1,1-Dichloroethylene	0.62	2.0	0.21	µg/L	1	J	EPA 624	5/27/16	5/28/16 13:21	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
1,1,1-Trichloroethane	28	2.0	0.094	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	5/27/16	5/28/16 13:21	EEH
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	111	70-130				5/28/16 13:21				
Toluene-d8	98.4	70-130				5/28/16 13:21				
4-Bromofluorobenzene	101	70-130				5/28/16 13:21				

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 16E1189

Date Received: 5/26/2016

Field Sample #: EFF 46 HZ

Sampled: 5/23/2016 06:50

Sample ID: 16E1189-03

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	5/27/16	5/28/16 11:34	EEH
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	111	70-130				5/28/16 11:34				
Toluene-d8	98.1	70-130				5/28/16 11:34				
4-Bromofluorobenzene	98.7	70-130				5/28/16 11:34				

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 16E1189

Date Received: 5/26/2016

Field Sample #: Trip Blank

Sampled: 5/23/2016 00:00

Sample ID: 16E1189-04

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
Toluene	0.79	1.0	0.17	µg/L	1	J	EPA 624	5/27/16	5/28/16 12:01	EEH
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
m+p Xylene	0.30	2.0	0.25	µg/L	1	J	EPA 624	5/27/16	5/28/16 12:01	EEH
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	5/27/16	5/28/16 12:01	EEH
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	111	70-130								
Toluene-d8	98.3	70-130								
4-Bromofluorobenzene	97.8	70-130								

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Sample Extraction Data

Prep Method: SW-846 5030B-EPA 624

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
16E1189-01 [RW-1]	B150221	5	5.00	05/27/16
16E1189-02 [RW-2]	B150221	5	5.00	05/27/16
16E1189-03 [EFF 46 HZ]	B150221	5	5.00	05/27/16
16E1189-04 [Trip Blank]	B150221	5	5.00	05/27/16

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL
Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

Batch B150221 - SW-846 5030B
Blank (B150221-BLK1)

Prepared: 05/27/16 Analyzed: 05/28/16

Benzene	ND	1.0	µg/L							
Bromodichloromethane	ND	2.0	µg/L							
Bromoform	ND	2.0	µg/L							
Bromomethane	ND	2.0	µg/L							
Carbon Tetrachloride	ND	2.0	µg/L							
Chlorobenzene	ND	2.0	µg/L							
Chlorodibromomethane	ND	2.0	µg/L							
Chloroethane	ND	2.0	µg/L							
2-Chloroethyl Vinyl Ether	ND	10	µg/L							
Chloroform	ND	2.0	µg/L							
Chloromethane	ND	2.0	µg/L							
1,2-Dichlorobenzene	ND	2.0	µg/L							
1,3-Dichlorobenzene	ND	2.0	µg/L							
1,4-Dichlorobenzene	ND	2.0	µg/L							
1,2-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethylene	ND	2.0	µg/L							
trans-1,2-Dichloroethylene	ND	2.0	µg/L							
1,2-Dichloropropane	ND	2.0	µg/L							
cis-1,3-Dichloropropene	ND	2.0	µg/L							
trans-1,3-Dichloropropene	ND	2.0	µg/L							
Ethylbenzene	ND	2.0	µg/L							
Methyl tert-Butyl Ether (MTBE)	ND	2.0	µg/L							
Methylene Chloride	ND	5.0	µg/L							
1,1,2,2-Tetrachloroethane	ND	2.0	µg/L							
Tetrachloroethylene	ND	2.0	µg/L							
Toluene	ND	1.0	µg/L							
1,1,1-Trichloroethane	ND	2.0	µg/L							
1,1,2-Trichloroethane	ND	2.0	µg/L							
Trichloroethylene	ND	2.0	µg/L							
Trichlorofluoromethane (Freon 11)	ND	2.0	µg/L							
Vinyl Chloride	ND	2.0	µg/L							
m+p Xylene	ND	2.0	µg/L							
o-Xylene	ND	2.0	µg/L							
Surrogate: 1,2-Dichloroethane-d4	28.3		µg/L	25.0		113	70-130			
Surrogate: Toluene-d8	24.7		µg/L	25.0		98.7	70-130			
Surrogate: 4-Bromofluorobenzene	25.1		µg/L	25.0		100	70-130			

LCS (B150221-BS1)

Prepared & Analyzed: 05/27/16

Benzene	8.29	1.0	µg/L	10.0		82.9	37-151			
Bromodichloromethane	9.69	2.0	µg/L	10.0		96.9	35-155			
Bromoform	10.9	2.0	µg/L	10.0		109	45-169			
Bromomethane	9.27	2.0	µg/L	10.0		92.7	20-242			
Carbon Tetrachloride	10.2	2.0	µg/L	10.0		102	70-140			
Chlorobenzene	9.20	2.0	µg/L	10.0		92.0	37-160			
Chlorodibromomethane	9.94	2.0	µg/L	10.0		99.4	53-149			
Chloroethane	9.56	2.0	µg/L	10.0		95.6	70-130			
2-Chloroethyl Vinyl Ether	95.9	10	µg/L	100		95.9	10-305			
Chloroform	9.27	2.0	µg/L	10.0		92.7	51-138			
Chloromethane	12.4	2.0	µg/L	10.0		124	20-273			
1,2-Dichlorobenzene	9.69	2.0	µg/L	10.0		96.9	18-190			
1,3-Dichlorobenzene	9.75	2.0	µg/L	10.0		97.5	59-156			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL
Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch B150221 - SW-846 5030B										
LCS (B150221-BS1)				Prepared & Analyzed: 05/27/16						
1,4-Dichlorobenzene	9.20	2.0	µg/L	10.0		92.0	18-190			
1,2-Dichloroethane	10.0	2.0	µg/L	10.0		100	49-155			
1,1-Dichloroethane	9.01	2.0	µg/L	10.0		90.1	59-155			
1,1-Dichloroethylene	10.4	2.0	µg/L	10.0		104	20-234			
trans-1,2-Dichloroethylene	9.40	2.0	µg/L	10.0		94.0	54-156			
1,2-Dichloropropane	9.04	2.0	µg/L	10.0		90.4	20-210			
cis-1,3-Dichloropropene	9.16	2.0	µg/L	10.0		91.6	20-227			
trans-1,3-Dichloropropene	9.24	2.0	µg/L	10.0		92.4	17-183			
Ethylbenzene	9.40	2.0	µg/L	10.0		94.0	37-162			
Methyl tert-Butyl Ether (MTBE)	9.54	2.0	µg/L	10.0		95.4	70-130			
Methylene Chloride	11.1	5.0	µg/L	10.0		111	50-221			
1,1,2,2-Tetrachloroethane	9.87	2.0	µg/L	10.0		98.7	46-157			
Tetrachloroethylene	9.71	2.0	µg/L	10.0		97.1	64-148			
Toluene	8.83	1.0	µg/L	10.0		88.3	47-150			
1,1,1-Trichloroethane	10.1	2.0	µg/L	10.0		101	52-162			
1,1,2-Trichloroethane	9.32	2.0	µg/L	10.0		93.2	52-150			
Trichloroethylene	9.44	2.0	µg/L	10.0		94.4	71-157			
Trichlorofluoromethane (Freon 11)	10.1	2.0	µg/L	10.0		101	17-181			
Vinyl Chloride	10.2	2.0	µg/L	10.0		102	20-251			
m+p Xylene	19.1	2.0	µg/L	20.0		95.6	70-130			
o-Xylene	9.62	2.0	µg/L	10.0		96.2	70-130			
Surrogate: 1,2-Dichloroethane-d4	27.6		µg/L	25.0		110	70-130			
Surrogate: Toluene-d8	24.2		µg/L	25.0		96.6	70-130			
Surrogate: 4-Bromofluorobenzene	25.4		µg/L	25.0		101	70-130			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
ND	Not Detected
RL	Reporting Limit
DL	Method Detection Limit
MCL	Maximum Contaminant Level
	Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
	No results have been blank subtracted unless specified in the case narrative section.
J	Detected but below the Reporting Limit (lowest calibration standard); therefore, result is an estimated concentration (CLP J-Flag).

CERTIFICATIONS
Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 624 in Water</i>	
Benzene	CT,MA,NH,NY,RI,NC,ME,VA
Bromodichloromethane	CT,MA,NH,NY,RI,NC,ME,VA
Bromoform	CT,MA,NH,NY,RI,NC,ME,VA
Bromomethane	CT,MA,NH,NY,RI,NC,ME,VA
Carbon Tetrachloride	CT,MA,NH,NY,RI,NC,ME,VA
Chlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
Chlorodibromomethane	CT,MA,NH,NY,RI,NC,ME,VA
Chloroethane	CT,MA,NH,NY,RI,NC,ME,VA
2-Chloroethyl Vinyl Ether	CT,MA,NH,NY,RI,NC,ME,VA
Chloroform	CT,MA,NH,NY,RI,NC,ME,VA
Chloromethane	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,3-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,4-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
trans-1,2-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichloropropane	CT,MA,NH,NY,RI,NC,ME,VA
cis-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA
trans-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA
Ethylbenzene	CT,MA,NH,NY,RI,NC,ME,VA
Methyl tert-Butyl Ether (MTBE)	NC
Methylene Chloride	CT,MA,NH,NY,RI,NC,ME,VA
1,1,2,2-Tetrachloroethane	CT,MA,NH,NY,RI,NC,ME,VA
Tetrachloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
Toluene	CT,MA,NH,NY,RI,NC,ME,VA
1,1,1-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1,2-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
Trichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
Trichlorofluoromethane (Freon 11)	CT,MA,NH,NY,RI,NC,ME,VA
Vinyl Chloride	CT,MA,NH,NY,RI,NC,ME,VA
m+p Xylene	CT,MA,NH,NY,RI,NC,VA
o-Xylene	CT,MA,NH,NY,RI,NC,VA

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

The CON-TEST Environmental Laboratory operates under the following certifications and accreditations:

Code	Description	Number	Expires
AIHA	AIHA-LAP, LLC	100033	02/1/2018
MA	Massachusetts DEP	M-MA100	06/30/2016
CT	Connecticut Department of Public Health	PH-0567	09/30/2017
NY	New York State Department of Health	10899 NELAP	04/1/2017
NH-S	New Hampshire Environmental Lab	2516 NELAP	02/5/2017
RI	Rhode Island Department of Health	LAO00112	12/30/2016
NC	North Carolina Div. of Water Quality	652	12/31/2016
NJ	New Jersey DEP	MA007 NELAP	06/30/2016
FL	Florida Department of Health	E871027 NELAP	06/30/2016
VT	Vermont Department of Health Lead Laboratory	LL015036	07/30/2016
ME	State of Maine	2011028	06/9/2017
VA	Commonwealth of Virginia	460217	12/14/2016
NH-P	New Hampshire Environmental Lab	2557 NELAP	09/6/2016



Phone: 413-525-2332
Fax: 413-525-6405
Email: info@contestlabs.com
www.contestlabs.com

CHAIN OF CUSTODY RECORD

39 Spruce Street
East Longmeadow, MA 01028

Page 1 of 1

Company Name: Arcadia's

Address: 855 Route 146, STE 210

Clifton Park, N.Y. 12065

Attention: J. Wyckoff

Project Location: S. Otseville, N.Y.

Sampled By: L. Whalen

Project PO#

Project # 00266406.0000

Telephone: 518-250-7360

DATA DELIVERY (check all that apply)

☐ FAX ☒ EMAIL ☐ WEBSITE

Format: PDF ☒ EXCEL ☒ GIS ☐ OTHER

Collection

Beginning Date/Time

Ending Date/Time

Client Sample ID / Description

Con-Test Lab ID (laboratory use only)

Composite

Grab

*Matrix Code

Conc Code

Comments:

Relinquished by: (signature)

Date/Time: 5/23/16 10:00

Received by: (signature)

Date/Time: 5/23/16 9:48

Relinquished by: (signature)

Date/Time: 5/23/16 9:48

Received by: (signature)

Date/Time: 5/23/16 9:48

Relinquished by: (signature)

Date/Time: 5/23/16 9:48

Received by: (signature)

Date/Time: 5/23/16 9:48

ANALYSIS REQUESTED

Field Filtered

Lab to Filter

***Cont. Code:

A=amber glass

G=glass

P=plastic

ST=sterile

V= vial

S=summa can

T=tetral bag

O=Other

***Preservation

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

*Matrix Code:

GW= groundwater

WW= wastewater

DW= drinking water

A = air

S = soil/solid

SL = sludge

O = other

of Containers

** Preservation

***Container Code

Dissolved Metals

Field Filtered

Lab to Filter

***Cont. Code:

A=amber glass

G=glass

P=plastic

ST=sterile

V= vial

S=summa can

T=tetral bag

O=Other

***Preservation

I = Iced

H = HCL

M = Methanol

N = Nitric Acid

S = Sulfuric Acid

B = Sodium bisulfate

X = Na hydroxide

T = Na thiosulfate

O = Other

*Matrix Code:

GW= groundwater

WW= wastewater

DW= drinking water

A = air

S = soil/solid

SL = sludge

O = other

11

H

V

629

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

11

H

V

629

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

11

H

V

629

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

11

H

V

629

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

11

H

V

629

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

11

H

V

629

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

11

H

V

629

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

11

H

V

629

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

X

39 Spruce St.
East Longmeadow, MA. 01028
P: 413-525-2332
F: 413-525-6405
www.contestlabs.com



Page 1 of 2

Sample Receipt Checklist

CLIENT NAME: Acadics RECEIVED BY: Lee DATE: 5/26/16

1) Was the chain(s) of custody relinquished and signed? Yes ☒ No ☐ No COC Incl.

2) Does the chain agree with the samples? Yes ☒ No ☐

If not, explain:

3) Are all the samples in good condition? Yes ☒ No ☐

If not, explain:

4) How were the samples received:

On Ice ☒ Direct from Sampling ☐ Ambient ☐ In Cooler(s) ☒

Were the samples received in Temperature Compliance of (2-6°C)? Yes ☒ No ☐ N/A ☐

Temperature °C by Temp blank 4°C Temperature °C by Temp gun ☐

5) Are there Dissolved samples for the lab to filter? Yes ☐ No ☒

Who was notified ☐ Date ☐ Time ☐

6) Are there any RUSH or SHORT HOLDING TIME samples? Yes ☐ No ☒

Who was notified ☐ Date ☐ Time ☐

7) Location where samples are stored:

Log in

Permission to subcontract samples? Yes No
(Walk-in clients only) if not already approved
Client Signature: ☐

8) Do all samples have the proper Acid pH: Yes ☐ No ☒ N/A

9) Do all samples have the proper Base pH: Yes ☐ No ☒ N/A

10) Was the PC notified of any discrepancies with the CoC vs the samples: Yes ☐ N/A ☒

Containers received at Con-Test

	# of containers			# of containers
1 Liter Amber			16 oz amber	
500 mL Amber			8 oz amber/clear jar	
250 mL Amber (8oz amber)			4 oz amber/clear jar	
1 Liter Plastic			2 oz amber/clear jar	
500 mL Plastic			Plastic Bag / Ziploc	
250 mL plastic			SOC Kit	
40 mL Vial - type listed below	<u>11</u>		Perchlorate Kit	
Colisure / bacteria bottle			Flashpoint bottle	
Dissolved Oxygen bottle			Other glass jar	
Encore			Other	

40 mL vials: # HCl 11 # Methanol ☐

Doc# 277 # Bisulfate ☐ # DI Water ☐

Rev. 4 August 2013 # Thiosulfate ☐ Unpreserved ☐

Time and Date Frozen: ☐

Login Sample Receipt Checklist**(Rejection Criteria Listing - Using Sample Acceptance Policy)****Any False statement will be brought to the attention of Client**

Question	Answer (True/False)	Comment
	T/F/NA	
1) The cooler's custody seal, if present, is intact.	T	
2) The cooler or samples do not appear to have been compromised or tampered with.	T	
3) Samples were received on ice.	T	
4) Cooler Temperature is acceptable.	T	
5) Cooler Temperature is recorded.	T	
6) COC is filled out in ink and legible.	T	
7) COC is filled out with all pertinent information.	T	
8) Field Sampler's name present on COC.	T	
9) There are no discrepancies between the sample IDs on the container and the COC.	T	
10) Samples are received within Holding Time.	T	
11) Sample containers have legible labels.	T	
12) Containers are not broken or leaking.	T	
13) Air Cassettes are not broken/open.	NA	
14) Sample collection date/times are provided.	T	
15) Appropriate sample containers are used.	T	
16) Proper collection media used.	T	
17) No headspace sample bottles are completely filled.	T	
18) There is sufficient volume for all requested analyses, including any requested MS/MSDs.	T	
19) Trip blanks provided if applicable.	T	
20) VOA sample vials do not have head space or bubble is <6mm (1/4") in diameter.	T	
21) Samples do not require splitting or compositing.	T	

Doc #277 Rev. 4 August 2013

Who notified of False statements?

Log-In Technician Initials:

Date/Time:

Date/Time:

August 8, 2016

Jeremy Wyckoff
Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065

Project Location: S. Otsell, NY
Client Job Number:
Project Number: 00266406.0000
Laboratory Work Order Number: 16G1140

Enclosed are results of analyses for samples received by the laboratory on July 26, 2016. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "Aaron L. Benoit", with a horizontal line extending to the right.

Aaron L. Benoit
Project Manager

Table of Contents

Sample Summary	3
Case Narrative	4
Sample Results	5
16G1140-01	5
16G1140-02	6
16G1140-03	7
16G1140-04	8
Sample Preparation Information	9
QC Data	10
Volatile Organic Compounds by GC/MS	10
B155071	10
Flag/Qualifier Summary	12
Certifications	13
Chain of Custody/Sample Receipt	15

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065
ATTN: Jeremy Wyckoff

REPORT DATE: 8/8/2016

PURCHASE ORDER NUMBER:

PROJECT NUMBER: 00266406.0000

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 16G1140

The results of analyses performed on the following samples submitted to the CON-TEST Analytical Laboratory are found in this report.

PROJECT LOCATION: S. OtsellC,NY

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
RW-1	16G1140-01	Ground Water		EPA 624	
RW-2	16G1140-02	Ground Water		EPA 624	
EFF 46 HZ	16G1140-03	Ground Water		EPA 624	
Trip Blank	16G1140-04	Trip Blank Water		EPA 624	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Con-Test Analytical Laboratory for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.

A handwritten signature in black ink, appearing to read "Lisa Worthington", is written over a light pink rectangular background.

Lisa A. Worthington
Project Manager

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otsell, NY

Sample Description:

Work Order: 16G1140

Date Received: 7/26/2016

Field Sample #: RW-1

Sampled: 7/25/2016 06:45

Sample ID: 16G1140-01

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
Bromodichloromethane	ND	2.0	0.30	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
Carbon Tetrachloride	ND	2.0	0.25	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
Chloromethane	0.77	2.0	0.55	µg/L	1	J	EPA 624	8/2/16	8/4/16 2:50	LBD
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
1,1-Dichloroethane	1.5	2.0	0.16	µg/L	1	J	EPA 624	8/2/16	8/4/16 2:50	LBD
1,1-Dichloroethylene	0.68	2.0	0.21	µg/L	1	J	EPA 624	8/2/16	8/4/16 2:50	LBD
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
Tetrachloroethylene	ND	2.0	0.27	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
1,1,1-Trichloroethane	35	2.0	0.13	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
1,1,2-Trichloroethane	ND	2.0	0.24	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
m+p Xylene	ND	2.0	0.26	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	8/2/16	8/4/16 2:50	LBD
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	89.7	70-130								
Toluene-d8	94.8	70-130								
4-Bromofluorobenzene	95.8	70-130								

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otsell, NY

Sample Description:

Work Order: 16G1140

Date Received: 7/26/2016

Field Sample #: RW-2

Sampled: 7/25/2016 06:50

Sample ID: 16G1140-02

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
Bromodichloromethane	ND	2.0	0.30	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
Carbon Tetrachloride	ND	2.0	0.25	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
Chloromethane	0.59	2.0	0.55	µg/L	1	J	EPA 624	8/2/16	8/4/16 3:20	LBD
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
1,1-Dichloroethane	0.66	2.0	0.16	µg/L	1	J	EPA 624	8/2/16	8/4/16 3:20	LBD
1,1-Dichloroethylene	0.48	2.0	0.21	µg/L	1	J	EPA 624	8/2/16	8/4/16 3:20	LBD
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
Tetrachloroethylene	ND	2.0	0.27	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
1,1,1-Trichloroethane	28	2.0	0.13	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
1,1,2-Trichloroethane	ND	2.0	0.24	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
m+p Xylene	ND	2.0	0.26	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	8/2/16	8/4/16 3:20	LBD
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	90.7	70-130				8/4/16 3:20				
Toluene-d8	95.3	70-130				8/4/16 3:20				
4-Bromofluorobenzene	92.8	70-130				8/4/16 3:20				

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otsell, NY

Sample Description:

Work Order: 16G1140

Date Received: 7/26/2016

Field Sample #: EFF 46 HZ

Sampled: 7/25/2016 07:00

Sample ID: 16G1140-03

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
Bromodichloromethane	ND	2.0	0.30	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
Carbon Tetrachloride	ND	2.0	0.25	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
Chloromethane	1.0	2.0	0.55	µg/L	1	J	EPA 624	8/2/16	8/4/16 3:51	LBD
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
Tetrachloroethylene	ND	2.0	0.27	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
1,1,1-Trichloroethane	ND	2.0	0.13	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
1,1,2-Trichloroethane	ND	2.0	0.24	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
m+p Xylene	ND	2.0	0.26	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	8/2/16	8/4/16 3:51	LBD
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	88.5	70-130								
Toluene-d8	96.5	70-130								
4-Bromofluorobenzene	94.8	70-130								

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otsell, NY

Sample Description:

Work Order: 16G1140

Date Received: 7/26/2016

Field Sample #: Trip Blank

Sampled: 7/25/2016 00:00

Sample ID: 16G1140-04

Sample Matrix: Trip Blank Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	0.21	1.0	0.12	µg/L	1	J	EPA 624	8/2/16	8/4/16 2:19	LBD
Bromodichloromethane	ND	2.0	0.30	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
Carbon Tetrachloride	ND	2.0	0.25	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
Chloromethane	ND	2.0	0.55	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
Ethylbenzene	0.13	2.0	0.13	µg/L	1	J	EPA 624	8/2/16	8/4/16 2:19	LBD
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
Tetrachloroethylene	ND	2.0	0.27	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
Toluene	1.0	1.0	0.17	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
1,1,1-Trichloroethane	ND	2.0	0.13	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
1,1,2-Trichloroethane	ND	2.0	0.24	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	8/2/16	8/4/16 2:19	LBD
m+p Xylene	0.53	2.0	0.26	µg/L	1	J	EPA 624	8/2/16	8/4/16 2:19	LBD
o-Xylene	0.25	2.0	0.13	µg/L	1	J	EPA 624	8/2/16	8/4/16 2:19	LBD
Surrogates	% Recovery	Recovery Limits		Flag/Qual						
1,2-Dichloroethane-d4	89.5	70-130								
Toluene-d8	95.6	70-130								
4-Bromofluorobenzene	95.1	70-130								

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Sample Extraction Data

Prep Method: SW-846 5030B-EPA 624

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
16G1140-01 [RW-1]	B155071	5	5.00	08/02/16
16G1140-02 [RW-2]	B155071	5	5.00	08/02/16
16G1140-03 [EFF 46 HZ]	B155071	5	5.00	08/02/16
16G1140-04 [Trip Blank]	B155071	5	5.00	08/02/16

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL
Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

Batch B155071 - SW-846 5030B
Blank (B155071-BLK1)

Prepared: 08/02/16 Analyzed: 08/03/16

Benzene	ND	1.0	µg/L							
Bromodichloromethane	ND	2.0	µg/L							
Bromoform	ND	2.0	µg/L							
Bromomethane	ND	2.0	µg/L							
Carbon Tetrachloride	ND	2.0	µg/L							
Chlorobenzene	ND	2.0	µg/L							
Chlorodibromomethane	ND	2.0	µg/L							
Chloroethane	ND	2.0	µg/L							
2-Chloroethyl Vinyl Ether	ND	10	µg/L							
Chloroform	ND	2.0	µg/L							
Chloromethane	ND	2.0	µg/L							
1,2-Dichlorobenzene	ND	2.0	µg/L							
1,3-Dichlorobenzene	ND	2.0	µg/L							
1,4-Dichlorobenzene	ND	2.0	µg/L							
1,2-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethylene	ND	2.0	µg/L							
trans-1,2-Dichloroethylene	ND	2.0	µg/L							
1,2-Dichloropropane	ND	2.0	µg/L							
cis-1,3-Dichloropropene	ND	2.0	µg/L							
trans-1,3-Dichloropropene	ND	2.0	µg/L							
Ethylbenzene	ND	2.0	µg/L							
Methyl tert-Butyl Ether (MTBE)	ND	2.0	µg/L							
Methylene Chloride	ND	5.0	µg/L							
1,1,2,2-Tetrachloroethane	ND	2.0	µg/L							
Tetrachloroethylene	ND	2.0	µg/L							
Toluene	ND	1.0	µg/L							
1,1,1-Trichloroethane	ND	2.0	µg/L							
1,1,2-Trichloroethane	ND	2.0	µg/L							
Trichloroethylene	ND	2.0	µg/L							
Trichlorofluoromethane (Freon 11)	ND	2.0	µg/L							
Vinyl Chloride	ND	2.0	µg/L							
m+p Xylene	ND	2.0	µg/L							
o-Xylene	ND	2.0	µg/L							
Surrogate: 1,2-Dichloroethane-d4	22.1		µg/L	25.0		88.4	70-130			
Surrogate: Toluene-d8	24.1		µg/L	25.0		96.5	70-130			
Surrogate: 4-Bromofluorobenzene	24.0		µg/L	25.0		95.9	70-130			

LCS (B155071-BS1)

Prepared: 08/02/16 Analyzed: 08/03/16

Benzene	9.85	1.0	µg/L	10.0		98.5	37-151			
Bromodichloromethane	9.00	2.0	µg/L	10.0		90.0	35-155			
Bromoform	9.33	2.0	µg/L	10.0		93.3	45-169			
Bromomethane	7.02	2.0	µg/L	10.0		70.2	20-242			
Carbon Tetrachloride	10.3	2.0	µg/L	10.0		103	70-140			
Chlorobenzene	10.4	2.0	µg/L	10.0		104	37-160			
Chlorodibromomethane	10.4	2.0	µg/L	10.0		104	53-149			
Chloroethane	7.77	2.0	µg/L	10.0		77.7	70-130			
2-Chloroethyl Vinyl Ether	105	10	µg/L	100		105	10-305			
Chloroform	9.24	2.0	µg/L	10.0		92.4	51-138			
Chloromethane	7.92	2.0	µg/L	10.0		79.2	20-273			
1,2-Dichlorobenzene	10.9	2.0	µg/L	10.0		109	18-190			
1,3-Dichlorobenzene	10.9	2.0	µg/L	10.0		109	59-156			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL
Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch B155071 - SW-846 5030B										
LCS (B155071-BS1)					Prepared: 08/02/16 Analyzed: 08/03/16					
1,4-Dichlorobenzene	10.8	2.0	µg/L	10.0		108	18-190			
1,2-Dichloroethane	8.49	2.0	µg/L	10.0		84.9	49-155			
1,1-Dichloroethane	9.05	2.0	µg/L	10.0		90.5	59-155			
1,1-Dichloroethylene	7.70	2.0	µg/L	10.0		77.0	20-234			
trans-1,2-Dichloroethylene	9.39	2.0	µg/L	10.0		93.9	54-156			
1,2-Dichloropropane	9.50	2.0	µg/L	10.0		95.0	20-210			
cis-1,3-Dichloropropene	9.75	2.0	µg/L	10.0		97.5	20-227			
trans-1,3-Dichloropropene	9.67	2.0	µg/L	10.0		96.7	17-183			
Ethylbenzene	9.72	2.0	µg/L	10.0		97.2	37-162			
Methyl tert-Butyl Ether (MTBE)	10.3	2.0	µg/L	10.0		103	70-130			
Methylene Chloride	10.1	5.0	µg/L	10.0		101	50-221			
1,1,2,2-Tetrachloroethane	10.0	2.0	µg/L	10.0		100	46-157			
Tetrachloroethylene	10.5	2.0	µg/L	10.0		105	64-148			
Toluene	9.25	1.0	µg/L	10.0		92.5	47-150			
1,1,1-Trichloroethane	9.39	2.0	µg/L	10.0		93.9	52-162			
1,1,2-Trichloroethane	10.2	2.0	µg/L	10.0		102	52-150			
Trichloroethylene	9.31	2.0	µg/L	10.0		93.1	71-157			
Trichlorofluoromethane (Freon 11)	8.15	2.0	µg/L	10.0		81.5	17-181			
Vinyl Chloride	7.91	2.0	µg/L	10.0		79.1	20-251			
m+p Xylene	19.1	2.0	µg/L	20.0		95.6	70-130			
o-Xylene	9.60	2.0	µg/L	10.0		96.0	70-130			
Surrogate: 1,2-Dichloroethane-d4	21.4		µg/L	25.0		85.7	70-130			
Surrogate: Toluene-d8	23.4		µg/L	25.0		93.7	70-130			
Surrogate: 4-Bromofluorobenzene	25.5		µg/L	25.0		102	70-130			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
ND	Not Detected
RL	Reporting Limit
DL	Method Detection Limit
MCL	Maximum Contaminant Level
	Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
	No results have been blank subtracted unless specified in the case narrative section.
J	Detected but below the Reporting Limit (lowest calibration standard); therefore, result is an estimated concentration (CLP J-Flag).

CERTIFICATIONS

Certified Analyses included in this Report

Analyte	Certifications
EPA 624 in Water	
Benzene	CT,MA,NH,NY,RI,NC,ME,VA
Bromodichloromethane	CT,MA,NH,NY,RI,NC,ME,VA
Bromoform	CT,MA,NH,NY,RI,NC,ME,VA
Bromomethane	CT,MA,NH,NY,RI,NC,ME,VA
Carbon Tetrachloride	CT,MA,NH,NY,RI,NC,ME,VA
Chlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
Chlorodibromomethane	CT,MA,NH,NY,RI,NC,ME,VA
Chloroethane	CT,MA,NH,NY,RI,NC,ME,VA
2-Chloroethyl Vinyl Ether	CT,MA,NH,NY,RI,NC,ME,VA
Chloroform	CT,MA,NH,NY,RI,NC,ME,VA
Chloromethane	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,3-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,4-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
trans-1,2-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichloropropane	CT,MA,NH,NY,RI,NC,ME,VA
cis-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA
trans-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA
Ethylbenzene	CT,MA,NH,NY,RI,NC,ME,VA
Methyl tert-Butyl Ether (MTBE)	NY,NC
Methylene Chloride	CT,MA,NH,NY,RI,NC,ME,VA
1,1,2,2-Tetrachloroethane	CT,MA,NH,NY,RI,NC,ME,VA
Tetrachloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
Toluene	CT,MA,NH,NY,RI,NC,ME,VA
1,1,1-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1,2-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
Trichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
Trichlorofluoromethane (Freon 11)	CT,MA,NH,NY,RI,NC,ME,VA
Vinyl Chloride	CT,MA,NH,NY,RI,NC,ME,VA
m+p Xylene	CT,MA,NH,NY,RI,NC,VA
o-Xylene	CT,MA,NH,NY,RI,NC,VA

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

The CON-TEST Environmental Laboratory operates under the following certifications and accreditations:

Code	Description	Number	Expires
AIHA	AIHA-LAP, LLC	100033	02/1/2018
MA	Massachusetts DEP	M-MA100	06/30/2017
CT	Connecticut Department of Public Health	PH-0567	09/30/2017
NY	New York State Department of Health	10899 NELAP	04/1/2017
NH-S	New Hampshire Environmental Lab	2516 NELAP	02/5/2017
RI	Rhode Island Department of Health	LAO00112	12/30/2016
NC	North Carolina Div. of Water Quality	652	12/31/2016
NJ	New Jersey DEP	MA007 NELAP	06/30/2017
FL	Florida Department of Health	E871027 NELAP	06/30/2017
VT	Vermont Department of Health Lead Laboratory	LL015036	07/30/2017
ME	State of Maine	2011028	06/9/2017
VA	Commonwealth of Virginia	460217	12/14/2016
NH-P	New Hampshire Environmental Lab	2557 NELAP	09/6/2016



Phone: 413-525-2332
Fax: 413-525-6405
Email: info@contestlabs.com
www.contestlabs.com

Company Name: Arcadia's

Address: 855 Route 146, STE 210
Clifton Park NY 12065

Telephone: 518-250-7300

Project # 00266406.0000

Client PO#

Attention: J. Wyckoff

Project Location: S. Otselee, NY.

Sampled By: L. Whalen

DATA DELIVERY (check all that apply)

☐ FAX ☒ EMAIL ☐ WEBSITE

Fax #

Email:

Format:

☐ PDF ☒ EXCEL ☒ GIS ☐ OTHER

☐ "Enhanced Data Package"

Collection

Beginning Date/Time

Ending Date/Time

Composite

Grab

*Matrix Code

Conc. Code

Con-Test Lab ID (laboratory use only)

Client Sample ID / Description

01 RW-1

02 RW-2

03 EFF 46 HZ

04 Trip Blank

7/25/16 0645

0650

0700

X

X

X

X

-

-

-

-

-

-

-

-

-

-

-

-

-

-

-

-

-

-

-

-

-

-

-

-

-

-

-

-

-

-

-

-

-

-

-

-

-

-

-

-

Comments:

Relinquished by: (signature)

Date/Time: 7/25/16 1400

Received by: (signature)

Date/Time: 7/26/16 0959

Relinquished by: (signature)

Date/Time:

Received by: (signature)

Date/Time:

Relinquished by: (signature)

Date/Time:

Received by: (signature)

Date/Time:

Relinquished by: (signature)

Date/Time:

CHAIN OF CUSTODY RECORD

NEW YORK STATE

1661140

39 Spruce Street
East Longmeadow, MA 01028

Page 1 of 1

TURNAROUND TIME (business days) STARTS AT 9:00 A.M. THE DAY AFTER SAMPLE RECEIPT UNLESS THERE ARE QUESTIONS ON YOUR CHAIN. IF THIS FORM IS NOT FILLED OUT COMPLETELY OR IS INCORRECT, TURNAROUND TIME WILL NOT START UNTIL ALL QUESTIONS ARE ANSWERED. PLEASE BE CAREFUL TO NOT CONTAMINATE THIS DOCUMENT

39 Spruce St.
East Longmeadow, MA. 01028
P: 413-525-2332
F: 413-525-6405
www.contestlabs.com



Page 1 of 2

Sample Receipt Checklist

CLIENT NAME: ARCADIS RECEIVED BY: MG DATE: 7/26/16

1) Was the chain(s) of custody relinquished and signed? Yes ☒ No ☐ No COC Incl.

2) Does the chain agree with the samples?

Yes ☒ No ☐

If not, explain:

3) Are all the samples in good condition?

Yes ☒ No ☐

If not, explain:

4) How were the samples received:

On Ice ☒ Direct from Sampling ☐ Ambient ☐ In Cooler(s) ☒

Were the samples received in Temperature Compliance of (2-6°C)? Yes ☐ No ☒ N/A ☐

Temperature °C by Temp blank ☐ Temperature °C by Temp gun 5.0

5) Are there Dissolved samples for the lab to filter?

Yes ☐ No ☒

Who was notified ☐ Date ☐ Time ☐

6) Are there any RUSH or SHORT HOLDING TIME samples?

Yes ☐ No ☒

Who was notified ☐ Date ☐ Time ☐

7) Location where samples are stored:

LOGIA

Permission to subcontract samples? Yes ☐ No ☒
(Walk-in clients only) if not already approved
Client Signature: /

8) Do all samples have the proper Acid pH: Yes ☐ No ☐ N/A ☒

9) Do all samples have the proper Base pH: Yes ☐ No ☐ N/A ☒

10) Was the PC notified of any discrepancies with the CoC vs the samples: Yes ☐ N/A ☒

Containers received at Con-Test

	# of containers		# of containers
1 Liter Amber		16 oz amber	
500 mL Amber		8 oz amber/clear jar	
250 mL Amber (8oz amber)		4 oz amber/clear jar	
1 Liter Plastic		2 oz amber/clear jar	
500 mL Plastic		Plastic Bag / Ziploc	
250 mL plastic		SOC Kit	
40 mL Vial - type listed below	<u>11</u>	Perchlorate Kit	
Colisure / bacteria bottle		Flashpoint bottle	
Dissolved Oxygen bottle		Other glass jar	
Encore		Other	

40 mL vials: # HCl 11 # Methanol ☐

Time and Date Frozen:

Doc# 277 # Bisulfate ☐ # DI Water ☐

Rev. 4 August 2013 # Thiosulfate ☐ Unpreserved ☐

Login Sample Receipt Checklist**(Rejection Criteria Listing - Using Sample Acceptance Policy)****Any False statement will be brought to the attention of Client**

Question	Answer (True/False)		Comment
	T/F/NA		
1) The cooler's custody seal, if present, is intact.	NA		
2) The cooler or samples do not appear to have been compromised or tampered with.	T		
3) Samples were received on ice.	T		
4) Cooler Temperature is acceptable.	T		
5) Cooler Temperature is recorded.	T		
6) COC is filled out in ink and legible.	T		
7) COC is filled out with all pertinent information.	T		
8) Field Sampler's name present on COC.	T		
9) There are no discrepancies between the sample IDs on the container and the COC.	T		
10) Samples are received within Holding Time.	T		
11) Sample containers have legible labels.	T		
12) Containers are not broken or leaking.	T		
13) Air Cassettes are not broken/open.	NA		
14) Sample collection date/times are provided.	T		
15) Appropriate sample containers are used.	T		
16) Proper collection media used.	T		
17) No headspace sample bottles are completely filled.	T		
18) There is sufficient volume for all requested analyses, including any requested MS/MSDs.	T		
19) Trip blanks provided if applicable.	T		
20) VOA sample vials do not have head space or bubble is <6mm (1/4") in diameter.	T		
21) Samples do not require splitting or compositing.	T		

Doc #277 Rev. 4 August 2013

Who notified of False statements?

Log-In Technician Initials:

MG

Date/Time:

Date/Time:

7/26/16
959

APPENDIX D


Groundwater 1,1,1-TCA Concentrations – May 2015




Document Path: G:\GISMOD\0266365\2015\Contours2015.mxd




SHALLOW WELLS



INTERMEDIATE WELLS




DEEP WELLS



LEGEND

1,1,1-Trichloroethane Concentrations (ug/L)



GLADDING CORDAGE SITE NUMBER 7-09-009
SOUTH OTSELIC, NEW YORK

**GROUNDWATER 1,1,1-TRICHLOROETHANE
CONCENTRATIONS**

MAY 6, 2015



FIGURE

4-5

Arcadis CE, Inc.

855 Route 146

Suite 210

Clifton Park, New York 12065

Tel 518 250 7300

Fax 518 250 7301

www.arcadis.com