

New York State Department of Environmental
Conservation

GLADDING CORDAGE SITE QUARTERLY REPORT

SITE 7-09-009

First Quarter 2016

April 2016

GLADDING CORDAGE SITE QUARTERLY REPORT

First Quarter 2016



Andy Vitolins, PG
Associate Vice President



Jeremy Wyckoff
Project Geologist

Prepared for:

New York State Department of
Environmental Conservation – Division of
Environmental Remediation

625 Broadway
Albany, NY 12233-7011

Prepared by:

Arcadis CE, Inc.
855 Route 146
Suite 210
Clifton Park
New York 12065
Tel 518 250 7300
Fax 518 250 7301

Our Ref.:

00266406.0000

Date:

April 2016

This document is intended only for the use of the individual or entity for which it was prepared and may contain information that is privileged, confidential and exempt from disclosure under applicable law. Any dissemination, distribution or copying of this document is strictly prohibited.

CONTENTS

Acronyms and Abbreviations.....	iii
1 introduction.....	1
2 SITE DESCRIPTION	2
3 OPERATION AND MAINTENANCE	3
3.1 Treatment Plant Upgrades.....	3
3.1.1 Variable Frequency Drive.....	3
3.1.2 Treatment Plant Controls	3
3.1.3 Geothermal Heat Exchanger.....	4
3.2 Treatment Plant Operation	4
3.3 Treatment System Sampling	4
3.3.1 Influent Sample Results	4
3.3.2 Effluent Sample Results	5
4 GROUNDWATER MONITORING PROGRAM.....	6
5 RECOMMENDATIONS.....	7
6 SUMMARY	8
7 REFERENCES.....	9

TABLES

Table 3-1	Treatment System Status and Flow Summary
Table 3-2	Groundwater Treatment System VOCs (RW-1)
Table 3-3	Groundwater Treatment System VOCs (RW-2)
Table 3-4	Groundwater Treatment System VOCs (Effluent)

FIGURES

Figure 2-1	Site Location
Figure 3-1	Treatment System Influent Sample Concentration (1,1,1-TCA)

APPENDICES

- A PLC Facsimile Reports
- B O&M Checklists
- C Analytical Reporting Forms
- D Groundwater 1,1,1-TCA Concentrations – May 2015

ACRONYMS AND ABBREVIATIONS

Amsl	above mean sea level
BTEX	Benzene, toluene, ethylbenzene, and xylene.
Ft	feet
GAP	generally accepted procedure
HZ	hertz
µg/L	micrograms per liter
NYSDEC	New York State Department of Environmental Conservation
O&M	operation and maintenance
PDB	passive diffusion bag
PLC	programmable logic controller
PCE	Tetrachloroethene
USEPA	United States Environmental Protection Agency
VFD	variable frequency drive
VOC	volatile organic compound
1,1-DCA	1,2-dichloroethane
1,1-DCE	1,2-dichloroethene
1,1,1-TCA	1,1,1-trichloroethane

1 INTRODUCTION

The New York State Department of Environmental Conservation (NYSDEC) has issued a Work Assignment (# D007618-9) to ARCADIS CE, Inc. (Arcadis) for Operation, Maintenance, and Monitoring at the Gladding Cordage Site (Site # 7-09-009). This Quarterly Report has been prepared in accordance with the NYSDEC-approved Work Plan to summarize first quarter 2016 site activities.

2 SITE DESCRIPTION

The Gladding Cordage Site is located on Ridge Road, South Otselic, Chenango County, New York (Figure 2-1), along the western bank of the Otselic River. The site contains an active braided wire and rope manufacturing facility that has been in operation since 1892.

3 OPERATION AND MAINTENANCE

On August 23, 2007, the NYSDEC provided a training session to Arcadis personnel on the operation and maintenance (O&M) of the groundwater treatment plant at the Gladding Cordage Site. Since then, Arcadis has maintained operation of the groundwater treatment plant. This includes the operation, maintenance, and influent/effluent sampling in accordance with the NYSDEC O&M manual (Operation and Maintenance Manual, Volume I, Gladding Cordage Site, Site 7-09-009, TAMS Consultants, Inc., 1996) (O&M Manual).

3.1 Treatment Plant Upgrades

3.1.1 Variable Frequency Drive

A variable frequency drive (VFD) was installed on January 9, 2008 to regulate the speed of the air stripper blower motor for reduced energy usage. Following the installation of the VFD, effluent samples were collected at various blower motor frequencies (speeds) to evaluate the minimum blower frequency required for the treatment plant to effectively treat groundwater extracted from the source area. Additional sampling was conducted again in February 2008 to further optimize the treatment system blower speed. Based on the results, the VFD setting was reduced to 42 hertz (HZ) beginning in March 2008. However, based on the detection of low-level VOCs in effluent samples from the treatment system, the VFD setting was subsequently increased to 46 HZ in September 2010 and was maintained at that frequency until November 19, 2014.

Based on a general trend of lower concentrations of VOCs in influent treatment system samples since September 2010, the NYSDEC authorized a reduction of the VFD frequency to 44 HZ in an attempt to further optimize treatment plant operations and reduce electric usage. The VFD frequency was lowered to 44 HZ on November 19, 2014. Following approximately one-half hour of operation, post-treatment effluent samples were collected in accordance with the Work Plan (see Section 3.2.1). Based on a review of post-treatment effluent sample data from November 19, 2014, 1,1,1 TCA and toluene were detected with the air stripper blower operating at 44 HZ, but at concentrations below the corresponding NYSDEC Class GA Standards. The NYSDEC was notified of the VOC detections and the blower motor frequency was subsequently increased to 46 HZ and has been maintained at that level since the December 18, 2014 O&M event.

3.1.2 Treatment Plant Controls

In August 2011, the NYSDEC authorized construction and installation of a new treatment plant controls system. The new control system is designed to provide remote access to treatment plant operating parameters and improve reliability of the groundwater remediation system. The treatment plant was shut down to begin repairs and upgrades on January 30, 2012 by Aztech Technologies, Inc. (Aztech). The upgrades to the treatment system controls were completed and the treatment plant resumed operation on March 22, 2012. The treatment plant functions are controlled and monitored using an EOS Research Ltd. ProControl Programmable Logic Controller (PLC). The interface software allows remote connection to the PLC via analog phone line. The PLC and interface software also allows the treatment system to be started or stopped remotely. The PLC is programmed to send a facsimile with the status of system inputs and outputs on a daily basis. If input and/or output device values exceed the defined operating parameters, an

alarm condition is set and the corresponding alarm information is sent via facsimile to the system user (i.e. Arcadis).

3.1.3 Geothermal Heat Exchanger

The NYSDEC authorized the installation of a geothermal heat exchanger to provide climate control (heating and humidity) for the treatment system building. The treatment plant was shut down to begin installation of the system on May 8, 2012 by Aztech. The geothermal heat exchanger installation and testing was completed on May 10, 2012. The heat-exchanger uses groundwater from the treatment plant as a geo-thermal energy source.

3.2 Treatment Plant Operation

As shown on PLC facsimile reports (Appendix A) and O&M Checklist and Operation Logs (Appendix B), the Gladding Cordage groundwater treatment system shut down on January 9, 2016 due to a power interruption. The system was restated remotely on January 11, 2016. The system also shut down on February 16 and 17, 2016 due to power interruptions. On both occasions, the treatment plant was restarted remotely on the same day of the interruption. The treatment system operated without interruption during March 2016.

The average monthly flow rates and total flow volumes for the first quarter 2016 operating period are summarized in Table 3-1. As shown in Table 3-1, the monthly flow rates from recovery wells RW-1 and RW-2 averaged approximately 21 gpm and 22 gpm, respectively. Based on the total flow values, approximately 5.5 million gallons of water were treated and discharged to the Otselic River between January and March 2016.

3.3 Treatment System Sampling

Influent and effluent groundwater samples were collected from the Gladding Cordage treatment system in accordance with the Work Plan and submitted to Contest Analytical following chain-of-custody protocols. Each sample was analyzed for volatile organic compounds (VOCs) by United States Environmental Protection Agency (USEPA) Method 624. Analytical Reporting Forms are provided in Appendix C.

3.3.1 Influent Sample Results

Table 3-2 and Table 3-3 summarize influent VOC sample results from recovery wells RW-1 and RW-2, respectively. Figure 3-1 provides a summary of 1,1,1-TCA concentrations in samples from recovery wells RW-1 and RW-2 since September 2007.

Tables 3-1 and 3-2, and Figure 3-1, show that the concentrations of 1,1,1-TCA in the first quarter 2016 samples from recovery well RW-1 decreased from 38 µg/L in January to 36 µg/L in February and March. The concentrations of 1,1,1-TCA in the samples from recovery well RW-2 decreased from 32 µg/L in January to 29 µg/L in February and March. As shown in Tables 3-1 and 3-2, these results are within the range of historic concentrations and exceed the corresponding NYSDEC Class GA Standard of 5 µg/L.

As shown in Tables 3-2 and 3-3, 1,1-dichloroethane (1,1-DCA) and 1,1-dichloroethene (1,1-DCE) were detected in the first quarter 2016 samples from recovery wells RW-1 and RW-2. However, consistent with previous results, the concentrations were less than the applicable NYSDEC Class GA Standard of 5 µg/L.

3.3.2 Effluent Sample Results

Table 3-4 summarizes laboratory analytical data for effluent samples collected from the treatment system. As shown in Table 3-4, no VOCs were detected in any of the first quarter 2015 effluent samples at the indicated quantitation limits.

Based on influent sample concentrations and total flow volumes from the Gladding Cordage treatment system, approximately 1.6 pounds of VOCs were removed by the treatment system during the first quarter 2016.

4 GROUNDWATER MONITORING PROGRAM

Groundwater samples were collected from the site during the second quarter 2015 in accordance with the Work Plan. The results of the sampling event were submitted in the second quarter 2015 Gladding Cordage Site Quarterly Report (Arcadis, 2015). The next groundwater sampling event is scheduled to take place during the third quarter 2016. A map showing the distribution of 1,1,1-TCA during the second quarter 2015 sampling event is provided in Appendix D for reference.

5 RECOMMENDATIONS

Based on the data presented herein, there are no recommended changes to site operations at this time.

6 SUMMARY

The Gladding Cordage groundwater treatment system operated with only minor interruptions in January and February 2016 due to power outages. The system operated without interruption in March 2016. The average total flow through the treatment system was approximately 43 GPM.

The concentrations of VOCs detected in pre-treatment influent samples from recovery wells RW-1 and RW-2 were consistent with previous results.

The treatment successfully removes VOCs from groundwater extracted from the capture zone at the current VFD setting of 46 Hz. The VFD setting will continue to be evaluated based on system monitoring results. Approximately 1.6 pounds of VOCs were removed by the treatment system during the first quarter 2016.

Based on the current five-quarter sampling interval, the next groundwater monitoring event is scheduled to occur during the third quarter 2016.

7 REFERENCES

Arcadis, 2015, Gladding Cordage Site Quarterly Report, Second Quarter 2015, Arcadis CE, Inc., November 2015.

Malcolm Pirnie, 2007, Gladding Cordage Site Work Plan, Site 7-09-009, Malcolm Pirnie, Inc., June, 2007.

TAMS, 1996, Operation and Maintenance Manual, Volume I, Gladding Cordage Site. Site 7-09-009, TAMS Consultants, Inc., March 1996.

TABLES



**TABLE 3-1
TREATMENT SYSTEM STATUS AND FLOW SUMMARY
GLADDING CORDAGE SITE
SOUTH OTSELIC, NEW YORK
NYSDEC SITE NO. 7-04-009A**

Date	System Operation (days)	System On-time (% of possible days)	Well On-time		Flow Rates		Totalizer		Recovery Well Total Flows		Total System Flow (gallons)	Quarterly Totals (gallons)
			RW-1 (% possible)	RW-2 (% possible)	RW-1 (gpm)	RW-2 (gpm)	RW-1 (gallons)	RW-2 (gallons)	RW-1 (gallons)	RW-2 (gallons)		
January-16	29	94%	100%	100%	20.7	22.1	39,095,592	35,850,122	875,567	912,846	1,788,413	5,501,623
February-16	29	100%	100%	100%	21.9	22.2	39,988,542	36,759,764	892,950	909,642	1,802,592	
March-15	31	100%	100%	100%	20.6	21.4	40,931,049	37,727,875	942,507	968,111	1,910,618	
Total Flow 2016									2,711,024	2,790,599	5,501,623	

Notes:
gpm - Gallons per minute

TABLE 3-2
GROUNDWATER TREATMENT SYSTEM VOCS (INFLUENT - RW-1)
GLADDING CORDAGE
SOUTH OTSELIC, NEW YORK
NYSDEC Site No. 7-09-009

Sample ID Sampling Date Matrix Units	NYSDEC Class GA Standard ug/L	RW-1 3/19/2015 WATER ug/L	RW-1 5/6/2015 WATER ug/L	RW-1 6/22/2015 WATER ug/L	RW-1 7/31/2015 WATER ug/L	RW-1 8/28/2015 WATER ug/L	RW-1 9/23/2015 WATER ug/L	RW-1 10/26/2015 WATER ug/L	RW-1 11/20/2015 WATER ug/L	RW-1 12/21/2015 WATER ug/L	RW-1 1/25/2016 WATER ug/L	RW-1 2/26/2016 WATER ug/L	RW-1 3/18/2016 WATER ug/L
VOCs													
1,1,1-Trichloroethane	5	36	38	41	40	42	32	38	41	32	38	36	36
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	1.5 J	2.0 U	1.8 J	1.6 J	1.8 J	1.5 J	1.8 J	2.1	1.5 J	1.8 J	1.5 J	1.4 J
1,1-Dichloroethene	5	0.89 J	0.92 J	0.99 J	0.96 J	0.97 J	0.8 J	0.85 J	1.0 J	0.8 J	0.84 J	0.79 J	0.86 J
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10.0 U	10 U	10 U	10.0 U	10 U	10 U	10.0 U	10 U	10 U	10.0 U	10 U	10 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	0.19 J	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Toluene	5	1.0 U	0.13 J	2.0 U	1.0 U	1.0 U	2.0 U	1.0 U	1.0 U	2.0 U	1.0 U	1.0 U	2.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	5.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Total VOCs		38.4	39.1	43.8	42.6	45.0	34.3	40.7	44.1	34.3	40.6	38.3	38.3

- Concentration exceeds corresponding NYSDEC
Class GA Standard.
U - Not detected at the indicated concentration
J - Estimated concentration.

**TABLE 3-3
GROUNDWATER TREATMENT SYSTEM VOCS (INFLUENT - RW-2)
GLADDING CORDAGE
SOUTH OTSELIC, NEW YORK
NYSDEC Site No. 7-09-009**

Sample ID Sampling Date Matrix Units	NYSDEC Class GA Standard ug/L	RW-2 3/19/2015 WATER ug/L	RW-2 5/6/2015 WATER ug/L	RW-2 6/23/2015 WATER ug/L	RW-2 7/31/2015 WATER ug/L	RW-2 8/28/2015 WATER ug/L	RW-2 9/23/2015 WATER ug/L	RW-2 10/26/2015 WATER ug/L	RW-2 11/20/2015 WATER ug/L	RW-2 12/21/2015 WATER ug/L	RW-2 1/25/2016 WATER ug/L	RW-2 2/26/2016 WATER ug/L	RW-2 3/18/2016 WATER ug/L
VOCs													
1,1,1-Trichloroethane	5	31	33	48	34	36	26	32	34	26	32	29	29
1,1,2,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	0.69 J	2.0 U	1.1 J	0.74 J	0.77 J	0.61 J	0.75 J	0.85 J	0.61 J	0.86 J	0.62 J	0.62 J
1,1-Dichloroethene	5	0.68 J	0.72 J	1 J	0.72 J	0.62 J	0.58 J	0.63 J	0.92 J	0.58 J	0.64 J	0.56 J	0.66 J
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10.0 U	10 U	10 U	10.0 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U	10 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	0.15 J	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Toluene	5	1.0 U	0.13 J	2.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	5.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Total VOCs		32.4	33.9	50.1	35.5	37.5	27.2	33.4	35.8	27.2	33.5	30.2	30.3

- Concentration exceeds corresponding NYSDEC Class GA Standard.
 U - Not detected at the indicated concentration
 J - Estimated concentration.

TABLE 3-4
GROUNDWATER TREATMENT SYSTEM VOCS (EFFLUENT)
GLADDING CORDAGE
SOUTH OTSELIC, NEW YORK
NYSDEC Site No. 7-09-009

Sample ID Sampling Date Matrix Units	NYSDEC GA Standard ug/L	EFF(46HZ) 3/19/2015 WATER ug/L	EFF(46HZ) 5/6/2015 WATER ug/L	EFF(46HZ) 6/23/2015 WATER ug/L	EFF(46HZ) 7/31/2015 WATER ug/L	EFF(46HZ) 8/28/2015 WATER ug/L	EFF(46HZ) 9/23/2015 WATER ug/L
VOCS							
1,1,1-Trichloroethane	5	2.0 U	1.0 U	0.22 J	0.22 J	0.17 J	1.0 U
1,1,1,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10 U	10 U	10 U	10 U	10 U	10 U
Benzene	1	1.0 U	2.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	0.2 J	2.0 U
Toluene	5	1.0 U	0.12 J	1.0 U	1.0 U	1.0 U	1.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	5.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U

Notes

U - Not detected at the indicated concentration.
J - Estimated concentration.

**TABLE 3-4
GROUNDWATER TREATMENT SYSTEM VOCS (EFFLUENT)
GLADDING CORDAGE
SOUTH OTSELIC, NEW YORK
NYSDEC Site No. 7-09-009**

Sample ID Sampling Date Matrix Units	NYSDEC GA Standard ug/L	EFF(46HZ) 10/26/2015 WATER ug/L	EFF(46HZ) 11/20/2015 WATER ug/L	EFF(46HZ) 12/21/2015 WATER ug/L	EFF(46HZ) 1/25/2016 WATER ug/L	EFF(46HZ) 2/26/2016 WATER ug/L	EFF(46HZ) 3/18/2016 WATER ug/L
VOCS							
1,1,1-Trichloroethane	5	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
1,1,1,2-Tetrachloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1,2-Trichloroethane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,1-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloroethane	0.6	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,2-Dichloropropane	1	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,3-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
1,4-Dichlorobenzene	3	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
2-Chloroethyl Vinyl Ether		10 U	10 U	10 U	10 U	10 U	10 U
Benzene	1	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromoform	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Bromomethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Carbon Tetrachloride	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chlorobenzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloroform	7	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Chloromethane		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
cis-1,3-Dichloropropene	0.4	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Dibromochloromethane	50	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Ethyl Benzene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
m/p-Xylenes	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methyl tert-butyl Ether		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Methylene Chloride	5	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U	5.0 U
o-Xylene		2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Tetrachloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Toluene	5	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
trans-1,2-Dichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
trans-1,3-Dichloropropene	0.4	5.0 U	2.0 U	2.0 U	5.0 U	2.0 U	2.0 U
Trichloroethene	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Trichlorofluoromethane	5	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U
Vinyl Chloride	2	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U	2.0 U

Notes


U - Not detected at the indicated concentration.
J - Estimated concentration.

FIGURES



Figure 2-1
Site Location

Gladding Cordage Site
South Otselic, New York
NYSDEC Site 7-09-009




Source: USGS 7.5-minute Series Topographic
Quadrangle, South Otselic (1988).

0 2,000 ft

Figure 3-1
Treatment System Influent Sample Concentrations (1,1,1-TCA)


Gladding Cordage Site
 NYSDEC Site Number 7-09-009



APPENDIX A

PLC Facsimile Reports





ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/01/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVED is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM TOTAL FLOW is 38251570	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 34968723	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 446925	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.63	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.04	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.01	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 53.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/02/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 22.0	GPM TOTAL FLOW is 38283123	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 35000142	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 447185	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.81	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.86	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 51.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/03/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 22.1	GPM TOTAL FLOW is 38314638	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 35031532	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 447477	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.41	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.57	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 52.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/04/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	ELRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.9	GPM TOTAL FLOW is 38346112	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 35062900	GAL	
ASBPRS is 11.1	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 447732	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.52	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.58	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.74	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 47.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/05/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.9	GPM TOTAL FLOW is 38377560	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 35094260	GAL	
ASBPRS is 11.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 448157	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.90	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.61	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 45.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/06/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	ELRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.8	GPM TOTAL FLOW is 38408978	GAL	
W2_FLO is 21.8	GPM TOTAL FLOW is 35125593	GAL	
ASBPRS is 11.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 448528	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.90	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.61	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 45.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/07/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACEFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 22.1	GPM TOTAL FLOW is 38440387	GAL		
W2_FLO is 21.9	GPM TOTAL FLOW is 35156908	GAL		
ASBPRS is 11.1	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 448869	GAL		
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 1.07	AMP LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.63	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.38	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 47.4	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/08/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.6	GPM TOTAL FLOW is 38471756	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 35188183	GAL	
ASBPRS is 11.0	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 449157	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.45	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.46	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.40	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.25	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 47.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/09/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 12:52:44 ON 09/23/2015 BY KEYPAD

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.4	GPM TOTAL FLOW is 38503081	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 35219430	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 449399	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 1.15	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.22	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.10	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 53.9	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT HAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/12/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.4	GPM TOTAL FLOW is 38526497	GAL	
W2_FLO is 22.8	GPM TOTAL FLOW is 35243894	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 449493	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.98	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.01	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 58.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/13/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASHPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 20.9	GPM TOTAL FLOW is 38557242	GAL	
W2_FLO is 22.3	GPM TOTAL FLOW is 35276502	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 449570	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.66	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.89	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 57.0	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/14/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 20.7	GPM TOTAL FLOW is 38587554	GAL	
W2_FLO is 22.1	GPM TOTAL FLOW is 35308812	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 2.36	GPM TOTAL FLOW is 449672	GAL	
HP_PRS is 8.4	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 6.40	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.44	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.47	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.67	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 57.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/15/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 20.8	GPM TOTAL FLOW is 38617731	GAL	
W2_FLO is 22.5	GPM TOTAL FLOW is 35341014	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 449719	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.46	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.53	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 62.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/16/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 21.2	GPM TOTAL FLOW is 38647715	GAL	
W2_FLO is 22.5	GPM TOTAL FLOW is 35373156	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 449719	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.91	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.36	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 67.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/17/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.1	GPM TOTAL FLOW is 38677692	GAL	
W2_FLO is 21.8	GPM TOTAL FLOW is 35405273	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 449719	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.37	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.46	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 64.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/18/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 20.6	GPM TOTAL FLOW is 38707705	GAL	
W2_FLO is 22.3	GPM TOTAL FLOW is 35437390	GAL	
ASBPRS is 11.0	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 449747	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.10	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.42	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 58.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/19/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 20.9	GPM TOTAL FLOW is 38737756	GAL	
W2_FLO is 22.2	GPM TOTAL FLOW is 35469461	GAL	
ASBPRS is 11.0	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 449848	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.20	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.29	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 58.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/20/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 20.9	GPM TOTAL FLOW is 38767810	GAL	
W2_FLO is 22.2	GPM TOTAL FLOW is 35501531	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 449933	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.46	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.31	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 61.5	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/21/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 20.8	GPM TOTAL FLOW is 38797778	GAL	
W2_FLO is 22.4	GPM TOTAL FLOW is 35533596	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 449974	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.44	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.36	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.27	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 62.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/22/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	ELRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 20.9	GPM TOTAL FLOW is 38827709	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 35565343	GAL	
ASBPRS is 11.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 450050	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.44	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.42	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.42	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 53.2	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/23/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 20.3	GPM TOTAL FLOW is 38857627	GAL	
W2_FLO is 22.6	GPM TOTAL FLOW is 35597000	GAL	
ASBPRS is 11.0	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 450145	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.15	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.21	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 58.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/24/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is ON	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.3	GPM TOTAL FLOW is 38887497	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 35628670	GAL	
ASBPRS is 11.1	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 2.34	GPM TOTAL FLOW is 450243	GAL	
HP_PRS is 8.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 8.18	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.45	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.05	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.27	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 55.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/25/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 20.6	GPM TOTAL FLOW is 38917282	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 35660351	GAL	
ASBPRS is 11.1	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 450285	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.18	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.15	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 58.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/26/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 20.6	GPM TOTAL FLOW is 38947035	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 35692028	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 450339	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.91	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.89	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 63.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/27/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 20.3	GPM TOTAL FLOW is 38976725	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 35723677	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 450394	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.93	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.96	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 63.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/28/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 20.8	GPM TOTAL FLOW is 39006434	GAL	
W2_FLO is 22.1	GPM TOTAL FLOW is 35755324	GAL	
ASBPRS is 11.0	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 450435	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.67	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.70	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.85	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.87	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 61.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/29/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 21.0	GPM TOTAL FLOW is 39036173	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 35787001	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 450506	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.76	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.80	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.36	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.81	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 61.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/30/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 20.6	GPM TOTAL FLOW is 39065898	GAL	
W2_FLO is 22.1	GPM TOTAL FLOW is 35818601	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 450574	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.86	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.91	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 61.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 01/31/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVED is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 20.6	GPM TOTAL FLOW is 39095592	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 35850122	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 450642	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.74	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.77	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 61.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/01/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 20.8	GPM	TOTAL FLOW is 39125023	GAL		
W2_FLO is 21.6	GPM	TOTAL FLOW is 35881600	GAL		
ASBPRS is 10.4	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 450656	GAL		
HP_PRS is 1.1	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.57	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.64	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 33.46	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 55.72	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.4	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.7	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 66.5	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/02/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 20.6	GPM TOTAL FLOW is 39154503	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 35913047	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 450691	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.46	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.26	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.08	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 63.9	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/03/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 20.8	GPM TOTAL FLOW is 39184004	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 35944497	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 450719	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.05	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.89	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 65.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/04/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 21.2	GPM TOTAL FLOW is 39213575	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 35976014	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 450746	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.47	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 35.41	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 57.39	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 64.0	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/05/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASHPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 20.8	GPM TOTAL FLOW is 39243238	GAL	
W2_FLO is 21.8	GPM TOTAL FLOW is 36007551	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 450804	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.43	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.18	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.99	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 63.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/06/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 21.2	GPM	TOTAL FLOW is 39272995	GAL		
W2_FLO is 21.6	GPM	TOTAL FLOW is 36039029	GAL		
ASBPRS is 11.1	IWC	LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM	TOTAL FLOW is 450862	GAL		
HP_PRS is 1.3	PSI	LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP	LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.59	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.59	AMP	LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 35.02	FT	LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.86	FT	LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.5	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.8	PSI	LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 61.2	DEG	LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/07/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.5	GPM TOTAL FLOW is 39303718	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 36070465	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 450903	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.58	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.57	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 62.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/09/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 21.2	GPM TOTAL FLOW is 39364987	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 36133232	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 450984	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.80	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.25	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 62.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/10/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMAGO is ON	

Analog Inputs:

W1_FLO is 21.1	GPM TOTAL FLOW is 39395601	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 36164577	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 451041	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.46	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.49	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.63	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.21	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 61.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/11/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 21.5	GPM TOTAL FLOW is 39426227	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 36195927	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 4511111	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.89	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.23	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 58.3	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/12/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.7	GPM TOTAL FLOW is 39456927	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 36227254	GAL	
ASBPRS is 11.2	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 451223	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.45	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.47	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.10	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.25	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 55.5	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/13/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 20.9	GPM TOTAL FLOW is 39487505	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 36258592	GAL	
ASBPRS is 11.1	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 451321	GAL	
HP_PRS is 1.3	PSI LIMITS are L: 2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.52	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.94	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.17	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 57.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/14/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.2	GPM TOTAL FLOW is 39518220	GAL	
W2_FLO is 21.8	GPM TOTAL FLOW is 36289928	GAL	
ASBPRS is 11.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 451568	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.46	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.61	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 44.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/15/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.0	GPM TOTAL FLOW is 39548943	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 36321271	GAL	
ASBPRS is 11.5	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 451785	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.51	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.61	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 5.0	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 46.9	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/16/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.3	GPM TOTAL FLOW is 39579600	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 36352545	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 451880	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.87	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.02	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 65.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ALARM Fax Report

EOS Research Ltd.

ProControl Series II+

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 11:07:03 ON 02/16/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P19 : LAST SHUTDOWN @ 09:24:23 ON 01/09/2016 BY ACFAIL
FAX REPORT INITIATED BY PROCESS 18

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 39586097	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 36359189	GAL	
ASBPRS is 9.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 451880	GAL	
HP_PRS is 0.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 0.01	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.35	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.31	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 66.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ALARM Fax Report

EOS Research Ltd.

ProControl Series II+

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 11:21:00 ON 02/16/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

MANUAL : LAST SHUTDOWN @ 11:17:03 ON 02/16/2016 BY ACFAIL
FAX REPORT INITIATED BY PROCESS 19

Discrete Inputs:

W1_CTR is OFF	W2_CTR is OFF	ASBVFD is OFF	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is OFF	W2_GO is OFF	ASB_GO is OFF	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is ON
W2_ALM is ON	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is OFF	

Analog Inputs:

W1_FLO is 0.0	GPM TOTAL FLOW is 39586097	GAL	
W2_FLO is 0.0	GPM TOTAL FLOW is 36359189	GAL	
ASBPRS is 0.2	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 451880	GAL	
HP_PRS is 0.8	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 0.01	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 0.00	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.56	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.43	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 0.0	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 65.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/17/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 11:17:03 ON 02/16/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMAGO is ON	

Analog Inputs:

W1_FLO is 22.9	GPM TOTAL FLOW is 39608607	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 36381118	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 451894	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.97	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 58.28	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 63.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/18/2016
 SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 22.5	GPM TOTAL FLOW is 39640713	GAL	
W2_FLO is 22.2	GPM TOTAL FLOW is 36412461	GAL	
ASBPRS is 11.1	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 451945	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.46	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.46	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.78	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.73	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 59.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/19/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 22.9	GPM TOTAL FLOW is 39673004	GAL	
W2_FLO is 22.3	GPM TOTAL FLOW is 36443998	GAL	
ASBPRS is 11.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452033	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.42	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.14	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 55.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/20/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 22.5	GPM TOTAL FLOW is 39705133	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 36475454	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452076	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.66	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.62	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.57	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.78	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 64.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/21/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPEGO is ON	

Analog Inputs:

W1_FLO is 21.9	GPM TOTAL FLOW is 39736955	GAL	
W2_FLO is 22.1	GPM TOTAL FLOW is 36506924	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452104	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.60	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.73	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.80	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 63.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/22/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMAGO is ON	

Analog Inputs:

W1_FLO is 22.1	GPM TOTAL FLOW is 39768691	GAL	
W2_FLO is 22.2	GPM TOTAL FLOW is 36538484	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452138	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.45	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.45	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.68	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.76	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 63.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/23/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACEFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACEFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.8	GPM TOTAL FLOW is 39800359	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 36570007	GAL	
ASBPRS is 11.1	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452196	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.73	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.57	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 60.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/24/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVED is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPEGO is ON	

Analog Inputs:

W1_FLO is 21.8	GPM TOTAL FLOW is 39832007	GAL		
W2_FLO is 22.1	GPM TOTAL FLOW is 36601488	GAL		
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452224	GAL		
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.37	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.38	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.9	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 65.3	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/25/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_III is OFF	ASHPIII is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.7	GPM TOTAL FLOW is 39863640	GAL	
W2_FLO is 22.2	GPM TOTAL FLOW is 36633015	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452224	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.48	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 58.38	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 66.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/26/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPEGO is ON	

Analog Inputs:

W1_FLO is 22.1	GPM TOTAL FLOW is 39895355	GAL	
W2_FLO is 22.1	GPM TOTAL FLOW is 36664748	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452266	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.98	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 58.34	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 60.5	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/27/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.2	GPM TOTAL FLOW is 39926589	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 36696451	GAL	
ASBPRS is 11.0	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452349	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.62	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.65	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 59.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/28/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACEFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACEFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.5	GPM TOTAL FLOW is 39957601	GAL		
W2_FLO is 21.5	GPM TOTAL FLOW is 36728104	GAL		
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452390	GAL		
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.64	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.63	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 35.13	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 57.24	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 62.0	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd. Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 02/29/2016
 SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 21.2	GPM TOTAL FLOW is 39988542	GAL		
W2_FLO is 22.2	GPM TOTAL FLOW is 36759764	GAL		
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452418	GAL		
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.59	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.61	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.51	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.97	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 65.8	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/01/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPEGO is ON	

Analog Inputs:

W1_FLO is 21.3	GPM TOTAL FLOW is 40019456	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 36791385	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452433	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.52	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 35.05	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 57.03	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 61.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/02/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPEGO is ON	

Analog Inputs:

W1_FLO is 21.5	GPM TOTAL FLOW is 40050361	GAL	
W2_FLO is 22.3	GPM TOTAL FLOW is 36822931	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452462	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.19	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.67	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 63.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/03/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 21.7	GPM TOTAL FLOW is 40081304	GAL		
W2_FLO is 22.1	GPM TOTAL FLOW is 36854335	GAL		
ASBPRS is 11.1	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452531	GAL		
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.74	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.80	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 58.5	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/04/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 21.5	GPM TOTAL FLOW is 40112187	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 36885680	GAL	
ASBPRS is 11.0	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452592	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.56	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.51	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.55	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 60.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/05/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPEGO is ON	

Analog Inputs:

W1_FLO is 21.4	GPM TOTAL FLOW is 40143037	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 36916947	GAL	
ASBPRS is 11.1	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452663	GAL	
HP_PRS is 1.1	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.51	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.57	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 57.2	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/06/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.4	GPM TOTAL FLOW is 40173876	GAL		
W2_FLO is 21.8	GPM TOTAL FLOW is 36948197	GAL		
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0	IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452711	GAL		
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0	PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:	AMP
W1_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W2_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00	AMP
W1_LVL is 34.46	FT LIMITS are L: 8.00	FT	H: 28.00	FT
W2_LVL is 56.46	FT LIMITS are L: 9.00	FT	H: 52.00	FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0	PSI
INTEMP is 61.3	DEG LIMITS are L: 42.0	DEG	H: 130.0	DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/07/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.2	GPM TOTAL FLOW is 40204574	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 36979456	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452755	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.22	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.23	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 64.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/08/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 20.9	GPM TOTAL FLOW is 40235173	GAL	
W2_FLO is 22.1	GPM TOTAL FLOW is 37010689	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452784	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.21	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.29	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 64.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/09/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.1	GPM TOTAL FLOW is 40265783	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 37041947	GAL	
ASBPRS is 10.8	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 452799	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.80	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.79	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 34.16	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.25	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.8	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 63.4	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/10/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.2	GPM TOTAL FLOW is 40296321	GAL	
W2_FLO is 21.9	GPM TOTAL FLOW is 37073190	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452813	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.80	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.78	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.99	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.12	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 67.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/11/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 21.2	GPM TOTAL FLOW is 40326827	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 37104385	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452813	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.52	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.52	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.64	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.74	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 67.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/12/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.2	GPM TOTAL FLOW is 40357317	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 37135617	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452813	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.75	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.48	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 64.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/13/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMAGO is ON	

Analog Inputs:

W1_FLO is 20.9	GPM TOTAL FLOW is 40387649	GAL	
W2_FLO is 22.1	GPM TOTAL FLOW is 37166766	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452828	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.36	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.42	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 63.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/14/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 20.8	GPM TOTAL FLOW is 40417900	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 37197919	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452828	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.19	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.23	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 65.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/15/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.1	GPM TOTAL FLOW is 40448110	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 37229072	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452828	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.45	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.96	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.27	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 66.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/16/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 20.9	GPM TOTAL FLOW is 40478221	GAL	
W2_FLO is 21.8	GPM TOTAL FLOW is 37260201	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452828	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.52	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.91	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.23	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 66.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/17/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.0	GPM TOTAL FLOW is 40508294	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 37291325	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452828	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.43	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.46	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.94	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.29	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.5	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 66.8	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/18/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPEGO is ON	

Analog Inputs:

W1_FLO is 20.9	GPM TOTAL FLOW is 40538376	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 37322526	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452828	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.51	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.82	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.23	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 67.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/19/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 20.8	GPM TOTAL FLOW is 40568605	GAL	
W2_FLO is 21.1	GPM TOTAL FLOW is 37353763	GAL	
ASBPRS is 11.0	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 452996	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.15	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.34	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 53.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/20/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 21.0	GPM TOTAL FLOW is 40598857	GAL	
W2_FLO is 21.4	GPM TOTAL FLOW is 37384994	GAL	
ASBPRS is 11.0	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 453193	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.46	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.47	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 34.11	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.17	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 52.2	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/21/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.2	GPM TOTAL FLOW is 40629116	GAL	
W2_FLO is 22.1	GPM TOTAL FLOW is 37416206	GAL	
ASBPRS is 10.6	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 453363	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.44	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.47	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.63	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.08	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 54.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/22/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPEGO is ON	

Analog Inputs:

W1_FLO is 20.9	GPM TOTAL FLOW is 40659400	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 37447399	GAL	
ASBPRS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0
HP_FLO is 0.00	GPM TOTAL FLOW is 453555	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H:
W1_AMP is 4.40	AMP LIMITS are L: 0.00	AMP	H: 10.00
W2_AMP is 4.44	AMP LIMITS are L: 0.00	AMP	H: 10.00
W1_LVL is 33.86	FT LIMITS are L: 8.00	FT	H: 28.00
W2_LVL is 56.06	FT LIMITS are L: 9.00	FT	H: 52.00
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0
INTEMP is 52.2	DEG LIMITS are L: 42.0	DEG	H: 130.0

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/23/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 20.9	GPM TOTAL FLOW is 40689605	GAL	
W2_FLO is 21.4	GPM TOTAL FLOW is 37478579	GAL	
ASBPRS is 10.4	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 453714	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.41	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.44	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.61	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.96	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 59.2	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/24/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVED is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.2	GPM TOTAL FLOW is 40719817	GAL	
W2_FLO is 22.1	GPM TOTAL FLOW is 37509755	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 453844	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.37	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.41	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.77	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.98	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 57.7	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/25/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.0	GPM TOTAL FLOW is 40749971	GAL	
W2_FLO is 21.8	GPM TOTAL FLOW is 37540927	GAL	
ASBPRS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 453953	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.05	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.54	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.26	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.87	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 59.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/26/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.3	GPM TOTAL FLOW is 40780165	GAL	
W2_FLO is 22.0	GPM TOTAL FLOW is 37572100	GAL	
ASBPRS is 10.7	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 454097	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.48	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.97	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.98	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 54.6	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/27/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPELL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 20.7	GPM TOTAL FLOW is 40810343	GAL	
W2_FLO is 21.5	GPM TOTAL FLOW is 37603278	GAL	
ASBPERS is 10.9	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 454224	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.57	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.58	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.93	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.91	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.4	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 55.4	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/28/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACEFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACEFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMGO is ON	

Analog Inputs:

W1_FLO is 20.4	GPM TOTAL FLOW is 40840452	GAL	
W2_FLO is 21.4	GPM TOTAL FLOW is 37634447	GAL	
ASBPERS is 10.3	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 454343	GAL	
HP_PRS is 1.1	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.46	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.50	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.31	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.79	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.2	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 60.0	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd.

Fax Report

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/30/2016
SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:


W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VEDRUN is OFF	VEDRST is OFF	HPMPO is ON	

Analog Inputs:

W1_FLO is 21.1	GPM TOTAL FLOW is 40900809	GAL	
W2_FLO is 21.7	GPM TOTAL FLOW is 37696748	GAL	
ASBPRS is 11.0	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 454678	GAL	
HP_PRS is 1.3	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.44	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.47	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.94	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 56.08	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.6	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 52.1	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN



ProControl Series II+

EOS Research Ltd. *Fax Report*

To:

JEREMY WYCKOFF

From:

THE NYSDEC GLADDING SYSTEM IN SOUTH OTSELIC NY @ 06:00:00 ON 03/31/2016
 SER NO 9605 : SETUP VER 1 : ROM 2.1996 : MODEL A2

System Status:

AUTO P35 : LAST SHUTDOWN @ 14:05:23 ON 02/17/2016 BY ACFAIL

Discrete Inputs:

W1_CTR is ON	W2_CTR is ON	ASBVFD is ON	SMPCTR is OFF
HP_OP is OFF	ASP_HH is OFF	ASP_LO is OFF	FLRSMP is OFF
ACFAIL is OFF	E_STOP is OFF		

Discrete Outputs:

W1_GO is ON	W2_GO is ON	ASB_GO is ON	SMP_GO is OFF
AIR_HH is OFF	ASMPHH is OFF	ASMPLL is OFF	W1_ALM is OFF
W2_ALM is OFF	ASBALM is OFF	SMPALM is OFF	AIR_LL is OFF
VFDRUN is OFF	VFDRST is OFF	HPMPGO is ON	

Analog Inputs:

W1_FLO is 21.1	GPM TOTAL FLOW is 40931049	GAL	
W2_FLO is 21.6	GPM TOTAL FLOW is 37727875	GAL	
ASBPRS is 10.5	IWC LIMITS are L: 5.0	IWC	H: 30.0 IWC
HP_FLO is 0.00	GPM TOTAL FLOW is 454808	GAL	
HP_PRS is 1.2	PSI LIMITS are L: -2.0	PSI	H: 20.0 PSI
HP_AMP is 0.04	AMP LIMITS are L: 0.00	AMP	H: AMP
W1_AMP is 4.53	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W2_AMP is 4.55	AMP LIMITS are L: 0.00	AMP	H: 10.00 AMP
W1_LVL is 33.35	FT LIMITS are L: 8.00	FT	H: 28.00 FT
W2_LVL is 55.89	FT LIMITS are L: 9.00	FT	H: 52.00 FT
W1_PRS is 4.3	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
W2_PRS is 4.7	PSI LIMITS are L: 0.5	PSI	H: 100.0 PSI
INTEMP is 58.9	DEG LIMITS are L: 42.0	DEG	H: 130.0 DEG

Analog Outputs:

ASBSPD 0.0 PCT MAN

APPENDIX B

O&M Checklists



APPENDIX C

Analytical Reporting Forms



February 5, 2016

Jeremy Wyckoff
Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065

Project Location: S. Otseliic, NY
Client Job Number:
Project Number: 00266406.0000
Laboratory Work Order Number: 16A1019

Enclosed are results of analyses for samples received by the laboratory on January 27, 2016. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "Aaron L. Benoit", with a horizontal line extending to the right from the end of the signature.

Aaron L. Benoit
Project Manager

Table of Contents

Sample Summary	3
Case Narrative	4
Sample Results	5
16A1019-01	5
16A1019-02	6
16A1019-03	7
16A1019-04	8
Sample Preparation Information	9
QC Data	10
Volatile Organic Compounds by GC/MS	10
B141448	10
Flag/Qualifier Summary	12
Certifications	13
Chain of Custody/Sample Receipt	15

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065
ATTN: Jeremy Wyckoff

REPORT DATE: 2/5/2016

PURCHASE ORDER NUMBER:

PROJECT NUMBER: 00266406.0000

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 16A1019

The results of analyses performed on the following samples submitted to the CON-TEST Analytical Laboratory are found in this report.

PROJECT LOCATION: S. Otseliic, NY

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
RW-1	16A1019-01	Ground Water		EPA 624	
RW-2	16A1019-02	Ground Water		EPA 624	
EFF 46 HZ	16A1019-03	Ground Water		EPA 624	
Trip Blank	16A1019-04	Trip Blank Water		EPA 624	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Con-Test Analytical Laboratory for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.

A handwritten signature in black ink, appearing to read "Tod Kopycinski". The signature is written in a cursive, somewhat stylized script.

Tod E. Kopycinski
Laboratory Director

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otseliic, NY

Sample Description:

Work Order: 16A1019

Date Received: 1/27/2016

Field Sample #: RW-1

Sampled: 1/25/2016 12:45

Sample ID: 16A1019-01

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
1,1-Dichloroethane	1.8	2.0	0.16	µg/L	1	J	EPA 624	2/4/16	2/4/16 23:59	MFF
1,1-Dichloroethylene	0.84	2.0	0.21	µg/L	1	J	EPA 624	2/4/16	2/4/16 23:59	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
1,1,1-Trichloroethane	38	2.0	0.094	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	2/4/16	2/4/16 23:59	MFF
Surrogates		% Recovery	Recovery Limits			Flag/Qual				
1,2-Dichloroethane-d4		101	70-130						2/4/16 23:59	
Toluene-d8		95.3	70-130						2/4/16 23:59	
4-Bromofluorobenzene		87.2	70-130						2/4/16 23:59	

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otseliic, NY

Sample Description:

Work Order: 16A1019

Date Received: 1/27/2016

Field Sample #: RW-2

Sampled: 1/25/2016 12:50

Sample ID: 16A1019-02

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
1,1-Dichloroethane	0.86	2.0	0.16	µg/L	1	J	EPA 624	2/4/16	2/5/16 0:25	MFF
1,1-Dichloroethylene	0.64	2.0	0.21	µg/L	1	J	EPA 624	2/4/16	2/5/16 0:25	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
1,1,1-Trichloroethane	32	2.0	0.094	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	2/4/16	2/5/16 0:25	MFF
Surrogates		% Recovery	Recovery Limits			Flag/Qual				
1,2-Dichloroethane-d4		99.6	70-130						2/5/16 0:25	
Toluene-d8		94.1	70-130						2/5/16 0:25	
4-Bromofluorobenzene		88.4	70-130						2/5/16 0:25	

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otseliic, NY

Sample Description:

Work Order: 16A1019

Date Received: 1/27/2016

Field Sample #: EFF 46 HZ

Sampled: 1/25/2016 12:55

Sample ID: 16A1019-03

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	2/4/16	2/4/16 23:33	MFF
Surrogates		% Recovery	Recovery Limits			Flag/Qual				
1,2-Dichloroethane-d4		101	70-130						2/4/16 23:33	
Toluene-d8		94.2	70-130						2/4/16 23:33	
4-Bromofluorobenzene		87.9	70-130						2/4/16 23:33	

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otseliic, NY

Sample Description:

Work Order: 16A1019

Date Received: 1/27/2016

Field Sample #: Trip Blank

Sampled: 1/25/2016 00:00

Sample ID: 16A1019-04

Sample Matrix: Trip Blank Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	2/4/16	2/4/16 23:07	MFF
Surrogates		% Recovery	Recovery Limits			Flag/Qual				
1,2-Dichloroethane-d4		96.6	70-130						2/4/16 23:07	
Toluene-d8		94.3	70-130						2/4/16 23:07	
4-Bromofluorobenzene		87.2	70-130						2/4/16 23:07	

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Sample Extraction Data

Prep Method: SW-846 5030B-EPA 624

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
16A1019-01 [RW-1]	B141448	5	5.00	02/04/16
16A1019-02 [RW-2]	B141448	5	5.00	02/04/16
16A1019-03 [EFF 46 HZ]	B141448	5	5.00	02/04/16
16A1019-04 [Trip Blank]	B141448	5	5.00	02/04/16

QUALITY CONTROL

Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

Batch B141448 - SW-846 5030B

Blank (B141448-BLK1)

Prepared & Analyzed: 02/04/16

Benzene	ND	1.0	µg/L							
Bromodichloromethane	ND	2.0	µg/L							
Bromoform	ND	2.0	µg/L							
Bromomethane	ND	2.0	µg/L							
Carbon Tetrachloride	ND	2.0	µg/L							
Chlorobenzene	ND	2.0	µg/L							
Chlorodibromomethane	ND	2.0	µg/L							
Chloroethane	ND	2.0	µg/L							
2-Chloroethyl Vinyl Ether	ND	10	µg/L							
Chloroform	ND	2.0	µg/L							
Chloromethane	ND	2.0	µg/L							
1,2-Dichlorobenzene	ND	2.0	µg/L							
1,3-Dichlorobenzene	ND	2.0	µg/L							
1,4-Dichlorobenzene	ND	2.0	µg/L							
1,2-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethylene	ND	2.0	µg/L							
trans-1,2-Dichloroethylene	ND	2.0	µg/L							
1,2-Dichloropropane	ND	2.0	µg/L							
cis-1,3-Dichloropropene	ND	2.0	µg/L							
trans-1,3-Dichloropropene	ND	2.0	µg/L							
Ethylbenzene	ND	2.0	µg/L							
Methyl tert-Butyl Ether (MTBE)	ND	2.0	µg/L							
Methylene Chloride	ND	5.0	µg/L							
1,1,2,2-Tetrachloroethane	ND	2.0	µg/L							
Tetrachloroethylene	ND	2.0	µg/L							
Toluene	ND	1.0	µg/L							
1,1,1-Trichloroethane	ND	2.0	µg/L							
1,1,2-Trichloroethane	ND	2.0	µg/L							
Trichloroethylene	ND	2.0	µg/L							
Trichlorofluoromethane (Freon 11)	ND	2.0	µg/L							
Vinyl Chloride	ND	2.0	µg/L							
m+p Xylene	ND	2.0	µg/L							
o-Xylene	ND	2.0	µg/L							
Surrogate: 1,2-Dichloroethane-d4	25.8		µg/L	25.0		103	70-130			
Surrogate: Toluene-d8	24.0		µg/L	25.0		96.0	70-130			
Surrogate: 4-Bromofluorobenzene	22.3		µg/L	25.0		89.4	70-130			

LCS (B141448-BS1)

Prepared & Analyzed: 02/04/16

Benzene	9.95	1.0	µg/L	10.0		99.5	37-151			
Bromodichloromethane	9.65	2.0	µg/L	10.0		96.5	35-155			
Bromoform	8.78	2.0	µg/L	10.0		87.8	45-169			
Bromomethane	11.5	2.0	µg/L	10.0		115	20-242			
Carbon Tetrachloride	9.44	2.0	µg/L	10.0		94.4	70-140			
Chlorobenzene	10.0	2.0	µg/L	10.0		100	37-160			
Chlorodibromomethane	9.32	2.0	µg/L	10.0		93.2	53-149			
Chloroethane	11.2	2.0	µg/L	10.0		112	70-130			
2-Chloroethyl Vinyl Ether	98.0	10	µg/L	100		98.0	10-305			
Chloroform	9.44	2.0	µg/L	10.0		94.4	51-138			
Chloromethane	7.83	2.0	µg/L	10.0		78.3	20-273			
1,2-Dichlorobenzene	10.6	2.0	µg/L	10.0		106	18-190			
1,3-Dichlorobenzene	11.0	2.0	µg/L	10.0		110	59-156			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL

Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch B141448 - SW-846 5030B										
LCS (B141448-BS1)										
Prepared & Analyzed: 02/04/16										
1,4-Dichlorobenzene	10.3	2.0	µg/L	10.0		103	18-190			
1,2-Dichloroethane	9.77	2.0	µg/L	10.0		97.7	49-155			
1,1-Dichloroethane	9.34	2.0	µg/L	10.0		93.4	59-155			
1,1-Dichloroethylene	10.8	2.0	µg/L	10.0		108	20-234			
trans-1,2-Dichloroethylene	9.75	2.0	µg/L	10.0		97.5	54-156			
1,2-Dichloropropane	9.12	2.0	µg/L	10.0		91.2	20-210			
cis-1,3-Dichloropropene	9.45	2.0	µg/L	10.0		94.5	20-227			
trans-1,3-Dichloropropene	9.13	2.0	µg/L	10.0		91.3	17-183			
Ethylbenzene	9.74	2.0	µg/L	10.0		97.4	37-162			
Methyl tert-Butyl Ether (MTBE)	8.94	2.0	µg/L	10.0		89.4	70-130			
Methylene Chloride	9.01	5.0	µg/L	10.0		90.1	50-221			
1,1,2,2-Tetrachloroethane	11.6	2.0	µg/L	10.0		116	46-157			
Tetrachloroethylene	9.67	2.0	µg/L	10.0		96.7	64-148			
Toluene	9.70	1.0	µg/L	10.0		97.0	47-150			
1,1,1-Trichloroethane	8.91	2.0	µg/L	10.0		89.1	52-162			
1,1,2-Trichloroethane	9.70	2.0	µg/L	10.0		97.0	52-150			
Trichloroethylene	8.94	2.0	µg/L	10.0		89.4	71-157			
Trichlorofluoromethane (Freon 11)	13.1	2.0	µg/L	10.0		131	17-181			
Vinyl Chloride	10.3	2.0	µg/L	10.0		103	20-251			
m+p Xylene	18.4	2.0	µg/L	20.0		92.0	70-130			
o-Xylene	9.83	2.0	µg/L	10.0		98.3	70-130			
Surrogate: 1,2-Dichloroethane-d4	23.8		µg/L	25.0		95.1	70-130			
Surrogate: Toluene-d8	24.7		µg/L	25.0		98.8	70-130			
Surrogate: 4-Bromofluorobenzene	22.5		µg/L	25.0		90.1	70-130			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
ND	Not Detected
RL	Reporting Limit
DL	Method Detection Limit
MCL	Maximum Contaminant Level
	Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
	No results have been blank subtracted unless specified in the case narrative section.
J	Detected but below the Reporting Limit (lowest calibration standard); therefore, result is an estimated concentration (CLP J-Flag).

CERTIFICATIONS

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 624 in Water</i>	
Benzene	CT,MA,NH,NY,RI,NC,ME,VA
Bromodichloromethane	CT,MA,NH,NY,RI,NC,ME,VA
Bromoform	CT,MA,NH,NY,RI,NC,ME,VA
Bromomethane	CT,MA,NH,NY,RI,NC,ME,VA
Carbon Tetrachloride	CT,MA,NH,NY,RI,NC,ME,VA
Chlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
Chlorodibromomethane	CT,MA,NH,NY,RI,NC,ME,VA
Chloroethane	CT,MA,NH,NY,RI,NC,ME,VA
2-Chloroethyl Vinyl Ether	CT,MA,NH,NY,RI,NC,ME,VA
Chloroform	CT,MA,NH,NY,RI,NC,ME,VA
Chloromethane	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,3-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,4-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
trans-1,2-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichloropropane	CT,MA,NH,NY,RI,NC,ME,VA
cis-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA
trans-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA
Ethylbenzene	CT,MA,NH,NY,RI,NC,ME,VA
Methyl tert-Butyl Ether (MTBE)	NC
Methylene Chloride	CT,MA,NH,NY,RI,NC,ME,VA
1,1,2,2-Tetrachloroethane	CT,MA,NH,NY,RI,NC,ME,VA
Tetrachloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
Toluene	CT,MA,NH,NY,RI,NC,ME,VA
1,1,1-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1,2-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
Trichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
Trichlorofluoromethane (Freon 11)	CT,MA,NH,NY,RI,NC,ME,VA
Vinyl Chloride	CT,MA,NH,NY,RI,NC,ME,VA
m+p Xylene	CT,MA,NH,NY,RI,NC,VA
o-Xylene	CT,MA,NH,NY,RI,NC,VA

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

The CON-TEST Environmental Laboratory operates under the following certifications and accreditations:

Code	Description	Number	Expires
AIHA	AIHA-LAP, LLC	100033	02/1/2018
MA	Massachusetts DEP	M-MA100	06/30/2016
CT	Connecticut Department of Public Health	PH-0567	09/30/2017
NY	New York State Department of Health	10899 NELAP	04/1/2016
NH-S	New Hampshire Environmental Lab	2516 NELAP	02/5/2016
RI	Rhode Island Department of Health	LAO00112	12/30/2016
NC	North Carolina Div. of Water Quality	652	12/31/2016
NJ	New Jersey DEP	MA007 NELAP	06/30/2016
FL	Florida Department of Health	E871027 NELAP	06/30/2016
VT	Vermont Department of Health Lead Laboratory	LL015036	07/30/2016
WA	State of Washington Department of Ecology	C2065	02/23/2016
ME	State of Maine	2011028	06/9/2017
VA	Commonwealth of Virginia	460217	12/14/2016
NH-P	New Hampshire Environmental Lab	2557 NELAP	09/6/2016

CHAIN OF CUSTODY RECORD

39 Spruce Street
East Longmeadow, MA 01028

Page 1 of 1

Phone: 413-525-2332
Fax: 413-525-6405
Email: info@contestlabs.com
www.contestlabs.com



Company Name: ARCADIS

Address: 855 Route 146, STE 210
Clifton Park N.Y. 12065

Attention: J. Wyckoff

Project Location: S. Otselec, N.Y.

Sampled By: L. Whalen

Telephone: 518-250-7300

Project # 00266406.0000

Client PO#

DATA DELIVERY (check all that apply)

FAX EMAIL WEBSITE

Fax #

Email:

Format: PDF EXCEL GIS

OTHER "Enhanced Data Package"

Project Proposal Provided? (for billing purposes)

Con-Test Lab ID <small>(laboratory use only)</small>	Client Sample ID / Description	Collection		Composite	Grab	*Matrix Code	Conc. Code
		Beginning Date/Time	Ending Date/Time				
<u>01</u>	<u>BW-1</u>	<u>1/25/16</u>	<u>12:45</u>	<input checked="" type="checkbox"/>	<u>GW</u>	<u>M</u>	
<u>02</u>	<u>BW-2</u>	<u>↓</u>	<u>12:50</u>	<input checked="" type="checkbox"/>	<u>↓</u>	<u>M</u>	
<u>03</u>	<u>EFF 46 HZ</u>	<u>↓</u>	<u>12:55</u>	<input checked="" type="checkbox"/>	<u>↓</u>	<u>L</u>	
<u>04</u>	<u>Trip Blank</u>	<u>↑</u>	<u>-</u>	<input checked="" type="checkbox"/>	<u>↑</u>	<u>-</u>	

Comments:

Please use the following codes to let Con-Test know if a specific sample may be high in concentration in Matrix/Conc. Code Box:

H - High; M - Medium; L - Low; C - Clean; U - Unknown

Relinquished by: (signature) <u>Lance S. Whalen</u>	Date/Time: <u>1/25/16</u>	Relinquished by:	Date/Time:
Received by: (signature) <u>Lance S. Whalen</u>	Date/Time: <u>9:48</u>	Received by:	Date/Time:
Relinquished by: (signature)	Date/Time:	Relinquished by:	Date/Time:
Received by: (signature)	Date/Time:	Received by:	Date/Time:

Turnaround

5-Day
 7 Day
 10-Day or RUSH †

24 hr 48 hr
72 hr 4 day

† Require lab approval

Program Information/Regulatory

NY TOGS NY Restricted Use
 AWQ STDS NY Unrestricted Use
 NYC Sewer Discharge
 Part 360 GW (Landfill)

Deliverables

ASP-A Equis (1 file)
 ASP-B Equis (4 file)

# of Containers	
** Preservation	
*** Container Code	
Dissolved Metals	
<input type="radio"/> Field Filtered	
<input type="radio"/> Lab to Filter	

*** Cont. Code:	
A=amber glass	
G=glass	
P=plastic	
ST=sterile	
V= vial	
S=summary can	
T=tetlar bag	
O=Other	
** Preservation	
I = Iced	
H = HCL	
M = Methanol	
N = Nitric Acid	
S = Sulfuric Acid	
B = Sodium bisulfate	
X = Na hydroxide	
T = Na thiosulfate	
O = Other	
*Matrix Code:	
GW= groundwater	
WW= wastewater	
DW= drinking water	
A = air	
S = soil/solid	
SL = sludge	
O = other	

ANALYSIS REQUESTED

624

URNAROUND TIME (business days) STARTS AT 9:00 A.M. THE DAY AFTER SAMPLE RECEIPT UNLESS THERE ARE QUESTIONS ON YOUR CHAIN. IF THIS FORM IS NOT FILLED OUT COMPLETELY OR IS INCORRECT, TURNAROUND TIME WILL NOT START UNTIL ALL QUESTIONS ARE ANSWERED. PLEASE BE CAREFUL TO NOT CONTAMINATE THIS DOCUMENT

39 Spruce St.
 East Longmeadow, MA. 01028
 P: 413-525-2332
 F: 413-525-6405
 www.contestlabs.com



Sample Receipt Checklist

CLIENT NAME: Arcadis **RECEIVED BY:** PB **DATE:** 1/27/2016

- 1) Was the chain(s) of custody relinquished and signed? Yes No **No COC Incl.**
- 2) Does the chain agree with the samples? Yes No
 If not, explain: _____
- 3) Are all the samples in good condition? Yes No
 If not, explain: _____
- 4) How were the samples received:
 On Ice Direct from Sampling Ambient In Cooler(s)
Were the samples received in Temperature Compliance of (2-6°C)? Yes No **N/A**
 Temperature °C by Temp blank 3 Temperature °C by Temp gun _____
- 5) Are there Dissolved samples for the lab to filter? Yes No
 Who was notified _____ Date _____ Time _____
- 6) Are there any RUSH or SHORT HOLDING TIME samples? Yes No
 Who was notified _____ Date _____ Time _____
- 7) Location where samples are stored:

Login

Permission to subcontract samples? Yes No
 (Walk-in clients only) if not already approved
 Client Signature: _____
- 8) Do all samples have the proper Acid pH: Yes No **N/A**
- 9) Do all samples have the proper Base pH: Yes No **N/A**
- 10) Was the PC notified of any discrepancies with the CoC vs the samples: Yes **N/A**

Containers received at Con-Test

	# of containers			# of containers
1 Liter Amber			16 oz amber	
500 mL Amber			8 oz amber/clear jar	
250 mL Amber (8oz amber)			4 oz amber/clear jar	
1 Liter Plastic			2 oz amber/clear jar	
500 mL Plastic			Plastic Bag / Ziploc	
250 mL plastic			SOC Kit	
40 mL Vial - type listed below	11		Perchlorate Kit	
Colisure / bacteria bottle			Flashpoint bottle	
Dissolved Oxygen bottle			Other glass jar	
Encore			Other	

40 mL vials: # HCl <u>11</u> # Methanol _____ # Bisulfate _____ # DI Water _____ # Thiosulfate _____ Unpreserved _____	Time and Date Frozen: _____
--	---------------------------------------

Doc# 277
 Rev. 4 August 2013

Login Sample Receipt Checklist
(Rejection Criteria Listing - Using Sample Acceptance Policy)
Any False statement will be brought to the attention of Client

<u>Question</u>	<u>Answer (True/False)</u>		<u>Comment</u>
	T/F/NA		
1) The cooler's custody seal, if present, is intact.	NA		
2) The cooler or samples do not appear to have been compromised or tampered with.	T		
3) Samples were received on ice.	T		
4) Cooler Temperature is acceptable.	T		
5) Cooler Temperature is recorded.	T		
6) COC is filled out in ink and legible.	T		
7) COC is filled out with all pertinent information.	T		
8) Field Sampler's name present on COC.	T		
9) There are no discrepancies between the sample IDs on the container and the COC.	T		
10) Samples are received within Holding Time.	T		
11) Sample containers have legible labels.	T		
12) Containers are not broken or leaking.	T		
13) Air Cassettes are not broken/open.	NA		
14) Sample collection date/times are provided.	T		
15) Appropriate sample containers are used.	T		
16) Proper collection media used.	T		
17) No headspace sample bottles are completely filled.	T		
18) There is sufficient volume for all requested analyses, including any requested MS/MSDs.	T		
19) Trip blanks provided if applicable.	T		
20) VOA sample vials do not have head space or bubble is <6mm (1/4") in diameter.	T		
21) Samples do not require splitting or compositing.	T		

Doc #277 Rev. 4 August 2013 **Who notified of False statements?**
Log-In Technician Initials: PB

Date/Time:
Date/Time:1/27/16 9:48AM

March 7, 2016

Jeremy Wyckoff
Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065

Project Location: S. Otselic, NY
Client Job Number:
Project Number: 00266406.0000
Laboratory Work Order Number: 16B1133

Enclosed are results of analyses for samples received by the laboratory on February 29, 2016. If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Aaron L. Benoit
Project Manager

Table of Contents

Sample Summary	3
Case Narrative	4
Sample Results	5
16B1133-01	5
16B1133-02	6
16B1133-03	7
16B1133-04	8
Sample Preparation Information	9
QC Data	10
Volatile Organic Compounds by GC/MS	10
B143521	10
Flag/Qualifier Summary	12
Certifications	13
Chain of Custody/Sample Receipt	15

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065
ATTN: Jeremy Wyckoff

REPORT DATE: 3/7/2016

PURCHASE ORDER NUMBER:

PROJECT NUMBER: 00266406.0000

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 16B1133

The results of analyses performed on the following samples submitted to the CON-TEST Analytical Laboratory are found in this report.

PROJECT LOCATION: S. Otselic, NY

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
RW-1	16B1133-01	Ground Water		EPA 624	
RW-2	16B1133-02	Ground Water		EPA 624	
EFF 46 HZ	16B1133-03	Ground Water		EPA 624	
Trip Blank	16B1133-04	Trip Blank Water		EPA 624	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Con-Test Analytical Laboratory for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.

A handwritten signature in black ink, appearing to read "Tod Kopycinski". The signature is written in a cursive style with a large, sweeping initial "T".

Tod E. Kopycinski
Laboratory Director

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 16B1133

Date Received: 2/29/2016

Field Sample #: RW-1

Sampled: 2/26/2016 07:15

Sample ID: 16B1133-01

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
1,1-Dichloroethane	1.5	2.0	0.16	µg/L	1	J	EPA 624	3/4/16	3/4/16 19:42	EEH
1,1-Dichloroethylene	0.79	2.0	0.21	µg/L	1	J	EPA 624	3/4/16	3/4/16 19:42	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
1,1,1-Trichloroethane	36	2.0	0.094	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	3/4/16	3/4/16 19:42	EEH
Surrogates		% Recovery	Recovery Limits			Flag/Qual				
1,2-Dichloroethane-d4		105	70-130						3/4/16 19:42	
Toluene-d8		99.2	70-130						3/4/16 19:42	
4-Bromofluorobenzene		97.0	70-130						3/4/16 19:42	

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 16B1133

Date Received: 2/29/2016

Field Sample #: RW-2

Sampled: 2/26/2016 07:20

Sample ID: 16B1133-02

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
1,1-Dichloroethane	0.62	2.0	0.16	µg/L	1	J	EPA 624	3/4/16	3/4/16 20:09	EEH
1,1-Dichloroethylene	0.56	2.0	0.21	µg/L	1	J	EPA 624	3/4/16	3/4/16 20:09	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
1,1,1-Trichloroethane	29	2.0	0.094	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	3/4/16	3/4/16 20:09	EEH

Surrogates	% Recovery	Recovery Limits	Flag/Qual
1,2-Dichloroethane-d4	104	70-130	3/4/16 20:09
Toluene-d8	99.4	70-130	3/4/16 20:09
4-Bromofluorobenzene	93.5	70-130	3/4/16 20:09

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 16B1133

Date Received: 2/29/2016

Field Sample #: EFF 46 HZ

Sampled: 2/26/2016 07:30

Sample ID: 16B1133-03

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	3/4/16	3/4/16 19:15	EEH
Surrogates		% Recovery	Recovery Limits							
1,2-Dichloroethane-d4		102	70-130						3/4/16 19:15	
Toluene-d8		99.0	70-130						3/4/16 19:15	
4-Bromofluorobenzene		96.6	70-130						3/4/16 19:15	

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: S. Otselic, NY

Sample Description:

Work Order: 16B1133

Date Received: 2/29/2016

Field Sample #: Trip Blank

Sampled: 2/26/2016 00:00

Sample ID: 16B1133-04

Sample Matrix: Trip Blank Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	3/4/16	3/4/16 18:48	EEH
Surrogates		% Recovery	Recovery Limits			Flag/Qual				
1,2-Dichloroethane-d4		104	70-130						3/4/16 18:48	
Toluene-d8		99.0	70-130						3/4/16 18:48	
4-Bromofluorobenzene		96.1	70-130						3/4/16 18:48	

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Sample Extraction Data

Prep Method: SW-846 5030B-EPA 624

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
16B1133-01 [RW-1]	B143521	5	5.00	03/04/16
16B1133-02 [RW-2]	B143521	5	5.00	03/04/16
16B1133-03 [EFF 46 HZ]	B143521	5	5.00	03/04/16
16B1133-04 [Trip Blank]	B143521	5	5.00	03/04/16

QUALITY CONTROL

Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

Batch B143521 - SW-846 5030B

Blank (B143521-BLK1)

Prepared: 03/03/16 Analyzed: 03/04/16

Benzene	ND	1.0	µg/L							
Bromodichloromethane	ND	2.0	µg/L							
Bromoform	ND	2.0	µg/L							
Bromomethane	ND	2.0	µg/L							
Carbon Tetrachloride	ND	2.0	µg/L							
Chlorobenzene	ND	2.0	µg/L							
Chlorodibromomethane	ND	2.0	µg/L							
Chloroethane	ND	2.0	µg/L							
2-Chloroethyl Vinyl Ether	ND	10	µg/L							
Chloroform	ND	2.0	µg/L							
Chloromethane	ND	2.0	µg/L							
1,2-Dichlorobenzene	ND	2.0	µg/L							
1,3-Dichlorobenzene	ND	2.0	µg/L							
1,4-Dichlorobenzene	ND	2.0	µg/L							
1,2-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethylene	ND	2.0	µg/L							
trans-1,2-Dichloroethylene	ND	2.0	µg/L							
1,2-Dichloropropane	ND	2.0	µg/L							
cis-1,3-Dichloropropene	ND	2.0	µg/L							
trans-1,3-Dichloropropene	ND	2.0	µg/L							
Ethylbenzene	ND	2.0	µg/L							
Methyl tert-Butyl Ether (MTBE)	ND	2.0	µg/L							
Methylene Chloride	ND	5.0	µg/L							
1,1,2,2-Tetrachloroethane	ND	2.0	µg/L							
Tetrachloroethylene	ND	2.0	µg/L							
Toluene	ND	1.0	µg/L							
1,1,1-Trichloroethane	ND	2.0	µg/L							
1,1,2-Trichloroethane	ND	2.0	µg/L							
Trichloroethylene	ND	2.0	µg/L							
Trichlorofluoromethane (Freon 11)	ND	2.0	µg/L							
Vinyl Chloride	ND	2.0	µg/L							
m+p Xylene	ND	2.0	µg/L							
o-Xylene	ND	2.0	µg/L							
Surrogate: 1,2-Dichloroethane-d4	25.2		µg/L	25.0		101	70-130			
Surrogate: Toluene-d8	24.8		µg/L	25.0		99.0	70-130			
Surrogate: 4-Bromofluorobenzene	23.8		µg/L	25.0		95.2	70-130			

LCS (B143521-BS1)

Prepared: 03/03/16 Analyzed: 03/04/16

Benzene	9.38	1.0	µg/L	10.0		93.8	37-151			
Bromodichloromethane	9.23	2.0	µg/L	10.0		92.3	35-155			
Bromoform	10.1	2.0	µg/L	10.0		101	45-169			
Bromomethane	8.15	2.0	µg/L	10.0		81.5	20-242			
Carbon Tetrachloride	9.34	2.0	µg/L	10.0		93.4	70-140			
Chlorobenzene	8.97	2.0	µg/L	10.0		89.7	37-160			
Chlorodibromomethane	8.87	2.0	µg/L	10.0		88.7	53-149			
Chloroethane	9.51	2.0	µg/L	10.0		95.1	70-130			
2-Chloroethyl Vinyl Ether	95.0	10	µg/L	100		95.0	10-305			
Chloroform	9.16	2.0	µg/L	10.0		91.6	51-138			
Chloromethane	8.44	2.0	µg/L	10.0		84.4	20-273			
1,2-Dichlorobenzene	9.18	2.0	µg/L	10.0		91.8	18-190			
1,3-Dichlorobenzene	8.78	2.0	µg/L	10.0		87.8	59-156			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL

Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch B143521 - SW-846 5030B										
LCS (B143521-BS1)										
Prepared: 03/03/16 Analyzed: 03/04/16										
1,4-Dichlorobenzene	8.81	2.0	µg/L	10.0		88.1	18-190			
1,2-Dichloroethane	9.23	2.0	µg/L	10.0		92.3	49-155			
1,1-Dichloroethane	9.40	2.0	µg/L	10.0		94.0	59-155			
1,1-Dichloroethylene	9.08	2.0	µg/L	10.0		90.8	20-234			
trans-1,2-Dichloroethylene	9.47	2.0	µg/L	10.0		94.7	54-156			
1,2-Dichloropropane	9.20	2.0	µg/L	10.0		92.0	20-210			
cis-1,3-Dichloropropene	8.18	2.0	µg/L	10.0		81.8	20-227			
trans-1,3-Dichloropropene	8.64	2.0	µg/L	10.0		86.4	17-183			
Ethylbenzene	8.94	2.0	µg/L	10.0		89.4	37-162			
Methyl tert-Butyl Ether (MTBE)	9.32	2.0	µg/L	10.0		93.2	70-130			
Methylene Chloride	9.64	5.0	µg/L	10.0		96.4	50-221			
1,1,2,2-Tetrachloroethane	9.64	2.0	µg/L	10.0		96.4	46-157			
Tetrachloroethylene	9.01	2.0	µg/L	10.0		90.1	64-148			
Toluene	8.59	1.0	µg/L	10.0		85.9	47-150			
1,1,1-Trichloroethane	9.34	2.0	µg/L	10.0		93.4	52-162			
1,1,2-Trichloroethane	9.37	2.0	µg/L	10.0		93.7	52-150			
Trichloroethylene	9.40	2.0	µg/L	10.0		94.0	71-157			
Trichlorofluoromethane (Freon 11)	9.05	2.0	µg/L	10.0		90.5	17-181			
Vinyl Chloride	9.49	2.0	µg/L	10.0		94.9	20-251			
m+p Xylene	17.9	2.0	µg/L	20.0		89.6	70-130			
o-Xylene	8.96	2.0	µg/L	10.0		89.6	70-130			
Surrogate: 1,2-Dichloroethane-d4	25.1		µg/L	25.0		100	70-130			
Surrogate: Toluene-d8	24.6		µg/L	25.0		98.3	70-130			
Surrogate: 4-Bromofluorobenzene	23.8		µg/L	25.0		95.4	70-130			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
ND	Not Detected
RL	Reporting Limit
DL	Method Detection Limit
MCL	Maximum Contaminant Level
	Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
	No results have been blank subtracted unless specified in the case narrative section.
J	Detected but below the Reporting Limit (lowest calibration standard); therefore, result is an estimated concentration (CLP J-Flag).

CERTIFICATIONS

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 624 in Water</i>	
Benzene	CT,MA,NH,NY,RI,NC,ME,VA
Bromodichloromethane	CT,MA,NH,NY,RI,NC,ME,VA
Bromoform	CT,MA,NH,NY,RI,NC,ME,VA
Bromomethane	CT,MA,NH,NY,RI,NC,ME,VA
Carbon Tetrachloride	CT,MA,NH,NY,RI,NC,ME,VA
Chlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
Chlorodibromomethane	CT,MA,NH,NY,RI,NC,ME,VA
Chloroethane	CT,MA,NH,NY,RI,NC,ME,VA
2-Chloroethyl Vinyl Ether	CT,MA,NH,NY,RI,NC,ME,VA
Chloroform	CT,MA,NH,NY,RI,NC,ME,VA
Chloromethane	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,3-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,4-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
trans-1,2-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichloropropane	CT,MA,NH,NY,RI,NC,ME,VA
cis-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA
trans-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA
Ethylbenzene	CT,MA,NH,NY,RI,NC,ME,VA
Methyl tert-Butyl Ether (MTBE)	NC
Methylene Chloride	CT,MA,NH,NY,RI,NC,ME,VA
1,1,2,2-Tetrachloroethane	CT,MA,NH,NY,RI,NC,ME,VA
Tetrachloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
Toluene	CT,MA,NH,NY,RI,NC,ME,VA
1,1,1-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1,2-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
Trichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
Trichlorofluoromethane (Freon 11)	CT,MA,NH,NY,RI,NC,ME,VA
Vinyl Chloride	CT,MA,NH,NY,RI,NC,ME,VA
m+p Xylene	CT,MA,NH,NY,RI,NC,VA
o-Xylene	CT,MA,NH,NY,RI,NC,VA

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

The CON-TEST Environmental Laboratory operates under the following certifications and accreditations:

Code	Description	Number	Expires
AIHA	AIHA-LAP, LLC	100033	02/1/2018
MA	Massachusetts DEP	M-MA100	06/30/2016
CT	Connecticut Department of Public Health	PH-0567	09/30/2017
NY	New York State Department of Health	10899 NELAP	04/1/2016
NH-S	New Hampshire Environmental Lab	2516 NELAP	02/5/2017
RI	Rhode Island Department of Health	LAO00112	12/30/2016
NC	North Carolina Div. of Water Quality	652	12/31/2016
NJ	New Jersey DEP	MA007 NELAP	06/30/2016
FL	Florida Department of Health	E871027 NELAP	06/30/2016
VT	Vermont Department of Health Lead Laboratory	LL015036	07/30/2016
WA	State of Washington Department of Ecology	C2065	02/23/2016
ME	State of Maine	2011028	06/9/2017
VA	Commonwealth of Virginia	460217	12/14/2016
NH-P	New Hampshire Environmental Lab	2557 NELAP	09/6/2016

CHAIN OF CUSTODY RECORD

NEW YORK STATE

Phone: 413-525-2332
 Fax: 413-525-6405
 Email: info@contestlabs.com
 www.contestlabs.com



Company Name: Arcadis
 Address: 855 Route 146 STE 210
Clifton Park NY 12065
 Attention: S. Wyckoff
 Project Location: S. Otschke, NY
 Sampled By: L. Lohman

39 Spruce Street
 East longmeadow, MA 01028

Page 1 of 1

Telephone: 518-250-7300
 Project # 00266406.0000
 Client PO#

DATA DELIVERY (check all that apply)
 FAX EMAIL WEBSITE
 Email:
 Format: PDF EXCEL GIS OTHER
 "Enhanced Data Package"

Con-Test Lab ID <small>(laboratory use only)</small>	Client Sample ID / Description	Collection		Composite	Grab	*Matrix Code	Conc. Code
		Beginning Date/Time	Ending Date/Time				
<u>01</u>	<u>RW-1</u>	<u>2/26/16</u>	<u>0715</u>		<u>X</u>	<u>GW</u>	<u>M</u>
<u>02</u>	<u>RW-2</u>		<u>0720</u>		<u>X</u>		<u>M</u>
<u>03</u>	<u>EFF 46 HZ</u>		<u>0730</u>		<u>X</u>		<u>L</u>
<u>04</u>	<u>Trip Blank</u>				<u>X</u>		<u>-</u>

ANALYSIS REQUESTED

# of Containers	
** Preservation	
*** Container Code	
Dissolved Metals	
<input type="radio"/> Field Filtered	
<input type="radio"/> Lab to Filter	
*** Cont. Code:	
A=amber glass	
G=glass	
P=plastic	
ST=sterile	
V= vial	
S= summa can	
T= tedlar bag	
O= Other	
** Preservation	
I = Iced	
H = HCL	
M = Methanol	
N = Nitric Acid	
S = Sulfuric Acid	
B = Sodium bisulfate	
X = Na hydroxide	
T = Na thiosulfate	
O = Other	
* Matrix Code:	
GW= groundwater	
WW= wastewater	
DW= drinking water	
A = air	
S = soil/solid	
SL = sludge	
O = other	

Please use the following codes to let Con-Test know if a specific sample may be high in concentration in Matrix/Conc. Code Box:

H - High; M - Medium; L - Low; C - Clean; U - Unknown

Turnaround

5-Day
 7 Day
 10-Day or RUSH †

24 hr 48 hr
 72 hr 4 day

† Require lab approval

Program Information/Regulatory

NY TOGS NY Restricted Use
 AWQ STDS NY Unrestricted Use
 NYC Sewer Discharge
 Part 360 GW (Landfill)

Deliverables

ASP-A Equis (1 file)
 ASP-B Equis (4 file)

Relinquished by: (signature)	Date/Time: <u>0740</u>	Relinquished by:	Date/Time: <u>2/26/16</u>
Received by: (signature)	Date/Time: <u>10:11</u>	Received by:	Date/Time: <u>2/29/16</u>
Relinquished by: (signature)	Date/Time:	Relinquished by:	Date/Time:
Received by: (signature)	Date/Time:	Received by:	Date/Time:

Comments:

URNAROUND TIME (business days) STARTS AT 9:00 A.M. THE DAY AFTER SAMPLE RECEIPT UNLESS THERE ARE QUESTIONS ON YOUR CHAIN. IF THIS FORM IS NOT FILLED OUT COMPLETELY OR IS INCORRECT, TURNAROUND TIME WILL NOT START UNTIL ALL QUESTIONS ARE ANSWERED. PLEASE BE CAREFUL TO NOT CONTAMINATE THIS DOCUMENT

39 Spruce St.
 East Longmeadow, MA. 01028
 P: 413-525-2332
 F: 413-525-6405
 www.contestlabs.com



Sample Receipt Checklist

CLIENT NAME: Arcadis RECEIVED BY: PB DATE: 2/29/2016

- 1) Was the chain(s) of custody relinquished and signed? Yes x No No COC Incl.
 2) Does the chain agree with the samples? Yes x No
 If not, explain:
 3) Are all the samples in good condition? Yes x No
 If not, explain:

4) How were the samples received:
 On Ice x Direct from Sampling Ambient In Cooler(s) x
 Were the samples received in Temperature Compliance of (2-6°C)? Yes x No N/A
 Temperature °C by Temp blank Temperature °C by Temp gun 4.2

- 5) Are there Dissolved samples for the lab to filter? Yes No x
 Who was notified Date Time
 6) Are there any RUSH or SHORT HOLDING TIME samples? Yes No x
 Who was notified Date Time

7) Location where samples are stored: Login
Permission to subcontract samples? Yes No
 (Walk-in clients only) if not already approved
 Client Signature:

- 8) Do all samples have the proper Acid pH: Yes No N/A x
 9) Do all samples have the proper Base pH: Yes No N/A x
 10) Was the PC notified of any discrepancies with the CoC vs the samples: Yes N/A x

Containers received at Con-Test

	# of containers			# of containers
1 Liter Amber			16 oz amber	
500 mL Amber			8 oz amber/clear jar	
250 mL Amber (8oz amber)			4 oz amber/clear jar	
1 Liter Plastic			2 oz amber/clear jar	
500 mL Plastic			Plastic Bag / Ziploc	
250 mL plastic			SOC Kit	
40 mL Vial - type listed below	11		Perchlorate Kit	
Colisure / bacteria bottle			Flashpoint bottle	
Dissolved Oxygen bottle			Other glass jar	
Encore			Other	

40 mL vials: # HCl 11 # Methanol Time and Date Frozen:
 Doc# 277 # Bisulfate # DI Water
 Rev. 4 August 2013 # Thiosulfate Unpreserved

Login Sample Receipt Checklist
(Rejection Criteria Listing - Using Sample Acceptance Policy)
Any False statement will be brought to the attention of Client

<u>Question</u>	<u>Answer (True/False)</u>		<u>Comment</u>
	T/F/NA		
1) The cooler's custody seal, if present, is intact.	NA		
2) The cooler or samples do not appear to have been compromised or tampered with.	T		
3) Samples were received on ice.	T		
4) Cooler Temperature is acceptable.	T		
5) Cooler Temperature is recorded.	T		
6) COC is filled out in ink and legible.	T		
7) COC is filled out with all pertinent information.	T		
8) Field Sampler's name present on COC.	T		
9) There are no discrepancies between the sample IDs on the container and the COC.	T		
10) Samples are received within Holding Time.	T		
11) Sample containers have legible labels.	T		
12) Containers are not broken or leaking.	T		
13) Air Cassettes are not broken/open.	NA		
14) Sample collection date/times are provided.	T		
15) Appropriate sample containers are used.	T		
16) Proper collection media used.	T		
17) No headspace sample bottles are completely filled.	T		
18) There is sufficient volume for all requested analyses, including any requested MS/MSDs.	T		
19) Trip blanks provided if applicable.	NA		
20) VOA sample vials do not have head space or bubble is <6mm (1/4") in diameter.	T		
21) Samples do not require splitting or compositing.	T		

Doc #277 Rev. 4 August 2013 **Who notified of False statements?**
Log-In Technician Initials: PB

Date/Time:
Date/Time:2/29/16

April 1, 2016

Jeremy Wyckoff
Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065

Project Location: South Otselic, NY
Client Job Number:
Project Number: 00266406.0000
Laboratory Work Order Number: 16C0904

Enclosed are results of analyses for samples received by the laboratory on March 21, 2016. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "Aaron L. Benoit", is written over a horizontal line.

Aaron L. Benoit
Project Manager

Table of Contents

Sample Summary	3
Case Narrative	4
Sample Results	5
16C0904-01	5
16C0904-02	6
16C0904-03	7
16C0904-04	8
Sample Preparation Information	9
QC Data	10
Volatile Organic Compounds by GC/MS	10
B145341	10
Flag/Qualifier Summary	12
Certifications	13
Chain of Custody/Sample Receipt	15

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Arcadis US, Inc. - Clifton Park-NY
855 Route 146, Suite 210
Clifton Park, NY 12065
ATTN: Jeremy Wyckoff

REPORT DATE: 4/1/2016

PURCHASE ORDER NUMBER:

PROJECT NUMBER: 00266406.0000

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 16C0904

The results of analyses performed on the following samples submitted to the CON-TEST Analytical Laboratory are found in this report.

PROJECT LOCATION: South Otselic, NY

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
RW-1	16C0904-01	Ground Water		EPA 624	
RW-2	16C0904-02	Ground Water		EPA 624	
EFF 46 HZ	16C0904-03	Ground Water		EPA 624	
Trip Blank	16C0904-04	Trip Blank Water		EPA 624	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Con-Test Analytical Laboratory for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.

A handwritten signature in black ink, appearing to read "Lisa A. Worthington", is written over a light gray rectangular background.

Lisa A. Worthington
Project Manager

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: South Otselic, NY

Sample Description:

Work Order: 16C0904

Date Received: 3/21/2016

Field Sample #: RW-1

Sampled: 3/18/2016 07:00

Sample ID: 16C0904-01

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
1,1-Dichloroethane	1.4	2.0	0.16	µg/L	1	J	EPA 624	3/29/16	3/30/16 9:22	MFF
1,1-Dichloroethylene	0.86	2.0	0.21	µg/L	1	J	EPA 624	3/29/16	3/30/16 9:22	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
1,1,1-Trichloroethane	36	2.0	0.094	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	3/29/16	3/30/16 9:22	MFF
Surrogates		% Recovery	Recovery Limits			Flag/Qual				
1,2-Dichloroethane-d4		96.1	70-130						3/30/16 9:22	
Toluene-d8		94.7	70-130						3/30/16 9:22	
4-Bromofluorobenzene		90.4	70-130						3/30/16 9:22	

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: South Otselic, NY

Sample Description:

Work Order: 16C0904

Date Received: 3/21/2016

Field Sample #: RW-2

Sampled: 3/18/2016 07:10

Sample ID: 16C0904-02

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
1,1-Dichloroethane	0.62	2.0	0.16	µg/L	1	J	EPA 624	3/29/16	3/30/16 9:48	MFF
1,1-Dichloroethylene	0.66	2.0	0.21	µg/L	1	J	EPA 624	3/29/16	3/30/16 9:48	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
1,1,1-Trichloroethane	29	2.0	0.094	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	3/29/16	3/30/16 9:48	MFF
Surrogates		% Recovery	Recovery Limits			Flag/Qual				
1,2-Dichloroethane-d4		94.1	70-130						3/30/16 9:48	
Toluene-d8		94.4	70-130						3/30/16 9:48	
4-Bromofluorobenzene		90.2	70-130						3/30/16 9:48	

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: South Otselic, NY

Sample Description:

Work Order: 16C0904

Date Received: 3/21/2016

Field Sample #: EFF 46 HZ

Sampled: 3/18/2016 07:20

Sample ID: 16C0904-03

Sample Matrix: Ground Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
Toluene	ND	1.0	0.17	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	3/29/16	3/30/16 8:56	MFF
Surrogates		% Recovery	Recovery Limits			Flag/Qual				
1,2-Dichloroethane-d4		92.3	70-130						3/30/16 8:56	
Toluene-d8		95.6	70-130						3/30/16 8:56	
4-Bromofluorobenzene		91.8	70-130						3/30/16 8:56	

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: South Otselic, NY

Sample Description:

Work Order: 16C0904

Date Received: 3/21/2016

Field Sample #: Trip Blank

Sampled: 3/18/2016 00:00

Sample ID: 16C0904-04

Sample Matrix: Trip Blank Water

Volatile Organic Compounds by GC/MS

Analyte	Results	RL	DL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Benzene	ND	1.0	0.12	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
Bromodichloromethane	ND	2.0	0.088	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
Bromoform	ND	2.0	0.21	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
Bromomethane	ND	2.0	0.94	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
Carbon Tetrachloride	ND	2.0	0.12	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
Chlorobenzene	ND	2.0	0.16	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
Chlorodibromomethane	ND	2.0	0.10	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
Chloroethane	ND	2.0	0.28	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
2-Chloroethyl Vinyl Ether	ND	10	2.2	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
Chloroform	ND	2.0	0.22	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
Chloromethane	ND	2.0	0.32	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
1,2-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
1,3-Dichlorobenzene	ND	2.0	0.17	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
1,4-Dichlorobenzene	ND	2.0	0.15	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
1,2-Dichloroethane	ND	2.0	0.19	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
1,1-Dichloroethane	ND	2.0	0.16	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
1,1-Dichloroethylene	ND	2.0	0.21	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
trans-1,2-Dichloroethylene	ND	2.0	0.15	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
1,2-Dichloropropane	ND	2.0	0.13	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
cis-1,3-Dichloropropene	ND	2.0	0.12	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
trans-1,3-Dichloropropene	ND	2.0	0.11	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
Ethylbenzene	ND	2.0	0.13	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
Methyl tert-Butyl Ether (MTBE)	ND	2.0	0.090	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
Methylene Chloride	ND	5.0	3.2	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
1,1,2,2-Tetrachloroethane	ND	2.0	0.16	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
Tetrachloroethylene	ND	2.0	0.17	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
Toluene	0.32	1.0	0.17	µg/L	1	J	EPA 624	3/29/16	3/30/16 13:43	MFF
1,1,1-Trichloroethane	ND	2.0	0.094	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
1,1,2-Trichloroethane	ND	2.0	0.12	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
Trichloroethylene	ND	2.0	0.20	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
Trichlorofluoromethane (Freon 11)	ND	2.0	0.15	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
Vinyl Chloride	ND	2.0	0.13	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
m+p Xylene	ND	2.0	0.25	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF
o-Xylene	ND	2.0	0.13	µg/L	1		EPA 624	3/29/16	3/30/16 13:43	MFF

Surrogates	% Recovery	Recovery Limits	Flag/Qual
1,2-Dichloroethane-d4	95.2	70-130	3/30/16 13:43
Toluene-d8	95.2	70-130	3/30/16 13:43
4-Bromofluorobenzene	89.6	70-130	3/30/16 13:43

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Sample Extraction Data

Prep Method: SW-846 5030B-EPA 624

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
16C0904-01 [RW-1]	B145341	5	5.00	03/29/16
16C0904-02 [RW-2]	B145341	5	5.00	03/29/16
16C0904-03 [EFF 46 HZ]	B145341	5	5.00	03/29/16
16C0904-04 [Trip Blank]	B145341	5	5.00	03/29/16

QUALITY CONTROL

Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

Batch B145341 - SW-846 5030B

Blank (B145341-BLK1)

Prepared: 03/29/16 Analyzed: 03/30/16

Benzene	ND	1.0	µg/L							
Bromodichloromethane	ND	2.0	µg/L							
Bromoform	ND	2.0	µg/L							
Bromomethane	ND	2.0	µg/L							
Carbon Tetrachloride	ND	2.0	µg/L							
Chlorobenzene	ND	2.0	µg/L							
Chlorodibromomethane	ND	2.0	µg/L							
Chloroethane	ND	2.0	µg/L							
2-Chloroethyl Vinyl Ether	ND	10	µg/L							
Chloroform	ND	2.0	µg/L							
Chloromethane	ND	2.0	µg/L							
1,2-Dichlorobenzene	ND	2.0	µg/L							
1,3-Dichlorobenzene	ND	2.0	µg/L							
1,4-Dichlorobenzene	ND	2.0	µg/L							
1,2-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethane	ND	2.0	µg/L							
1,1-Dichloroethylene	ND	2.0	µg/L							
trans-1,2-Dichloroethylene	ND	2.0	µg/L							
1,2-Dichloropropane	ND	2.0	µg/L							
cis-1,3-Dichloropropene	ND	2.0	µg/L							
trans-1,3-Dichloropropene	ND	2.0	µg/L							
Ethylbenzene	ND	2.0	µg/L							
Methyl tert-Butyl Ether (MTBE)	ND	2.0	µg/L							
Methylene Chloride	ND	5.0	µg/L							
1,1,2,2-Tetrachloroethane	ND	2.0	µg/L							
Tetrachloroethylene	ND	2.0	µg/L							
Toluene	ND	1.0	µg/L							
1,1,1-Trichloroethane	ND	2.0	µg/L							
1,1,2-Trichloroethane	ND	2.0	µg/L							
Trichloroethylene	ND	2.0	µg/L							
Trichlorofluoromethane (Freon 11)	ND	2.0	µg/L							
Vinyl Chloride	ND	2.0	µg/L							
m+p Xylene	ND	2.0	µg/L							
o-Xylene	ND	2.0	µg/L							
Surrogate: 1,2-Dichloroethane-d4	24.6		µg/L	25.0		98.5	70-130			
Surrogate: Toluene-d8	23.8		µg/L	25.0		95.2	70-130			
Surrogate: 4-Bromofluorobenzene	21.8		µg/L	25.0		87.0	70-130			

LCS (B145341-BS1)

Prepared: 03/29/16 Analyzed: 03/30/16

Benzene	10.3	1.0	µg/L	10.0		103	37-151			
Bromodichloromethane	12.2	2.0	µg/L	10.0		122	35-155			
Bromoform	15.5	2.0	µg/L	10.0		155	45-169			
Bromomethane	9.32	2.0	µg/L	10.0		93.2	20-242			
Carbon Tetrachloride	11.8	2.0	µg/L	10.0		118	70-140			
Chlorobenzene	9.76	2.0	µg/L	10.0		97.6	37-160			
Chlorodibromomethane	14.5	2.0	µg/L	10.0		145	53-149			
Chloroethane	10.3	2.0	µg/L	10.0		103	70-130			
2-Chloroethyl Vinyl Ether	65.9	10	µg/L	100		65.9	10-305			
Chloroform	9.97	2.0	µg/L	10.0		99.7	51-138			
Chloromethane	7.69	2.0	µg/L	10.0		76.9	20-273			
1,2-Dichlorobenzene	9.72	2.0	µg/L	10.0		97.2	18-190			
1,3-Dichlorobenzene	9.64	2.0	µg/L	10.0		96.4	59-156			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL

Volatile Organic Compounds by GC/MS - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch B145341 - SW-846 5030B										
LCS (B145341-BS1)										
					Prepared: 03/29/16 Analyzed: 03/30/16					
1,4-Dichlorobenzene	9.56	2.0	µg/L	10.0		95.6	18-190			
1,2-Dichloroethane	9.35	2.0	µg/L	10.0		93.5	49-155			
1,1-Dichloroethane	9.02	2.0	µg/L	10.0		90.2	59-155			
1,1-Dichloroethylene	8.54	2.0	µg/L	10.0		85.4	20-234			
trans-1,2-Dichloroethylene	8.70	2.0	µg/L	10.0		87.0	54-156			
1,2-Dichloropropane	8.88	2.0	µg/L	10.0		88.8	20-210			
cis-1,3-Dichloropropene	9.43	2.0	µg/L	10.0		94.3	20-227			
trans-1,3-Dichloropropene	9.47	2.0	µg/L	10.0		94.7	17-183			
Ethylbenzene	10.0	2.0	µg/L	10.0		100	37-162			
Methyl tert-Butyl Ether (MTBE)	8.45	2.0	µg/L	10.0		84.5	70-130			
Methylene Chloride	8.65	5.0	µg/L	10.0		86.5	50-221			
1,1,2,2-Tetrachloroethane	10.4	2.0	µg/L	10.0		104	46-157			
Tetrachloroethylene	9.99	2.0	µg/L	10.0		99.9	64-148			
Toluene	10.2	1.0	µg/L	10.0		102	47-150			
1,1,1-Trichloroethane	9.85	2.0	µg/L	10.0		98.5	52-162			
1,1,2-Trichloroethane	9.23	2.0	µg/L	10.0		92.3	52-150			
Trichloroethylene	9.82	2.0	µg/L	10.0		98.2	71-157			
Trichlorofluoromethane (Freon 11)	11.3	2.0	µg/L	10.0		113	17-181			
Vinyl Chloride	10.3	2.0	µg/L	10.0		103	20-251			
m+p Xylene	19.8	2.0	µg/L	20.0		99.2	70-130			
o-Xylene	9.76	2.0	µg/L	10.0		97.6	70-130			
Surrogate: 1,2-Dichloroethane-d4	23.0		µg/L	25.0		92.0	70-130			
Surrogate: Toluene-d8	25.2		µg/L	25.0		101	70-130			
Surrogate: 4-Bromofluorobenzene	23.7		µg/L	25.0		94.9	70-130			

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
ND	Not Detected
RL	Reporting Limit
DL	Method Detection Limit
MCL	Maximum Contaminant Level
	Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
	No results have been blank subtracted unless specified in the case narrative section.
J	Detected but below the Reporting Limit (lowest calibration standard); therefore, result is an estimated concentration (CLP J-Flag).

CERTIFICATIONS

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 624 in Water</i>	
Benzene	CT,MA,NH,NY,RI,NC,ME,VA
Bromodichloromethane	CT,MA,NH,NY,RI,NC,ME,VA
Bromoform	CT,MA,NH,NY,RI,NC,ME,VA
Bromomethane	CT,MA,NH,NY,RI,NC,ME,VA
Carbon Tetrachloride	CT,MA,NH,NY,RI,NC,ME,VA
Chlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
Chlorodibromomethane	CT,MA,NH,NY,RI,NC,ME,VA
Chloroethane	CT,MA,NH,NY,RI,NC,ME,VA
2-Chloroethyl Vinyl Ether	CT,MA,NH,NY,RI,NC,ME,VA
Chloroform	CT,MA,NH,NY,RI,NC,ME,VA
Chloromethane	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,3-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,4-Dichlorobenzene	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1-Dichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
trans-1,2-Dichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
1,2-Dichloropropane	CT,MA,NH,NY,RI,NC,ME,VA
cis-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA
trans-1,3-Dichloropropene	CT,MA,NH,NY,RI,NC,ME,VA
Ethylbenzene	CT,MA,NH,NY,RI,NC,ME,VA
Methyl tert-Butyl Ether (MTBE)	NC
Methylene Chloride	CT,MA,NH,NY,RI,NC,ME,VA
1,1,2,2-Tetrachloroethane	CT,MA,NH,NY,RI,NC,ME,VA
Tetrachloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
Toluene	CT,MA,NH,NY,RI,NC,ME,VA
1,1,1-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
1,1,2-Trichloroethane	CT,MA,NH,NY,RI,NC,ME,VA
Trichloroethylene	CT,MA,NH,NY,RI,NC,ME,VA
Trichlorofluoromethane (Freon 11)	CT,MA,NH,NY,RI,NC,ME,VA
Vinyl Chloride	CT,MA,NH,NY,RI,NC,ME,VA
m+p Xylene	CT,MA,NH,NY,RI,NC,VA
o-Xylene	CT,MA,NH,NY,RI,NC,VA

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

The CON-TEST Environmental Laboratory operates under the following certifications and accreditations:

Code	Description	Number	Expires
AIHA	AIHA-LAP, LLC	100033	02/1/2018
MA	Massachusetts DEP	M-MA100	06/30/2016
CT	Connecticut Department of Public Health	PH-0567	09/30/2017
NY	New York State Department of Health	10899 NELAP	04/1/2016
NH-S	New Hampshire Environmental Lab	2516 NELAP	02/5/2017
RI	Rhode Island Department of Health	LAO00112	12/30/2016
NC	North Carolina Div. of Water Quality	652	12/31/2016
NJ	New Jersey DEP	MA007 NELAP	06/30/2016
FL	Florida Department of Health	E871027 NELAP	06/30/2016
VT	Vermont Department of Health Lead Laboratory	LL015036	07/30/2016
WA	State of Washington Department of Ecology	C2065	02/23/2016
ME	State of Maine	2011028	06/9/2017
VA	Commonwealth of Virginia	460217	12/14/2016
NH-P	New Hampshire Environmental Lab	2557 NELAP	09/6/2016

CHAIN OF CUSTODY RECORD

Phone: 413-525-2332
 Fax: 413-525-6405
 Email: info@contestlabs.com
 www.contestlabs.com



39 Spruce Street
 East Longmeadow, MA 01028

Page 1 of 1

Company Name: Arcadi's
 Address: 855 Route 146, STE 210
Clifton Park N.Y. 12065
 Attention: S. Wyczkoff
 Project Location: S. Otseatic, N.Y.
 Sampled By: L. Whalen

Telephone: 518-250-7360
 Project # 00266406.0000
 Client PO# _____

DATA DELIVERY (check all that apply)
 FAX EMAIL WEBSITE

Email: _____
 Format: PDF EXCEL GIS OTHER

Project Proposal Provided? (for billing purposes)

Con-Test Lab ID <small>(laboratory use only)</small>	Client Sample ID / Description	Collection		Ending Date/Time	Matrix Conc Code
		Beginning Date/Time	Grab		
<u>C01</u>	<u>RW-1</u>	<u>3/18/16</u>	<u>X</u>	<u>0700</u>	<u>GW M</u>
<u>C02</u>	<u>RW-2</u>	<u>↓</u>	<u>X</u>	<u>0710</u>	<u>M</u>
<u>C03</u>	<u>EFF 46 HZ</u>	<u>↓</u>	<u>X</u>	<u>0720</u>	<u>L</u>
<u>C04</u>	<u>Trip Blank</u>	<u>↓</u>	<u>X</u>	<u>-</u>	<u>-</u>

Comments:

Please use the following codes to let Con-Test know if a specific sample may be high in concentration in Matrix/Conc. Code Box:
 H - High; M - Medium; L - Low; C - Clean; U - Unknown

Relinquished by: (signature)	Date/Time	Relinquished by:	Date/Time	Turnaround [†]	Program Information/Regulatory
<u>L. Whalen</u>	<u>3/18/16</u>	<u>0940</u>		<input type="checkbox"/> 5-Day <input type="checkbox"/> 7 Day <input checked="" type="checkbox"/> 10-Day or RUSH [†]	<input checked="" type="radio"/> NY TOGS <input type="radio"/> NY Restricted Use <input type="radio"/> AWQ STDS <input type="radio"/> NY Unrestricted Use <input type="radio"/> NYC Sewer Discharge <input type="radio"/> Part 360 GW (Landfill)
<u>S. Wyczkoff</u>	<u>3/21/16</u>	<u>1341</u>		<input type="checkbox"/> 24 hr <input type="checkbox"/> 48 hr <input type="checkbox"/> 4 day	Deliverables <input type="radio"/> ASP-A <input type="radio"/> Equis (1 file) <input checked="" type="radio"/> ASP-B <input checked="" type="radio"/> Equis (4 file)
					<input type="radio"/> NY Part 375 <input type="radio"/> NY CP-51 <input type="radio"/> Other: <input type="radio"/> Other:

TURNAROUND TIME (business days) STARTS AT 9:00 A.M. THE DAY AFTER SAMPLE RECEIPT UNLESS THERE ARE QUESTIONS ON YOUR CHAIN. IF THIS FORM IS NOT FILLED OUT COMPLETELY OR IS INCORRECT, TURNAROUND TIME WILL NOT START UNTIL ALL QUESTIONS ARE ANSWERED. PLEASE BE CAREFUL TO NOT CONTAMINATE THIS DOCUMENT

39 Spruce St.
 East Longmeadow, MA. 01028
 P: 413-525-2332
 F: 413-525-6405
 www.contestlabs.com



Sample Receipt Checklist

CLIENT NAME: Arcadis RECEIVED BY: RLF DATE: 3/21/2016

1) Was the chain(s) of custody relinquished and signed? Yes X No No COC Incl.

2) Does the chain agree with the samples? Yes X No

If not, explain:

3) Are all the samples in good condition? Yes X No

If not, explain:

4) How were the samples received:

On Ice X Direct from Sampling Ambient In Cooler(s) X

Were the samples received in Temperature Compliance of (2-6°C)? Yes X No N/A

Temperature °C by Temp blank Temperature °C by Temp gun 3.8

5) Are there Dissolved samples for the lab to filter? Yes No X

Who was notified Date Time

6) Are there any RUSH or SHORT HOLDING TIME samples? Yes No X

Who was notified Date Time

7) Location where samples are stored:

Permission to subcontract samples? Yes No
 (Walk-in clients only) if not already approved
 Client Signature:

8) Do all samples have the proper Acid pH: Yes No N/A X

9) Do all samples have the proper Base pH: Yes No N/A X

10) Was the PC notified of any discrepancies with the CoC vs the samples: Yes N/A X

Containers received at Con-Test

	# of containers			# of containers
1 Liter Amber			16 oz amber	
500 mL Amber			8 oz amber/clear jar	
250 mL Amber (8oz amber)			4 oz amber/clear jar	
1 Liter Plastic			2 oz amber/clear jar	
500 mL Plastic			Plastic Bag / Ziploc	
250 mL plastic			SOC Kit	
40 mL Vial - type listed below	11		Perchlorate Kit	
Colisure / bacteria bottle			Flashpoint bottle	
Dissolved Oxygen bottle			Other glass jar	
Encore			Other	

40 mL vials: # HCl <u>11</u> # Methanol <u> </u>	Time and Date Frozen:
Doc# 277 # Bisulfate <u> </u> # DI Water <u> </u>	
Rev. 4 August 2013 # Thiosulfate <u> </u> Unpreserved <u> </u>	

Login Sample Receipt Checklist
(Rejection Criteria Listing - Using Sample Acceptance Policy)
Any False statement will be brought to the attention of Client

<u>Question</u>	<u>Answer (True/False)</u>		<u>Comment</u>
	T/F/NA		
1) The cooler's custody seal, if present, is intact.	T		
2) The cooler or samples do not appear to have been compromised or tampered with.	T		
3) Samples were received on ice.	T		
4) Cooler Temperature is acceptable.	T		
5) Cooler Temperature is recorded.	T		
6) COC is filled out in ink and legible.	T		
7) COC is filled out with all pertinent information.	T		
8) Field Sampler's name present on COC.	T		
9) There are no discrepancies between the sample IDs on the container and the COC.	T		
10) Samples are received within Holding Time.	T		
11) Sample containers have legible labels.	T		
12) Containers are not broken or leaking.	T		
13) Air Cassettes are not broken/open.	N/A		
14) Sample collection date/times are provided.	T		
15) Appropriate sample containers are used.	T		
16) Proper collection media used.	T		
17) No headspace sample bottles are completely filled.	T		
18) There is sufficient volume for all requested analyses, including any requested MS/MSDs.	T		
19) Trip blanks provided if applicable.	T		
20) VOA sample vials do not have head space or bubble is <6mm (1/4") in diameter.	T		
21) Samples do not require splitting or compositing.	T		

Doc #277 Rev. 4 August 2013 **Who notified of False statements?**
Log-In Technician Initials: RLF

Date/Time:
Date/Time: 3/21/16 13:41

APPENDIX D

Groundwater 1,1,1-TCA Concentrations – May 2015









SHALLOW WELLS


INTERMEDIATE WELLS

DEEP WELLS



LEGEND

1,1,1-Trichloroethane Concentrations (ug/L)



GLADDING CORDAGE SITE NUMBER 7-09-009
SOUTH OTSELIC, NEW YORK

GROUNDWATER 1,1,1-TRICHLOROETHANE CONCENTRATIONS

MAY 6, 2015



FIGURE

4-5

Arcadis CE, Inc.

855 Route 146

Suite 210

Clifton Park, New York 12065

Tel 518 250 7300

Fax 518 250 7301

www.arcadis.com

A decorative graphic consisting of three thin orange lines: one horizontal line extending across the width of the page, and two parallel diagonal lines extending from the bottom left towards the top right.