518.951.2300 fax

October 19, 2015

Ms. Sarah Saucier: Site Project Manager

NYSDEC 625 Broadway

Albany, New York 12233-7014

Phone: (518) 402-9662

E-mail: sarah.saucier@dec.ny.gov

Subject: NAPL Recovery – Status Report for September 2015

Site #: 7-09-011

NYSEG - Norwich Former MGP Site

Dear Ms. Saucier:

On behalf of New York State Electric and Gas Corporation (NYSEG), AECOM has prepared this monthly status report to describe events associated with non-aqueous phase liquid (NAPL) recovery at the Norwich Former Manufactured Gas Plant (Site) in Norwich, NY. This letter provides a summary of activities at the Site during the month of September 2015. Figure 1 shows the layout of the NAPL recovery system.

PRODUCT RECOVERY

During system operation throughout the month of September, the NAPL collection system recovered 1277 gallons of total fluids (NAPL and water) for a total volume of 94,517 gallons to date. The total fluids recovery rate was approximately 43 gallons per day (gpd). A summary of recovered fluids in the month of September is provided below and a cumulative NAPL recovery summary is provided in Figure 2.

Measurements of NAPL thickness were taken as part of Site visits on September 2, September 10, September 15, and September 23 (see Table 1). As proposed in the March 2012 Status Report, a weighted steel tape with Kolor Kut® was used to gauge the wells for NAPL. Thicknesses are measured while recovery pumps are operational and do not reflect the static NAPL thickness in each well. Thicknesses of NAPL in each currently active recovery well are shown in Figures 3 through 6 and thicknesses of non-recovery wells are shown on Figures 7 through 12.

During the September 10th Site visit it was noted that the pump in well RW-09-07 was malfunctioning. At this time, the pump in RW-09-07 was shut off due to a severed discharge line. This is believed to be the result of a blockage caused by a more viscous tar than typically encountered. Once the problem has been resolved pumping from RW-09-07 will resume. On September 23rd, the collected coal tar reached the allowable volume within the tank trailer. The system has been turned off and will renew operation upon replacement of the current tank trailer.



Table 1. NAPL Thickness in Recovery Well (feet)

Well	09-02-15	09-10-15	09-15-15	09-23-15	Ave ¹ 2010	Ave ¹ 2011	Ave ¹ 2012	Ave ¹ 2013	Ave ¹ 2014	Ave ¹ 2015
RW-09-01	0.0	1.4	0.0	0.0	3.6	1.8	2.1	1.9	1.7	1.1
RW-09-02	1.9	1.9	1.9	2.2	2.7	2.0	1.9	2.1	1.8	1.9
RW-09-03	1.4	4.3	0.7	1.3	7.1	3.5	4.3	3.5	3.3	2.7
RW-09-04	1.5	3.7	0.9	2.6	4.0	4.4	2.3	3.2	4.5	3.8
RW-09-05	1.4	1.1	5.4	4.9	3.5	0.6	1.2	1.4	1.4	2.3
RW-09-06	5.4	5.5	7.7	7.8	8.4	8.5	6.9	6.7	6.3	5.9
RW-09-07	0.6	3.5	1.3	2.8	4.6	8.0	4.4	3.4	4.3	4.1
RW-10-01	1.0	3.9	0.6	1.2	2.0	2.7	3.3	3.2	1.8	1.9
RW-10-02	5.8	6.4	2.3	7.0	2.1	3.4	11.1	6.8	6.3	5.9
RW-10-03	4.4	1.0	4.3	3.8	0.8	3.4	3.6	4.1	3.9	2.9

Ave is the average NAPL thickness measured during that period (running total for 2015)

Note wells are constructed with 2 foot sumps at the base exaggerating DNAPL thicknesses by up to 2 feet

Pumping wells presented in Bold

RECOMMENDATIONS

NAPL recovery and monitoring will be reestablished following replacement of the current tank trailer.

Should you have any questions or require additional information in the meantime, please do not hesitate to call me at (518) 951-2391 or Tracy Blazicek at (607) 762-8839.


Yours sincerely,

Scott McDonough Project Manager

cc: T. Blazicek, NYSEG Scott Underhill, AECOM



Figures



Filename: L:\WORK\106404\CADD\REF\INVESTIGATION\ACAD-NORWICH_RECOVERY_MEMO.DWG

