



AECOM
40 British American Boulevard
Latham, NY 12110

518.951.2200 tel
518.951.2300 fax

May 02, 2016

SENT VIA EMAIL

Ms. Sarah Saucier
NYSDEC
625 Broadway
Albany, New York 12233-7014
Phone: (518) 402-9662
E-mail: sarah.saucier@dec.ny.gov

Subject: **NAPL Recovery – Status Report for April 2016**
Site #: 7-09-011
NYSEG – Norwich Former MGP Site

Dear Ms. Saucier:

On behalf of New York State Electric and Gas Corporation (NYSEG), AECOM has prepared this monthly status report to describe events associated with non-aqueous phase liquid (NAPL) recovery at the Norwich Former Manufactured Gas Plant (Site) in Norwich, NY. This letter provides a summary of activities at the Site during the month of April 2016. Figure 1 shows the layout of the NAPL recovery system.

PRODUCT RECOVERY

During system operation throughout the month of April, the NAPL collection system recovered approximately 90 gallons of total fluids (NAPL and water) for a total volume of 97,116 gallons to date. April system operation, further discussed below, is estimated at approximately 10 days resulting in the total fluid recovery rate of approximately 9 gallons per day (gpd). A cumulative total fluid recovery summary is provided in Figure 2.

During the month of April, the site air compressor, responsible for part of the operation of the collection system, encountered operation impediments resulting in a power “trip” or automatic power shutoff. The power shutoff was encountered upon site arrival on 4/14 and 4/21 with repairs on 4/15 (start capacitor replacement) and 4/28 (30amp breaker replacement). The repairs are aimed at allowing continuous recovery system operation.

The system is currently operational in wells RW-09-03, RW-09-06, and RW-10-02. Each recovery well will continue to be monitored and pumping activities will be maintained through the month of May.

RECOMMENDATIONS

NAPL recovery and monitoring will continue through the month of May.



Should you have any questions or require additional information in the meantime, please do not hesitate to call me at (518) 951-2391 or Tracy Blazicek at (607) 762-8839.

Yours sincerely,

A handwritten signature in blue ink, appearing to read "Scott McDonough". The signature is fluid and cursive, with a long horizontal stroke at the end.

Scott McDonough
Project Manager

cc: T. Blazicek, NYSEG
Melissa Doroski, NYSDOH
Scott Underhill, AECOM

Figures

Plotted By: meisterk
Layout-Sheet Name: RECOVERY MEMO
Plot File Date Created: Jan/18/2012 3:01 PM




Figure 2
Total Fluids Recovery (2009 - April 2016)
NYSEG Norwich Former MGP Site

