

STAUFFER MANAGEMENT COMPANY LLC

Environmental Services & Engineering
DCC II
1800 Concord Pike PO Box 15437
Wilmington, DE 19850-5437

Telephone: (302) 886-4238
Facsimile: (302) 886-5933

July 19, 2005


Mr. David Chiusano
Remedial Bureau E, Section A
Division Environmental Remediation
New York State Department
of Environmental Conservation
625 Broadway 12th Floor
Albany, NY 12233-7017

Subject: Stauffer Management Company
Maestri Site #7-34-025

Dear Mr. Chiusano:


Enclosed please find the monitoring report and groundwater elevation tabulation for the above referenced site for June 2005.

Very truly yours,



T. K. Haldas
Project Manager

cc: Regional Water Engineer - NYSDEC Region 7
H. Hamel, NYSDOH
J. Burke, NYSDEC - Region 7
J. Abraham, SMC



MAESTRI GROUNDWATER ELEVATIONS- June, 2005

WELL NUMBER	MEASURING POINT	6/7/2005			6/14/2005			6/21/2005			6/28/2005		
		DEPTH TO	GROUND WATER	ELEVATION	DEPTH TO	GROUND WATER	ELEVATION	DEPTH TO	GROUND WATER	ELEVATION	DEPTH TO	GROUND WATER	ELEVATION
MW-9	407.51	13.10	394.41	13.30	394.21	13.50	394.01	14.00	393.51				
MW-10	413.92	9.10	404.82	9.20	404.72	9.30	404.62	11.60	402.32				
MW-12	418.36	9.80	408.56	9.90	408.46	10.10	408.26	11.10	407.26				
MW-14	405.18	15.60	389.58	16.00	389.18	16.20	388.98	16.70	388.48				
PZ-2	407.24	12.80	394.44	13.10	394.14	13.20	394.04	13.75	393.49				
PZ-3	409.60	14.80	394.80	13.80	395.80	14.00	395.60	14.40	395.20				
PZ-4	394.50	8.10	386.40	8.00	386.50	8.10	386.40	8.40	386.10				
PZ-5	393.34	6.30	387.04	7.10	386.24	7.20	386.14	7.30	386.04				
PZ-6	410.22	13.10	397.12	13.50	396.72	13.60	396.62	14.60	395.62				
PZ-7	409.17	13.80	395.37	14.05	395.12	14.10	395.07	14.80	394.37				
PZ-9	408.77	13.70	395.07	14.00	394.77	14.20	394.57	14.60	394.17				
PZ-10	407.07	12.60	394.47	12.80	394.27	12.90	394.17	13.40	393.67				
PZ-12	408.21	15.70	392.51	15.10	393.11	15.30	392.91	15.50	392.71				
PZ-13	407.17	14.70	392.47	14.80	392.37	14.90	392.27	15.20	391.97				
PZ-14	408.47	12.50	395.97	12.70	395.77	12.80	395.67	13.50	394.97				
PZ-15	406.77	16.90	389.87	17.20	389.57	17.40	389.37	17.70	389.07				
PZ-18	406.32	16.75	389.57	17.10	389.22	17.30	389.02	17.80	388.52				
PZ-19	406.90	16.70	390.20	16.80	390.10	17.10	389.80	17.20	389.70				
RW-2	406.46	16.10	390.36	17.20	389.26	17.30	389.16	15.70	390.76				
RW-3	407.02	20.80	386.22	20.70	386.32	21.10	385.92	22.00	385.02				
RW-5	409.67	22.10	387.57	16.90	392.77	20.80	388.87	22.90	386.77				
RW-6	393.29	15.20	378.09	15.30	377.99	17.30	375.99	15.00	378.29				
RW-7	405.97	22.10	383.87	21.10	384.87	21.30	384.67	21.70	384.27				
RW-8	406.87	21.60	385.27	19.80	387.07	16.50	390.37	23.10	383.77				

MAESTRI EFFLUENT MONITORING REPORT - June 2005

DATE	BENZENE ug/l	VINYL CHLORIDE ug/l	o-XYLENE ug/l	m-XYLENE ug/l	p-XYLENE ug/l	pH
6/7/2005	<1.0	<2.0	<1.0	<1.0	<1.0	7.7
LIMIT	1.0	5.0	5.0	5.0	5.0	6.5-8.5

MONTHLY DAILY AVERAGE FLOW (GPD) = 849

MONTHLY MAXIMUM DAILY FLOW (GPD) = 1,294