

**STAUFFER MANAGEMENT COMPANY LLC**

Environmental Services & Engineering  
DCC II  
1800 Concord Pike PO Box 15437  
Wilmington, DE 19850-5437

Telephone: (302) 886-4238  
Facsimile: (302) 886-5933

September 12, 2005


Mr. David Chiusano  
Remedial Bureau E, Section A  
Division Environmental Remediation  
New York State Department  
of Environmental Conservation  
625 Broadway 12<sup>th</sup> Floor  
Albany, NY 12233-7017

Subject: Stauffer Management Company  
Maestri Site #7-34-025

Dear Mr. Chiusano:


Enclosed please find the monitoring report and groundwater elevation tabulation for the above referenced site for August 2005.

Very truly yours,



T. K. Haldas  
Project Manager

cc: Regional Water Engineer - NYSDEC Region 7  
H. Hamel, NYSDOH  
J. Burke, NYSDEC - Region 7  
J. Abraham, SMC



**MAESTRI GROUNDWATER ELEVATIONS- August, 2005**

WELL NUMBER	MEASURING POINT	8/2/2005	GROUND WATER	8/9/2005	GROUND WATER	8/16/2005	GROUND WATER	8/23/2005	GROUND WATER	8/30/2005	GROUND WATER
		DEPTH TO WATER		DEPTH TO WATER		DEPTH TO WATER		DEPTH TO WATER		DEPTH TO WATER	
	ELEVATION		ELEVATION		ELEVATION		ELEVATION		ELEVATION		ELEVATION
MW-9	407.51	16.30	391.21	15.80	391.71	16.10	389.61	16.30	391.21	16.70	390.81
MW-10	413.92	13.80	400.12	14.50	399.42	15.00	398.92	15.40	398.52	15.90	398.02
MW-12	418.36	12.30	406.06	12.70	405.66	13.00	405.36	13.30	405.06	13.30	405.06
MW-14	405.18	17.30	387.88	17.60	387.58	17.90	405.18	18.10	387.08	18.20	386.98
PZ-2	407.24	15.70	391.54	15.10	392.14	15.50	391.74	15.70	391.54	16.10	391.14
PZ-3	409.60	16.10	393.50	16.70	392.90	17.10	392.50	17.20	392.40	17.70	391.90
PZ-4	394.50	8.90	385.60	9.10	385.40	9.20	385.30	9.30	385.20	9.50	385.00
PZ-5	393.34	7.70	385.64	7.90	385.44	8.10	385.24	8.20	385.14	8.30	385.04
PZ-6	410.22	16.20	394.02	16.70	393.52	17.10	393.12	17.20	393.02	17.90	392.32
PZ-7	409.17	16.30	392.87	16.80	392.37	17.10	392.07	17.30	391.87	17.70	391.47
PZ-9	408.77	16.10	392.67	15.60	393.17	15.90	392.87	16.10	392.67	17.60	391.17
PZ-10	407.07	14.90	392.17	15.30	391.77	15.60	391.47	15.80	391.27	16.30	390.77
PZ-12	408.21	16.30	391.91	16.60	391.61	16.80	391.41	17.00	391.21	17.10	391.11
PZ-13	407.17	16.20	390.97	16.50	390.67	18.70	388.47	16.90	390.27	17.05	390.12
PZ-14	408.47	14.50	393.97	14.80	393.67	15.00	393.47	15.20	393.27	15.30	393.17
PZ-15	406.77	18.60	388.17	19.00	387.77	19.10	387.67	19.30	387.47	19.50	387.27
PZ-18	406.32	18.50	387.82	18.70	387.62	19.00	387.32	19.20	387.12	19.30	387.02
PZ-19	406.90	18.10	388.80	18.30	388.60	18.40	388.50	18.50	388.40	18.75	388.15
RW-2	406.46	16.20	390.26	16.70	389.76	17.30	389.16	17.20	389.26	17.60	388.86
RW-3	407.02	21.20	385.82	21.00	386.02	21.25	385.77	21.30	385.72	21.15	385.87
RW-5	409.67	22.30	387.37	22.60	387.07	22.40	387.27	20.10	389.57	17.25	392.42
RW-6	393.29	15.90	377.39	15.00	378.29	15.20	378.09	15.10	378.19	15.80	377.49
RW-7	405.97	21.30	384.67	21.00	384.97	21.10	384.87	21.70	384.27	21.40	384.57
RW-8	406.87	18.90	387.97	18.00	388.87	21.60	385.27	21.40	385.47	21.70	385.17

# MAESTRI EFFLUENT MONITORING REPORT - August 2005

DATE	BENZENE ug/l	VINYL CHLORIDE ug/l	o-XYLENE ug/l	m-XYLENE ug/l	p-XYLENE ug/l	pH
8/2/2005	<1.0	<2.0	<1.0	<1.0	<1.0	7.4
<b>LIMIT</b>	1.0	5.0	5.0	5.0	5.0	6.5-8.5

MONTHLY DAILY AVERAGE FLOW (GPD) = 301

MONTHLY MAXIMUM DAILY FLOW (GPD) = 445