


STAUFFER MANAGEMENT COMPANY LLC



October 10, 2005

Mr. David Chiusano
Remedial Bureau E, Section A
Division Environmental Remediation
New York State Department
of Environmental Conservation
625 Broadway 12th Floor
Albany, NY 12233-7017

Subject: Stauffer Management Company
Maestri Site #7-34-025

Dear Mr. Chiusano:

Enclosed please find the monitoring report and groundwater elevation tabulation for the above referenced site for September 2005.

Very truly yours,

A handwritten signature in cursive script, appearing to read "T K Haldas".

T. K. Haldas
Project Manager

cc: Regional Water Engineer - NYSDEC Region 7
H. Hamel, NYSDOH
J. Burke, NYSDEC - Region 7
J. Abraham, SMC

MAESTRI GROUNDWATER ELEVATIONS- September, 2005

WELL NUMBER	MEASURING POINT	9/5/2005		9/13/2005		9/20/2005		9/27/2005	
		DEPTH TO	WATER	GROUND ELEVATION	DEPTH TO	WATER	GROUND ELEVATION	DEPTH TO	WATER
MW-9	407.51	16.80	390.71	16.80	390.71	17.10	390.41	18.40	389.11
MW-10	413.92	16.10	397.82	16.00	397.92	16.10	397.82	16.50	397.42
MW-12	418.36	13.50	404.86	13.10	405.26	13.30	405.06	13.50	404.86
MW-14	405.18	18.30	386.88	17.30	387.88	17.70	387.48	17.90	387.28
PZ-2	407.24	16.30	390.94	14.00	393.24	14.60	392.64	15.10	392.14
PZ-3	409.60	17.90	391.70	18.10	391.50	18.40	391.20	18.60	391.00
PZ-4	394.50	9.60	384.90	9.10	385.40	9.20	385.30	9.20	385.30
PZ-5	393.34	8.40	384.94	8.00	385.34	8.10	385.24	8.10	385.24
PZ-6	410.22	18.10	392.12	18.30	391.92	18.60	391.62	18.90	391.32
PZ-7	409.17	17.90	391.27	18.10	391.07	18.50	390.67	18.90	390.27
PZ-9	408.77	17.70	391.07	17.70	391.07	18.00	390.77	18.30	390.47
PZ-10	407.07	16.50	390.57	16.50	390.57	16.70	390.37	17.00	390.07
PZ-12	408.21	17.30	390.91	17.30	390.91	16.60	391.61	17.00	391.21
PZ-13	407.17	17.20	389.97	16.80	390.37	16.80	390.37	16.80	390.37
PZ-14	408.47	15.50	392.97	14.30	394.17	14.50	393.97	14.90	393.57
PZ-15	406.77	19.60	387.17	18.80	387.97	19.00	387.77	19.40	387.37
PZ-18	406.32	19.40	386.92	18.40	387.92	18.80	387.52	19.00	387.32
PZ-19	406.90	19.00	387.90	18.00	388.90	18.30	388.60	18.60	388.30
RW-2	406.46	17.70	388.76	16.80	389.66	18.00	388.46	18.30	388.16
RW-3	407.02	22.10	384.92	22.10	384.92	21.85	385.17	20.90	386.12
RW-5	409.67	21.70	387.97	21.70	387.97	21.50	388.17	21.85	387.82
RW-6	393.29	16.10	377.19	15.50	377.79	15.40	377.89	15.70	377.59
RW-7	405.97	21.40	384.57	21.20	384.77	21.10	384.87	21.80	384.17
RW-8	406.87	21.70	385.17	16.80	390.07	21.70	385.17	21.00	385.87

MAESTRI EFFLUENT MONITORING REPORT - September 2005

DATE	BENZENE ug/l	VINYL CHLORIDE ug/l	o-XYLENE ug/l	m-XYLENE ug/l	p-XYLENE ug/l	pH
9/5/2005	<1.0	<2.0	<1.0	<1.0	<1.0	7.6
LIMIT	1.0	5.0	5.0	5.0	5.0	6.5-8.5

MONTHLY DAILY AVERAGE FLOW (GPD) = 284

MONTHLY MAXIMUM DAILY FLOW (GPD) = 471