

STAUFFER MANAGEMENT COMPANY LLC

Environmental Services & Engineering
DCC II
1800 Concord Pike PO Box 15437
Wilmington, DE 19850-5437

Telephone: (302) 886-4238
Facsimile: (302) 886-5933

April 13, 2006

Mr. David Chiusano
Remedial Bureau E, Section A
Division Environmental Remediation
NYS Department of Environmental Conservation
625 Broadway 12th Floor
Albany, NY 12233-7017

Subject: Stauffer Management Company
Maestri Site #7-34-025

Dear Mr. Chiusano:

Enclosed please find the monitoring report and groundwater elevation tabulation for the above referenced site for March 2006.

Very truly yours,

T. K. Haldas

T. K. Haldas
Project Manager

cc: Regional Water Engineer - NYSDEC Region 7
H. Hamel, NYSDOH
J. Burke, NYSDEC - Region 7
J. Abraham, SMC
B. A. Spiller
L. W. Mette
A. Lawrence - SPEC
FILE: ENV-Maestri-WPO-RGY

MAESTRI GROUNDWATER ELEVATIONS- MARCH, 2006

WELL NUMBER	MEASURING POINT	3/7/2006	GROUND WATER	3/14/2006	GROUND WATER	3/21/2006	GROUND WATER	3/28/2006	GROUND WATER
		DEPTH TO ELEVATION		DEPTH TO ELEVATION		DEPTH TO ELEVATION		DEPTH TO ELEVATION	
MW-9	407.51	11.30	396.21	6.30	401.21	10.60	396.91	10.90	396.61
MW-10	413.92	6.50	407.42	3.40	410.52	4.20	409.72	4.90	409.02
MW-12	418.36	8.15	410.21	5.20	413.16	6.50	411.86	7.20	411.16
MW-14	405.18	15.00	390.18	11.00	394.18	13.05	392.13	13.30	391.88
PZ-2	407.24	10.30	396.94	6.00	401.24	9.00	398.24	9.20	398.04
PZ-3	409.60	12.30	397.30	8.60	401.00	10.90	398.70	11.00	398.60
PZ-4	394.50	6.40	388.10	2.00	392.50	5.30	389.20	5.80	388.70
PZ-5	393.34	5.30	388.04	0.70	392.64	4.80	388.54	5.20	388.14
PZ-6	410.22	11.60	398.62	7.20	403.02	9.70	400.52	10.10	400.12
PZ-7	409.17	12.20	396.97	8.50	400.67	11.10	398.07	11.30	397.87
PZ-9	408.77	11.80	396.97	8.50	400.27	11.00	397.77	11.20	397.57
PZ-10	407.07	10.80	396.27	7.70	399.37	10.50	396.57	10.80	396.27
PZ-12	408.21	13.90	394.31	8.50	399.71	12.35	395.86	12.60	395.61
PZ-13	407.17	13.20	393.97	6.90	400.27	12.30	394.87	12.50	394.67
PZ-14	408.47	10.30	398.17	7.50	400.97	9.00	399.47	9.30	399.17
PZ-15	406.77	16.15	390.62	12.50	394.27	14.30	392.47	15.30	391.47
PZ-18	406.32	16.10	390.22	12.30	394.02	14.20	392.12	15.10	391.22
PZ-19	406.90	15.60	391.30	12.00	394.90	13.80	393.10	14.20	392.70
RW-2	406.46	16.20	390.26	16.30	390.16	17.50	388.96	16.90	389.56
RW-3	407.02	20.50	386.52	19.30	387.72	19.30	387.72	19.50	387.52
RW-5	409.67	20.40	389.27	20.40	389.27	21.10	388.57	20.90	388.77
RW-6	393.29	14.20	379.09	1.60	391.69	14.20	379.09	10.20	383.09
RW-7	405.97	21.10	384.87	19.90	386.07	19.20	386.77	19.40	386.57
RW-8	406.87	21.80	385.07	22.00	384.87	21.60	385.27	21.30	385.57

MAESTRI EFFLUENT MONITORING REPORT - March 2006

DATE	BENZENE ug/l	VINYL CHLORIDE ug/l	o-XYLENE ug/l	m-XYLENE ug/l	p-XYLENE ug/l	pH
3/7/2006	<1.0	<1.0	<1.0	<1.0	<1.0	7.2
LIMIT	1.0	5.0	5.0	5.0	5.0	6.5-8.5

MONTHLY DAILY AVERAGE FLOW (GPD) = 2055 gpd
 MONTHLY MAXIMUM DAILY FLOW (GPD) = 3905 gpd