



18 Computer Drive West
Albany, NY 12205

518.438.6809
Fax 518.438.8527

December 13, 2006

Mr. George W. Harris, P.E.
New York State Department of Environmental Conservation
Division of Environmental Remediation
Remedial Bureau E, 12th Floor
625 Broadway, Albany, New York 12233-7017

Subject: **SMC- Maestri Site**
Site #7-34-025, Onondaga County

Dear Mr. Harris:

Enclosed is the November 2006 monitoring report for the Maestri Site, prepared by SPEC Consulting on behalf of Stauffer Management Company LLC (SMC). Due to operator error, the water elevations in the wells were not gauged for November. The December 2006 water elevation data has been provided instead. Should you have any questions, please do not hesitate to contact me at (518) 438-6809.

Sincerely,

Amy Lawrence

Amy Lawrence
Environmental Engineer

cc: Regional Water Engineer - NYSDEC Region 7
H. Hamel, NYSDOH
J. Burke, NYSDEC - Region 7
R. Shay- SMC
P. Ekoniak- SMC
J. Abraham- SMC

MAESTRI EFFLUENT MONITORING REPORT - November 2006

DATE	BENZENE ug/l	VINYL CHLORIDE ug/l	o-XYLENE ug/l	m-XYLENE ug/l	p-XYLENE ug/l	pH
11/7/2006	<1.0	<1.0	<1.0	<1.0	<1.0	7.6
LIMIT	1.0	5.0	5.0	5.0	5.0	6.5-8.5

MONTHLY DAILY AVERAGE FLOW (GPD) = 523 gpd
 MONTHLY MAXIMUM DAILY FLOW (GPD) = 2020 gpd

MAESTRI GROUNDWATER ELEVATIONS- DECEMBER 2006

12/12/2006			
WELL NUMBER	MEASURING POINT	DEPTH TO	GROUND WATER
	ELEVATION	WATER	ELEVATION
MW-9	407.51	13.20	394.31
MW-10	413.92	11.50	402.42
MW-12	418.36	6.10	412.26
MW-14	405.18	7.20	397.98
PZ-2	407.24	13.60	393.64
PZ-3	409.60	10.70	398.90
PZ-4	394.50	12.80	381.70
PZ-5	393.34	6.10	387.24
PZ-6	410.22	5.50	404.72
PZ-7	409.17	11.90	397.27
PZ-9	408.77	12.70	396.07
PZ-10	407.07	12.40	394.67
PZ-12	408.21	11.30	396.91
PZ-13	407.17	13.20	393.97
PZ-14	408.47	12.70	395.77
PZ-15	406.77	10.50	396.27
PZ-18	406.32	14.70	391.62
PZ-19	406.90	18.70	388.20
MW-2A (RW-2)	406.46	14.60	391.86
RW-3	407.02	18.90	388.12
RW-5	409.67	20.50	389.17
RW-6	393.29	12.45	380.84
RW-7	405.97	15.10	390.87
RW-8	406.87	22.10	384.77