



18 Computer Drive West
Albany, NY 12205

518.438.6809
Fax 518.438.8527

January 15, 2007

Mr. David Chiusano
Remedial Bureau E, Section A
Division Environmental Remediation
NYS Department of Environmental Conservation
625 Broadway 12th Floor
Albany, NY 12233-7017

Subject: **SMC- Maestri Site**
Site #7-34-025, Onondaga County

Dear Mr. Chiusano:

Enclosed is the December 2006 monitoring report for the Maestri Site, prepared by SPEC Consulting on behalf of Stauffer Management Company. Should you have any questions, please do not hesitate to contact me at (518) 438-6809.

Sincerely,

Amy Lawrence

Amy Lawrence
Environmental Engineer

cc: Regional Water Engineer - NYSDEC Region 7
H. Hamel, NYSDOH
J. Burke, NYSDEC - Region 7
R. Shay- SMC
P. Ekoniak- SMC
J. Abraham- SMC

MAESTRI GROUNDWATER ELEVATIONS- DECEMBER 2006

12/12/2006			
WELL NUMBER	MEASURING POINT	DEPTH TO	GROUND WATER
	ELEVATION	WATER	ELEVATION
MW-9	407.51	13.20	394.31
MW-10	413.92	11.50	402.42
MW-12	418.36	6.10	412.26
MW-14	405.18	7.20	397.98
PZ-2	407.24	13.60	393.64
PZ-3	409.60	10.70	398.90
PZ-4	394.50	12.80	381.70
PZ-5	393.34	6.10	387.24
PZ-6	410.22	5.50	404.72
PZ-7	409.17	11.90	397.27
PZ-9	408.77	12.70	396.07
PZ-10	407.07	12.40	394.67
PZ-12	408.21	11.30	396.91
PZ-13	407.17	13.20	393.97
PZ-14	408.47	12.70	395.77
PZ-15	406.77	10.50	396.27
PZ-18	406.32	14.70	391.62
PZ-19	406.90	18.70	388.20
MW-2A (RW-2)	406.46	14.60	391.86
RW-3	407.02	18.90	388.12
RW-5	409.67	20.50	389.17
RW-6	393.29	12.45	380.84
RW-7	405.97	15.10	390.87
RW-8	406.87	22.10	384.77

MAESTRI EFFLUENT MONITORING REPORT - December 2006

DATE	BENZENE ug/l	VINYL CHLORIDE ug/l	o-XYLENE ug/l	m-XYLENE ug/l	p-XYLENE ug/l	pH
12/5/2006	<1.0	<1.0	<1.0	<1.0	<1.0	7.4
LIMIT	1.0	5.0	5.0	5.0	5.0	6.5-8.5

MONTHLY DAILY AVERAGE FLOW (GPD) = 2036 gpd

MONTHLY MAXIMUM DAILY FLOW (GPD) = 2982 gpd