



16 Computer Drive West
Albany, NY 12205
Phone: 518.438.6809
Fax: 518.438.8527

November 3, 2007

Mr. David Chiusano
Remedial Bureau E, Section A
Division Environmental Remediation
NYS Department of Environmental Conservation
625 Broadway 12th Floor
Albany, NY 12233-7017

Subject: **SMC- Maestri Site**
Site #7-34-025, Onondaga County

Dear Mr. Chiusano:

Enclosed is the September 2007 monitoring report for the Maestri Site, prepared by EnviroSpec Engineering, PLLC on behalf of Stauffer Management Company. Should you have any questions, please do not hesitate to contact me at (518) 438-6809.

Sincerely,

Gianna Aiezza

Gianna Aiezza, PE
Principal Engineer

cc: Regional Water Engineer - NYSDEC Region 7
H. Hamel - NYSDOH
G. Townsend, NYSDEC - Region 7
R. Shay - SMC
P. Ekoniak - SMC
J. Abraham/E. Rice - SMC

MAESTRI EFFLUENT MONITORING REPORT - September 2007

DATE	BENZENE ug/l	VINYL CHLORIDE ug/l	o-XYLENE ug/l	m-XYLENE ug/l	p-XYLENE ug/l	pH
9/4/2007	<1.0	<1.0	<1.0	<1.0	<1.0	7.7
LIMIT	1.0	5.0	5.0	5.0	5.0	6.5-8.5

MONTHLY DAILY AVERAGE FLOW (GPD) = 218 gpd

MONTHLY MAXIMUM DAILY FLOW (GPD) = 279 gpd

MAESTRI GROUNDWATER ELEVATIONS- SEPTEMBER 2007

WELL NUMBER	MEASURING POINT	9/4/2007	
		DEPTH TO	GROUND WATER
	ELEVATION	WATER	ELEVATION
MW-9	407.51	Removed	
MW-10	413.92	15.90	398.02
MW-12	418.36	13.40	404.96
MW-14	405.18	18.15	387.03
PZ-2	407.24	15.60	391.64
PZ-3	409.60	17.40	392.20
PZ-4	394.50	9.50	385.00
PZ-5	393.34	8.30	385.04
PZ-6	410.22	17.60	392.62
PZ-7	409.17	17.50	391.67
PZ-9	408.77	17.20	391.57
PZ-10	407.07	16.00	391.07
PZ-12	408.21	16.40	391.81
PZ-13	407.17	15.20	391.97
PZ-14	408.47	15.20	393.27
PZ-15	406.77	19.40	387.37
PZ-18	406.32	19.30	387.02
PZ-19	406.90	Dry	
MW-2A (RW-2)	406.46	17.20	389.26
RW-3	407.02	20.00	387.02
RW-5	409.67	21.70	387.97
RW-6	393.29	12.80	380.49
RW-7	405.97	18.80	387.17
RW-8	406.87	17.00	389.87

MW-9 removed on 7/25/07 during site investigation.