



16 Computer Drive West
Albany, NY 12205
Phone: 518.438.6809
Fax: 518.438.8527

April 11, 2008

Mr. David Chiusano
Remedial Bureau E, Section A
Division Environmental Remediation
NYS Department of Environmental Conservation
625 Broadway 12th Floor
Albany, NY 12233-7017

Subject: **SMC- Maestri Site**
Site #7-34-025, Onondaga County

Dear Mr. Chiusano:

Enclosed is the March 2008 monitoring report for the Maestri Site, prepared by Envirospec Engineering, PLLC on behalf of Stauffer Management Company. Should you have any questions, please do not hesitate to contact me at (518) 438-6809.

Sincerely,

Gianna Aiezza

Gianna Aiezza, PE
Principal Engineer

cc: Regional Water Engineer - NYSDEC Region 7
H. Hamel - NYSDOH
G. Townsend, NYSDEC - Region 7
R. Shay - SMC
P. Ekoniak - SMC
J. Abraham/E. Rice - SMC

MAESTRI EFFLUENT MONITORING REPORT - March 2008

DATE	BENZENE ug/l	VINYL CHLORIDE ug/l	o-XYLENE ug/l	m-XYLENE ug/l	p-XYLENE ug/l	pH
3/12/2008	<1.0	<1.0	<1.0	<1.0	<1.0	7.5
LIMIT	1.0	5.0	5.0	5.0	5.0	6.5-8.5

MONTHLY DAILY AVERAGE FLOW (GPD) = 2252 gpd
MONTHLY MAXIMUM DAILY FLOW (GPD) = 4687 gpd

MAESTRI GROUNDWATER ELEVATIONS- MARCH, 2008

WELL NUMBER	MEASURING POINT ELEVATION	3/12/2008 DEPTH TO	GROUND WATER ELEVATION
		WATER	
MW-9	408.87	8.70	400.17
MW-10	413.82	3.80	410.02
MW-12	418.28	6.75	411.53
MW-14	405.17	12.20	392.97
PZ-2	407.23	6.80	400.43
PZ-3	409.60	8.10	401.50
PZ-4	394.37	4.10	390.27
PZ-5	393.37	5.05	388.32
PZ-6	410.15	7.40	402.75
PZ-7	409.13	8.40	400.73
PZ-9	408.69	8.10	400.59
PZ-10	407.04	7.40	399.64
PZ-12	408.17	9.10	399.07
PZ-13	407.12	8.80	398.32
PZ-14	408.44	7.30	401.14
PZ-15	406.74	13.80	392.94
PZ-18	406.30	13.40	392.90
PZ-19	406.88	12.90	393.98
MW-2A (formerly RW-2)	406.40	9.30	397.10
RW-3	407.01	14.00	393.01
RW-5	409.18	10.70	398.48
RW-6	393.64	13.20	380.44
RW-7	405.76	15.00	390.76
RW-8	406.81	17.70	389.11