



Erin Crotty
Commissioner

DAILY INSPECTION REPORT

Site Code #: 7-55-008	Date: April 26, 2004	Report #: NYSEG042604
------------------------------	-----------------------------	------------------------------

Site Name: NYSEG Ithaca Court St.- Wooden Duct Removal
Location: Ithaca, Tompkins County
NYSEG Proj. Mgr.: Bert Finch
DEC Proj. Mgr.: Bill Ottaway
Consultant Proj. Mgr.: Dave Budosh
Proj. Contr.: Sevenson
Site Phone & Fax:

	AM	PM
Weather	sunny	Sunny
Temperature	55	65
Wind Direction	ENE - 2 mph	ENE - 2 mph

Description of work performed by contr. this report period:

- Contractor excavated material from the north side of Court St. within intersection of Washington St. They excavated a 6" dia. clay tile pipe and a wooden duct, both containing tar, and surrounding soils. Excavation to 8' below road surface. A large amount of water entered excavation from nearby storm sewer drop inlet. It was removed with a pump, but this is an obviously inadequate method. Some water was still present as we removed the last soil .
-

Description of inspections performed by engr. this report period:

-

Discussions/comments regarding visitors, contractor and/or engineer:

Change Orders:

-

Sampling and Analyses:

-

Major Issues	Description & Reason

Water control	Contractor does not have sufficient means of dewatering excavation
---------------	--

Health & Safety:

Level of protection: D.

Is the level of protection in conformance with the approved Health & Safety Plan? Yes.

List deviations.

Are atmospheric monitoring results acceptable? Yes.

Site Visitors	Representing	Entered Exclusion Zone

Contractor's Information:

Prime contractor worked from 7:00A to 5:00P.

Subcontractor	Activity	Hours Worked
PAGE	hauling waste	

Equipment	P	1	2	3	Personnel	P	1	2	3
Komatsu W140 backhoe, with hoe-ram	1				Supervisor	1			
Komatsu PW170ES excavator	1				Operator	2			
Tractor trailer		3			Laborer	3			
Loader	1				Teamster		2		
					Health & Safety	1			

NYSDEC Site Representative: Eric S. Knapp

Date: April 26, 2004

Representative's signature:

Reviewed By:

Date:

REVISED 5/99 @BLANK.wpd