APPENDIX C-1

TANK SECONDARY CONTAINMENT INTEGRITY TESTING DRY TEST METHOD

Facility Name: Dandy Mini Mart 71			Owner:			
Address: 3564 Watkins Rd			Address:			
City, State, Zip Code: PIne Valley, NY 14872			City, State, Zip Code:			
Facility I.D. #: 8-097594			Phone #:			
Testing Company: PPSCO			Phone #:		Date: 9/29/2026	
This data sheet is for testing the integrity of the dry secondary containment of a underground storage tank (UST). See PEI/RP1200 Section 4.2 for the test procedure.						
Tank Number	007/008					
Tank Material	Fiberglass coated Steel					
Product Stored	regular / super					
Tank Capacity,* gallons	12,000					
Test Start Time	11:16am					
Initial Vacuum Reading, inches Hg (See Table 4-1 below.)	-10					
Specified Test Duration (See Table 4-1 below.)	■ 1 hour ☐ 2 hours	☐ 1 hour ☐ 2 hours	☐ 1 hour ☐ 2 hours	☐ 1 hour ☐ 2 hours	☐ 1 hour ☐ 2 hours	☐ 1 hour ☐ 2 hours
Test End Time	12:16pm					
Final Vacuum Reading, inches Hg	-10					
Is the Annular Space Dry After the Test?	■ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No
Test Results	■ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail

TABLE 4-1

Vacuum, inches Hg	Capacity, gallons	Duration, hours
10	<20,000	1
	20,000+	2

Comments: Installed new vac. gauge on 007, and tested.

*Total tank capacity, including all compartments in a multi-compartment tank.

Tester's Name (print) Tony Bruce

Tester's Signature Tony Bruce Tony Bruce (Sep 30, 2026 12:39:25 EDT)

Tank Secondary Containment Integrity Testing Dry Test Method Appendix_c-1

Final Audit Report 2026-09-30

Created:	2026-09-30
By:	Farrah Kelly (fkelly@propetro.com)
Status:	Signed
Transaction ID:	CBJCHBCAABAAfLfAirkS0SpOu0N1PkjLgP-2O3EColar

"Tank Secondary Containment Integrity Testing Dry Test Method Appendix_c-1" History

Document created by Farrah Kelly (fkelly@propetro.com)
2026-09-30 - 4:34:37 PM GMT

Document emailed to tbruce@propetro.com for signature
2026-09-30 - 4:35:08 PM GMT

Email viewed by tbruce@propetro.com
2026-09-30 - 4:38:29 PM GMT

Signer tbruce@propetro.com entered name at signing as Tony Bruce
2026-09-30 - 4:39:23 PM GMT

Document e-signed by Tony Bruce (tbruce@propetro.com)
Signature Date: 2026-09-30 - 4:39:25 PM GMT - Time Source: server - Signature Appearance Selected: TYPE

Agreement completed.
2026-09-30 - 4:39:25 PM GMT