SOAP
SPECIALTY OPERATIONS AND PRODUCTS

LEAK DETECTION FUNCTIONALITY AND LINE TIGHTNESS TEST

Facility Name:	Crosby's Childs	Date:	10/19/2026
Address:	14383 Ridge Rd	Testing Company:	Reid Petroleum
City, State, Zip:	Albion, NY 14411	Address:	100 W. Genesee St
PBS #:	8-231940	Contact:	

LEAK DETECTION TEST

Product	Make	Model	Operating Pressure	Holding Pressure	Opening Time	Resiliency	Pass/Fail
Regular 87	Veeder-Root	FX1V	28 PSI	15 PSI	1 sec	80 mL	Pass
Premium 93	Veeder-Root	FX1V	25 PSI	12 PSI	2 sec	60 mL	Pass
Kerosene	Veeder-Root	FX1DV	26 PSI	16 PSI	2 sec	70 mL	Pass

Test Method: Estabrooks EZY Chek

LINE TIGHTNESS TEST

Product	Test Pressure	Start Time	End Time	Loss Rate/GPH	Threshold	Pass/Fail	Pressure/ Suction
Regular 87	50 PSI	11:45 am	12:45 pm	0.0148	0.0592	Pass	Pressure
Premium 93	50 PSI	11:45 am	12:45 pm	0	0.0592	Pass	Pressure
Kerosene	50 PSI	1:05 pm	2:05 pm	0	0.0592	Pass	Pressure
					0.0592		
					0.0592		
					0.0592		

Test Method: Estabrooks EZY Chek

Comments:	All Pass

Technician:	John W. Vincent
Signature:	John W. Vincent

Cert #:	78-8312
Date:	10/23/2026