

From: [ted.senecamac.com](mailto:ted@senecamac.com)
To: [Griffiths, Matthew J \(DEC\)](mailto:Griffiths, Matthew J (DEC))
Subject: RE: Leroy Express 8-393193
Date: Sunday, April 19, 2026 10:50:19 AM
Attachments: [LT.xls](#)
[LDT.xls](#)
[CPT.xls](#)

ATTENTION: This email came from an external source. Do not open attachments or click on links from unknown senders or unexpected emails.

Hi Matt. I'll schedule him in June for all testing.
Ted

From: Griffiths, Matthew J (DEC) <matthew.griffiths@dec.ny.gov>
Sent: Tuesday, April 14, 2026 4:04 PM
To: ted.senecamac.com <ted@senecamac.com>
Subject: RE: Leroy Express 8-393193

Ok. Thanks. If you can please fit them into your schedule in June or July this yr since they are already past due for the 3-yr tests. They will be getting an NOV.

From: ted.senecamac.com <ted@senecamac.com>
Sent: Tuesday, April 14, 2026 3:38 PM
To: Griffiths, Matthew J (DEC) <matthew.griffiths@dec.ny.gov>
Subject: RE: Leroy Express 8-393193

ATTENTION: This email came from an external source. Do not open attachments or click on links from unknown senders or unexpected emails.

Hi Matt;
I'll schedule the spill fill & overfill tests in August.

Ted

From: Griffiths, Matthew J (DEC) <matthew.griffiths@dec.ny.gov>
Sent: Tuesday, April 14, 2026 10:14 AM
To: ted.senecamac.com <ted@senecamac.com>
Subject: Leroy Express 8-393193

Last ALLD / line test on file 8/7/24.
Did you do in 2025?
Also would need 3-yr SB and OP, due 9/22/25

Get [Outlook for iOS](#)

SMAC CO.

SENECA MAINTENANCE & CONSTRUCTION CO.

DATE: 8/6/2025

STORE: Leroy Express LLC

ADDRESS: 100 W. Main St.

CITY: Leroy, NY 14482

PBS #: 8-393193

Leak Detector Test

TANK NUMBER	# 001A	# 001B			
PRODUCT	Premium UL	Regular			
METERING PSI	26	28			
HOLD PRESSURE	14	235			
RESILIENCY ML.	80	60			
LEAK TEST RATE	190 ML/MIN.	190ML/MIN.	190 ML/MIN.	190 ML/MIN.	190ML/MIN.
OPENING TIME	2 Seconds	1 Second			
PASS / FAIL	PASS	PASS			
MANUFACTURER	Veeder-Root	Red Jacket			
MODEL #	FX1V	N/A			
SERIAL #	5571	41293			

COMPANY NAME: Seneca Maintenance & Construction Co.

COMPANY ADDRESS: PO Box 123 Dresden, NY 14441

TECHNICIAN NAME: Theodore A. Ginther

TECHNICIAN CERT. #: 38-2607

TECHNICIAN SIGNATURE: *Theodore A. Ginther*

SMAC CO.
SENECA
MAINTENANCE AND CONSTRUCTION CO.
PO Box 123 DRESDEN, NY 14441

CORROSION PROTECTION TESTING FORM										
UNDERGROUND STORAGE TANK (UST)										
Facility Name:	Leroy Express LLC				Date:	8/6/2025				
Address:	100 W. Main St.				PBS Facility ID #	8-393193				
	Leroy, NY 14482				<div style="text-align: center;">TEST LOCATIONS</div> <p>The diagram shows a central rectangular box labeled 'Tank'. To its right is a dashed line labeled 'Line'. Further right is a box labeled 'Pump'. Seven numbered boxes (1-7) are arranged around these elements: 1, 2, and 3 are above the Tank; 4 is to the right of the Tank; 5 is above the Line; 6 is to the right of the Line; and 7 is above the Pump.</p>					
Testing Company:	SMAC CO.									
Address:	PO Box 123									
	Dresden, NY 14441									
	TANK NO.		# 001A/B		PRODUCT	Premium/Reg. UL		SIZE	15,000	
Test Locations:	1	2	3	4	5	6	7			
Reading (-mV)	911	901	890							
Test Results:	TANK			PASS			PIPING	N/A		
	TANK NO.				PRODUCT			SIZE		
Test Locations	1	2	3	4	5	6	7			
Reading (-mV)										
Test Results:	TANK						PIPING			
	TANK NO.				PRODUCT			SIZE		
Test Locations:	1	2	3	4	5	6	7			
Reading (-mV)										
Test Results:	TANK						PIPING			
Comments:										
My signature below affirms that I have sufficient education and experience to be a cathodic protection tester. I am competent to perform the tests indicated above; and that the results on this form are a complete and accurate record of all testing at this location on the date shown.										
Tester Name:	Theodore A. Ginther				Certification #:	38-2607				
Signature:	<i>Theodore A. Ginther</i>									