

From: [leroyexpress1](#)
To: [Griffiths, Matthew J \(DEC\)](#)
Subject: FW: Reports & Invoice
Date: Tuesday, May 12, 2026 4:57:45 PM
Attachments: [Scan_20260508.pdf](#)
[LT.xls](#)
[LDT.xls](#)
[CPT.xls](#)
[SF.xlsx](#)

ATTENTION: This email came from an external source. Do not open attachments or click on links from unknown senders or unexpected emails.

Sr,

Please see attached testing reports for Leroy Express LLC.

Thank You,
Kyle Palmer

Sent from my Galaxy

----- Original message -----

From: "ted senecamac.com" <ted@senecamac.com>
Date: 5/8/26 6:08 PM (GMT-05:00)
To: [leroyexpress1 <leroyexpress1@gmail.com>](mailto:leroyexpress1@gmail.com)
Subject: Reports & Invoice

Thanks for the opportunity to serve you. We'll contact you next year to schedule at that time.

Ted Ginther

SMAC CO.

SMAC CO. SENECA MAINTENANCE AND CONSTRUCTION CO.

EZY Chek Systems Product Line Tester Data Sheet

DATE:	5/7/2026	PBS NUMBER:	8-393193
LOCATION:	Leroy Express LLC		
ADDRESS:	100 W. Main St.		
CITY STATE ZIPCODE	Leroy, NY 14482		
TECHNICIAN:	Theodore A. Ginther		
CERTIFICATION #:	38-2607		
APPLIED LINE TEST PRESSURE:	50 PSI		

TANK #	PRODUCT	TIME	DATA	LOSS	GAL/LINE	RESULT	GAL/HR.
# 001A	Premium UL	10:20 AM	41	0	0.0037	0	0
RESULT	PASS	10:35 AM	41	0	0.0037	0	0
		10:50 AM	41	0	0.0037	0	0
					0.0037		
					0.0037		
					0.0037		
# 001B	Regular UL	11:15 AM	55	0	0.0037	0	0
RESULT	PASS	11:30 AM	54	1	0.0037	0.0037	0.0148
		11:45 AM	54	0	0.0037	0	0

RESULT							

RESULT							

TECHNICIAN:	Theodore A. Ginther
TECHNICIAN CERTIFICATION #	38-2607
TECHNICIAN SIGNATURE:	<i>Theodore A. Ginther</i>

SMAC CO.

SENECA MAINTENANCE & CONSTRUCTION CO.

DATE: 5/7/2026

STORE: Leroy Express LLC

ADDRESS: 100 W. Main St.

CITY: Leroy, NY 14482

PBS #: 8-393193

Leak Detector Test

TANK NUMBER	# 001A	# 001B			
PRODUCT	Premium UL	Regular			
METERING PSI	29	26			
HOLD PRESSURE	16	18			
RESILIENCY ML.	30	20			
LEAK TEST RATE	190 ML/MIN.	190ML/MIN.	190 ML/MIN.	190 ML/MIN.	190ML/MIN.
OPENING TIME	1 Second	1 Second			
PASS / FAIL	PASS	PASS			
MANUFACTURER	Veeder-Root	Red Jacket			
MODEL #	FX1V	N/A			
SERIAL #	5571	41293			

COMPANY NAME: Seneca Maintenance & Construction Co.

COMPANY ADDRESS: PO Box 123 Dresden, NY 14441

TECHNICIAN NAME: Theodore A. Ginther

TECHNICIAN CERT. #: 38-2607

TECHNICIAN SIGNATURE: *Theodore A. Ginther*

SMAC CO.
SENECA
MAINTENANCE AND CONSTRUCTION CO.
PO Box 123 DRESDEN, NY 14441

CORROSION PROTECTION TESTING FORM									
UNDERGROUND STORAGE TANK (UST)									
Facility Name:	Leroy Express LLC				Date:	5/7/2026			
Address:	100 W. Main St.				PBS Facility ID #	8-393193			
	Leroy, NY 14482				<div style="text-align: center;">TEST LOCATIONS</div> <p>The diagram shows a central rectangular box labeled 'Tank'. To its right is a dashed line labeled 'Line'. Further right is a box labeled 'Pump'. Seven numbered boxes (1-7) are arranged around these elements: 1, 2, and 3 are above the Tank; 4 is to the right of the Tank; 5 is above the Line; 6 is to the right of the Line; and 7 is above the Pump.</p>				
Testing Company:	SMAC CO.								
Address:	PO Box 123								
	Dresden, NY 14441								
	TANK NO.		# 001A/B		PRODUCT	Premium/Reg. UL		SIZE	15,000
Test Locations:	1	2	3	4	5	6	7		
Reading (-mV)	1001	1044	941						
Test Results:	TANK			PASS			PIPING	N/A	
	TANK NO.				PRODUCT			SIZE	
Test Locations	1	2	3	4	5	6	7		
Reading (-mV)									
Test Results:	TANK						PIPING		
	TANK NO.				PRODUCT			SIZE	
Test Locations:	1	2	3	4	5	6	7		
Reading (-mV)									
Test Results:	TANK						PIPING		
Comments:									
My signature below affirms that I have sufficient education and experience to be a cathodic protection tester. I am competent to perform the tests indicated above; and that the results on this form are a complete and accurate record of all testing at this location on the date shown.									
Tester Name:	Theodore A. Ginther				Certification #:	38-2607			
Signature:	<i>Theodore A. Ginther</i>								

SMAC CO.

SPILL BUCKET INTEGRITY TESTING- HYDROSTATIC/ VACUUM TEST METHODS											
FACILITY NAME:	LeRoy Express LLC			DATE:	5/7/2026						
ADDRESS:	100 W. Main St.			OWNER:	Same						
CITY, STATE & ZIP CODE:	LeRoy , NY 14482			ADDRESS:							
PBS NUMBER:	8-393193			CITY, STATE & ZIP:							
TESTING COMPANY:	SMAC CO.			PAGE NUMBER:	1 of 1						
Tank Number:	# 001A			# 001B							
Product Stored:	Premium UL			Regular UL							
Spill Bucket Capacity	5 Gallons			7 Gallons							
Manufacturer:	OPW			OPW							
Construction:	X	Single Wall		X	Single Wall		Single Wall		Single Wall		
		Double Wall			Double Wall		Double Wall		Double Wall		
Test Type:	X	Hydrostatic		X	Hydrostatic		Hydrostatic		Hydrostatic		
		Vacuum			Vacuum		Vacuum		Vacuum		
Spill Bucket Type:	X	Product		X	Product		Product		Product		
		Vapor			Vapor		Vapor		Vapor		
Liquid & Debris Removed?	X	Yes	No	X	Yes	No	Yes	No	Yes	No	
Visual Inspection Passed?	X	Yes	No	X	Yes	No	Yes	No	Yes	No	
Fill Cap Included in Test?	X	Yes	No	X	Yes	No	Yes	No	Yes	No	
Drain Valve Included in Test?		Yes	X N/A	Yes	X	N/A	Yes	N/A	Yes	N/A	
Starting Level	5 3/4"			10"							
Test Start Time	9:20 AM			9:25 AM							
Ending Level	5 3/4"			10"							
Test End Time	10:20 AM			10:25 AM							
Test Period	1 Hr.			1 Hr.							
Level Change	0"			0"							
PASS/FAIL CRITERIA: MUST PASS VISUAL INSPECTION. HYDROSTATIC: WATER LEVEL DROP OF LESS THAN 1/8".											
Vacuum single walled only; must maintain at least 26 inches of water column.											
Vacuum double walled only; must maintain at least 12 inches of water column.											
Test Results:	PASS			PASS							
Test Technician:	Theodore A. Ginther										
Signature:	<i>Theodore A. Ginther</i>										