



11000 N. MoPac Expressway, Suite 500
Austin, Texas 78759
Phone: (512) 451-6334
Fax: (512) 459-1459

Date Printed and Mailed: 5/27/2026

DEC-AVON
REGION 8
6274 EAST AVON-LIMA ROAD
AVON, NY 14414

Test Date: 5/27/2026
Order Number: 8617733

Dear Regulator,

Enclosed are the results of recent testing performed at the following facility:

BJ's Wholesale #168
400 Jay Scutti Blvd
PBS # 8-601122
Rochester, NY 14623

Testing conducted in accordance with paragraph 613-2.3(d)(2) of NYCRR. Technician is a certified Vacutect tank tester and/or a certified TLD-1 line tester in accordance with company protocol. Technician address on file at Tanknology corporate office: 11000 N. MoPac Expressway, Suite 500, Austin, TX 78759

Testing performed:
IMPACT VALVE
LEAK DETECTOR
MONITOR CERTIFICATION

Sincerely,

A handwritten signature in black ink that reads 'Dawn Kohlmeier'.

Dawn Kohlmeier
Manager, Field Reporting



LDT 5000 Field Test Apparatus
Line Leak Detector Test

Page 1 of 1

Work Order: 8617733 Date: 5/27/2026
Site Name / ID: BJ's Wholesale #168 / 168
Address: 400 Jay Scutti Blvd PBS # 8-601122
City: Rochester State: NY Zip: 14623

Tank ID	1 RUL NYDEC 001	3 PUL NYDEC 002B				
Product	RUL	PREMIUM				
Product Line	1	1				
Tested From	11	11				
Existing/New	Existing	Existing				
Mechanical/Electronic	Electronic	Electronic				
Manufacturer/Model	Veeder Root PLLD	Veeder Root PLLD				
Serial No.	06030071	05070605				
Pump Operating Pressure (psi)	35.00	35.00				
Calibrated Leak (ml/min)	189.0	189.0				
Calibrated Leak (gph)	3.00	3.00				
Holding PSI <i>*N/A for Electronic LD's</i>						
Resiliency (ml) <i>*N/A for Electronic LD's</i>						
Metering PSI <i>*N/A for Electronic LD's</i>						
Opening Time (sec) <i>*N/A for Electronic LD's</i>						
Test Results	Pass	Pass				

Technician Comments:

Technician Name: Samuel LoGiudice Certification #: 167537
Technician Signature:  Expire Date: 3/3/2027



Impact Valve Inspection

Impact Valve Operational Inspection

Work Order: 8617733 Date: 5/27/2026
Site Name/ID: BJ's Wholesale #168
Address: 400 Jay Scutti Blvd PBS # 8-601122
City: Rochester State: NY Zip: 14623

How Inspected: Line Test ☐ NFPA 30A ☐ PEI RP1200 ☒ Other ☐

Dispenser Number	Grade	Secure Mount?	Valve Lock?	Pass/ Fail	Comments
1/2	87	☒	☒	☒ Pass ☐ Fail ☐ Not Tested	
1/2	93	☒	☒	☒ Pass ☐ Fail ☐ Not Tested	
3/4	87	☒	☒	☒ Pass ☐ Fail ☐ Not Tested	
3/4	93	☒	☒	☒ Pass ☐ Fail ☐ Not Tested	
5/6	87	☒	☒	☒ Pass ☐ Fail ☐ Not Tested	
5/6	93	☒	☒	☒ Pass ☐ Fail ☐ Not Tested	
7/8	87	☒	☒	☒ Pass ☐ Fail ☐ Not Tested	
7/8	93	☒	☒	☒ Pass ☐ Fail ☐ Not Tested	
9/10	87	☒	☒	☒ Pass ☐ Fail ☐ Not Tested	
9/10	93	☒	☒	☒ Pass ☐ Fail ☐ Not Tested	
11/12	87	☒	☒	☒ Pass ☐ Fail ☐ Not Tested	
11/12	93	☒	☒	☒ Pass ☐ Fail ☐ Not Tested	

Technician Comments:

Technician Name: Samuel LoGiudice
Signature: 

MONITORING SYSTEM CERTIFICATION

This form is used to document testing and servicing of tank and piping leak monitoring equipment. If required by applicable law, a copy of the completed form must be provided by the Testing Contractor or owner to the governing UST agency as required by regulation.

A. General Information

Facility Name: BJ's Wholesale #168 Bldg. No.: _____
Site Address: 400 Jay Scutti BlvdPBS # 8-601122 City: Rochester State: NY Zip: 14623
Facility Contact Person: _____ Contact Phone No.: -
Make/Model of Monitoring System: Veeder Root TLS-350 Date of Testing/Servicing: 5/27/2026

B. Inventory of Equipment Tested/Certified

 Check the appropriate boxes to indicate specific equipment inspected/serviced:

Tank ID: <u>1 RUL NYDEC 001 - RUL</u> ☒ In-Tank Gauging Probe. Model: <u>mag</u> ☒ Annular Space or Vault Sensor. Model: <u>794380-303</u> ☒ Piping Sump / Trench Sensor(s). Model: <u>794380-208</u> ☐ Fill Sump Sensor(s). Model: _____ ☒ Mechanical Line Leak Detector. Model: <u>FE Petro MLD</u> ☐ Electronic Line Leak Detector. Model: _____ ☐ Tank Overfill / High-Level Sensor. Model: _____ ☐ Other (specify equipment type and model in Section E on Page 2).	Tank ID: <u>3 PUL NYDEC 002B - PREMIUM</u> ☒ In-Tank Gauging Probe. Model: <u>mag</u> ☒ Annular Space or Vault Sensor. Model: <u>794380-303</u> ☒ Piping Sump / Trench Sensor(s). Model: <u>794380-208</u> ☐ Fill Sump Sensor(s). Model: _____ ☒ Mechanical Line Leak Detector. Model: <u>FE Petro MLD</u> ☐ Electronic Line Leak Detector. Model: _____ ☐ Tank Overfill / High-Level Sensor. Model: _____ ☐ Other (specify equipment type and model in Section E on Page 2).
Tank ID: <u>2 RUL NYDEC 002A - RUL 2</u> ☒ In-Tank Gauging Probe. Model: <u>mag</u> ☒ Annular Space or Vault Sensor. Model: <u>794380-303</u> ☒ Piping Sump / Trench Sensor(s). Model: <u>794380-208</u> ☐ Fill Sump Sensor(s). Model: _____ ☐ Mechanical Line Leak Detector. Model: _____ ☐ Electronic Line Leak Detector. Model: _____ ☐ Tank Overfill / High-Level Sensor. Model: _____ ☐ Other (specify equipment type and model in Section E on Page 2).	Tank ID: _____ ☐ In-Tank Gauging Probe. Model: _____ ☐ Annular Space or Vault Sensor. Model: _____ ☐ Piping Sump / Trench Sensor(s). Model: _____ ☐ Fill Sump Sensor(s). Model: _____ ☐ Mechanical Line Leak Detector. Model: _____ ☐ Electronic Line Leak Detector. Model: _____ ☐ Tank Overfill / High-Level Sensor. Model: _____ ☐ Other (specify equipment type and model in Section E on Page 2).
Dispenser ID: <u>1/2</u> ☒ Dispenser Containment Sensor(s). Model: <u>794380-208</u> ☒ Shear Valve(s). ☐ Dispenser Containment Float(s) and Chain(s).	Dispenser ID: <u>7/8</u> ☒ Dispenser Containment Sensor(s). Model: <u>794380-208</u> ☒ Shear Valve(s). ☐ Dispenser Containment Float(s) and Chain(s).
Dispenser ID: <u>3/4</u> ☒ Dispenser Containment Sensor(s). Model: <u>794380-208</u> ☒ Shear Valve(s). ☐ Dispenser Containment Float(s) and Chain(s).	Dispenser ID: <u>9/10</u> ☒ Dispenser Containment Sensor(s). Model: <u>794380-208</u> ☒ Shear Valve(s). ☐ Dispenser Containment Float(s) and Chain(s).
Dispenser ID: <u>5/6</u> ☒ Dispenser Containment Sensor(s). Model: <u>794380-208</u> ☒ Shear Valve(s). ☐ Dispenser Containment Float(s) and Chain(s).	Dispenser ID: <u>11/12</u> ☒ Dispenser Containment Sensor(s). Model: <u>794380-208</u> ☒ Shear Valve(s). ☐ Dispenser Containment Float(s) and Chain(s).

*If the facility contains more tanks or dispensers, copy this form. Include information for every tank and dispenser at the facility.

C. Certification - I certify that the equipment identified in this document was inspected/serviced in accordance with the manufacturers' guidelines. Attached to this Certification is a Plot Plan showing the layout of monitoring equipment. For any equipment capable of generating such reports, I have also attached a copy of the report; (check all that apply): ☐ System set-up ☐ Alarm history report

Technician Name (print): Samuel LoGiudice Signature: 
Certification No.: C29748 License No.: _____
Testing Company Name: Tanknology Phone No.: (800) 800-4633
Testing Company Address: 11000 N. MoPac Expressway Suite 500 Date of Testing/Servicing: 5/27/2026

D. Results of Testing/Servicing

Software Version Installed: _____

Complete the following checklist:

☒ Yes	☐ No* ☐ N/A	Is the visual alarm on the console operational?
☒ Yes	☐ No* ☐ N/A	Is the audible alarm on the console operational?
☐ Yes	☒ No	Is the external visual overfill alarm (light unit) present?
☐ Yes	☐ No* ☒ N/A	Is the external visual overfill alarm operating properly?
☐ Yes	☒ No	Is the external audible overfill alarm present?
☐ Yes	☐ No* ☒ N/A	Is the external audible overfill alarm operating properly?
90 %	☐ N/A	At what percent of tank(s) capacity is the external alarm programmed to trigger? <i>If different % between tanks, clarify in section E.</i>
☒ Yes	☐ No* ☐ N/A	Were all sensors visually inspected, functionally tested, and confirmed operational?
☒ Yes	☐ No* ☐ N/A	Were all sensors installed at lowest point of secondary containment and positioned so that other equipment will not interfere with their proper operation?
☐ Yes	☐ No* ☒ N/A	For pressurized piping systems, does the turbine automatically shut down if the piping secondary containment monitoring system detects a leak, fails to operate, or is electrically disconnected? If yes: which sensors initiate positive shut-down? <i>(Check all that apply)</i> ☐ Sump/Trench Sensors; ☐ Dispenser Containment Sensors. Did you confirm positive shut-down due to leaks <u>and</u> sensor failure/disconnection? ☐ Yes; ☐ No
☐ Yes*	☒ No	Was any monitoring equipment replaced? If yes, identify specific sensors, probes, or other equipment replaced and list the manufacturer name and model for all replacement parts in Section E, below.
☐ Yes*	☒ No	Was liquid found inside any secondary containment systems designed as dry systems? <i>(Check all that apply)</i> ☐ Product; ☐ Water. If yes, describe causes in Section E, below.
☒ Yes	☐ No*	Was monitoring system set-up reviewed to ensure proper settings? Attach set up reports, if applicable
☒ Yes	☐ No*	Is all monitoring equipment operational per manufacturer's specifications?

* In Section E below, describe how and when these deficiencies were or will be corrected.

E. Comments:

Backup Battery reading, if applicable (Required for VR TLS 300/350):3.6

F. In-Tank Gauging / SIR Equipment:

☐ Check this box if tank gauging is used only for inventory control.
☐ Check this box if no tank gauging or SIR equipment is installed.

This section must be completed if in-tank gauging equipment is used to perform leak detection monitoring.

Complete the following checklist:

☒ Yes	☐ No*	Were all tank gauging probes visually inspected for damage and residue buildup?
☒ Yes	☐ No*	Was accuracy of system product level readings tested?
☒ Yes	☐ No*	Was accuracy of system water level readings tested?
☒ Yes	☐ No*	Were all probes reinstalled properly?
☒ Yes	☐ No*	Were all items on the equipment manufacturer's maintenance checklist completed?

* In the Section G, below, describe how and when these deficiencies were or will be corrected.

G. Comments:

--

DID OVERALL MONITOR SYSTEM TESTING PASS (Check One)? YES ☒ NO ☐
INCONCLUSIVE ☐

