

Erosion and Sediment Control

Name of Inspector: George Fischer
4/5/2018

Weather: Mostly sunny and cold, 28°

Are all the erosions controls functioning properly?	YES - Comment	NO – Comment
	YES - West side silt fence sagging again - fabric separated from several stakes Still functioning but should be repiared.	
Is any silt fence in need of repair or replacement?	NO	
Are any storm drain inlet protections in need of repair or replacement?		N/A
Is there any potentially contaminated water migrating off-site?		No
Are any hay bales in need of repair or replacement?		N/A

AECOM

2

Additional Checks

	Comments:	
Condition of runoff at all points of discharge from the site (pipe, culverts and ditches	N/A	
Condition of all natural water bodies which receive runoff	Clear	
Corrective action to repair E&S	N/A	

Construction activity not in line with SWPPP	N/A
--	-----

Notes:

Inspection completed during temporary shut-down.

