

Petroleum Bulk Storage (PBS) Update and Renewal Application

version 3.39

(Submission #: HQP-DAYK-74B4K, version 1)

Digitally signed by:
nFormNY
dec0117pw5web.svc.ny.gov
Date: 2026.06.18 12:44:03 -04:00
Reason: Copy Of Record
Location: Albany, New York

Details

Submitted 6/18/2026 (0 days ago) by Francesco DiVito

PBS Number 9-120138 Cuba (Allegany) (0248)

Submission ID HQP-DAYK-74B4K

Form Input

Overview

Your Registration expires on the date below. Please note that renewals are only available to facilities which are within 1 year of expiring.

09/17/2030

PBS Number

9-120138

Facility Name

CROSBY'S CUBA

Town and County

Cuba (Allegany) (0248)

Type of Facility

Retail Gasoline Sales

Facility

Would you like to modify any Facility information on this page?

No

PBS Number

9-120138

Facility Name

CROSBY'S CUBA

Facility's Address

66 GENESEE ST
CUBA, NY 14727

Town and County

Cuba (Allegany) (0248)

Facility Location - Please enter your facility's address in order to calculate its Latitude and Longitude. Alternatively, find your facility on the map to automatically generate the Latitude and Longitude.

42.220633682,-78.277036585

Facility's Phone Number

(585) 209-4086

Facility Type

Retail Gasoline Sales

Some information is "read-only". If you want to make any updates to "read-only" information, please reach out to your NYSDEC regional office*, bulk storage program. Contact information for each region can be found below:

Central office: dec.sm.e-regbspreregion0@dec.ny.gov

Region 1: dec.sm.e-regbspreregion1@dec.ny.gov

Region 2: dec.sm.e-regbspreregion0@dec.ny.gov

Region 3: dec.sm.e-regbspreregion3@dec.ny.gov

Region 4: dec.sm.e-regbspreregion4@dec.ny.gov

Region 5: dec.sm.e-regbspreregion5@dec.ny.gov

Region 6: dec.sm.e-regbspreregion6@dec.ny.gov

Region 7: dec.sm.e-regbspreregion7@dec.ny.gov

Region 8: dec.sm.e-regbspreregion8@dec.ny.gov

Region 9: dec.sm.e-regbspreregion9@dec.ny.gov

Property Owner

Would you like to modify any Property Owner information on this page?

No

Owner Type

Corporate/Commercial/Other

Are all tanks at this facility owned by this property owner?

No

Property Owner Name (Legal Entity)

HAWLEY DEVELOPMENT

Property Owner Contact Information (facility/property owner on the deed)

Phone Type	Number	Extension
Business	(800) 348-8400	NONE PROVIDED

Email
NONE PROVIDED

Property Owner's Address
100 W GENESEE ST
LOCKPORT, NY 14094

This section contains information pertaining to the property owner. Some information is "read-only". If you want to make any updates to "read-only" information, please reach out to your NYSDEC regional office*, bulk storage program. Contact information for each region can be found here:

Central office: dec.sm.e-regbspreigion0@dec.ny.gov
Region 1: dec.sm.e-regbspreigion1@dec.ny.gov
Region 2: dec.sm.e-regbspreigion0@dec.ny.gov
Region 3: dec.sm.e-regbspreigion3@dec.ny.gov
Region 4: dec.sm.e-regbspreigion4@dec.ny.gov
Region 5: dec.sm.e-regbspreigion5@dec.ny.gov
Region 6: dec.sm.e-regbspreigion6@dec.ny.gov
Region 7: dec.sm.e-regbspreigion7@dec.ny.gov
Region 8: dec.sm.e-regbspreigion8@dec.ny.gov
Region 9: dec.sm.e-regbspreigion9@dec.ny.gov

*Please note that applicants within Region 2 (i.e., New York City) must instead contact the central office in Albany if their application includes a fee (i.e., renewal, new facility, or transfer of ownership).

Tank Owner(s) (1 of 1)

Tank Owner: Reid Petroleum Corp

By default, the property (facility) owner is the tank owner for all tanks. However, if this facility has additional tank owners, after completing the owner information below, please go to the TANKS section and assign which tank owner owns each tank. You will need to select "Tank repair/modification" for any tank you wish to assign a different tank owner to.

Tank Owner Name (legal entity)
Reid Petroleum Corp

Tank Owner

Phone Type	Number	Extension
Business	(800) 348-8400	NONE PROVIDED

Email

environmental@REIDPETROLEUM.COM

Tank Owner's Address

100 W Genesee St
Lockport, NY 14094

Contacts

Facility Operator

Please enter the facility operator information.

Would you like to modify the Facility Operator information?

Yes

Operator Information

Operator Name (Legal Entity)

JAMES A SMITH

Phone Type	Number	Extension
-------------------	---------------	------------------

Business	(585) 209-4086	
----------	----------------	--

Email

environmental@reidpetroleum.com

Address

100 West Genesee St
Lockport, NY 14094

Facility Correspondence Contact

Please enter the contact information for the individual that we should contact for questions regarding this facility's PBS registration.

Would you like to modify Mail (Correspondence) Contact information?

No

Correspondence Name (First and Last)

JAMES A SMITH

Correspondence Title

NONE PROVIDED

Facility Correspondence

|

Correspondence Company Name

REID PETROLEUM

Phone Type Number ExtensionBusiness (800) 348-8400 *NONE PROVIDED***Email**

ENVIRONMENTAL@REIDPETROLEUM.COM

Address

100 W GENESEE ST

LOCKPORT, NY 14094

Emergency Contact Information

Please enter the contact information for the individual that we should contact in the event of an emergency at the PBS facility.

Would you like to modify the Emergency Contact information?

No

Emergency Contact Name

JAMES A SMITH

Emergency Contact Phone Number

(716) 534-4165

Tanks (1 of 4)**Tank Number: 001****Modification Type**

Tank repair/modification

Name of Tank

001

Is this tank aboveground or underground?

Underground including vaulted with no access for inspection

Type of petroleum stored

gasoline/ethanol

Tank installation date

09/01/2007

Tank status

In Service

Tank storage capacity (gallons)

12000

Percent ethanol or biodiesel

10.00

Tank design/construction material

Fiberglass Reinforced Plastic (FRP)

Tank internal corrosion protection

None

Tank external corrosion protection

Fiberglass

Tank secondary containment

Double-Walled (Underground)

Tank leak detection

Interstitial - Electronic Monitoring

Tank overfill prevention

Automatic Shut-Off

Tank spill prevention

Catch Basin

If this tank has dispenser(s), do they have under dispenser containment?

Yes

Pumping/dispensing method

Pressurized Dispenser

Does this tank have piping?

Yes

Piping install date

NONE PROVIDED

Is the piping aboveground or underground?

Underground/On-ground

Piping design/construction material

Flexible Piping

Piping secondary containment

Double walled UG

Piping external corrosion protection

Jacketed

Piping leak detection

Interstitial - Electronic Monitoring

Pressurized Piping Leak Detector

Is this tank owned by the property owner?

No

Please select the Tank Owner for this tank

Reid Petroleum Corp

A/B OPERATORS

This tank is regulated under subpart 2. Therefore this tank requires an A and B Operator.

Class A Operator's Name

JAMES SMITH

Class A Operator's Authorization Number

MGX-DWN

Is your Class A Operator also your Class B Operator?

Yes

Tanks (2 of 4)

Tank Number: 002

Modification Type

Tank repair/modification

Name of Tank

002

Is this tank aboveground or underground?

Underground including vaulted with no access for inspection

Type of petroleum stored

gasoline/ethanol

Tank installation date

09/01/2007

Tank status

In Service

Tank storage capacity (gallons)

3000

Percent ethanol or biodiesel

10.00

Tank design/construction material

Fiberglass Reinforced Plastic (FRP)

Tank internal corrosion protection

None

Tank external corrosion protection

Fiberglass

Tank secondary containment

Double-Walled (Underground)

Tank leak detection

Interstitial - Electronic Monitoring

Tank overfill prevention

Automatic Shut-Off

Tank spill prevention

Catch Basin

If this tank has dispenser(s), do they have under dispenser containment?

Yes

Pumping/dispensing method

Pressurized Dispenser

Does this tank have piping?

Yes

Piping install date

NONE PROVIDED

Is the piping aboveground or underground?

Underground/On-ground

Piping design/construction material

Flexible Piping

Piping secondary containment

Double walled UG

Piping external corrosion protection

Jacketed

Piping leak detection

Interstitial - Electronic Monitoring

Pressurized Piping Leak Detector

Is this tank owned by the property owner?

No

Please select the Tank Owner for this tank

Reid Petroleum Corp

A/B OPERATORS

This tank is regulated under subpart 2. Therefore this tank requires an A and B Operator.

Class A Operator's Name

JAMES SMITH

Class A Operator's Authorization Number

MGX-DWN

Is your Class A Operator also your Class B Operator?

Yes

Tanks (3 of 4)

Tank Number: 003

Modification Type

Tank repair/modification

Name of Tank

003

Is this tank aboveground or underground?

Underground including vaulted with no access for inspection

Type of petroleum stored

diesel

Tank installation date

09/01/2007

Tank status

In Service

Tank storage capacity (gallons)

8000

Tank design/construction material

Fiberglass Reinforced Plastic (FRP)

Tank internal corrosion protection

None

Tank external corrosion protection

Fiberglass

Tank secondary containment

Double-Walled (Underground)

Tank leak detection

Interstitial - Electronic Monitoring

Tank overfill prevention

Automatic Shut-Off

Tank spill prevention

Catch Basin

If this tank has dispenser(s), do they have under dispenser containment?

Yes

Pumping/dispensing method

Pressurized Dispenser

Does this tank have piping?

Yes

Piping install date

NONE PROVIDED

Is the piping aboveground or underground?

Underground/On-ground

Piping design/construction material

Flexible Piping

Piping secondary containment

Double walled UG

Piping external corrosion protection

Jacketed

Piping leak detection

Interstitial - Electronic Monitoring

Pressurized Piping Leak Detector

Is this tank owned by the property owner?

No

Please select the Tank Owner for this tank

Reid Petroleum Corp

A/B OPERATORS

This tank is regulated under subpart 2. Therefore this tank requires an A and B Operator.

Class A Operator's Name

JAMES SMITH

Class A Operator's Authorization Number

MGX-DWN

Is your Class A Operator also your Class B Operator?
Yes

Tanks (4 of 4)

Tank Number: 004

Modification Type
Tank repair/modification

Name of Tank
004

Is this tank aboveground or underground?
Underground including vaulted with no access for inspection

Type of petroleum stored
kerosene [#1 fuel oil] (resale/redistribute)

Tank installation date
09/01/2007

Tank status
In Service

Tank storage capacity (gallons)
6000

Tank design/construction material
Fiberglass Reinforced Plastic (FRP)

Tank internal corrosion protection
None

Tank external corrosion protection
Fiberglass

Tank secondary containment
Double-Walled (Underground)

Tank leak detection
Interstitial - Electronic Monitoring

Tank overfill prevention
Automatic Shut-Off

Tank spill prevention
Catch Basin

If this tank has dispenser(s), do they have under dispenser containment?
Yes

Pumping/dispensing method

Suction Dispenser

Does this tank have piping?

Yes

Piping install date

NONE PROVIDED

Is the piping aboveground or underground?

Underground/On-ground

Piping design/construction material

Flexible Piping

Piping secondary containment

Double walled UG

Piping external corrosion protection

Jacketed

Piping leak detection

Exempt Suction Piping

Interstitial - Electronic Monitoring

Is this tank owned by the property owner?

No

Please select the Tank Owner for this tank

Reid Petroleum Corp

A/B OPERATORS

This tank is regulated under subpart 2. Therefore this tank requires an A and B Operator.

Class A Operator's Name

JAMES SMITH

Class A Operator's Authorization Number

MGX-DWN

Is your Class A Operator also your Class B Operator?

Yes

Certification Statement

By submitting this form electronically, I hereby certify, under penalty of law, that all of the information provided on this form is true and correct.

False statements made herein may be punishable as a criminal offense and/or a civil violation in accordance with applicable state and federal law.