



Inactive Hazardous Waste Site Operations and Maintenance Review Report

Form Date 98.10.01

Site Name: Niagara Mohawk Cherry Farm		Class: 4	Number: 915063
O&M Funding Source: <input type="checkbox"/> State Superfund <input type="checkbox"/> Federal Superfund <input type="checkbox"/> Municipal <input checked="" type="checkbox"/> Responsible Party			
O&M Information: O&M Start: January, 2000 End: Annual Cost: \$250,000 <input checked="" type="checkbox"/> Estimated			
Interim Remedial Measures/Operable Units in O&M Phase: <div style="display: flex; flex-wrap: wrap;"> <div style="width: 33%;"><input type="checkbox"/> Drum Removal</div> <div style="width: 33%;"><input type="checkbox"/> Soil Removal</div> <div style="width: 33%;"><input type="checkbox"/> Tank Removal</div> <div style="width: 33%;"><input checked="" type="checkbox"/> Cap/Cover</div> <div style="width: 33%;"><input type="checkbox"/> Containment Structure</div> <div style="width: 33%;"><input checked="" type="checkbox"/> Fence/Security</div> <div style="width: 33%;"><input checked="" type="checkbox"/> Groundwater Recovery/Treatment</div> <div style="width: 33%;"><input checked="" type="checkbox"/> Leachate Collection/Treatment</div> <div style="width: 33%;"><input type="checkbox"/> Vapor Extraction/Treatment</div> <div style="width: 33%;"><input type="checkbox"/> Air Sparging/Stripper System</div> <div style="width: 33%;"><input checked="" type="checkbox"/> Treatment/Filtration Plant/System</div> <div style="width: 33%;"><input type="checkbox"/> Potable Water Supply/System</div> <div style="width: 33%;"><input type="checkbox"/> Other:</div> </div>			
Institutional Controls: <input checked="" type="checkbox"/> Deed Restriction <input type="checkbox"/> Discharge Permit <input type="checkbox"/> Department of Health Sampling <input type="checkbox"/> Other:			
O&M Review Information: Reports: 2001 Annual Report, dated March 2002 Inspection: Quarterly, last inspection May 2002 Sampling: Semi-annual for groundwater pumping wells, and collection trench Other: Monthly sampling of pre-treatment plant influent/effluent per Town of Tonawanda discharge permit Annual reports prepared and submitted to the Corps of Engineers regarding the wetland mitigation requirements			
Conclusions: Remedy Effective? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No ROD Compliance? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No: Consent Order Compliance? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No: Other:			
Recommendations: Improve LNAPL recovery procedure at S-1 Repair minor erosion caused by burrowing animals Continue animal control to remove unwanted burrowing animals (muskrat, woodchuck etc.) Address iron deposits/scaling problem at RW-1 to improve performance Shot rock erosion noted on north end of barrier island #1. Does not appear to have worsened since 2001. Parsons to monitor area closely			
ROD/Consent Order Modifications? <input type="checkbox"/> Yes (per above) Reclassify the Site? <input checked="" type="checkbox"/> No <input type="checkbox"/> Yes → Class:			
Comments: Parsons Engineering Science performing O&M activity at site. O'Brien & Gere performing semi-annual groundwater sampling O&M activity at this site is tied to the River Road Site #915031			
Project Manager:  May 29, 2002 Date		Reviewer:  May 30, 2002 Date	
Michael J. Hinton Div. of Env. Remediation Region 9 Name Region or Bureau Telephone		Daniel K. King R-9 716/851-7220 Name Region or Bureau Telephone	