

# Scott Figgie LLC

Scott Figgie LLC

c/o GSF Management Company LLC  
34407 DuPont Boulevard, Suite 6  
Frankford, DE 19945

July 15, 2024

Ms. Laura Surdej  
Erie County Department of Environment and Planning  
Division of Sewerage Management  
Erie County Sewer District # 6  
260 Lehigh Avenue  
Lackawanna, New York 14218

**RE: Third Quarter 2024 Discharge Monitoring Report  
Groundwater Remediation Operation  
25A Walter Winter Drive, Lancaster, New York 14086  
NYSDEC Site 9-15-149  
EC/BPDES Permit No. 21-10-E4054**

Dear Ms. Surdej:

AVOX Systems Inc owns the subject property. Scott Figgie LLC (Scott Figgie) is currently responsible for certain environmental activities at that property, including compliance with Erie County/Buffalo Pollution Discharge Elimination System (EC/BPDES) Permit No. 21-10-E4054. Scott Figgie is pleased to provide you with the enclosed Third Quarter 2024 Discharge Monitoring Report for the groundwater remediation operation located on that property. This report is submitted in partial fulfillment of EC/BPDES Permit No. 21-10-E4054, effective October 1, 2021.

GSF Management Company LLC (GSF), an affiliate of Scott Figgie, is managing the remediation of groundwater on the subject property on behalf of Scott Figgie. Scott Figgie/GSF commissioned AECOM Technical Services, Inc. (AECOM), with an office located in Buffalo, New York, to perform the required EC/BPDES quarterly sampling during the month of July 2024 and to prepare the enclosed report with the results.

Figures 1 and 2 in the report depict the entire groundwater collection and treatment system that is covered by the subject permit.

I certify under the penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the systems, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of a fine and imprisonment for known violations.

Scott Figgie or AVOX Systems Inc will continue to monitor the influent and effluent of the active remediation system located at the site on a quarterly basis. The next quarterly discharge monitoring report is due by November 30, 2024; under the new permit not yet received (note the permit application was submitted to your attention on February 26, 2024).



Ms. Laura Surdej  
July 15, 2024  
Page 2

If you have any questions regarding this submittal, please do not hesitate to contact me or Troy Chute at the above address, or to send an email either to me at [stuart.rixman@gsfmanagementco.com](mailto:stuart.rixman@gsfmanagementco.com) or to Mr. Chute at [troy.chute@gsfmanagementco.com](mailto:troy.chute@gsfmanagementco.com).

Very truly yours,  
Scott Figgie LLC




Stuart I. Rixman  
Project Manager, GSF Management Company

\enclosures

cc: Mr. Al Alagna, Buffalo Sewer Authority (electronic copy sent by AECOM)  
Mr. Glenn May, NYSDEC Region 9 (electronic copy sent by AECOM)  
Mr. Troy Chute, GSF Management Company LLC (electronic copy sent by AECOM)  
Mr. Raymond DeCarlo, AVOX Systems Inc (electronic copy sent by AECOM)  
Mr. Allan Thomalla, AVOX Systems Inc (electronic copy sent by AECOM)  
Mr. Joshua Gehan, AVOX Systems Inc (electronic copy)  
Facility File, Lancaster, New York (hard copy sent by AECOM)



*I certify, under penalty of law, that this document and all attachments were prepared under/by direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.*



*On behalf of and as an agent of Scott Figgie LLC  
(aka GSF Management Company LLC)*

July 15, 2024

---

Signature

Date



## TABLE



**Scott Technologies, Inc. - Groundwater Remediation Site  
Lancaster, New York**

EC/BPDES Permit No. 21-10-E4054

**Third Quarter 2024 Discharge Monitoring Report  
Sample Date - July 1, 2024**

Parameter	Units	Total Maximum Daily Load per Permit	Measured or Calculated Daily Load	Within Limits?
pH (Method SM 4500 H+ B)	SU	5 - 12	7.6	Y
Total Extractable Hydrocarbons (Method 1664B)	mg/L	100	< 4.8	Y
Total Suspended Solids (Method SM 2540D)	mg/L	250	< 4.0	Y
<u>VOCs (Method 8260C)</u>				
Methylene Chloride	lbs/day	0.12	0.000018	Y
1,1,1-Trichloroethane	lbs/day	0.09	< 0.000012	Y
Trichloroethylene	lbs/day	0.04	< 0.000012	Y
Total 1,2-DCE (cis-1,2-DCE and trans-1,2-DCE)	lbs/day	0.02	< 0.000012	Y
1,1-Dichloroethane	lbs/day	0.0025	< 0.000012	Y
Chloroethane	lbs/day	0.025	< 0.000012	Y
Toluene	lbs/day	0.04	< 0.000012	Y
Total Daily Flow (discharge meter reading)	gallons per day	14,000	1,384	Y


Notes:

SU standard units  
mg/L milligrams per liter  
ug/L micrograms per liter  
lbs/day pounds per day  
< (value) Indicates calculated concentration less than the reported value, using effluent reporting limit as maximum possible concentration.  
New totalizer installed following the 3Q23 compliance sampling event.



## FIGURES






# AECOM

**FIGURE 1**  
**WEST OF PLANT 2 SITE FEATURES MAP**

FORMER SCOTT AVIATION FACILITY  
 LANCASTER, NEW YORK





**AECOM**

**FIGURE 2**  
**PROCESS AND INSTRUMENTATION DIAGRAM**  
**FOR COMBINED DUAL PHASE EXTRACTION**  
**REMEDICATION SYSTEM**  
 FORMER SCOTT AVIATION FACILITY  
 LANCASTER, NEW YORK



## DAILY FIELD LOG



## DAILY FIELD LOG

**Project** Scott Figgie LLC, West of Plant 2 Groundwater Remediation Site, Lancaster, NY  
**Date** 7/1/2024  
**Weather** sunny  
**Temperature Range** 70-73 degrees F  
**AECOM Personnel on Site** Dino Zack  
**Time on Site** 06:10 hrs - 15:30 hrs

**AS Totalizer Start Sampling (06:30 hrs)** 576,755 gallons  
**AS Totalizer After Sampling (14:30 hrs)** 577,217 gallons

## Summary of Sample Activities

Time = 06:30hrs  
 pH = 8  
 Filled 2, 40-ml vials (preserved with HCl) from influent sample tap. Filled 2, 1-L amber glass bottle (preserved with H<sub>2</sub>SO<sub>4</sub>) 1/4 full, from influent tap. Filled 1, 500-ml plastic bottle (unpreserved) 1/4 full from influent tap. Filled 1 250-ml plastic bottle (unpreserved) 1/4 full from influent tap. Water quality was clear with slight odor (no sheen).  
 Filled 2, 40-ml vials (preserved with HCl) from effluent sample tap. Filled 2, 1-L amber glass bottle (preserved with H<sub>2</sub>SO<sub>4</sub>) 1/4 full from effluent tap. Filled 1, 500-ml plastic bottle (unpreserved) 1/4 full from effluent tap. Filled 1 250-ml plastic bottle (unpreserved) 1/4 full from effluent tap. Water quality is clear with no discernable odor or sheen.

Time = 9:30hrs  
 pH = 8  
 Filled 2, 40-ml vials (preserved with HCl) from influent sample tap. Filled 2, 1-L amber glass bottle (preserved with H<sub>2</sub>SO<sub>4</sub>) 1/4 full, from influent tap. Filled 1, 500-ml plastic bottle (unpreserved) 1/4 full from influent tap. Filled 1 250-ml plastic bottle (unpreserved) 1/4 full from influent tap. Water quality was clear with slight odor (no sheen).  
 Filled 2, 40-ml vials (preserved with HCl) from effluent sample tap. Filled 2, 1-L amber glass bottle (preserved with H<sub>2</sub>SO<sub>4</sub>) 1/4 full from effluent tap. Filled 1, 500-ml plastic bottle (unpreserved) 1/4 full from effluent tap. Filled 1 250-ml plastic bottle (unpreserved) 1/4 full from effluent tap. Water quality is clear with no discernable odor or sheen.

Time = 12:00hrs  
 pH = 8  
 Filled 2, 40-ml vials (preserved with HCl) from influent sample tap. Filled 2, 1-L amber glass bottle (preserved with H<sub>2</sub>SO<sub>4</sub>) 1/4 full, from influent tap. Filled 1, 500-ml plastic bottle (unpreserved) 1/4 full from influent tap. Filled 1 250-ml plastic bottle (unpreserved) 1/4 full from influent tap. Water quality was clear with slight odor (no sheen).  
 Filled 2, 40-ml vials (preserved with HCl) from effluent sample tap. Filled 2, 1-L amber glass bottle (preserved with H<sub>2</sub>SO<sub>4</sub>) 1/4 full from effluent tap. Filled 1, 500-ml plastic bottle (unpreserved) 1/4 full from effluent tap. Filled 1 250-ml plastic bottle (unpreserved) 1/4 full from effluent tap. Water quality is clear with no discernable odor or sheen.


Time = 14:30hrs  
 pH = 8  
 Filled 2, 40-ml vials (preserved with HCl) from influent sample tap. Filled 2, 1-L amber glass bottle (preserved with H<sub>2</sub>SO<sub>4</sub>) 1/4 full, from influent tap. Filled 1, 500-ml plastic bottle (unpreserved) 1/4 full from influent tap. Filled 1 250-ml plastic bottle (unpreserved) 1/4 full from influent tap. Water quality was clear with slight odor (no sheen).  
 Filled 2, 40-ml vials (preserved with HCl) from effluent sample tap. Filled 2, 1-L amber glass bottle (preserved with H<sub>2</sub>SO<sub>4</sub>) 1/4 full from effluent tap. Filled 1, 500-ml plastic bottle (unpreserved) 1/4 full from effluent tap. Filled 1 250-ml plastic bottle (unpreserved) 1/4 full from effluent tap. Water quality is clear with no discernable odor or sheen.

## Comments

DPE and GWCT remedial systems running at time of sample collection. Samples collected at approximately equally spaced intervals over an 8-hour period.

Maintained samples at <4 degrees C. Hand delivered samples to Eurofins Environment Testing Northeast, LLC (Amherst, NY) under COC for analysis. Requested laboratory to composite 40-ml samples and analyze for VOCs (8260C). Requested laboratory to analyze influent and effluent samples for TEH (1664A), TSS (SM 2540D), and pH (SM 4500 H+).

Signature:



Date: 1-Jul-24



## **LABORATORY REPORT**



# ANALYTICAL REPORT

## PREPARED FOR

Attn: Mr. Dino Zack  
AECOM  
50 Lakefront Boulevard  
Suite 111  
Buffalo, New York 14202  
Generated 7/11/2024 12:00:23 PM

## JOB DESCRIPTION

Scott Figgie West of Plant 2

## JOB NUMBER

480-221321-1




# Eurofins Buffalo

## Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Environment Testing Northeast, LLC Project Manager.

## Authorization



Generated  
7/11/2024 12:00:23 PM

Authorized for release by  
Anton Gruning, Project Management Assistant I  
[Anton.Gruning@et.eurofinsus.com](mailto:Anton.Gruning@et.eurofinsus.com)  
Designee for  
Brian Fischer, Manager of Project Management  
[Brian.Fischer@et.eurofinsus.com](mailto:Brian.Fischer@et.eurofinsus.com)  
(716)504-9835





# Table of Contents

Cover Page . . . . .	1
Table of Contents . . . . .	3
Definitions/Glossary . . . . .	4
Case Narrative . . . . .	5
Client Sample Results . . . . .	6
Lab Chronicle . . . . .	12
Certification Summary . . . . .	13
Method Summary . . . . .	14
Sample Summary . . . . .	15
Receipt Checklists . . . . .	16
Chain of Custody . . . . .	17



# Definitions/Glossary

Client: AECOM

Job ID: 480-221321-1

Project/Site: Scott Figgie West of Plant 2

## Qualifiers

### GC/MS VOA

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

### General Chemistry

Qualifier	Qualifier Description
HF	Parameter with a holding time of 15 minutes. Test performed by laboratory at client's request. Sample was analyzed outside of hold time.

## Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
□	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count



# Case Narrative

Client: AECOM  
Project: Scott Figgie West of Plant 2

Job ID: 480-221321-1

**Job ID: 480-221321-1**

**Eurofins Buffalo**

## **Job Narrative 480-221321-1**

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers are applied to indicate exceptions. Noncompliant quality control (QC) is further explained in narrative comments.

- Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

### **Receipt**

The samples were received on 7/2/2024 3:20 PM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 4.9°C.

### **GC/MS VOA**

Method 8260C: The following volatiles samples were diluted due to foaming at the time of purging during the original sample analysis: EFFLUENT (480-221321-1) and INFLUENT (480-221321-2). Elevated reporting limits (RLs) are provided.

Method 8260C: The following Volatile samples were composited by the laboratory on 07/03/2024 as requested by the client: EFFLUENT (480-221321-1) and INFLUENT (480-221321-2). Regulatory defined guidance for in-laboratory compositing of samples, is currently not available. Laboratory sample compositing was performed using established project specifications and/or laboratory standard operating procedures.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### **General Chemistry**

Method 1664B: Analysis for Hexane Extractable Material (HEM) was performed for the following samples: EFFLUENT (480-221321-1) and INFLUENT (480-221321-2). Since the HEM result(s) was below the reporting limit (RL), the result(s) for Silica Gel Treated - Hexane Extractable Material (SGT-HEM) was reported as a non-detect. All HEM quality control criteria were met.

Method SM4500\_H+: This analysis is normally performed in the field and has a method-defined holding time of 15 minutes. The following samples has been qualified with the "HF" flag to indicate analysis was performed in the laboratory outside the 15 minute timeframe: EFFLUENT (480-221321-1) and INFLUENT (480-221321-2).

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Buffalo



# Client Sample Results

Client: AECOM  
Project/Site: Scott Figgie West of Plant 2

Job ID: 480-221321-1

Client Sample ID: EFFLUENT

Lab Sample ID: 480-221321-1

Date Collected: 07/01/24 06:30

Matrix: Water

Date Received: 07/02/24 15:20

## Method: SW846 8260C - Volatile Organic Compounds by GC/MS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1-Trichloroethane	ND		2.0	1.6	ug/L			07/04/24 01:22	2
1,1,2,2-Tetrachloroethane	ND		2.0	0.42	ug/L			07/04/24 01:22	2
1,1,2-Trichloro-1,2,2-trifluoroethane	ND		2.0	0.62	ug/L			07/04/24 01:22	2
1,1,2-Trichloroethane	ND		2.0	0.46	ug/L			07/04/24 01:22	2
1,1-Dichloroethane	ND		2.0	0.76	ug/L			07/04/24 01:22	2
1,1-Dichloroethene	ND		2.0	0.58	ug/L			07/04/24 01:22	2
1,2,4-Trichlorobenzene	ND		2.0	0.82	ug/L			07/04/24 01:22	2
1,2-Dibromo-3-Chloropropane	ND		2.0	0.78	ug/L			07/04/24 01:22	2
1,2-Dibromoethane	ND		2.0	1.5	ug/L			07/04/24 01:22	2
1,2-Dichlorobenzene	ND		2.0	1.6	ug/L			07/04/24 01:22	2
1,2-Dichloroethane	ND		2.0	0.42	ug/L			07/04/24 01:22	2
1,2-Dichloropropane	ND		2.0	1.4	ug/L			07/04/24 01:22	2
1,3-Dichlorobenzene	ND		2.0	1.6	ug/L			07/04/24 01:22	2
1,4-Dichlorobenzene	ND		2.0	1.7	ug/L			07/04/24 01:22	2
2-Butanone (MEK)	ND		20	2.6	ug/L			07/04/24 01:22	2
2-Hexanone	ND		10	2.5	ug/L			07/04/24 01:22	2
4-Methyl-2-pentanone (MIBK)	ND		10	4.2	ug/L			07/04/24 01:22	2
Acetone	ND		20	6.0	ug/L			07/04/24 01:22	2
Benzene	ND		2.0	0.82	ug/L			07/04/24 01:22	2
Bromodichloromethane	ND		2.0	0.78	ug/L			07/04/24 01:22	2
Bromoform	ND		2.0	0.52	ug/L			07/04/24 01:22	2
Bromomethane	ND		2.0	1.4	ug/L			07/04/24 01:22	2
Carbon disulfide	ND		2.0	0.38	ug/L			07/04/24 01:22	2
Carbon tetrachloride	ND		2.0	0.54	ug/L			07/04/24 01:22	2
Chlorobenzene	ND		2.0	1.5	ug/L			07/04/24 01:22	2
Chloroethane	ND		2.0	0.64	ug/L			07/04/24 01:22	2
Chloroform	ND		2.0	0.68	ug/L			07/04/24 01:22	2
Chloromethane	ND		2.0	0.70	ug/L			07/04/24 01:22	2
cis-1,2-Dichloroethene	ND		2.0	1.6	ug/L			07/04/24 01:22	2
cis-1,3-Dichloropropene	ND		2.0	0.72	ug/L			07/04/24 01:22	2
Cyclohexane	ND		2.0	0.36	ug/L			07/04/24 01:22	2
Dibromochloromethane	ND		2.0	0.64	ug/L			07/04/24 01:22	2
Dichlorodifluoromethane	ND		2.0	1.4	ug/L			07/04/24 01:22	2
Ethylbenzene	ND		2.0	1.5	ug/L			07/04/24 01:22	2
Isopropylbenzene	ND		2.0	1.6	ug/L			07/04/24 01:22	2
Methyl acetate	ND		5.0	2.6	ug/L			07/04/24 01:22	2
Methyl tert-butyl ether	ND		2.0	0.32	ug/L			07/04/24 01:22	2
Methylcyclohexane	ND		2.0	0.32	ug/L			07/04/24 01:22	2
Methylene Chloride	1.6	J	2.0	0.88	ug/L			07/04/24 01:22	2
Styrene	ND		2.0	1.5	ug/L			07/04/24 01:22	2
Tetrachloroethene	ND		2.0	0.72	ug/L			07/04/24 01:22	2
Toluene	ND		2.0	1.0	ug/L			07/04/24 01:22	2
trans-1,2-Dichloroethene	ND		2.0	1.8	ug/L			07/04/24 01:22	2
trans-1,3-Dichloropropene	ND		2.0	0.74	ug/L			07/04/24 01:22	2
Trichloroethene	ND		2.0	0.92	ug/L			07/04/24 01:22	2
Trichlorofluoromethane	ND		2.0	1.8	ug/L			07/04/24 01:22	2
Vinyl chloride	ND		2.0	1.8	ug/L			07/04/24 01:22	2
Xylenes, Total	ND		4.0	1.3	ug/L			07/04/24 01:22	2

Eurofins Buffalo



# Client Sample Results

Client: AECOM  
Project/Site: Scott Figgie West of Plant 2

Job ID: 480-221321-1

**Client Sample ID: EFFLUENT**

**Lab Sample ID: 480-221321-1**

Date Collected: 07/01/24 06:30

Matrix: Water

Date Received: 07/02/24 15:20

## Method: SW846 8260C - Volatile Organic Compounds by GC/MS (Continued)

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	105		77 - 120		07/04/24 01:22	2
4-Bromofluorobenzene (Surr)	103		73 - 120		07/04/24 01:22	2
Toluene-d8 (Surr)	96		80 - 120		07/04/24 01:22	2
Dibromofluoromethane (Surr)	109		75 - 123		07/04/24 01:22	2

## General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Petroleum Hydrocarbons (1664A) (1664B)	ND		4.8	1.8	mg/L		07/05/24 08:12	07/05/24 09:46	1

## General Chemistry

Analyte	Result	Qualifier	RL	RL	Unit	D	Prepared	Analyzed	Dil Fac
Total Suspended Solids (SM 2540D)	ND		4.0	4.0	mg/L			07/05/24 11:25	1
pH (SM 4500 H+ B)	7.6	HF	0.1	0.1	SU			07/05/24 14:39	1
Temperature (SM 4500 H+ B)	19.4	HF	0.001	0.001	Degrees C			07/05/24 14:39	1



# Client Sample Results

Client: AECOM  
Project/Site: Scott Figgie West of Plant 2

Job ID: 480-221321-1

Client Sample ID: INFLUENT

Lab Sample ID: 480-221321-2

Date Collected: 07/01/24 06:30

Matrix: Water

Date Received: 07/02/24 15:20

## Method: SW846 8260C - Volatile Organic Compounds by GC/MS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1-Trichloroethane	ND		4.0	3.3	ug/L			07/04/24 01:45	4
1,1,2,2-Tetrachloroethane	ND		4.0	0.84	ug/L			07/04/24 01:45	4
1,1,2-Trichloro-1,2,2-trifluoroethane	ND		4.0	1.2	ug/L			07/04/24 01:45	4
1,1,2-Trichloroethane	ND		4.0	0.92	ug/L			07/04/24 01:45	4
1,1-Dichloroethane	ND		4.0	1.5	ug/L			07/04/24 01:45	4
1,1-Dichloroethene	ND		4.0	1.2	ug/L			07/04/24 01:45	4
1,2,4-Trichlorobenzene	ND		4.0	1.6	ug/L			07/04/24 01:45	4
1,2-Dibromo-3-Chloropropane	ND		4.0	1.6	ug/L			07/04/24 01:45	4
1,2-Dibromoethane	ND		4.0	2.9	ug/L			07/04/24 01:45	4
1,2-Dichlorobenzene	ND		4.0	3.2	ug/L			07/04/24 01:45	4
1,2-Dichloroethane	ND		4.0	0.84	ug/L			07/04/24 01:45	4
1,2-Dichloropropane	ND		4.0	2.9	ug/L			07/04/24 01:45	4
1,3-Dichlorobenzene	ND		4.0	3.1	ug/L			07/04/24 01:45	4
1,4-Dichlorobenzene	ND		4.0	3.4	ug/L			07/04/24 01:45	4
2-Butanone (MEK)	ND		40	5.3	ug/L			07/04/24 01:45	4
2-Hexanone	ND		20	5.0	ug/L			07/04/24 01:45	4
4-Methyl-2-pentanone (MIBK)	ND		20	8.4	ug/L			07/04/24 01:45	4
Acetone	ND		40	12	ug/L			07/04/24 01:45	4
Benzene	ND		4.0	1.6	ug/L			07/04/24 01:45	4
Bromodichloromethane	ND		4.0	1.6	ug/L			07/04/24 01:45	4
Bromoform	ND		4.0	1.0	ug/L			07/04/24 01:45	4
Bromomethane	ND		4.0	2.8	ug/L			07/04/24 01:45	4
Carbon disulfide	ND		4.0	0.76	ug/L			07/04/24 01:45	4
Carbon tetrachloride	ND		4.0	1.1	ug/L			07/04/24 01:45	4
Chlorobenzene	ND		4.0	3.0	ug/L			07/04/24 01:45	4
Chloroethane	5.9		4.0	1.3	ug/L			07/04/24 01:45	4
Chloroform	ND		4.0	1.4	ug/L			07/04/24 01:45	4
Chloromethane	ND		4.0	1.4	ug/L			07/04/24 01:45	4
cis-1,2-Dichloroethene	13		4.0	3.2	ug/L			07/04/24 01:45	4
cis-1,3-Dichloropropene	ND		4.0	1.4	ug/L			07/04/24 01:45	4
Cyclohexane	ND		4.0	0.72	ug/L			07/04/24 01:45	4
Dibromochloromethane	ND		4.0	1.3	ug/L			07/04/24 01:45	4
Dichlorodifluoromethane	ND		4.0	2.7	ug/L			07/04/24 01:45	4
Ethylbenzene	ND		4.0	3.0	ug/L			07/04/24 01:45	4
Isopropylbenzene	ND		4.0	3.2	ug/L			07/04/24 01:45	4
Methyl acetate	ND		10	5.2	ug/L			07/04/24 01:45	4
Methyl tert-butyl ether	ND		4.0	0.64	ug/L			07/04/24 01:45	4
Methylcyclohexane	ND		4.0	0.64	ug/L			07/04/24 01:45	4
Methylene Chloride	3.1 J		4.0	1.8	ug/L			07/04/24 01:45	4
Styrene	ND		4.0	2.9	ug/L			07/04/24 01:45	4
Tetrachloroethene	ND		4.0	1.4	ug/L			07/04/24 01:45	4
Toluene	ND		4.0	2.0	ug/L			07/04/24 01:45	4
trans-1,2-Dichloroethene	ND		4.0	3.6	ug/L			07/04/24 01:45	4
trans-1,3-Dichloropropene	ND		4.0	1.5	ug/L			07/04/24 01:45	4
Trichloroethene	ND		4.0	1.8	ug/L			07/04/24 01:45	4
Trichlorofluoromethane	ND		4.0	3.5	ug/L			07/04/24 01:45	4
Vinyl chloride	ND		4.0	3.6	ug/L			07/04/24 01:45	4
Xylenes, Total	ND		8.0	2.6	ug/L			07/04/24 01:45	4

Eurofins Buffalo



# Client Sample Results

Client: AECOM  
Project/Site: Scott Figgie West of Plant 2

Job ID: 480-221321-1

**Client Sample ID: INFLUENT**

**Lab Sample ID: 480-221321-2**

Date Collected: 07/01/24 06:30

Matrix: Water

Date Received: 07/02/24 15:20

## Method: SW846 8260C - Volatile Organic Compounds by GC/MS (Continued)

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	104		77 - 120		07/04/24 01:45	4
4-Bromofluorobenzene (Surr)	103		73 - 120		07/04/24 01:45	4
Toluene-d8 (Surr)	96		80 - 120		07/04/24 01:45	4
Dibromofluoromethane (Surr)	110		75 - 123		07/04/24 01:45	4

## General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Petroleum Hydrocarbons (1664A) (1664B)	ND		4.8	1.9	mg/L		07/05/24 08:12	07/05/24 09:46	1

## General Chemistry

Analyte	Result	Qualifier	RL	RL	Unit	D	Prepared	Analyzed	Dil Fac
Total Suspended Solids (SM 2540D)	ND		4.0	4.0	mg/L			07/05/24 11:25	1
pH (SM 4500 H+ B)	7.2	HF	0.1	0.1	SU			07/05/24 14:45	1
Temperature (SM 4500 H+ B)	19.3	HF	0.001	0.001	Degrees C			07/05/24 14:45	1



# Client Sample Results

Client: AECOM  
Project/Site: Scott Figgie West of Plant 2

Job ID: 480-221321-1

Client Sample ID: Trip Blank

Lab Sample ID: 480-221321-3

Date Collected: 07/01/24 06:30

Matrix: Water

Date Received: 07/02/24 15:20

## Method: SW846 8260C - Volatile Organic Compounds by GC/MS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1-Trichloroethane	ND		1.0	0.82	ug/L			07/04/24 02:07	1
1,1,2,2-Tetrachloroethane	ND		1.0	0.21	ug/L			07/04/24 02:07	1
1,1,2-Trichloro-1,2,2-trifluoroethane	ND		1.0	0.31	ug/L			07/04/24 02:07	1
1,1,2-Trichloroethane	ND		1.0	0.23	ug/L			07/04/24 02:07	1
1,1-Dichloroethane	ND		1.0	0.38	ug/L			07/04/24 02:07	1
1,1-Dichloroethene	ND		1.0	0.29	ug/L			07/04/24 02:07	1
1,2,4-Trichlorobenzene	ND		1.0	0.41	ug/L			07/04/24 02:07	1
1,2-Dibromo-3-Chloropropane	ND		1.0	0.39	ug/L			07/04/24 02:07	1
1,2-Dibromoethane	ND		1.0	0.73	ug/L			07/04/24 02:07	1
1,2-Dichlorobenzene	ND		1.0	0.79	ug/L			07/04/24 02:07	1
1,2-Dichloroethane	ND		1.0	0.21	ug/L			07/04/24 02:07	1
1,2-Dichloropropane	ND		1.0	0.72	ug/L			07/04/24 02:07	1
1,3-Dichlorobenzene	ND		1.0	0.78	ug/L			07/04/24 02:07	1
1,4-Dichlorobenzene	ND		1.0	0.84	ug/L			07/04/24 02:07	1
2-Butanone (MEK)	ND		10	1.3	ug/L			07/04/24 02:07	1
2-Hexanone	ND		5.0	1.2	ug/L			07/04/24 02:07	1
4-Methyl-2-pentanone (MIBK)	ND		5.0	2.1	ug/L			07/04/24 02:07	1
Acetone	ND		10	3.0	ug/L			07/04/24 02:07	1
Benzene	ND		1.0	0.41	ug/L			07/04/24 02:07	1
Bromodichloromethane	ND		1.0	0.39	ug/L			07/04/24 02:07	1
Bromoform	ND		1.0	0.26	ug/L			07/04/24 02:07	1
Bromomethane	ND		1.0	0.69	ug/L			07/04/24 02:07	1
Carbon disulfide	ND		1.0	0.19	ug/L			07/04/24 02:07	1
Carbon tetrachloride	ND		1.0	0.27	ug/L			07/04/24 02:07	1
Chlorobenzene	ND		1.0	0.75	ug/L			07/04/24 02:07	1
Chloroethane	ND		1.0	0.32	ug/L			07/04/24 02:07	1
Chloroform	ND		1.0	0.34	ug/L			07/04/24 02:07	1
Chloromethane	ND		1.0	0.35	ug/L			07/04/24 02:07	1
cis-1,2-Dichloroethene	ND		1.0	0.81	ug/L			07/04/24 02:07	1
cis-1,3-Dichloropropene	ND		1.0	0.36	ug/L			07/04/24 02:07	1
Cyclohexane	ND		1.0	0.18	ug/L			07/04/24 02:07	1
Dibromochloromethane	ND		1.0	0.32	ug/L			07/04/24 02:07	1
Dichlorodifluoromethane	ND		1.0	0.68	ug/L			07/04/24 02:07	1
Ethylbenzene	ND		1.0	0.74	ug/L			07/04/24 02:07	1
Isopropylbenzene	ND		1.0	0.79	ug/L			07/04/24 02:07	1
Methyl acetate	ND		2.5	1.3	ug/L			07/04/24 02:07	1
Methyl tert-butyl ether	ND		1.0	0.16	ug/L			07/04/24 02:07	1
Methylcyclohexane	ND		1.0	0.16	ug/L			07/04/24 02:07	1
Methylene Chloride	ND		1.0	0.44	ug/L			07/04/24 02:07	1
Styrene	ND		1.0	0.73	ug/L			07/04/24 02:07	1
Tetrachloroethene	ND		1.0	0.36	ug/L			07/04/24 02:07	1
Toluene	ND		1.0	0.51	ug/L			07/04/24 02:07	1
trans-1,2-Dichloroethene	ND		1.0	0.90	ug/L			07/04/24 02:07	1
trans-1,3-Dichloropropene	ND		1.0	0.37	ug/L			07/04/24 02:07	1
Trichloroethene	ND		1.0	0.46	ug/L			07/04/24 02:07	1
Trichlorofluoromethane	ND		1.0	0.88	ug/L			07/04/24 02:07	1
Vinyl chloride	ND		1.0	0.90	ug/L			07/04/24 02:07	1
Xylenes, Total	ND		2.0	0.66	ug/L			07/04/24 02:07	1

Eurofins Buffalo



# Client Sample Results

Client: AECOM  
Project/Site: Scott Figgie West of Plant 2

Job ID: 480-221321-1

**Client Sample ID: Trip Blank**  
**Date Collected: 07/01/24 06:30**  
**Date Received: 07/02/24 15:20**

**Lab Sample ID: 480-221321-3**  
**Matrix: Water**

**Method: SW846 8260C - Volatile Organic Compounds by GC/MS (Continued)**

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	106		77 - 120		07/04/24 02:07	1
4-Bromofluorobenzene (Surr)	102		73 - 120		07/04/24 02:07	1
Toluene-d8 (Surr)	96		80 - 120		07/04/24 02:07	1
Dibromofluoromethane (Surr)	111		75 - 123		07/04/24 02:07	1



# Lab Chronicle

Client: AECOM  
Project/Site: Scott Figgie West of Plant 2

Job ID: 480-221321-1

## Client Sample ID: EFFLUENT

## Lab Sample ID: 480-221321-1

Date Collected: 07/01/24 06:30

Matrix: Water

Date Received: 07/02/24 15:20

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8260C		2	717526	ERS	EET BUF	07/04/24 01:22
Total/NA	Prep	1664B			717461	KM	EET BUF	07/05/24 08:12
Total/NA	Analysis	1664B		1	717608	KM	EET BUF	07/05/24 09:46
Total/NA	Analysis	SM 2540D		1	717630	AB	EET BUF	07/05/24 11:25
Total/NA	Analysis	SM 4500 H+ B		1	717688	KB	EET BUF	07/05/24 14:39

## Client Sample ID: INFLUENT

## Lab Sample ID: 480-221321-2

Date Collected: 07/01/24 06:30

Matrix: Water

Date Received: 07/02/24 15:20

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8260C		4	717526	ERS	EET BUF	07/04/24 01:45
Total/NA	Prep	1664B			717461	KM	EET BUF	07/05/24 08:12
Total/NA	Analysis	1664B		1	717608	KM	EET BUF	07/05/24 09:46
Total/NA	Analysis	SM 2540D		1	717630	AB	EET BUF	07/05/24 11:25
Total/NA	Analysis	SM 4500 H+ B		1	717688	KB	EET BUF	07/05/24 14:45

## Client Sample ID: Trip Blank

## Lab Sample ID: 480-221321-3

Date Collected: 07/01/24 06:30

Matrix: Water

Date Received: 07/02/24 15:20

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8260C		1	717526	ERS	EET BUF	07/04/24 02:07

### Laboratory References:

EET BUF = Eurofins Buffalo, 10 Hazelwood Drive, Amherst, NY 14228-2298, TEL (716)691-2600



Accreditation/Certification Summary

Client: AECOM  
Project/Site: Scott Figgie West of Plant 2

Job ID: 480-221321-1

Laboratory: Eurofins Buffalo

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
New York	NELAP	10026	03-31-25

The following analytes are included in this report, but the laboratory is not certified by the governing authority. This list may include analytes for which the agency does not offer certification.

Analysis Method	Prep Method	Matrix	Analyte
SM 4500 H+ B		Water	pH
SM 4500 H+ B		Water	Temperature



# Method Summary

Client: AECOM

Job ID: 480-221321-1

Project/Site: Scott Figgie West of Plant 2

Method	Method Description	Protocol	Laboratory
8260C	Volatile Organic Compounds by GC/MS	SW846	EET BUF
1664B	HEM and SGT-HEM	1664B	EET BUF
SM 2540D	Solids, Total Suspended (TSS)	SM	EET BUF
SM 4500 H+ B	pH	SM	EET BUF
1664B	HEM and SGT-HEM (Aqueous)	1664B	EET BUF
5030C	Purge and Trap	SW846	EET BUF

## Protocol References:

1664B = EPA-821-98-002

SM = "Standard Methods For The Examination Of Water And Wastewater"

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

## Laboratory References:

EET BUF = Eurofins Buffalo, 10 Hazelwood Drive, Amherst, NY 14228-2298, TEL (716)691-2600



# Sample Summary

Client: AECOM  
Project/Site: Scott Figgie West of Plant 2

Job ID: 480-221321-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
480-221321-1	EFFLUENT	Water	07/01/24 06:30	07/02/24 15:20
480-221321-2	INFLUENT	Water	07/01/24 06:30	07/02/24 15:20
480-221321-3	Trip Blank	Water	07/01/24 06:30	07/02/24 15:20





## Login Sample Receipt Checklist

Client: AECOM

Job Number: 480-221321-1

**Login Number: 221321**

**List Number: 1**

**Creator: Stapleton, Kaitlyn**

**List Source: Eurofins Buffalo**

Question	Answer	Comment
Radioactivity either was not measured or, if measured, is at or below background	True	
The cooler's custody seal, if present, is intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	4.9 #1 ice
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time (Excluding tests with immediate HTs)..	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	True	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Sampling Company provided.	True	AECOM
Samples received within 48 hours of sampling.	True	
Samples requiring field filtration have been filtered in the field.	True	
Chlorine Residual checked.	N/A	



Ver: 04/02/2024