



July 29, 2008

Gloria M. Sosa  
Environmental Protection Agency  
Emergency and Remedial Response  
290 Broadway - 20th Floor  
NY, NY 10007-1866

Mr. Will Welling  
New York State DEC  
Remedial Bureau D, 12<sup>th</sup> Floor  
625 Broadway  
Albany, NY 12233-7013

Re: **Quarterly Operations Report – 2nd Quarter 2008**  
Hyde Park Remedial Program  
Bedrock and Overburden Monitoring Programs

Dear Ms. Sosa and Mr. Welling:

In accordance with the July 2006 "Performance Monitoring Plan", the following is the quarterly data report for the Hyde Park Remedial Program for the period April 1, 2008 to June 30, 2008. A total of 10.9 million gallons of APL were collected, treated, and discharged in compliance with our City of Niagara Falls POTW permit; no NAPL was shipped for incineration. The potentiometric contours are consistent with previous interpretations. Flow zones 6, 7, and 9 have large dewatered areas between the landfill and the gorge face. The current data continue to support the interpretation of effective hydraulic containment.


Inconsistencies with the APW levels have been caused by radio problems. These radios are scheduled to be replaced in the next quarter.

The performance monitoring data are presented as follows:

1. Figures 1-9 showing groundwater contours for the flow zones and overburden.
2. Figure 10 – Showing continuously recorded water levels at flow zone piezometer PMW-1M-09.
3. Table 1 – Water Level Elevation Summary
4. Tables 2, 3, and 4 – Daily, Weekly, and Quarterly Treatment System Effluent Monitoring Data.
5. Attachment 1 – Purge well performance graphs indicating daily level and flow information.

An electronic copy of this report is included on the attached CD as an Adobe® Acrobat® file. If you have any questions, please feel free to contact me at 859-543-2174 or by email at [clint\\_babcock@oxy.com](mailto:clint_babcock@oxy.com).

Sincerely,



Clinton J. Babcock

**Project Manager**  
Glenn Springs Holdings, Inc.  
972-687-7506 Office  
859-421-4233 Cell

## FIGURES






figure 1  
FZ-01 POTENTIOMETRIC SURFACE MAY 2008  
2ND QUARTER REPORT  
HYDE PARK LANDFILL SITE  
Town of Niagara, NY













figure 4  
FZ-05 POTENTIOMETRIC SURFACE MAY 2008  
2ND QUARTER REPORT  
HYDE PARK LANDFILL SITE  
Town of Niagara, NY




















figure 10

## **TABLES**



**TABLE 1**  
**WATER LEVEL ELEVATION SUMMARY**  
**SECOND QUARTER - 2008**  
**HYDE PARK RRT PROGRAM**

| Well                   | Reference Elevation<br>(ft AMSL) | Depth to Water<br>(ft) | Water Level Elevation<br>(ft AMSL) |
|------------------------|----------------------------------|------------------------|------------------------------------|
| <b>Overburden</b>      |                                  |                        |                                    |
| CMW-2OB                | 590.05                           | 6.55                   | 583.50                             |
| CMW-3OB                | 582.79                           | 6.70                   | 576.09                             |
| CMW-4OB                | 574.85                           | 0.90                   | 573.95                             |
| CMW-5OB                | 584.13                           | 2.04                   | 582.09                             |
| CMW-6OB                | 572.55                           | 2.44                   | 570.11                             |
| CMW-7OB                | 611.38                           | 4.00                   | 607.38                             |
| CMW-8OB                | 616.78                           | 3.05                   | 613.73                             |
| CMW-9OB                | 572.41                           | 2.36                   | 570.05                             |
| CMW-10B                | 576.12                           | 5.30                   | 570.82                             |
| CMW-11OB               | 573.51                           | 3.80                   | 569.71                             |
| CMW-12OB               | 595.26                           | 18.00                  | 577.26                             |
| OMW-1                  | 605.87                           | 5.50                   | 600.37                             |
| OMW-2                  | 606.39                           | 2.60                   | 603.79                             |
| OMW-3                  | 599.27                           | 9.00                   | 590.27                             |
| OMW-4R                 | 601.83                           | 10.90                  | 590.93                             |
| OMW-5R                 | 588.25                           | 5.80                   | 582.45                             |
| OMW-6                  | 588.27                           | 2.30                   | 585.97                             |
| OMW-7                  | 593.39                           | 8.60                   | 584.79                             |
| OMW-8R                 | 598.16                           | 9.80                   | 588.36                             |
| OMW-8R2                | 595.31                           | 9.20                   | 586.11                             |
| OMW-9                  | 595.97                           | 8.30                   | 587.67                             |
| OMW-10                 | 595.51                           | 9.00                   | 586.51                             |
| OMW-10R                | 595.79                           | 8.40                   | 587.39                             |
| OMW-11R                | 598.07                           | 7.10                   | 590.97                             |
| OMW-12R                | 596.95                           | 5.00                   | 591.95                             |
| OMW-13R                | 602.04                           | 9.90                   | 592.14                             |
| OMW-14R                | 599.42                           | 2.60                   | 596.82                             |
| OMW-15                 | 608.04                           | 8.90                   | 599.14                             |
| OMW-16R                | 608.23                           | 7.00                   | 601.23                             |
| SC-2                   | 626.50                           | -                      | 595.50                             |
| SC-3                   | 638.48                           | -                      | 598.10                             |
| SC-4                   | 639.67                           | -                      | 599.80                             |
| SC-5                   | 635.05                           | -                      | 605.70                             |
| SC-6                   | 629.78                           | -                      | 578.20                             |
| <b>Shallow Bedrock</b> |                                  |                        |                                    |
| CMW-1SH                | 576.68                           | 11.90                  | 564.78                             |
| CMW-2SH                | 589.73                           | 27.13                  | 562.60                             |
| CMW-3SH                | 582.74                           | 27.97                  | 554.77                             |
| CMW-4SH                | 574.97                           | 7.70                   | 567.27                             |
| CMW-5SH                | 584.13                           | 6.46                   | 577.67                             |
| CMW-6SH                | 572.68                           | 10.01                  | 562.67                             |
| CMW-7SH                | 611.16                           | 9.22                   | 601.94                             |
| CMW-8SH                | 617.01                           | 5.70                   | 611.31                             |
| CMW-9SH                | 572.59                           | 11.97                  | 560.62                             |
| CMW-11SH               | 573.86                           | 8.27                   | 565.59                             |
| CMW-12SH               | 597.65                           | 27.10                  | 570.55                             |
| <b>Flow Zone 1</b>     |                                  |                        |                                    |
| G1U-01                 | 617.08                           | 12.65                  | 604.43                             |
| G6-01                  | 608.11                           | 5.75                   | 602.36                             |
| H2U-01                 | 620.92                           | 8.52                   | 612.40                             |
| H5-01                  | 617.61                           | 17.50                  | 600.11                             |
| I1-01                  | 621.55                           | 24.42                  | 597.13                             |
| I1-01                  | 621.55                           | 24.42                  | 597.13                             |

**TABLE 1**  
**WATER LEVEL ELEVATION SUMMARY**  
**SECOND QUARTER - 2008**  
**HYDE PARK RRT PROGRAM**

| Well               | Reference Elevation<br>(ft AMSL) | Depth to Water<br>(ft) | Water Level Elevation<br>(ft AMSL) |
|--------------------|----------------------------------|------------------------|------------------------------------|
| <b>Flow Zone 2</b> |                                  |                        |                                    |
| F2U-02             | 599.89                           | 24.25                  | 575.64                             |
| F4U-02             | 602.32                           | 16.00                  | 586.32                             |
| G1-02              | 616.86                           | 23.43                  | 593.43                             |
| G6-02              | 608.11                           | 16.50                  | 591.61                             |
| H2U-02             | 620.88                           | 27.50                  | 593.38                             |
| H5-02              | 617.47                           | 23.22                  | 594.25                             |
| I1-02              | 621.42                           | 32.70                  | 588.72                             |
| J2U-02             | 609.66                           | 13.40                  | 596.26                             |
| J5U-02             | 606.21                           | 8.63                   | 597.58                             |
| J6-02              | 609.23                           | 12.71                  | 596.52                             |
| <b>Flow Zone 4</b> |                                  |                        |                                    |
| AFW-2U-04          | 593.48                           | 16.50                  | 576.98                             |
| D1U-04             | 593.77                           | 12.90                  | 580.87                             |
| D2U-04             | 590.65                           | 9.80                   | 580.85                             |
| E6-04              | 578.23                           | 12.68                  | 565.55                             |
| F2U-04             | 599.76                           | 21.30                  | 578.46                             |
| F4U-04             | 602.19                           | 15.12                  | 587.07                             |
| F6-04              | 588.06                           | 18.50                  | 569.56                             |
| G1U-04             | 616.96                           | 23.18                  | 593.78                             |
| G6-04              | 608.11                           | 16.62                  | 591.49                             |
| H5-04              | 617.40                           | 24.26                  | 593.14                             |
| I1-04              | 621.31                           | 38.49                  | 582.82                             |
| J2U-04             | 609.42                           | 17.21                  | 592.21                             |
| J5U-04             | 606.05                           | 18.92                  | 587.13                             |
| J6-04              | 609.12                           | 28.14                  | 580.98                             |
| <b>Flow Zone 5</b> |                                  |                        |                                    |
| AFW-2U-05          | 593.33                           | 16.53                  | 576.80                             |
| AGW-1U-05          | 591.80                           | 6.88                   | 584.92                             |
| D1U-05             | 593.51                           | 15.00                  | 578.51                             |
| D2U-05             | 590.56                           | 10.52                  | 580.04                             |
| E6-05              | 578.04                           | 10.98                  | 567.06                             |
| F2U-05             | 599.64                           | 20.80                  | 578.84                             |
| F4U-05             | 602.06                           | 16.33                  | 585.73                             |
| F6-05              | 587.85                           | 18.36                  | 569.49                             |
| G6-05              | 608.11                           | 17.26                  | 590.85                             |
| H2M-05             | 621.59                           | 27.30                  | 594.29                             |
| H5-05              | 617.31                           | 24.47                  | 592.84                             |
| I1-05              | 621.21                           | 63.67                  | 557.54                             |
| J2U-05             | 609.30                           | 30.64                  | 578.66                             |
| J5U-05             | 605.87                           | 27.08                  | 578.79                             |
| J6-05              | 609.02                           | 28.76                  | 580.26                             |
| PMW-1U-05          | 598.00                           | 19.93                  | 578.07                             |

**TABLE 1**  
**WATER LEVEL ELEVATION SUMMARY**  
**SECOND QUARTER - 2008**  
**HYDE PARK RRT PROGRAM**

| Well               | Reference Elevation<br>(ft AMSL) | Depth to Water<br>(ft) | Water Level Elevation<br>(ft AMSL) |
|--------------------|----------------------------------|------------------------|------------------------------------|
| <b>Flow Zone 6</b> |                                  |                        |                                    |
| ABP-7-06           | 575.78                           | -                      | -                                  |
| AFW-1U-06          | 571.83                           | 15.00                  | 556.83                             |
| AFW-2U-06          | 593.22                           | -                      | -                                  |
| AGW-1U-06          | 591.66                           | 38.22                  | 553.44                             |
| B2U-06             | 589.29                           | 35.22                  | 554.07                             |
| C3-06              | 585.78                           | -                      | -                                  |
| D1U-06             | 593.25                           | -                      | -                                  |
| D2U-06             | 590.38                           | 46.75                  | 543.63                             |
| E6-06              | 577.99                           | 6.68                   | 571.31                             |
| F2M-06             | 599.06                           | 32.90                  | 566.16                             |
| F4M-06             | 602.05                           | 50.95                  | 551.10                             |
| F6-06              | 587.84                           | 16.54                  | 571.30                             |
| G1M-06             | 616.75                           | 45.33                  | 571.42                             |
| G6-06              | 608.11                           | 37.38                  | 570.73                             |
| H2M-06             | 621.42                           | 57.30                  | 564.12                             |
| H5-06              | 617.17                           | 27.10                  | 590.07                             |
| I1-06              | 621.08                           | 68.15                  | 552.93                             |
| J2M-06             | 608.94                           | 55.78                  | 553.16                             |
| J5M-06             | 606.22                           | 62.60                  | 543.62                             |
| J6-06              | 608.93                           | 53.91                  | 555.02                             |
| PMW-1U-06          | 597.92                           | 52.74                  | 545.18                             |
| <b>Flow Zone 7</b> |                                  |                        |                                    |
| ABP-1-07           | *                                | *                      | *                                  |
| ABP-7-07           | 575.67                           | 40.50                  | 535.17                             |
| AFW-1M-07          | 571.41                           | -                      | -                                  |
| AFW-2M-07          | 593.44                           | 66.15                  | 527.29                             |
| AGW-1M-07          | 592.91                           | 38.60                  | 554.31                             |
| B2M-07             | 589.52                           | 45.39                  | 544.13                             |
| C3-07              | 585.62                           | 48.00                  | 537.62                             |
| D1M-07             | 594.15                           | 62.80                  | 531.35                             |
| D2M-07             | 590.77                           | -                      | -                                  |
| E6-07              | 577.91                           | 22.94                  | 554.97                             |
| F2M-07             | 598.91                           | 80.15                  | 518.76                             |
| F4M-07             | 601.91                           | 75.83                  | 526.08                             |
| F6-07              | 587.63                           | 20.55                  | 567.13                             |
| G1M-07             | 616.68                           | 69.85                  | 546.83                             |
| G6-07              | 608.11                           | 61.81                  | 546.30                             |
| H5-07              | 617.05                           | 60.98                  | 556.07                             |
| I1-07              | 620.97                           | 68.88                  | 552.09                             |
| J5M-07             | 606.07                           | 53.28                  | 552.79                             |
| J6-07              | 608.85                           | 50.69                  | 558.16                             |
| PMW-1M-07          | 598.50                           | 66.47                  | 532.03                             |

**TABLE 1**  
**WATER LEVEL ELEVATION SUMMARY**  
**SECOND QUARTER - 2008**  
**HYDE PARK RRT PROGRAM**

| Well                | Reference Elevation<br>(ft AMSL) | Depth to Water<br>(ft) | Water Level Elevation<br>(ft AMSL) |
|---------------------|----------------------------------|------------------------|------------------------------------|
| <b>Flow Zone 9</b>  |                                  |                        |                                    |
| ABP-1-09            | *                                | *                      | *                                  |
| ABP-7-09            | 575.67                           | 40.72                  | 534.95                             |
| AFW-1M-09           | 571.12                           | 38.81                  | 532.31                             |
| AFW-2M-09           | 593.32                           | 76.10                  | 517.22                             |
| AGW-1M-09           | 592.75                           | 38.75                  | 554.00                             |
| B2M-09              | 589.34                           | 68.19                  | 521.15                             |
| C3-09               | 585.54                           | 49.55                  | 535.99                             |
| D1M-09              | 594.02                           | 74.50                  | 519.52                             |
| D2M-09              | 590.66                           | 72.30                  | 518.36                             |
| E6-09               | 577.82                           | 22.81                  | 555.01                             |
| F2M-09              | 598.71                           | 80.26                  | 518.45                             |
| F4M-09              | 601.79                           | 83.90                  | 517.89                             |
| F6-09               | 587.53                           | 3.05                   | 584.48                             |
| G1M-09              | 616.58                           | 67.02                  | 549.56                             |
| G6-09               | 608.11                           | 61.80                  | 546.31                             |
| H2M-09              | 621.32                           | 67.83                  | 553.49                             |
| H5-09               | 616.93                           | 65.95                  | 550.98                             |
| I1-09               | 620.86                           | 56.41                  | 564.45                             |
| J2M-09              | 608.77                           | 57.07                  | 551.70                             |
| J5M-09              | 605.82                           | 52.85                  | 552.97                             |
| J6-09               | 608.76                           | 31.25                  | 577.51                             |
| PMW-1M-09           | 598.34                           | 80.06                  | 518.28                             |
| <b>Flow Zone 11</b> |                                  |                        |                                    |
| AFW-1L-11           | 572.10                           | 55.91                  | 516.19                             |
| AFW-2L-11           | 593.43                           | 99.00                  | 494.43                             |
| AGW-1L-11           | 592.71                           | 24.11                  | 568.60                             |
| B2L-11              | 589.65                           | 92.11                  | 497.54                             |
| D1L-11              | 593.80                           | 86.60                  | 507.20                             |
| D2L-11              | 590.21                           | 70.70                  | 519.51                             |
| E6-11               | 577.72                           | 52.03                  | 525.69                             |
| F2L-11              | 598.94                           | 46.22                  | 552.72                             |
| F4L-11              | 602.22                           | 36.18                  | 566.04                             |
| F6-11               | 587.40                           | 61.24                  | 526.16                             |
| G1L-11              | 616.84                           | 52.14                  | 564.70                             |
| G6-11               | 608.11                           | 39.50                  | 568.61                             |
| H2L-11              | 620.73                           | 57.88                  | 562.85                             |
| H5-11               | 616.81                           | 64.80                  | 552.01                             |
| I1-11               | 620.71                           | 72.03                  | 548.68                             |
| J5L-11              | 607.20                           | 57.30                  | 549.90                             |
| J6-11               | 608.68                           | 30.17                  | 578.51                             |
| PMW-1L-11           | 598.84                           | 90.81                  | 508.03                             |

Notes

\* Well damaged by car.

**TABLE 2**  
**LEACHATE TREATMENT SYSTEM DAILY EFFLUENT MONITORING DATA**  
**SECOND QUARTER - 2008**  
**HYDE PARK RRT PROGRAM**

| Date     | Effluent         |            |               | Comments |
|----------|------------------|------------|---------------|----------|
|          | Phenol<br>(mg/L) | pH<br>(su) | Flow<br>(gal) |          |
| 04/01/08 | -                | 7.00       | 349,000       |          |
| 04/02/08 | 0.019 UJ         | 7.10       | 286,000       |          |
| 04/03/08 | -                | 7.10       | 247,000       |          |
| 04/04/08 | -                | 7.00       | 393,000       |          |
| 04/05/08 | -                | -          | -             |          |
| 04/06/08 | -                | -          | -             |          |
| 04/07/08 | -                | 6.90       | 375,000       |          |
| 04/08/08 | -                | 7.00       | 373,000       |          |
| 04/09/08 | 0.016 U          | 7.00       | 277,000       |          |
| 04/10/08 | -                | 6.90       | 163,000       |          |
| 04/11/08 | -                | 6.90       | 252,000       |          |
| 04/12/08 | -                | -          | -             |          |
| 04/13/08 | -                | -          | -             |          |
| 04/14/08 | -                | 6.90       | 335,000       |          |
| 04/15/08 | -                | 6.90       | 277,000       |          |
| 04/16/08 | 0.028 U          | 6.90       | 244,000       |          |
| 04/17/08 | -                | 7.00       | 236,000       |          |
| 04/18/08 | -                | 6.90       | 143,000       |          |
| 04/19/08 | -                | -          | -             |          |
| 04/20/08 | -                | -          | -             |          |
| 04/21/08 | -                | 6.88       | 169,000       |          |
| 04/22/08 | -                | 6.90       | 163,000       |          |
| 04/23/08 | 0.015 U          | 6.80       | 165,000       |          |
| 04/24/08 | -                | 6.90       | 166,000       |          |
| 04/25/08 | -                | 6.80       | 168,000       |          |
| 04/26/08 | -                | -          | -             |          |
| 04/27/08 | -                | -          | -             |          |
| 04/28/08 | -                | 6.80       | 170,000       |          |
| 04/29/08 | 0.014 U          | 6.80       | 161,000       |          |
| 04/30/08 | -                | 6.80       | 158,000       |          |



**TABLE 2**  
**LEACHATE TREATMENT SYSTEM DAILY EFFLUENT MONITORING DATA**  
**SECOND QUARTER - 2008**  
**HYDE PARK RRT PROGRAM**

| Date     | Effluent         |            |               | Comments |
|----------|------------------|------------|---------------|----------|
|          | Phenol<br>(mg/L) | pH<br>(su) | Flow<br>(gal) |          |
| 05/01/08 | -                | 6.78       | 145,000       |          |
| 05/02/08 | -                | 6.90       | 108,000       |          |
| 05/03/08 | -                | -          | -             |          |
| 05/04/08 | -                | -          | -             |          |
| 05/05/08 | -                | 6.70       | 164,000       |          |
| 05/06/08 | -                | 6.80       | 164,000       |          |
| 05/07/08 | 0.012 UJ         | 6.50       | 170,000       |          |
| 05/08/08 | -                | 6.50       | 164,000       |          |
| 05/09/08 | -                | 6.40       | 126,000       |          |
| 05/10/08 | -                | -          | -             |          |
| 05/11/08 | -                | -          | -             |          |
| 05/12/08 | -                | 6.50       | 168,000       |          |
| 05/13/08 | -                | 6.50       | 153,000       |          |
| 05/14/08 | 0.020            | 6.40       | 155,000       |          |
| 05/15/08 | -                | 6.50       | 120,000       |          |
| 05/16/08 | -                | 6.60       | 96,000        |          |
| 05/17/08 | -                | -          | -             |          |
| 05/18/08 | -                | -          | -             |          |
| 05/19/08 | -                | 7.00       | 162,000       |          |
| 05/20/08 | -                | 6.50       | 161,000       |          |
| 05/21/08 | 0.016 U          | 6.30       | 124,000       |          |
| 05/22/08 | -                | 6.40       | 95,000        |          |
| 05/23/08 | -                | 7.00       | 84,000        |          |
| 05/24/08 | -                | -          | -             |          |
| 05/25/08 | -                | -          | -             |          |
| 05/26/08 | -                | 7.00       | -             |          |
| 05/27/08 | -                | 7.00       | 163,000       |          |
| 05/28/08 | 0.0076 J         | 6.80       | 168,000       |          |
| 05/29/08 | -                | 6.70       | 146,000       |          |
| 05/30/08 | -                | 6.90       | 88,000        |          |
| 05/31/08 | -                | -          | -             |          |

**TABLE 2**  
**LEACHATE TREATMENT SYSTEM DAILY EFFLUENT MONITORING DATA**  
**SECOND QUARTER - 2008**  
**HYDE PARK RRT PROGRAM**

| Date     | Effluent         |            |               | Comments |
|----------|------------------|------------|---------------|----------|
|          | Phenol<br>(mg/L) | pH<br>(su) | Flow<br>(gal) |          |
| 06/01/08 | -                | -          | -             |          |
| 06/02/08 | -                | 6.80       | 169,000       |          |
| 06/03/08 | -                | 6.50       | 161,000       |          |
| 06/04/08 | 0.023            | 6.80       | 115,000       |          |
| 06/05/08 | -                | 6.30       | 89,000        |          |
| 06/06/08 | -                | 6.50       | 78,000        |          |
| 06/07/08 | -                | -          | -             |          |
| 06/08/08 | -                | -          | -             |          |
| 06/09/08 | -                | 6.90       | 167,000       |          |
| 06/10/08 | -                | 6.70       | 145,000       |          |
| 06/11/08 | 0.0069           | 6.60       | 81,000        |          |
| 06/12/08 | -                | 6.70       | 75,000        |          |
| 06/13/08 | -                | 6.50       | 79,000        |          |
| 06/14/08 | -                | -          | -             |          |
| 06/15/08 | -                | -          | -             |          |
| 06/16/08 | -                | 6.80       | 165,000       |          |
| 06/17/08 | -                | 6.60       | 153,000       |          |
| 06/18/08 | 0.014            | 6.90       | 89,000        |          |
| 06/19/08 | -                | 6.90       | 117,000       |          |
| 06/20/08 | -                | 6.80       | 81,000        |          |
| 06/21/08 | -                | -          | -             |          |
| 06/22/08 | -                | -          | -             |          |
| 06/23/08 | -                | 6.70       | 164,000       |          |
| 06/24/08 | -                | 6.80       | 111,000       |          |
| 06/25/08 | 0.015 U          | 6.80       | 98,000        |          |
| 06/26/08 | -                | 6.70       | 91,000        |          |
| 06/27/08 | -                | 7.20       | 80,000        |          |
| 06/28/08 | -                | -          | -             |          |
| 06/29/08 | -                | -          | -             |          |
| 06/30/08 | -                | 7.20       | 173,000       |          |




## **ATTACHMENTS**

### **1. Purge Well performance Graphs**

# PW-1U

2nd Quarter 2008 - Flow Rates and Levels


Glenn Springs Holdings, Inc.



# PW-1L

## 2nd Quarter 2008 - Flow Rates and Levels

Glenn Springs Holdings, Inc.






# PW-2UR

2nd Quarter 2008 - Flow Rates and Levels




Glenn Springs Holdings, Inc.



# PW-2M

## 2nd Quarter 2008 - Flow Rates and Levels


Glenn Springs Holdings, Inc.



PW-2L

2nd Quarter 2008 - Flow Rates and Levels

Glenn Springs Holdings, Inc.




# PW-3M

## 2nd Quarter 2008 - Flow Rates and Levels




Glenn Springs Holdings, Inc.



# PW-3L

2nd Quarter 2008 - Flow Rates and Levels


Glenn Springs Holdings, Inc.



PW-4U

# 2nd Quarter 2008 - Flow Rates and Levels


Glenn Springs Holdings, Inc.



# PW-4M

2nd Quarter 2008 - Flow Rates and Levels

Glenn Springs Holdings, Inc.






PW-5UR

2nd Quarter 2008 - Flow Rates and Levels

Glenn Springs Holdings, Inc.




PW-6UR

2nd Quarter 2008 - Flow Rates and Levels




Glenn Springs Holdings, Inc.



# PW-6MR 2nd Quarter 2008 - Flow Rates and Levels


Glenn Springs Holdings, Inc.



# PW-7U

2nd Quarter 2008 - Flow Rates and Levels


Glenn Springs Holdings, Inc.



# PW-8U

2nd Quarter 2008 - Flow Rates and Levels

Glenn Springs Holdings, Inc.




# PW-8M

2nd Quarter 2008 - Flow Rates and Levels



Glenn Springs Holdings, Inc.




# PW-9U

## 2nd Quarter 2008 - Flow Rates and Levels



Glenn Springs Holdings, Inc.






# PW-10U

2nd Quarter 2008 - Flow Rates and Levels


Glenn Springs Holdings, Inc.



APW-1

2nd Quarter 2008 - Flow Rates and Levels

Glenn Springs Holdings, Inc.



# APW-2

2nd Quarter 2008 - Flow Rates and Levels

Glenn Springs Holdings, Inc.

