



Glenn Springs Holdings, Inc.

A subsidiary of Occidental Petroleum

Joe Branch
Site Manager
Direct Dial (231) 670-6809

7601 Old Channel Trail
Montague, MI 49437
Fax (231) 894-4033

July 31, 2015

Reference No. 001069

Ms. Gloria M. Sosa
USEPA
Region II, Site Investigation & Compliance Branch
290 Broadway, 20th Floor
New York, NY 10007-1866

Mr. Brian P. Sadowski
NYSDEC
270 Michigan Avenue
Buffalo, NY 14203-2999

Dear Ms. Sosa and Mr. Sadowski:

**Re: Quarterly Operations Report – Second Quarter 2015
Hyde Park Remedial Program
Bedrock and Overburden Monitoring Programs**

In accordance with the July 2006 "Performance Monitoring Plan" (PMP), the following is the Quarterly Operations Report for the Hyde Park Remedial Program for the period April 1, 2015 through June 30, 2015. A total of 8.4 million gallons of aqueous phase liquid (APL) was collected, treated, and discharged in compliance with the Site's City of Niagara Falls Publicly Owned Treatment Works (POTW) Significant Industrial Users Wastewater Discharge Permit #49. No non-aqueous phase liquid (NAPL) was shipped for disposal this quarter. The potentiometric contours are consistent with previous interpretations. Flow Zones 6, 7, and 9 have dewatered areas between the landfill and the gorge face. The current data continue to support the interpretation of effective hydraulic containment and inward gradients.

The performance monitoring data are presented as follows:

- Figures 1-9: Show the potentiometric surface for the bedrock flow zones and overburden
- Figure 10: Show continuously recorded water levels at flow zone 9 piezometer PMW-1M-09
- Table 1: Water level elevation summary
- Tables 2, 3, and 4: Daily, weekly, and quarterly treatment system effluent monitoring data
- Attachment A: Purge well performance graphs indicating daily level and flow information

The pumping wells are operational and functioning as designed. The pumps are operated to maintain a water level between a typical range of 2.5 feet above (pump on) and 2.5 feet below (pump off) a specific setpoint in accordance with the setpoint range defined in the Operation & Maintenance Manual. The following minor operational and setpoint issues were investigated or resolved during the Second Quarter 2015:

- A false high alarm due to a faulty level transmitter in Decanter 3 caused all site wells to be shut down on April 4. The transmitter was repaired immediately and has functioned properly since that time.
- A false high alarm in Storage Tank 4 caused all wells to shut down on June 6. The alarm was due to a communications signal error, and the system worked upon reset.

- 2 -

- The water level in APW-1 and APW-2 exceeded setpoint on April 11 and April 22 due to large rain events. In both cases, the water levels returned to setpoint within three days.
- The water level in APW-2 exceeded setpoint on June 29 due to a large rain event on June 28. The water level was still decreasing at the end of the quarter, but had not yet decreased to within setpoint range.
- On May 18 and June 2, the pump in PW-3M shut down after tripping an electrical breaker. On May 18 the pump worked upon reset, but on June 3 it was discovered that the variable speed drive had failed. The drive was bypassed on June 3, allowing the pump to work while repairs were completed on the variable speed drive. The water level returned to within setpoint range on June 4.
- On June 9, a run-feedback communications fault caused the pump in PW-6UR to shut down, likely due to interference from an electrical storm. The pump functioned properly upon reset.
- The pump in PW-8U shut down on April 14, May 8, and May 11 due to run-feedback communications faults. The pump worked upon reset.
- The water level in PW-8U exceeded setpoint on June 2, due to a large rain event. The water level returned to within setpoint range on June 5.
- The pump in PW-9U failed at the end of the last quarter (March 31) and was removed for repairs. The pump was replaced on April 8, but failed again on April 14. The pump was again pulled and repaired, and water levels returned to within setpoint range by April 16. The pump has functioned properly since that time.

An electronic copy of this report is included on the attached CD. If you have any questions, please feel free to contact me at (231) 670-6809 or by email at joseph_branch@oxy.com.

Very truly yours,

GLENN SPRINGS HOLDINGS, INC.



Joe Branch
Site Manager
231-670-6809 Cell

JB/eew/20
Encl.

cc: M. Anderson, GSH (1)
C. Babcock, GSH (1)
M. Forcucci, NYSDOH (email)
J. Pentilchuk, CRA (email)

B. Sadowski, NYSDEC (CD Only)
G. Sosa, USEPA (4*)
J. Raby, CRA (email)

*Includes one copy on CD





figure 1
FZ-01 Potentiometric Surface June 2015
2nd Quarter Report
Hyde Park Landfill Site
Glenn Springs Holdings, Inc.
Niagara Falls, New York





Legend

- Potentiometric Contour (ft AMSL)
- 2003 Delineation of NAPL Limits
- Flow Zone Subcrop
- Dewatered area of flow zone
- Piezometer used in contouring
- Piezometer considered unreliable - data not used in contouring
- Purge Well - data not used in contouring

Tilde at a piezometer indicates that the flow zone is dewatered. At a purge well, the pumping water level is below the flow zone, but the flow zone is not necessarily dewatered. Value shown is the flow zone elevation.





figure 2
FZ-02 Potentiometric Surface June 2015
2nd Quarter Report
Hyde Park Landfill Site
Glenn Springs Holdings, Inc.
Niagara Falls, New York



Legend

- Potentiometric Contour (ft AMSL)
- 2003 Delineation of NAPL Limits
- Flow Zone Subcrop
- Dewatered area of flow zone
- Piezometer used in contouring
- Piezometer considered unreliable - data not used in contouring
- Purge Well - data not used in contouring

Tilde at a piezometer indicates that the flow zone is dewatered. At a purge well, the pumping water level is below the flow zone, but the flow zone is not necessarily dewatered. Value shown is the flow zone elevation.





figure 3
 FZ-04 Potentiometric Surface June 2015
 2nd Quarter Report
 Hyde Park Landfill Site
 Glenn Springs Holdings, Inc.
 Niagara Falls, New York



Legend

- Potentiometric Contour (ft AMSL)
- 2003 Delineation of NAPL Limits
- Flow Zone Subcrop
- Dewatered area of flow zone
- Piezometer used in contouring
- Piezometer considered unreliable - data not used in contouring
- Purge Well - data not used in contouring

Tilde at a piezometer indicates that the flow zone is dewatered. At a purge well, the pumping water level is below the flow zone, but the flow zone is not necessarily dewatered. Value shown is the flow zone elevation.





figure 4
FZ-05 Potentiometric Surface June 2015
2nd Quarter Report
Hyde Park Landfill Site
Glenn Springs Holdings, Inc.
Niagara Falls, New York



Legend

- Potentiometric Contour (ft AMSL)
- 2003 Delineation of NAPL Limits
- Flow Zone Subcrop
- Dewatered area of flow zone
- Piezometer used in contouring
- Piezometer considered unreliable - data not used in contouring
- Purge Well - data not used in contouring

Tilde at a piezometer indicates that the flow zone is dewatered. At a purge well, the pumping water level is below the flow zone, but the flow zone is not necessarily dewatered. Value shown is the flow zone elevation.




figure 5
 FZ-06 Potentiometric Surface June 2015
 2nd Quarter Report
 Hyde Park Landfill Site
 Glenn Springs Holdings, Inc.
 Niagara Falls, New York




figure 6
FZ-07 Potentiometric Surface June 2015
2nd Quarter Report
Hyde Park Landfill Site
Glenn Springs Holdings, Inc.
Niagara Falls, New York







figure 7
 FZ-09 Potentiometric Surface June 2015
 2nd Quarter Report
 Hyde Park Landfill Site
 Glenn Springs Holdings, Inc.
 Niagara Falls, New York



Legend

- Potentiometric Contour (ft AMSL)
- 2003 Delineation of NAPL Limits
- Flow Zone Subcrop
- Dewatered area of flow zone
- Piezometer used in contouring
- Piezometer considered unreliable - data not used in contouring
- Purge Well - data not used in contouring

Tilde at a piezometer indicates that the flow zone is dewatered. At a purge well, the pumping water level is below the flow zone, but the flow zone is not necessarily dewatered. Value shown is the flow zone elevation.





figure 8
 FZ-11 Potentiometric Surface June 2015
 2nd Quarter Report
 Hyde Park Landfill Site
 Glenn Springs Holdings, Inc.
 Niagara Falls, New York





PMW-1M-09 2nd Quarter 2015 - Hourly Water Level Elevation




figure 10

Table 1

**Water Level Elevation Summary
Second Quarter - 2015
Hyde Park RRT Program**

Well	Reference Elevation (ft AMSL)	Depth to Water (ft)	Water Level Elevation (ft AMSL)
Overburden			
CMW-2OB	590.79	4.08	586.71
CMW-3OB	582.13	7.30	574.83
CMW-4OB	574.28	Surcharged	-
CMW-5OB	583.43	1.48	581.95
CMW-6OB	571.89	Surcharged	-
CMW-7OB	611.00	Dry	-
CMW-8OB	616.11	Dry	-
CMW-9OB	571.76	Dry	-
CMW-10B	576.80	4.90	571.90
CMW-11OB	572.85	2.71	570.14
CMW-12OB	594.74	8.69	586.05
OMW-1	605.28	5.75	599.53
OMW-2	605.99	3.93	602.06
OMW-3	598.63	10.58	588.05
OMW-4R	601.17	11.29	589.88
OMW-5R	591.31	5.88	585.43
OMW-6	587.62	2.22	585.40
OMW-7	592.74	7.64	585.10
OMW-8R2	594.67	8.08	586.59
OMW-9	595.27	8.06	587.21
OMW-10R	595.13	9.06	586.07
OMW-11R	597.52	6.99	590.53
OMW-12R	597.20	5.85	591.35
OMW-13R	601.50	9.51	591.99
OMW-14R	599.64	6.93	592.71
OMW-15	607.48	5.27	602.21
OMW-16R	607.62	4.40	603.22
SC-2	625.61	30.71	594.90
SC-3	638.72	41.02	597.70
SC-4	639.35	30.75	608.60
SC-5	634.07	28.37	605.70
SC-6	631.15	52.95	578.20
Shallow Bedrock			
CMW-1SH	576.11	12.36	563.75
CMW-2SH	590.51	19.39	571.12
CMW-3SH	581.91	33.48	548.43
CMW-4SH	574.16	7.50	566.66
CMW-5SH	583.36	7.31	576.05
CMW-6SH	572.05	9.71	562.34
CMW-7SH	610.58	11.22	599.36
CMW-8SH	615.95	7.49	608.46
CMW-9SH	571.96	11.84	560.12
CMW-11SH	573.21	8.05	565.16
CMW-12SH	597.02	27.88	569.14

Table 1

**Water Level Elevation Summary
Second Quarter - 2015
Hyde Park RRT Program**

Well	Reference Elevation (ft AMSL)	Depth to Water (ft)	Water Level Elevation (ft AMSL)
Flow Zone 1			
G1U-01	617.08	13.88	603.20
G6-01	609.24	6.70	602.54
H2U-01	620.92	9.75	611.17
H5-01	617.61	21.17	596.44
I1-01	625.58	26.40	599.18
Flow Zone 2			
F2U-02	599.89	24.19	575.70
F4U-02	602.32	15.92	586.40
G1-02	616.86	24.79	592.07
G6-02	608.65	17.16	591.49
H2U-02	620.88	27.22	593.66
H5-02	617.47	23.89	593.58
I1-02	625.47	37.30	588.17
J2U-02	609.66	14.33	595.33
J5U-02	606.21	10.22	595.99
J6-02	609.23	14.18	595.05
Flow Zone 4			
AFW-2U-04	593.48	17.98	575.50
D1U-04	593.77	12.51	581.26
D2U-04	590.65	10.60	580.05
E6-04	578.23	13.60	564.63
F2U-04	599.76	21.62	578.14
F4U-04	602.19	16.37	585.82
F6-04	588.06	18.39	569.67
G1U-04	616.96	25.23	591.73
G6-04	609.15	17.31	591.84
H5-04	617.40	23.89	593.51
I1-04	625.30	39.06	586.24
J2U-04	609.42	16.42	593.00
J5U-04	606.05	19.98	586.07
J6-04	609.12	28.29	580.83
Flow Zone 5			
AFW-2U-05	593.33	17.68	575.65
AGW-1U-05	591.80	5.71	586.09
D1U-05	593.51	14.08	579.43
D2U-05	590.56	11.24	579.32
E6-05	578.04	11.18	566.86
F2U-05	599.64	21.39	578.25
F4U-05	602.06	16.77	585.29
F6-05	587.85	18.28	569.57
G6-05	609.13	17.62	591.51
H2M-05	621.59	29.19	592.40
H5-05	617.31	25.48	591.83
I1-05	625.25	70.25	555.00
J2U-05	609.30	29.85	579.45
J5U-05	605.87	26.43	579.44
J6-05	609.02	28.42	580.60
PMW-1U-05	598.00	21.49	576.51

Table 1

**Water Level Elevation Summary
Second Quarter - 2015
Hyde Park RRT Program**

Well	Reference Elevation (ft AMSL)	Depth to Water (ft)	Water Level Elevation (ft AMSL)
Flow Zone 6			
ABP-7-06	575.78	Dry	-
AFW-1U-06	571.83	14.88	556.95
AFW-2U-06	593.22	48.00	545.22
AGW-1U-06	591.66	38.11	553.55
B2U-06	589.29	35.59	553.70
C3-06	585.78	Dry	-
D1U-06	593.25	46.19	547.06
D2U-06	590.38	42.59	547.79
E6-06	577.99	4.58	573.41
F2M-06	599.06	43.17	555.89
F4M-06	602.05	49.28	552.77
F6-06	587.84	14.43	573.41
G1M-06	616.75	43.21	573.54
G6-06	609.09	33.86	575.23
H2M-06	621.42	58.27	563.15
H5-06	617.17	26.10	591.07
I1-06	625.15	73.26	551.89
J2M-06	608.94	54.02	554.92
J5M-06	606.22	59.18	547.04
J6-06	608.93	53.00	555.93
PMW-1U-06	597.92	50.27	547.65
Flow Zone 7			
ABP-1-07	576.44	29.47	546.97
ABP-7-07	575.73	40.72	535.01
AFW-1M-07	571.41	Dry	-
AFW-2M-07	593.44	66.81	526.63
AGW-1M-07	592.91	36.86	556.05
B2M-07	589.52	55.78	533.74
C3-07	585.62	43.18	542.44
D1M-07	594.15	63.46	530.69
D2M-07	590.77	65.51	525.26
E6-07	577.91	23.63	554.28
F2M-07	598.91	80.99	517.92
F4M-07	601.91	71.09	530.82
F6-07	587.68	20.50	567.18
G1M-07	616.68	33.54	583.14
G6-07	609.06	26.27	582.79
H5-07	617.05	61.44	555.61
I1-07	625.14	68.09	557.05
J5M-07	606.07	48.89	557.18
J6-07	608.85	51.57	557.28
PMW-1M-07	598.50	67.22	531.28

Table 1

**Water Level Elevation Summary
Second Quarter - 2015
Hyde Park RRT Program**

Well	Reference Elevation (ft AMSL)	Depth to Water (ft)	Water Level Elevation (ft AMSL)
Flow Zone 9			
ABP-1-09	575.49	41.22	534.27
ABP-7-09	575.67	41.13	534.54
AFW-1M-09	571.12	45.33	525.79
AFW-2M-09	593.32	72.21	521.11
AGW-1M-09	592.75	36.51	556.24
B2M-09	589.34	-	-
C3-09	585.00	44.24	540.76
D1M-09	594.02	76.69	517.33
D2M-09	590.66	73.41	517.25
E6-09	577.82	24.37	553.45
F2M-09	598.71	81.62	517.09
F4M-09	601.79	84.80	516.99
F6-09	587.53	13.32	574.21
G1M-09	616.58	35.31	581.27
G6-09	608.98	25.19	583.79
H2M-09	621.32	67.59	553.73
H5-09	616.93	60.29	556.64
I1-09	624.91	61.58	563.33
J2M-09	608.77	51.62	557.15
J5M-09	605.82	48.78	557.04
J6-09	608.76	43.73	565.03
PMW-1M-09	598.34	81.13	517.21
Flow Zone 11			
AFW-1L-11	572.10	63.86	508.24
AFW-2L-11	593.43	97.68	495.75
AGW-1L-11	592.71	12.57	580.14
B2L-11	589.65	90.62	499.03
D1L-11	593.80	89.32	504.48
D2L-11	590.21	71.85	518.36
E6-11	577.72	41.00	536.72
F2L-11	598.94	48.85	550.09
F4L-11	602.22	21.35	580.87
F6-11	587.40	56.65	530.75
G1L-11	616.84	56.23	560.61
G6-11	608.89	44.96	563.93
H2L-11	620.73	63.04	557.69
H5-11	616.81	68.35	548.46
I1-11	624.75	75.29	549.46
J5L-11	607.20	58.32	548.88
J6-11	608.68	23.31	585.37
PMW-1L-11	598.84	88.28	510.56

Table 1

**Water Level Elevation Summary
Second Quarter - 2015
Hyde Park RRT Program**

Well	Reference Elevation (ft AMSL)	Depth to Water (ft)	Water Level Elevation (ft AMSL)
Purge Wells			
APW-1	564.98	49.98	515.00
APW-2	569.89	57.89	512.00
PW-1L	593.16	93.66	499.50
PW-1U	593.16	47.16	546.00
PW-2L	597.29	101.49	495.80
PW-2M	596.61	84.51	512.10
PW-2UR	594.75	35.05	559.70
PW-3L	599.05	97.35	501.70
PW-3M	597.79	76.59	521.20
PW-4M	606.93	82.63	524.30
PW-4U	604.85	31.05	573.80
PW-5UR	601.31	45.01	556.30
PW-6UMR	609.31	102.41	506.90
PW-6UR	608.47	48.27	560.20
PW-7U	592.47	50.87	541.60
PW-8M	592.67	71.07	521.60
PW-8U	589.27	35.17	554.10
PW-9U	587.47	48.17	539.30
PW-10U	593.54	28.54	565.00

Notes:

ft AMSL Feet above mean sea level
 Dry No water present at the time of measurement
 Surcharged Well full of water to top of casing
 - Not available/not applicable

Table 2

**Leachate Treatment System Daily Effluent Monitoring Data
Second Quarter - 2015
Hyde Park RRT Program**

Date	Phenol (mg/L)	pH (su)	Effluent	Comments
			Flow (gal)	
04/01/15	0.010 U	7.0	71,000	
04/02/15	-	7.0	103,000	
04/03/15	-	-	-	
04/04/15	-	-	-	
04/05/15	-	-	-	
04/06/15	-	7.0	465,000	
04/07/15	-	7.0	129,000	
04/08/15	-	7.0	115,000	
04/09/15	0.010 U	7.0	339,000	
04/10/15	-	7.0	65,000	
04/11/15	-	-	-	
04/12/15	-	7.0	362,000	
04/13/15	-	7.0	110,000	
04/14/15	-	7.1	124,000	
04/15/15	0.010 U	7.1	294,000	
04/16/15	-	7.1	53,000	
04/17/15	-	7.1	93,000	
04/18/15	-	-	-	
04/19/15	-	-	-	
04/20/15	-	7.0	403,000	
04/21/15	-	7.0	134,000	
04/22/15	0.020	7.0	166,000	
04/23/15	-	7.0	123,000	
04/24/15	-	7.0	115,000	
04/25/15	-	-	-	
04/26/15	-	-	-	
04/27/15	-	7.0	462,000	
04/28/15	-	-	-	
04/29/15	0.011	7.0	101,000	
04/30/15	-	7.0	86,000	

Table 2

Leachate Treatment System Daily Effluent Monitoring Data
Second Quarter - 2015
Hyde Park RRT Program

Date	Effluent			Comments
	Phenol (mg/L)	pH (su)	Flow (gal)	
05/01/15	-	7.0	39,000	
05/02/15	-	-	-	
05/03/15	-	-	-	
05/04/15	-	-	-	
05/05/15	-	7.0	142,000	
05/06/15	0.020 U	7.0	131,000	
05/07/15	-	7.0	143,000	
05/08/15	-	7.0	96,000	
05/09/15	-	-	-	
05/10/15	-	-	-	
05/11/15	-	-	-	
05/12/15	0.026	7.0	137,000	
05/13/15	-	7.1	132,000	
05/14/15	-	7.0	68,000	
05/15/15	-	-	-	
05/16/15	-	-	-	
05/17/15	-	-	-	
05/18/15	-	7.0	114,000	
05/19/15	-	7.0	167,000	
05/20/15	0.029	7.0	124,000	
05/21/15	-	7.0	73,000	
05/22/15	-	-	-	
05/23/15	-	-	-	
05/24/15	-	-	-	
05/25/15	-	-	-	
05/26/15	-	7.0	130,000	
05/27/15	0.010 U	7.0	117,000	
05/28/15	-	7.0	126,000	
05/29/15	-	-	-	
05/30/15	-	-	-	
05/31/15	-	-	-	

Table 2

**Leachate Treatment System Daily Effluent Monitoring Data
Second Quarter - 2015
Hyde Park RRT Program**

Date	Phenol (mg/L)	pH (su)	Effluent	Comments
			Flow (gal)	
06/01/15	-	7.0	128,000	
06/02/15	-	7.1	134,000	
06/03/15	0.016	7.0	150,000	
06/04/15	-	7.0	124,000	
06/05/15	-	7.0	62,000	
06/06/15	-	-	-	
06/07/15	-	-	-	
06/08/15	-	7.0	126,000	
06/09/15	-	7.0	131,000	
06/10/15	0.0093 J	7.0	132,000	
06/11/15	-	7.0	129,000	
06/12/15	-	7.0	74,000	
06/13/15	-	-	-	
06/14/15	-	-	-	
06/15/15	-	7.0	144,000	
06/16/15	-	7.0	144,000	
06/17/15	0.017	7.0	115,000	
06/18/15	-	7.0	113,000	
06/19/15	-	7.0	84,000	
06/20/15	-	-	-	
06/21/15	-	-	-	
06/22/15	-	7.0	121,000	
06/23/15	-	7.0	142,000	
06/24/15	0.017 UJ	7.0	119,000	
06/25/15	-	7.0	60,000	
06/26/15	-	7.0	96,000	
06/27/15	-	-	-	
06/28/15	-	-	-	
06/29/15	-	7.0	324,000	
06/30/15	-	7.0	123,000	
TOTAL			8,427,000	

Notes:

mg/L Milligram per liter
 su Standard unit
 gal Gallons
 - Not available
 U Non-detect at associated value
 J Estimated concentration
 UJ Non-detect, with associated reporting limit estimated

Table 3

Analytical Results Summary
Weekly Sampling - Leachate Treatment System
Second Quarter - 2015
Hyde Park RRT Program

Effluent

Parameter	Units	04/01/15	04/09/15	04/15/15	04/22/15	04/29/15	05/06/15	05/12/15	05/20/15
Volatiles									
1,1,1-Trichloroethane	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
1,1,2,2-Tetrachloroethane	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
1,1,2-Trichloroethane	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
1,1-Dichloroethane	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
1,1-Dichloroethene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
1,2,4-Trichlorobenzene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
1,2-Dichlorobenzene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
1,2-Dichloroethane	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
1,2-Dichloropropane	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
1,3-Dichlorobenzene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
1,4-Dichlorobenzene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
2-Chlorotoluene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
3-Chlorotoluene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
4-Chlorotoluene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
Benzene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
Bromodichloromethane	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
Bromoform	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
Bromomethane (Methyl Bromide)	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
Carbon disulfide	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
Carbon tetrachloride	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
Chlorobenzene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
Chloroethane	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
Chloroform (Trichloromethane)	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
Chloromethane (Methyl Chloride)	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
cis-1,2-Dichloroethene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
cis-1,3-Dichloropropene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
Dichlorodifluoromethane (CFC-12)	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
Ethylbenzene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
Methylene chloride	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	0.89 J	1.0 U
m-Monochlorobenzotrifluoride	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
o-Monochlorobenzotrifluoride	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
p-Monochlorobenzotrifluoride	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
Styrene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
Tetrachloroethene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
Toluene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
trans-1,2-Dichloroethene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
trans-1,3-Dichloropropene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
Trichloroethene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
Trichlorofluoromethane (CFC-11)	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
Vinyl acetate	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U	1.0 UJ	1.0 U	1.0 U
Vinyl chloride	µg/L	21	25	22	51	44	55	84	89
Xylenes (total)	µg/L	3.0 U	3.0 U	3.0 U	3.0 U	3.0 U	3.0 UJ	3.0 U	3.0 U

Table 3

Analytical Results Summary
Weekly Sampling - Leachate Treatment System
Second Quarter - 2015
Hyde Park RRT Program

Effluent

<i>Parameter</i>	<i>Units</i>	<u>05/27/15</u>	<u>06/03/2015</u>	<u>06/10/2015</u>	<u>06/17/2015</u>	<u>06/24/2015</u>
Volatiles						
1,1,1-Trichloroethane	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
1,1,2,2-Tetrachloroethane	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
1,1,2-Trichloroethane	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
1,1-Dichloroethane	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
1,1-Dichloroethene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
1,2,4-Trichlorobenzene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
1,2-Dichlorobenzene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
1,2-Dichloroethane	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
1,2-Dichloropropane	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
1,3-Dichlorobenzene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
1,4-Dichlorobenzene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
2-Chlorotoluene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
3-Chlorotoluene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
4-Chlorotoluene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Benzene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromodichloromethane	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromoform	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Bromomethane (Methyl Bromide)	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Carbon disulfide	µg/L	1.0 U	1.0 U	0.23 J	1.0 U	1.0 U
Carbon tetrachloride	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Chlorobenzene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Chloroethane	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Chloroform (Trichloromethane)	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Chloromethane (Methyl Chloride)	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
cis-1,2-Dichloroethene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
cis-1,3-Dichloropropene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Dichlorodifluoromethane (CFC-12)	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Ethylbenzene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Methylene chloride	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
m-Monochlorobenzotrifluoride	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
o-Monochlorobenzotrifluoride	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
p-Monochlorobenzotrifluoride	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Styrene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Tetrachloroethene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Toluene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
trans-1,2-Dichloroethene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
trans-1,3-Dichloropropene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Trichloroethene	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Trichlorofluoromethane (CFC-11)	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Vinyl acetate	µg/L	1.0 U	1.0 U	1.0 U	1.0 U	1.0 U
Vinyl chloride	µg/L	83	76	90	130	140
Xylenes (total)	µg/L	3.0 U	3.0 U	3.0 U	3.0 U	3.0 U

Notes:

J Estimated at associated value
 U Non-detect at associated value
 µg/L Microgram per liter

Table 4

**Analytical Results Summary
Quarterly Sampling - Leachate Treatment System
Second Quarter - 2015
Hyde Park RRT Program**

Sample Location:		EFFLUENT	EFFLUENT
Sample ID:		HP32415 EFF ABCD	HP32515 EFF (effluent)
Sample Date:		06/16/2015	06/16/2015
<i>Parameters</i>	<i>Units</i>		
<i>Volatile Organic Compounds</i>			
Vinyl chloride	µg/L	110	--
<i>General Chemistry</i>			
Phosphorus	mg/L	--	0.27

Notes:


µg/L Microgram per liter

mg/L Milligram per liter


Attachment A

SECOND QUARTER 2015 - PUMPING WELL PERFORMANCE GRAPHS
HYDE PARK

Well APW-1




Well APW-2




SECOND QUARTER 2015 - PUMPING WELL PERFORMANCE GRAPHS
HYDE PARK

Well PW-1L




Well PW-1U




SECOND QUARTER 2015 - PUMPING WELL PERFORMANCE GRAPHS
HYDE PARK

Well PW-2L




Well PW-2M




SECOND QUARTER 2015 - PUMPING WELL PERFORMANCE GRAPHS
HYDE PARK

Well PW-2UR




Well PW-3L




SECOND QUARTER 2015 - PUMPING WELL PERFORMANCE GRAPHS
HYDE PARK

Well PW-3M




Well PW-4M




SECOND QUARTER 2015 - PUMPING WELL PERFORMANCE GRAPHS
HYDE PARK

Well PW-4U




Well PW-5UR




SECOND QUARTER 2015 - PUMPING WELL PERFORMANCE GRAPHS
HYDE PARK

Well PW-6MR




Well PW-6UR




SECOND QUARTER 2015 - PUMPING WELL PERFORMANCE GRAPHS
HYDE PARK

Well PW-7U




Well PW-8M




SECOND QUARTER 2015 - PUMPING WELL PERFORMANCE GRAPHS
HYDE PARK

Well PW-8U



Well PW-9U



SECOND QUARTER 2015 - PUMPING WELL PERFORMANCE GRAPHS
HYDE PARK

