



P. O. BOX 248, 1186 LOWER RIVER ROAD, NW, CHARLESTON, TN 37310-0248

(423) 336-4000 FAX: (423) 336-4183

RECEIVED  
NOV 7 2000  
NYSDEC - REG. 9  
REL. FOIL UNREL

October 27, 2000

VIA AIRBORNE EXPRESS

Mr. Daniel King P. E.  
Division of Environmental Remediation  
New York State Department of Environmental Conservation  
270 Michigan Avenue  
Buffalo, New York 14203-2999

Subject: Frontier Chemical - Pendleton Site, Pendleton, New York  
Order on Consent (#B9-0270-89-05)  
September 2000, Semi-Annual Report #7  
Post Closure Operation, Maintenance, and Monitoring Activities

Dear Mr. King:

In accordance with the approved Pendleton O & M Manual, enclosed are three copies of the Semi-Annual Report on the Post-Closure Operation, Maintenance, and Monitoring of the Closure Components for the Frontier Chemical-Pendleton Site by the Pendleton PRP Group.

If you have any questions regarding the above submittals, please contact me by telephone at 423-336-4057, by facsimile at 423-336-4166 or by e-mail at [jmburns@corp.olin.com](mailto:jmburns@corp.olin.com).

Sincerely,

Pendleton PRP Group

*John Burns*  
MAB

John M. Burns  
Chairman, Technical Committee

Distribution

Daniel King, P. E. (3 copies)  
Division of Environmental Remediation  
NYSDEC  
270 Michigan Avenue  
Buffalo, New York 14203-2999

G. Anders Carlson, Ph.D., (2 Copies)  
Director  
Bureau of Environmental Exposure Investigation  
New York State Department of Health  
2 University Place, Room 205  
Albany, New York 12203-3399

Mr. Gerald Rider (1 copy)  
Division of Hazardous Waste Remediation  
NYSDEC  
50 Wolf Road  
Albany, New York 12233

Mr. James Devald (1 copy)  
Niagara County Health Department  
Environmental Services Division  
5460 Upper Mountain Road  
Lockport, New York 14094

Pendleton PRP Technical Committee

David Cook, Esq.  
Nixon, Hargrave, Devans & Doyle  
900 Clinton Square  
P.O. Box 1051  
Rochester, NY 14604

Mark Piazza  
Elf AtoChem  
2000 Market Street  
Philadelphia, PA 19103

Dave Moreira  
Waste Management – Closed Sites  
Department  
4 Liberty Lane West  
Hampton, New Jersey 03842

David Paley  
Honeywell, Inc.  
101 Columbia Road  
P.O. Box 1139  
Morristown, NJ 07962

Colleen K. Sanson, Esq.  
Law Offices of Ted Hadzi-Antich  
Key Center  
Suite 1230  
50 Fountain Plaza  
Buffalo, NY 14202-2212

Dennis P. Harkowitz, Esq.  
Jaeckle, Fleishman & Mugel  
Fleet Bank Building  
Twelve Fountain Plaza  
Buffalo, NY 14202-2292

Tracy Goad Walter, Esq.  
Legal Department  
The Dow Chemical Company  
2030 Dow Center  
Midland, MI 48674

Table of Contents  
Semi-Annual Report #5  
September 2000

Introduction

Background

Discussion

Conclusion

---

Attachments

Attachment A – Quarry Lake Level Plot versus Time

Attachment B – Niagara County Sewer District #1 Submittals and Operation, Maintenance and Monitoring Activities

Attachment C – Frontier Chemical – Pendleton Site; Semi-Annual Ground Water Monitoring Report; September 2000; Frontier Chemical - Pendleton Site; Town of Pendleton, Niagara County, NY, Water Samples Volume 1 of 2, August 10 and 11, 2000

Attachment D – Field Observation Reports

Attachment E – Wetlands Inspection Report

## **Introduction**

This seventh semi-annual report is submitted on behalf of the Frontier Chemical - Pendleton Site PRP Group (PRP Group) for the Frontier Chemical - Pendleton Site located in Pendleton, New York. This report summarizes the activities performed since March 2000 for Post-Closure Operation, Maintenance, and Monitoring of the Closure Components at the subject site.

## **Background**

The Frontier Chemical-Pendleton Site is located on Town Line Road in the Town of Pendleton, Niagara County, New York. The total site comprises approximately 22 acres of the 75-acre Frontier Chemical property. Prior to remediation activities, Quarry Lake, a flooded quarry that resulted from the excavation of clay for use in clay brick and tile manufacturing at an on-site facility, occupied 15 acres of the 22-acre site. The remaining 7 acres, identified as the former Process Area, were utilized by Frontier Chemical Waste Process, Inc. (Frontier) when the site was operated as an industrial waste treatment facility from 1958 to 1974. Plating wastes, pickle liquors and other liquid acid wastes from plating and metal finishing industries were treated at the site, with residuals from the waste treatment process being discharged into Quarry Lake. Much of the former Process Area was filled and graded following termination of waste treatment operations.

The site remediation project with remedial designed by O'Brien & Gere Engineers, Inc. and remedial action by Severson Environmental Services, Inc. included the following major components:

1. Dewatering Quarry Lake to allow drying and consolidation of sediments;
2. Excavation and relocation of sediments from Quarry Lake after dewatering operations to within the limits of the capped area;
3. Excavation and relocation of surface soils, fill or debris to within the limits of the capped area;
4. Capping of consolidated sediments, previously dredged materials, and surface soils with a low-permeability cap;
5. Installation, in conjunction with a cap, of a low-permeability barrier to ground water flow;
6. Construction of a ground water collection trench along the eastern shore of Quarry Lake and the southern portion of the capped area;
7. Reconstruction of the berm around Quarry Lake and installation of a new outlet structure;
8. Construction of a ground water pumping station consisting of a wet well and dry vault;
9. Installation of a ground water pre-treatment system within the dry vault;
10. Conveyance of collected and pre-treated ground water to the local Publicly Owned Treatment Works (POTW);
11. Creation of new wetlands at the site;
12. Construction of a surface water swale adjacent to the cap access road to direct surface water away from the capped area;
13. Installation of piezometers inside and outside the capped area and a standpipe within the ground water collection trench; and
14. Installation of a chain link fence around the capped area and pump station to limit access.

## Discussion

Post-closure operation, maintenance, and monitoring of the closure components of the Frontier Chemical-Pendleton Site are the responsibility of the Pendleton PRP Group. Operation, maintenance, and monitoring activities performed by the Pendleton PRP Group during this reporting period includes the following five elements:

1. Routine inspection and maintenance of constructed features, including the capped area, ground water collection and conveyance system, surface water runoff facilities, constructed wetlands, access road, perimeter and containment berms, and outlet weir,

The semi-annual site and initial wetland inspections were performed on August 9, 2000. The inspection reports are included in this report as Attachment D and E, respectively.

The relocated wetlands inside the Quarry Lake levee have elevations of 574 feet for aquatic bed species (Zone A), 575 feet for non-persistent emergent species (Zone B), and 576 feet for persistent emergence species (Zone C). A water elevation chart is included as Attachment A-2. This water level chart shows the history of the lake elevation starting in April 1996 until present.

2. Operation and maintenance of the ground water pre-treatment system, as described in the Pre-Treatment System Operations Plan, O'Brien & Gere, 1997.

Included in Attachment B are the operation and maintenance activities performed during this reporting period. The activities include monthly submittals to the Niagara Country Sewer District #1 detailing analytical and discharge flow data. Six months (April 2000 September 2000) of submittals are located in Table 2-1.

<b>Submittal Date</b>	<b>Sampling Date</b>
September 10,2000	August 10, 2000
August 10, 2000	July 6, 2000
July 11, 2000	June 2, 2000
June 10, 2000	May 5, 2000
May 10, 2000	April 7, 2000
April 10. 2000	March 2, 2000

Operation, Maintenance, and Monitoring Activities for the site during this reporting period are summarized in Table 2-2.

3. Regarding performance of a ground water monitoring program, the report "Frontier Chemical - Pendleton Site, Semi-Annual Ground Water Monitoring Report" dated September 2000 is included as Attachment C-2.

The main purpose of the groundwater monitoring program is to monitor on-site and off-site groundwater condition and to verify that an inward hydraulic gradient is occurring within the capped area and to evaluate the operation, maintenance, and monitoring activities and identify proposed

changes to the O&M Manual or site procedures and policies which would provide a safer and/or more cost-effective operation.

#### 5. Recordkeeping

Records for site operation and maintenance activities are maintained at the site and Olin's Niagara Falls Plant. These records include daily and weekly logs and charts. Glynn Geotechnical provides assistance to the site caretaker and updates O&M documentation.

O'Brien & Gere Engineers provide ground water level measurement, sampling, monitoring, and analytical field and office support. The PRP representative maintains analytical results and reports submitted to NCSD #1 and NYSDEC at the Olin's Charleston Plant. These records are available for your review and inspection.

#### **Conclusions**

The work performed during this reporting period, April 2000 to September 2000 were reviewed and found to be in accordance with the approved O&M Manual for the Site.

**Attachment A – Quarry Lake Level Plot versus Time**  
**Quarry Lake Level – August 9, 2000**


## **Quarry Lake Level – August 9, 2000**

- **Table A-1 Quarry Lake Level**
- **Chart A-1 Quarry Lake Water Elevations**

**TABLE A-1**  
**Quarry Lake Level**

<b>Date</b>	<b>Elevation</b>
4/16/96	569.00
5/9/96	568.70
5/14/96	567.70
5/15/96	567.20
5/16/96	566.80
5/21/96	567.20
5/24/96	567.00
8/19/96	565.92
9/13/96	566.30
9/30/96	566.50
10/22/96	567.00
11/13/96	568.90
1/17/97	570.00
3/7/97	571.80
4/4/97	572.60
4/16/97	572.50
6/13/97	572.30
6/24/97	573.15
9/8/97	572.34
10/28/97	572.88
2/23/98	578.00
4/30/98	578.26
9/21/98	577.42
2/4/99	577.97
8/4/99	577.60
2/7/00	578.16
8/9/00	578.07

# CHART A-1 QUARRY LAKE WATER LEVELS



**ATTACHMENT B –Niagara County Sewer District #1 Submittals and  
Operation, Maintenance and Monitoring Activities**

B-1 Niagara County Sewer District #1 Submittals

B-2 Operation, Maintenance and Monitoring Activities

**B-1 Niagara County Sewer District #1 Submittals**

**TABLE B-1**

**Niagara County Sewer District #1 Submittals**

<b>Submittal Date</b>	<b>Sampling Date</b>
September 10,2000	August 10, 2000
August 10, 2000	July 6, 2000
July 11, 2000	June 2, 2000
June 10, 2000	May 5, 2000
May 10, 2000	April 7, 2000
April 10. 2000	March 2, 2000

**FILE COPY**

April 10, 2000

VIA AIRBORNE EXPRESS

Mr. Frank Nerone  
Chief Operator  
Niagara County Sewer District #1  
7346 Liberty Drive  
Niagara Falls, NY 14304

Subject: Analytical Sampling Results (3/2/2000 Monthly Sample)  
Groundwater Discharge Through Pre-Treatment System  
Pendleton (Frontier Chemical) Site


Dear Mr. Nerone:

Enclosed for your review are the analytical results from the March 2, 2000, sampling event for discharge of collected groundwater from the pre-treatment system at the Pendleton Site. Analytical results for this sampling event are compared against the Permit (#98-11) requirements on the attached Analytical Summary and Daily Flow sheets.

A review of the analytical and flow data shows that all permit parameters are significantly below the permit discharge requirements.

This data is being provided for your review and concurrence that all permit parameters are well within their limits. If, following review of the enclosed information, you are not in agreement with the above stated conclusion, please contact me at 423-336-4057 as soon as possible so we may discuss any future monitoring requirements.

Sincerely,



John M. Burns  
For the Frontier Chemical - Pendleton Site PRP Group

Enclosures: as stated

David Cook, Esq.  
Nixon, Hargrave, Devans & Doyle  
900 Clinton Square  
P.O. Box 1051  
Rochester, NY 14604

Dave Moreira  
Waste Management – Closed Sites  
Department  
4 Liberty Lane West  
Hampton, New Jersey 03842

Bill Witt  
Radian  
304 West Wackerly St.  
Midland, MI 48640

David Paley  
Allied Signal, Inc.  
101 Columbia Road  
P.O. Box 1139  
Morristown, NJ 07962

Mark Piazza  
Elf AtoChem  
2000 Market Street  
Philadelphia, PA 19103

Colleen K. Sanson, Esq.  
Law Offices of Ted Hadzi-Antich  
Key Center  
Suite 1230  
50 Fountain Plaza  
Buffalo, NY 14202-2212

Dennis P. Harkowitz, Esq.  
Jaeckle, Fleishman & Mugel  
Fleet Bank Building  
Twelve Fountain Plaza  
Buffalo, NY 14202-2292

Brent Schindler, Esq.  
Dow Chemical  
Base of Loveridge Road  
P.O. Box 1398  
Pittsburgh, CA 94565

# March 2000 Analytical Summary for WS 001

## Permit # 98-11

Groundwater Discharge Point: D 002

375,622 Gallons Discharged Prior To 3/2/00  
4,506 Gallons Since Last Report  
161 Average Daily Flow Based on 28 days Between Samples

Parameters	Permit Limit	Detection Limits	3/2/00 Sample Results
Treatment System Discharge	GPD		GPD
Discharge Rate (1)	662		
<b>624 Analytes</b>	<b>ug/L</b>	<b>ug/L</b>	<b>ug/L</b>
Toluene	10.0	1.0	
1,2-Dichloroethane	10.0	1.0	
4-Methyl-2-Pentanone	10.0	5.0	
Vinyl Chloride	10.0	2.0	
Methylene Chloride	10.0	2.8	
trans-1,2-Dichloroethene	10.0	1.0	
1,1,1-Trichloroethane	10.0	1.0	
Trichloroethene	10.0	1.0	
Benzene	10.0	1.0	
Chloromethane		2.0	
Bromomethane		2.0	
Chloroethane		2.0	
Chloroform		1.0	
Carbon Tetrachloride		1.0	
1,1-Dichloroethene		1.0	
Trichlorofluoromethane		2.0	
1,1-Dichloroethane		1.0	
1,2-Dichloropropane		1.0	
Bromodichloromethane		1.0	
2-Chloroethylvinyl ether		2.0	
cis-1,3-Dichloropropene		1.0	
trans-1,3-Dichloropropene		1.0	
1,1,2-Trichloroethane		1.0	
Tetrachloroethene		1.2	
Dibromochloromethane		1.0	
Chlorobenzene		1.0	
Ethylbenzene		1.0	
Bromoform		1.0	
1,1,2,2-Tetrachloroethane		1.0	
1,3-Dichlorobenzene		1.0	
1,4-Dichlorobenzene		1.0	
1,2-Dichlorobenzene		1.0	
Sum of 624 Analytes		100.0	0.0
<b>608 Pesticides (2)</b>	<b>ug/L</b>	<b>ug/L</b>	<b>ug/L</b>
alpha BHC	10.0		
beta BHC	20.0		
delta BHC	10.0		
gamma BHC	10.0		
Heptachlor	8.0		
Aldrin	8.0		
Heptachlor Epoxide	9.0		
4,4-DDE	20.0		
Methoxychlor	18.0		
<b>Metals</b>	<b>mg/L</b>	<b>mg/L</b>	<b>mg/L</b>
Antimony	0.1	0.009	< 0.009
Boron	4.00	0.012	0.295
Chromium	5.33	0.005	< 0.005
Cyanide(T)	2.0	0.005	< 0.005
<b>Other</b>	<b>mg/L</b>	<b>mg/L</b>	<b>mg/L</b>
Total Phenolics	NA	0.005	0.012
TSS	300	4.000	< 4.000

**Legend:**

- (1) Permit limit @ 662 GPD with maximum daily discharged @ 2500 GPD
- (2) Discontinued per April 14, 1997 Letter from F. Narrone to PRP Group.
- (B) Detected in blank
- NA Not applicable

**DAILY FLOW DATA - PENDLETON SITE  
MARCH 2000**

DATE	TOTALIZER READING	DAILY FLOW	COMMENTS
3/1/00	372429	102.0	
3/2/00	372575	146.0	Average Flow & Sampling
3/3/00		16.3	Average Flow
3/4/00		16.3	Average Flow
3/5/00	372624	16.3	Average Flow
3/6/00	372726	102.0	
3/7/00	372776	50.0	
3/8/00	372825	49.0	
3/9/00	372875	50.0	
3/10/00		51.3	Average Flow
3/11/00		51.3	Average Flow
3/12/00		51.3	Average Flow
3/13/00	373080	51.3	
3/14/00	373283	203.0	
3/15/00	373389	106.0	
3/16/00	373813	424.0	
3/17/00		140.7	Average Flow
3/18/00		140.7	Average Flow
3/19/00	374235	140.7	Average Flow
3/20/00	374284	49.0	
3/21/00	374385	101.0	
3/22/00	374485	100.0	
3/23/00	376197	1712.0	Surface water leaking into vault
3/24/00		67.7	Surface water leaking into vault & Avg. Flow
3/25/00		67.7	Average Flow
3/26/00	376400	67.7	Average Flow
3/27/00		67.7	Average Flow
3/28/00	376501	67.7	Average Flow
3/29/00	376552	51.0	
3/30/00	376654	102.0	
3/31/00	376833	179.0	

AVERAGE DAILY FLOW IN GALLONS 146.5

= DRY VAULT GROUNDWATER RELIEF		
		gallons
TOTAL GALLONS	<u>0</u>	

avg =flow between data points divided by days of missing data

# WASTE STREAM TECHNOLOGY, INC.

302 Grote Street  
Buffalo, NY 14207  
(716) 876-5290

## Analytical Data Report

Report Date : 03/17/00  
Group Number : 2001-391

Prepared For :  
Mr. Ben Brayley  
Olin Corporation  
P.O. Box 248  
1186 Lower River Road NW  
Charleston, TN 37310

Site : Frontier - Pendleton

### Field and Laboratory Information

Client Id	WST Lab #	Matrix	Date Sampled	Date Received	Time
00C02690	WS62220	Aqueous	03/02/00	03/03/00	14:00
00C02691	WS62221	Aqueous	03/02/00	03/03/00	14:00
00C02692	WS62222	Aqueous	03/02/00	03/03/00	14:00
00C02693	WS62223	Aqueous	03/02/00	03/03/00	14:00

Sample Status Upon Receipt : No irregularities.

Analytical Parameters	Analytical Services Number of Samples	Turnaround Time
Metals	1	Standard
Cyanide	1	Standard
Phenol	1	Standard
Total Suspended Solids	1	Standard

Report Released By : B. Schepart  
Dr. Brian Schepart, Laboratory Director

ENVIRONMENTAL LABORATORY ACCREDITATION CERTIFICATION NUMBERS  
NYSDOH ELAP #11179 NJDEPE #73977 FDOH #E87581



## METHODOLOGIES

The specific methodologies employed in obtaining the analytical data reported are indicated on each of the result forms. The method numbers shown refer to the following U.S. Environmental Protection Agency Reference:

Methods for Chemical Analysis of Water and Wastes. EPA 600/4-79-020, March 1979, Revised 1983, U.S. Environmental Monitoring and Support Laboratory, Cincinnati, Ohio 45268.

Federal Register, 40 CFR Part 136: Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act. Revised July 1992.

Test Methods for Evaluating Solid Waste: Physical/Chemical Methods. Third Edition, Revised December 1996, U.S. EPA SW-846.

Annual Book of ASTM Standards, Volume II. ASTM, 100 Harbor Drive, West Conshohocken, PA 19428-2959.

Standard Methods for the Examination of Water and Wastewater. (20th Edition). American Public Health Association, 1105 18th Street, NW, Washington, D.C. 20036.

**Waste Stream Technology, Inc.**  
**Total Recoverable Phenol**  
**EPA 420.1**

Site: Frontier Pendleton  
Date Sampled: 03/02/00  
Date Received: 03/03/00

Group Number: 2001-390  
Matrix: Aqueous  
Units: mg/L

<b>WST ID</b>	<b>Client ID</b>	<b>Detection Limit</b>	<b>Result</b>	<b>Date Analyzed</b>
WS62221	00C02691	0.005	0.012	03/13/00

**Waste Stream Technology, Inc.**  
**Cyanide in Water**  
**EPA 335.2**

Site: Frontier Pendleton  
Date Sampled: 03/02/00  
Date Received: 03/03/00

Group Number: 2001-390  
Matrix: Aqueous  
Units: mg/L

<b>WST ID</b>	<b>Client ID</b>	<b>Detection Limit</b>	<b>Result</b>	<b>Date Analyzed</b>
WS62222	00C02692	0.005	Not detected	03/07/00

**Waste Stream Technology, Inc.**  
**Total Suspended Solids**  
**EPA 160.2**

Site: Frontier Pendleton  
Date Sampled: 03/02/00  
Date Received: 03/03/00

Group Number: 2001-390  
Matrix: Aqueous  
Units: mg/L

<b>WST ID</b>	<b>Client ID</b>	<b>Detection Limit</b>	<b>Result</b>	<b>Date Analyzed</b>
WS62223	00C02693	4.0	Not detected	03/08/00

**Waste Stream Technology, Inc.**  
**Metals Analysis Result Report**

Site: Frontier Pendleton  
Date Sampled: 03/02/00  
Date Received: 03/03/00

Group Number: 2001-390  
Units: mg/L  
Matrix: Aqueous

WST ID: WS62220  
Client ID: 00C02690  
Digestion Date: 03/13/00

Analyte	Detection Limit	Result	Date Analyzed	Analysis Method
Antimony by GFAA	0.009	Not detected	03/15/00	EPA 200.9
Boron by ICP	0.012	0.295	03/16/00	EPA 200.7
Chromium by ICP	0.005	Not detected	03/16/00	EPA 200.7

# CHAIN OF CUSTODY

# WASTE STREAM TECHNOLOGY

REPORT TO: *Don*

Waste Stream Technology Inc.  
302 Grote Street, Buffalo, NY 14207  
(716) 876-5290 • FAX (716) 876-2412

OFFICE USE ONLY  
GROUP # *2001-390*

DUE DATE

PAGE \_\_\_\_\_ OF \_\_\_\_\_

ARE SPECIAL DETECTION LIMITS REQUIRED:  
YES NO  
If yes please attach requirements.

TURN AROUND TIME: *10 days*

QUOTATION NUMBER:

Is a QC Package required:  
YES NO  
If yes please attach requirements

- DW DRINKING WATER
- GW GROUND WATER
- SW SURFACE WATER
- WW WASTE WATER
- OIL
- SL SLUDGE
- SO SOIL
- S SOLID
- W W/PE
- OTHER

ANALYSES TO BE PERFORMED

CONTACT: *Don Bradley*  
PH #: *716-298-6422*  
FAX #: ( )  
BILL TO:  
PO#:  
PROJECT DESCRIPTION: *Frontier Radiation*  
SAMPLER SIGNATURE: *Bill Bradley*  
SAMPLER I.D.

NO	SAMPLE I.D.	DATE SAMPLED	TIME OF SAMPLING	SAMPLE TYPE	TOTAL NO. OF CONTAINERS	ANALYSES TO BE PERFORMED				TYPE OF CONTAINER/ COMMENTS:	OFFICE USE ONLY WST. I.D.	
						Br	Cr	Sb	TSS			
1	00002690 1L	3/02/00 330P (Camp)			1						1L (HNO3)	WS62220
2	00002691 1L	3/02/00 330P (Camp)			1						1L (H2SO4)	21
3	00002692 1L	3/02/00 330P (Camp)			1						1L (NaOH)	22
4	00002693 500ML	3/02/00 330P (Camp)			1						500ML (03)	23
5												
6												
7												
8												
9												
10												

REMARKS:

RELINQUISHED BY: *M. P. [Signature]* DATE: *3/31/00* TIME: *3:30*

RECEIVED BY: *[Signature]* DATE: *3/31/00* TIME: *11:00*

RELINQUISHER: *[Signature]* DATE: *3/21/00* TIME: *1:00*

FILE COPY

May 10, 2000

VIA AIRBORNE EXPRESS

Mr. Frank Nerone  
Chief Operator  
Niagara County Sewer District #1  
7346 Liberty Drive  
Niagara Falls, NY 14304

Subject: Analytical Sampling Results (4/7/2000 Monthly Sample)  
Groundwater Discharge Through Pre-Treatment System  
Pendleton (Frontier Chemical) Site

Dear Mr. Nerone:

Enclosed for your review are the analytical results from the April 7, 2000, sampling event for discharge of collected groundwater from the pre-treatment system at the Pendleton Site. Analytical results for this sampling event are compared against the Permit (#98-11) requirements on the attached Analytical Summary and Daily Flow sheets.

A review of the analytical and flow data shows that all permit parameters are significantly below the permit discharge requirements.

This data is being provided for your review and concurrence that all permit parameters are well within their limits. If, following review of the enclosed information, you are not in agreement with the above stated conclusion, please contact me at 423-336-4057 as soon as possible so we may discuss any future monitoring requirements.

Sincerely,



John M. Burns  
For the Frontier Chemical - Pendleton Site PRP Group

Enclosures: as stated

David Cook, Esq.  
Nixon, Hargrave, Devans & Doyle  
900 Clinton Square  
P.O. Box 1051  
Rochester, NY 14604

Dave Moreira  
Waste Management – Closed Sites  
Department  
4 Liberty Lane West  
Hampton, New Jersey 03842

Bill Witt  
Radian  
304 West Wackerly St.  
Midland, MI 48640

David Paley  
Allied Signal, Inc.  
101 Columbia Road  
P.O. Box 1139  
Morristown, NJ 07962

Mark Piazza  
Elf AtoChem  
2000 Market Street  
Philadelphia, PA 19103

Colleen K. Sanson, Esq.  
Law Offices of Ted Hadzi-Antich  
Key Center  
Suite 1230  
50 Fountain Plaza  
Buffalo, NY 14202-2212

Dennis P. Harkowitz, Esq.  
Jaecekle, Fleishman & Mugel  
Fleet Bank Building  
Twelve Fountain Plaza  
Buffalo, NY 14202-2292

Tracy Goad Walter, Esq.  
Legal Department  
The Dow Chemical Company  
2030 Dow Center  
Midland, MI 48674

# April 2000 Analytical Summary for WS 001

Permit # 98-11

Groundwater Discharge Point: D 002

381,341 Gallons Discharged Prior To 4/7/00  
5,719 Gallons Since Last Report  
161 Average Daily Flow Based on 36 days Between Samples

Parameters	Permit Limit GPD	Detection Limits	4/7/00 Sample Results GPD
Treatment System Discharge			
Discharge Rate (1)	662		
624 Analytes	ug/L	ug/L	ug/L
Toluene	10.0	1.0	
1,2-Dichloroethane	10.0	1.0	
4-Methyl-2-Pentanone	10.0	5.0	
Vinyl Chloride	10.0	2.0	
Methylene Chloride	10.0	2.8	
trans-1,2-Dichloroethene	10.0	1.0	
1,1,1-Trichloroethane	10.0	1.0	
Trichloroethene	10.0	1.0	
Benzene	10.0	1.0	
Chloromethane		2.0	
Bromomethane		2.0	
Chloroethane		2.0	
Chloroform		1.0	
Carbon Tetrachloride		1.0	
1,1-Dichloroethene		1.0	
Trichlorofluoromethane		2.0	
1,1-Dichloroethane		1.0	
1,2-Dichloropropane		1.0	
Bromodichloromethane		1.0	
2-Chloroethylvinyl ether		2.0	
cis-1,3-Dichloropropene		1.0	
trans-1,3-Dichloropropene		1.0	
1,1,2-Trichloroethane		1.0	
Tetrachloroethene		1.2	
Dibromochloromethane		1.0	
Chlorobenzene		1.0	
Ethylbenzene		1.0	
Bromoform		1.0	
1,1,2,2-Tetrachloroethane		1.0	
1,3-Dichlorobenzene		1.0	
1,4-Dichlorobezene		1.0	
1,2-Dichlorobenzene		1.0	
Sum of 624 Analytes		100.0	0.0
608 Pesticides (2)	ug/L	ug/L	ug/L
alpha BHC	10.0		
beta BHC	20.0		
delta BHC	10.0		
gamme BHC	10.0		
Heptachlor	8.0		
Aldrin	8.0		
Heptachlor Epoxide	9.0		
4,4-DDE	20.0		
Methoxychlor	18.0		
Metals	mg/L	mg/L	mg/L
Antimony	0.1	0.009	< 0.009
Boron	4.00	0.012	0.448
Chromium	5.33	0.005	< 0.005
Cyanide(T)	2.0	0.005	< 0.005
Other	mg/L	mg/L	mg/L
Total Phenolics	NA	0.005	< 0.012
TSS	300	4.000	5.200

**Legend:**

- (1) Permit limit @ 662 GPD with maximum daily discharged @ 2500 GPD
- (2) Discontinued per April 14, 1997 Letter from F. Narrone to PRP Group.
- (B) Detected in blank
- NA Not applicable

## DAILY FLOW DATA - PENDLETON SITE APRIL 2000

DATE	TOTALIZER READING	DAILY FLOW	COMMENTS
4/1/00		23.7	Average Flow
4/2/00		23.7	Average Flow
4/3/00	366904	23.7	
4/4/00	377162	285.0	
4/5/00	377265	103.0	
4/6/00	377541	276.0	
4/7/00		504.8	Average Flow & Sampling
4/8/00		504.8	Average Flow
4/9/00		504.8	Average Flow
4/10/00	379560	504.8	Average Flow
4/11/00	379663	103.0	
4/12/00	379826	163.0	
4/13/00	380038	212.0	
4/14/00	380195	157.0	
4/15/00		87.3	Average Flow
4/16/00		87.3	Average Flow
4/17/00	380457	87.3	Average Flow
4/18/00	380559	102.0	
4/19/00	380660	101.0	
4/20/00	380759	99.0	
4/21/00		500.0	Surface water leaking into vault & Avg. Flow
4/22/00		500.0	Surface water leaking into vault & Avg. Flow
4/23/00	382259	500.0	Surface water leaking into vault & Avg. Flow
4/24/00	382360	101.0	
4/25/00	382461	101.0	
4/26/00	382566	105.0	
4/27/00	382666	100.0	
4/28/00		100.3	Average Flow
4/29/00		100.3	Average Flow
4/30/00	382967	100.3	Average Flow


AVERAGE DAILY FLOW IN GALLONS 205.4

	= DRY VAULT GROUNDWATER RELIEF	
		gallons
	TOTAL GALLONS	<u>0</u>

avg =flow between data points divided by days of missing data

**WASTE STREAM TECHNOLOGY, INC.**

302 Grote Street  
Buffalo, NY 14207  
(716) 876-5290



**Analytical Data Report**

Report Date : 04/24/00  
Group Number : 2001-657

Prepared For :  
Mr. James Young  
Olin Corporation  
P.O. Box 248  
1186 Lower River Road NW  
Charleston, TN 37310

Site : Frontier - Pendleton

**Field and Laboratory Information**

Client Id	WST Lab #	Matrix	Date Sampled	Date Received	Time
00D07694	WS63423	Aqueous	04/07/00	04/07/00	13:00
00D07695	WS63424	Aqueous	04/07/00	04/07/00	13:00
00D07696	WS63425	Aqueous	04/07/00	04/07/00	13:00
00D07697	WS63426	Aqueous	04/07/00	04/07/00	13:00
Sample Status Upon Receipt : No irregularities.					

Analytical Parameters	Analytical Services Number of Samples	Turnaround Time
Total Metals	1	Standard
Cyanide	1	Standard
Phenol	1	Standard
Total Suspended Solids	1	Standard

Report Released By : Daniel W. Vollmer  
Daniel Vollmer, Laboratory QA QC Officer

**ENVIRONMENTAL LABORATORY ACCREDITATION CERTIFICATION NUMBERS**  
NYSDOH ELAP #11179 NJDEPE #73977 FDOH #E87581



## METHODOLOGIES

The specific methodologies employed in obtaining the analytical data reported are indicated on each of the result forms. The method numbers shown refer to the following U.S. Environmental Protection Agency Reference:

Methods for Chemical Analysis of Water and Wastes. EPA 600/4-79-020, March 1979, Revised 1983, U.S. Environmental Monitoring and Support Laboratory, Cincinnati, Ohio 45268.

Federal Register, 40 CFR Part 136: Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act. Revised July 1992.

Test Methods for Evaluating Solid Waste: Physical/Chemical Methods. Third Edition, Revised December 1996, U.S. EPA SW-846.

Annual Book of ASTM Standards, Volume II. ASTM, 100 Harbor Drive, West Conshohocken, PA 19428-2959.

Standard Methods for the Examination of Water and Wastewater. (20th Edition). American Public Health Association, 1105 18th Street, NW, Washington, D.C. 20036.

**Waste Stream Technology, Inc.**  
**Metals Analysis Result Report**

Site: Frontier Pendleton  
Date Sampled: 04/07/00  
Date Received: 04/07/00

Group Number: 2001-657  
Units: mg/L  
Matrix: Aqueous

WST ID: WS63423  
Client ID: 00D07694  
Digestion Date: 04/17/00

Analyte	Detection Limit	Result	Date Analyzed	Analysis Method
Antimony by GFAA	0.009	Not detected	04/18/00	EPA 200.9
Boron by ICP	0.012	0.448	04/24/00	EPA 200.7
Chromium by ICP	0.005	Not detected	04/24/00	EPA 200.7

**Waste Stream Technology, Inc.**  
**Total Recoverable Phenol**  
**EPA 420.1**

Site: Frontier Pendleton  
Date Sampled: 04/07/00  
Date Received: 04/07/00

Group Number: 2001-657  
Matrix: Aqueous  
Units: mg/L

<b>WST ID</b>	<b>Client ID</b>	<b>Detection Limit</b>	<b>Result</b>	<b>Date Analyzed</b>
WS63424	00D07695	0.005	Not detected	04/17/00

**Waste Stream Technology, Inc.**  
**Cyanide in Water**  
**EPA 335.2**

Site: Frontier Pendleton  
Date Sampled: 04/07/00  
Date Received: 04/07/00

Group Number: 2001-657  
Matrix: Aqueous  
Units: mg/L

<b>WST ID</b>	<b>Client ID</b>	<b>Detection Limit</b>	<b>Result</b>	<b>Date Analyzed</b>
WS63425	00D07696	0.005	Not detected	04/14/00

**Waste Stream Technology, Inc.**  
**Total Suspended Solids**  
**EPA 160.2**

Site: Frontier Pendleton  
Date Sampled: 04/07/00  
Date Received: 04/07/00

Group Number: 2001-657  
Matrix: Aqueous  
Units: mg/L

<b>WST ID</b>	<b>Client ID</b>	<b>Detection Limit</b>	<b>Result</b>	<b>Date Analyzed</b>
WS63426	00D07697	4.0	5.2	04/11/00



FILE COPY

June 10, 2000

VIA AIRBORNE EXPRESS

Mr. Frank Nerone  
Chief Operator  
Niagara County Sewer District #1  
7346 Liberty Drive  
Niagara Falls, NY 14304

Subject: Analytical Sampling Results (5/5/2000 Monthly Sample)  
Groundwater Discharge Through Pre-Treatment System  
Pendleton (Frontier Chemical) Site


Dear Mr. Nerone:

Enclosed for your review are the analytical results from the May 5, 2000, sampling event for discharge of collected groundwater from the pre-treatment system at the Pendleton Site. Analytical results for this sampling event are compared against the Permit (#98-11) requirements on the attached Analytical Summary and Daily Flow sheets.

A review of the analytical and flow data shows that all permit parameters are significantly below the permit discharge requirements.

This data is being provided for your review and concurrence that all permit parameters are well within their limits. If, following review of the enclosed information, you are not in agreement with the above stated conclusion, please contact me at 423-336-4057 as soon as possible so we may discuss any future monitoring requirements.

Sincerely,



John M. Burns  
For the Frontier Chemical - Pendleton Site PRP Group

Enclosures: as stated

David Cook, Esq.  
Nixon, Hargrave, Devans & Doyle  
900 Clinton Square  
P.O. Box 1051  
Rochester, NY 14604

Dave Moreira  
Waste Management – Closed Sites  
Department  
4 Liberty Lane West  
Hampton, New Jersey 03842

Bill Witt  
Radian  
304 West Wackerly St.  
Midland, MI 48640

David Paley  
Allied Signal, Inc.  
101 Columbia Road  
P.O. Box 1139  
Morristown, NJ 07962

Mark Piazza  
Elf AtoChem  
2000 Market Street  
Philadelphia, PA 19103

Colleen K. Sanson, Esq.  
Law Offices of Ted Hadzi-Antich  
Key Center  
Suite 1230  
50 Fountain Plaza  
Buffalo, NY 14202-2212

Dennis P. Harkowitz, Esq.  
Jaecekle, Fleishman & Mugel  
Fleet Bank Building  
Twelve Fountain Plaza  
Buffalo, NY 14202-2292

Tracy Goad Walter, Esq.  
Legal Department  
The Dow Chemical Company  
2030 Dow Center  
Midland, MI 48674

# April 2000 Analytical Summary for WS 001

## Permit # 98-11

Groundwater Discharge Point: D 002

387,879 Gallons Discharged Prior 5/5/00  
6,538 Gallons Since Last Report  
112.9 Average Daily Flow Based on 28 days Between Samples

Parameters	Permit Limit	Detection Limits	5/5/00 Sample Results
Treatment System Discharge	GPD		GPD
Discharge Rate (1)	662		
<b>624 Analytes</b>	ug/L	ug/L	ug/L
Toluene	10.0	1.0	< 1.0
1,2-Dichloroethane	10.0	1.0	< 1.0
4-Methyl-2-Pentanone	10.0	5.0	< 5.0
Vinyl Chloride	10.0	2.0	< 2.0
Methylene Chloride	10.0	2.8	< 2.8
trans-1,2-Dichloroethene	10.0	1.0	< 1.0
1,1,1-Trichloroethane	10.0	1.0	< 1.0
Trichloroethene	10.0	1.0	< 1.0
Benzene	10.0	1.0	< 1.0
Chloromethane		2.0	< 2.0
Bromomethane		2.0	< 2.0
Chloroethane		2.0	< 2.0
Chloroform		1.0	< 1.0
Carbon Tetrachloride		1.0	< 1.0
1,1-Dichloroethene		1.0	< 1.0
Trichlorofluoromethane		2.0	< 2.0
1,1-Dichloroethane		1.0	< 1.0
1,2-Dichloropropane		1.0	< 1.0
Bromodichloromethane		1.0	< 1.0
2-Chloroethylvinyl ether		2.0	< 2.0
cis-1,3-Dichloropropene		1.0	< 1.0
trans-1,3-Dichloropropene		1.0	< 1.0
1,1,2-Trichloroethane		1.0	< 1.0
Tetrachloroethene		1.2	< 1.2
Dibromochloromethane		1.0	< 1.0
Chlorobenzene		1.0	< 1.0
Ethylbenzene		1.0	< 1.0
Bromoform		1.0	< 1.0
1,1,2,2-Tetrachloroethane		1.0	< 1.0
1,3-Dichlorobenzene		1.0	< 1.0
1,4-Dichlorobenzene		1.0	< 1.0
1,2-Dichlorobenzene		1.0	< 1.0
Sum of 624 Analytes		100.0	< 44.0
<b>608 Pesticides (2)</b>	ug/L	ug/L	ug/L
alpha BHC	10.0		
beta BHC	20.0		
delta BHC	10.0		
gamma BHC	10.0		
Heptachlor	8.0		
Aldrin	8.0		
Heptachlor Epoxide	9.0		
4,4-DDE	20.0		
Methoxychlor	18.0		
<b>Metals</b>	mg/L	mg/L	mg/L
Antimony	0.1	0.009	< 0.009
Boron	4.00	0.012	< 0.912
Chromium	5.33	0.005	< 0.005
Cyanide(T)	2.0	0.005	< 0.005
<b>Other</b>	mg/L	mg/L	mg/L
Total Phenolics	NA	0.005	0.008
TSS	300	4.000	5.200

**Legend:**

- (1) Permit limit @ 662 GPD with maximum daily discharged @ 2500 GPD
- (2) Discontinued per April 14, 1997 Letter from F. Narrone to PRP Group.
- (B) Detected in blank
- NA Not applicable

**DAILY FLOW DATA - PENDLETON SITE  
MAY 2000**

DATE	TOTALIZER READING	DAILY FLOW	COMMENTS
5/1/00	383067	100.0	
5/2/00	383117	50.0	
5/3/00	383243	126.0	
5/4/00	383592	349.0	
5/5/00		25.0	Avg. Flow, Sampling & Site Inspection
5/6/00		25.0	Average Flow
5/7/00		25.0	Average Flow
5/8/00	383692	25.0	Average Flow
5/9/00	383792	100.0	
5/10/00	383892	100.0	
5/11/00	384103	211.0	
5/12/00	384321	218.0	Average Flow
5/13/00		410.9	Average Flow
5/14/00		410.9	Average Flow
5/15/00		410.9	Average Flow
5/16/00		410.9	Average Flow
5/17/00		410.9	Average Flow
5/18/00		410.9	Average Flow
5/19/00		410.9	Average Flow
5/20/00		410.9	Average Flow
5/21/00	388019	410.9	Average Flow
5/22/00	388171	152.0	
5/23/00	388486	315.0	
5/24/00		127.0	Average Flow
5/25/00	388740	127.0	Average Flow
5/26/00	388847	107.0	
5/27/00		153.3	Average Flow
5/28/00		153.3	Average Flow
5/29/00	389307	153.3	Average Flow
5/30/00	389406	99.0	
5/31/00	389505	99.0	


AVERAGE DAILY FLOW IN GALLONS 207.7

	= DRY VAULT GROUNDWATER RELIEF	
		gallons
TOTAL GALLONS		<u>0</u>

avg =flow between data points divided by days of missing data

**WASTE STREAM TECHNOLOGY, INC.**

302 Grote Street  
Buffalo, NY 14207  
(716) 876-5290



**Analytical Data Report**

Report Date : 05/23/00  
Group Number : 2001-871

Prepared For :  
Mr. John Burns  
Olin Corporation  
P.O. Box 248  
1186 Lower River Road NW  
Charleston, TN 37310

Site : Frontier Pendleton

**Field and Laboratory Information**

Client Id	WST Lab #	Matrix	Date Sampled	Date Received	Time
00E05698-703 Comp Sample	WS64541	Aqueous	05/05/00	05/05/00	14:45
Trip Blank	WS64625	Aqueous	05/05/00	05/05/00	14:45

Sample Status Upon Receipt : No irregularities.

Analytical Parameters	Analytical Services Number of Samples	Turnaround Time
Total Metals	1	Standard
Cyanide	1	Standard
Phenol	1	Standard
Total Suspended Solids	1	Standard
TCL 8260B	2	Standard

Report Released By : Daniel W. Vollmer  
Daniel Vollmer, Laboratory QA QC Officer

**ENVIRONMENTAL LABORATORY ACCREDITATION CERTIFICATION NUMBERS**  
NYSDOH ELAP #11179 NJDEPE #73977 FDOH #E87581



## METHODOLOGIES

The specific methodologies employed in obtaining the analytical data reported are indicated on each of the result forms. The method numbers shown refer to the following U.S. Environmental Protection Agency Reference:

Methods for Chemical Analysis of Water and Wastes. EPA 600/4-79-020, March 1979, Revised 1983, U.S. Environmental Monitoring and Support Laboratory, Cincinnati, Ohio 45268.

Federal Register, 40 CFR Part 136: Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act. Revised July 1992.

Test Methods for Evaluating Solid Waste: Physical/Chemical Methods. Third Edition, Revised December 1996, U.S. EPA SW-846.

Annual Book of ASTM Standards, Volume II. ASTM, 100 Harbor Drive, West Conshohocken, PA 19428-2959.

Standard Methods for the Examination of Water and Wastewater. (20th Edition). American Public Health Association, 1105 18th Street, NW, Washington, D.C. 20036.

## ORGANIC DATA QUALIFIERS

- U** - Indicates compound was analyzed for but not detected.
- J** - Indicates an estimated value. This flag is used either when estimating a concentration for tentatively identified compounds where a 1:1 response is assumed, or when the mass spectral data indicates the presence of a compound that meets identification criteria, but the result is less than the sample quantitation limit but greater than zero.
- C** - This flag applies to pesticide results where the identification has been confirmed by GC/MS.
- B** - This flag is used when the analyte is found in the associated blank as well as the sample.
- E** - This flag identifies all compounds whose concentrations exceed the calibration range of the GC/MS instrument of that specific analysis.
- D** - This flag identifies all compounds identified in an analysis at a secondary dilution factor.
- G** - Matrix spike recovery is greater than the expected upper limit of analytical performance.
- L** - Matrix spike recovery is less than the expected lower limit of analytical performance.
- #** - Indicates that a surrogate recovery was found to be outside the expected limits of analytical performance.
- \$** - Indicates that the surrogate compound was diluted out. The sample had to be diluted to obtain analytical results and a recovery could not be calculated.
- (%)** - Indicates that the compound is a surrogate and that the value reported for this compound is in percent recovery. The quality control recovery limits are indicated in the detection limit or QC limits column.

**Waste Stream Technology, Inc.**  
**Metals Analysis Result Report**

Site: Frontier Pendleton  
Date Sampled: 05/05/00  
Date Received: 05/05/00

Group Number: 2001-871  
Units: mg/L  
Matrix: Aqueous

WST ID: WS64541  
Client ID: 00E05698-703 COMP SAMPLE  
Digestion Date: 05/19/00

Analyte	Detection Limit	Result	Date Analyzed	Analysis Method
Antimony by GFAA	0.009	Not detected	05/22/00	EPA 200.9
Boron by ICP	0.012	0.925	05/22/00	EPA 200.7
Chromium by ICP	0.005	Not detected	05/22/00	EPA 200.7

# Waste Stream Technology, Inc.

40 CFR Part 136 Method 624

EPA 624

Site: Frontier Pendleton  
Date Sampled: 05/05/00  
Date Received: 05/05/00

Group Number: 2001-871  
Units: µg/L  
Matrix: Aqueous

WST ID: WS64541  
Client ID: 00E05698-703 COMP SAMPLE  
Extraction Date: NA  
Date Analyzed: 05/08/00

Compound	Detection Limit	Result	QC Limits (%)	Qualifier
chloromethane	2.0	Not detected		U
vinyl chloride	2.0	Not detected		U
bromomethane	2.0	Not detected		U
chloroethane	2.0	Not detected		U
trichlorofluoromethane	2.0	Not detected		U
1,1-dichloroethene	1.0	Not detected		U
methylene chloride	2.8	Not detected		U
trans-1,2-dichloroethene	1.0	Not detected		U
1,1-dichloroethane	1.0	Not detected		U
chloroform	1.0	Not detected		U
1,1,1-trichloroethane	1.0	Not detected		U
carbon tetrachloride	1.0	Not detected		U
benzene	1.0	Not detected		U
1,2-dichloroethane	1.0	Not detected		U
trichloroethene	1.0	Not detected		U
1,2-dichloropropane	1.0	Not detected		U
1,1-dichloromethane	1.0	Not detected		U
2-chloroethylvinyl ether	2.0	Not detected		U
cis-1,3-dichloropropene	1.0	Not detected		U
toluene	1.0	Not detected		U
trans-1,3-dichloropropene	1.0	Not detected		U
1,1,2-trichloroethane	1.0	Not detected		U
tetrachloroethene	1.2	Not detected		U
dibromochloromethane	1.0	Not detected		U
chlorobenzene	1.0	Not detected		U
ethylbenzene	1.0	Not detected		U
bromoform	1.0	Not detected		U
1,1,2,2-tetrachloroethane	1.0	Not detected		U
1,3-dichlorobenzene	1.0	Not detected		U
1,4-dichlorobenzene	1.0	Not detected		U
1,2-dichlorobenzene	1.0	Not detected		U
4-methyl-2-pentanone	5.0	Not detected		U
1,2-Dichloroethane-d4 (%)		99	76-114	
Toluene-d8 (%)		100	88-110	
Bromofluorobenzene (%)		94	86-115	
<b>Dilution Factor</b>	<b>1</b>			

# Waste Stream Technology, Inc.

40 CFR Part 136 Method 624

EPA 624

Site: Frontier Pendleton  
 Date Sampled: 05/05/00  
 Date Received: 05/05/00

Group Number: 2001-871  
 Units: µg/L  
 Matrix: Aqueous

WST ID: WS64625  
 Client ID: TRIP BLANK  
 Extraction Date: NA  
 Date Analyzed: 05/08/00

Compound	Detection Limit	Result	QC Limits (%)	Qualifier
chloromethane	2.0	Not detected		U
vinyl chloride	2.0	Not detected		U
bromomethane	2.0	Not detected		U
chloroethane	2.0	Not detected		U
trichlorofluoromethane	2.0	Not detected		U
1,1-dichloroethene	1.0	Not detected		U
methylene chloride	2.8	Not detected		U
trans-1,2-dichloroethene	1.0	Not detected		U
1,1-dichloroethane	1.0	Not detected		U
chloroform	1.0	Not detected		U
1,1,1-trichloroethane	1.0	Not detected		U
carbon tetrachloride	1.0	Not detected		U
benzene	1.0	Not detected		U
1,2-dichloroethane	1.0	Not detected		U
trichloroethene	1.0	Not detected		U
1,2-dichloropropane	1.0	Not detected		U
1,1-dichloroethane	1.0	Not detected		U
2-chloroethylvinyl ether	2.0	Not detected		U
cis-1,3-dichloropropene	1.0	Not detected		U
toluene	1.0	Not detected		U
trans-1,3-dichloropropene	1.0	Not detected		U
1,1,2-trichloroethane	1.0	Not detected		U
tetrachloroethene	1.2	Not detected		U
dibromochloromethane	1.0	Not detected		U
chlorobenzene	1.0	Not detected		U
ethylbenzene	1.0	Not detected		U
bromoform	1.0	Not detected		U
1,1,2,2-tetrachloroethane	1.0	Not detected		U
1,3-dichlorobenzene	1.0	Not detected		U
1,4-dichlorobenzene	1.0	Not detected		U
1,2-dichlorobenzene	1.0	Not detected		U
4-methyl-2-pentanone	5.0	Not detected		U
1,2-Dichloroethane-d4 (%)		100	76- 114	
Toluene-d8 (%)		98	88- 110	
Bromofluorobenzene (%)		91	86- 115	
<b>Dilution Factor</b>	<b>1</b>			

# Waste Stream Technology, Inc.

## Method 624 Method Blank Results

EPA 624

Site: Frontier Pendleton  
 Date Sampled: NA  
 Date Received: NA

Group Number: 2001-871  
 Units: µg/L

WST ID: IB050800  
 Client ID: NA  
 Extraction Date: NA  
 Date Analyzed: 05/08/00

Compound	Detection Limit	Result	QC Limits (%)	Qualifier
chloromethane	2.0	Not detected		U
vinyl chloride	2.0	Not detected		U
bromomethane	2.0	Not detected		U
chloroethane	2.0	Not detected		U
trichlorofluoromethane	2.0	Not detected		U
1,1-dichloroethene	1.0	Not detected		U
methylene chloride	2.8	Not detected		U
trans-1,2-dichloroethene	1.0	Not detected		U
1,1-dichloroethane	1.0	Not detected		U
chloroform	1.0	Not detected		U
1,1,1,-trichloroethane	1.0	Not detected		U
carbon tetrachloride	1.0	Not detected		U
benzene	1.0	Not detected		U
1,2-dichloroethane	1.0	Not detected		U
trichloroethene	1.0	Not detected		U
1,2-dichloropropane	1.0	Not detected		U
bromodichloromethane	1.0	Not detected		U
chloroethylvinyl ether	2.0	Not detected		U
cis-1,3-dichloropropene	1.0	Not detected		U
toluene	1.0	Not detected		U
trans-1,3-dichloropropene	1.0	Not detected		U
1,1,2-trichloroethane	1.0	Not detected		U
tetrachloroethene	1.2	Not detected		U
dibromochloromethane	1.0	Not detected		U
chlorobenzene	1.0	Not detected		U
ethylbenzene	1.0	Not detected		U
bromoform	1.0	Not detected		U
1,1,2,2-tetrachloroethane	1.0	Not detected		U
1,3-dichlorobenzene	1.0	Not detected		U
1,4-dichlorobenzene	1.0	Not detected		U
1,2-dichlorobenzene	1.0	Not detected		U
4-methyl-2-pentanone	5.0	Not detected		U
1,2-Dichloroethane-d4 (%)		96	76-114	
Toluene-d8 (%)		91	88-110	
Bromofluorobenzene (%)		94	86-115	

IB denotes Instrument Blank  
 NA denotes Not Applicable

**Dilution Factor      1**

**Waste Stream Technology, Inc.**  
**Wet Chemistry Analyses**

Site: Frontier Pendleton  
Date Sampled: 05/05/00  
Date Received: 05/05/00

Group Number: 2001-871  
Matrix: Aqueous

WST ID: WS64541  
Client ID: 00E05698-703 COMP SAMPLE

<b>Analysis</b>	<b>Method Reference</b>	<b>Detection Limit</b>	<b>Result</b>	<b>Units</b>	<b>Date Analyzed</b>
Cyanide in Water	EPA 335.2	0.005	Not detected	mg/L	05/10/00
Total Recoverable Phenol	EPA 420.1	0.005	0.008	mg/L	05/10/00
Total Suspended Solids	EPA 160.2	4.0	5.2	mg/L	05/10/00

# CHAIN OF CUSTODY

REPORT TO: Jimmy Young  
Toba Burns  
 CONTACT  
 PH. # ( )  
 FAX # ( )

BILL TO: Dyn Corp (ERG)  
Charleston, TN  
 PO#

PROJECT DESCRIPTION  
Fertilizer  
 SAMPLER SIGNATURE  
[Signature]  
 #SAMPLE I.D.

**WALDE JINEMIII**  
**TECHNOLOGY**  
**Waste Stream Technology Inc.**  
 302 Grote Street, Buffalo, NY 14207  
 (716) 876-5290 • FAX (716) 876-2412

OFFICE USE ONLY  
 GROUP # 2001-871  
 DUE DATE

TURN AROUND TIME:  
10:30  
 QUOTATION NUMBER:

DW DRINKING WATER  
 GW GROUND WATER  
 SW SURFACE WATER  
 WW WASTE WATER  
 O OIL

SL SLUDGE  
 SO SOIL  
 S SOLID  
 W WIPE  
 OTHER

ARE SPECIAL DETECTION LIMITS REQUIRED:  
 YES  
 NO  
 If yes please attach requirements.

Is a QC Package required:  
 YES  
 NO  
 If yes please attach requirements

## ANALYSES TO BE PERFORMED

DATE SAMPLED	TIME OF SAMPLING	SAMPLE TYPE	TOTAL NO. OF CONTAINERS	ANALYSES TO BE PERFORMED							TYPE OF CONTAINER/ COMMENTS:	OFFICE USE ONLY WST. I.D.	
				Bio, S, B	Phenols	Cyanide	TSS	VOC	VOC	Top Blank			
5/5/00	8:00 AM	Comp	1									1L	WS041541
5/5/00	8:00 AM	Comp	1									1L	
5/5/00	8:00 AM	Comp	1									1L	
5/5/00	8:00 AM	Comp	1									500 ML	
5/5/00	8:00 AM	Comp	1									40 ML HCL	
5/5/00	8:00 AM	Comp	1									40 ML HCL	
5/5/00	8:00 AM	Comp	1									40 ML HCL	WS041025

REMARKS:

RELINQUISHED BY: [Signature]  
 RELINQUISHED: P. F. Young

DATE: 5/5/00 TIME: 8:45  
 DATE: 5/5/00 TIME: 3:45

RECEIVED BY: [Signature]  
 RECEIVED BY: [Signature]

DATE: 5/5/00 TIME: 1:45  
 DATE: 5/5/00 TIME: 1:45

**FRONTIER CHEMICAL PENDLETON PRP GROUP  
C/O OLIN CORPORATION  
1186 LOWER RIVER ROAD  
CHARLESTON, TN 37310**

**FILE COPY**

July 11, 2000

VIA AIRBORNE EXPRESS

Mr. Frank Nerone  
Chief Operator  
Niagara County Sewer District #1  
7346 Liberty Drive  
Niagara Falls, NY 14304

Subject: Analytical Sampling Results (6/2/2000 Monthly Sample)  
Groundwater Discharge Through Pre-Treatment System  
Pendleton (Frontier Chemical) Site

Dear Mr. Nerone:

Enclosed for your review are the analytical results from the June 2, 2000, sampling event for discharge of collected groundwater from the pre-treatment system at the Pendleton Site. Analytical results for this sampling event are compared against the Permit (#98-11) requirements on the attached Analytical Summary and Daily Flow sheets.

A review of the analytical and flow data shows that all permit parameters are significantly below the permit discharge requirements.

Note that due to significant rainfall events the volume of water (surface water and treated water) discharged through the treatment system exceeds the permit limits. The PRP Group has implemented steps to address this phenomenon. A status update of the steps taken will be provided in the next report submittal.

This data is being provided for your review and concurrence that all permit parameters are well within their limits. If, following review of the enclosed information, you are not in agreement with the above stated conclusion, please contact me at 423-336-4057 as soon as possible so we may discuss any future monitoring requirements.

Sincerely,



John M. Burns

For the Frontier Chemical - Pendleton Site PRP Group

Enclosures: as stated

David Cook, Esq.  
Nixon, Hargrave, Devans & Doyle  
900 Clinton Square  
P.O. Box 1051  
Rochester, NY 14604

Dave Moreira  
Waste Management – Closed Sites  
Department  
4 Liberty Lane West  
Hampton, New Jersey 03842

Bill Witt  
Radian  
304 West Wackerly St.  
Midland, MI 48640

David Paley  
Honeywell  
101 Columbia Road  
P.O. Box 1139  
Morristown, NJ 07962

Mark Piazza  
Elf AtoChem  
2000 Market Street  
Philadelphia, PA 19103

Colleen K. Sanson, Esq.  
Law Offices of Ted Hadzi-Antich  
Key Center  
Suite 1230  
50 Fountain Plaza  
Buffalo, NY 14202-2212

Dennis P. Harkowitz, Esq.  
Jaeckle, Fleishman & Mugel  
Fleet Bank Building  
Twelve Fountain Plaza  
Buffalo, NY 14202-2292

Tracy Goad Walter, Esq.  
Legal Department  
The Dow Chemical Company  
2030 Dow Center  
Midland, MI 48674

## DAILY FLOW DATA - PENDLETON SITE JUNE 2000

DATE	TOTALIZER READING	DAILY FLOW	COMMENTS
6/1/00	389605	100.0	
6/2/00		315.8	Avg. Flow, Sampling & Site Inspection
6/3/00		315.8	Average Flow
6/4/00		315.8	Average Flow
6/5/00	390868	315.8	Average Flow
6/6/00		355.0	Average Flow
6/7/00		355.0	Average Flow
6/8/00		355.0	Average Flow
6/9/00		355.0	Average Flow
6/10/00		355.0	Average Flow
6/11/00		355.0	Average Flow
6/12/00	393353	355.0	Average Flow
6/13/00	393567	214.0	
6/14/00	394494	927.0	
6/15/00	394704	210.0	
6/16/00		320.0	Average Flow
6/17/00		320.0	Average Flow
6/18/00		320.0	Average Flow
6/19/00	395984	320.0	Average Flow
6/20/00	396402	418.0	
6/21/00	396725	323.0	
6/22/00	396927	368.3	Average Flow
6/23/00		368.3	Average Flow
6/24/00		368.3	Average Flow
6/25/00	398400	368.3	Average Flow
6/26/00	398710	310.0	
6/27/00		206.3	Average Flow
6/28/00		206.3	Average Flow
6/29/00	399329	206.3	Average Flow
6/30/00	399539	210.0	

AVERAGE DAILY FLOW IN GALLONS 327.7

	= DRY VAULT GROUNDWATER RELIEF	
		gallons
	TOTAL GALLONS	<u>0</u>

avg =flow between data points divided by days of missing data

# June 2000 Analytical Summary for WS 001

## Permit # 98-11

Groundwater Discharge Point: D 002

397,661 Gallons Discharged Prior To 6/2/00  
 9,832 Gallons Since Last Report  
 351.1 Average Daily Flow Based on 28 days Between Samples

Parameters	Permit Limit	Detection Limits	6/2/00 Sample Results
Treatment System Discharge	GPD		GPD
Discharge Rate (1)	662		
624 Analytes	ug/L	ug/L	ug/L
Toluene	10.0	1.0	
1,2-Dichloroethane	10.0	1.0	
4-Methyl-2-Pentanone	10.0	5.0	
Vinyl Chloride	10.0	2.0	
Methylene Chloride	10.0	2.8	
trans-1,2-Dichloroethene	10.0	1.0	
1,1,1-Trichloroethane	10.0	1.0	
Trichloroethene	10.0	1.0	
Benzene	10.0	1.0	
Chloromethane		2.0	
Bromomethane		2.0	
Chloroethane		2.0	
Chloroform		1.0	
Carbon Tetrachloride		1.0	
1,1-Dichloroethene		1.0	
Trichlorofluoromethane		2.0	
1,1-Dichloroethane		1.0	
1,2-Dichloropropane		1.0	
Bromodichloromethane		1.0	
2-Chloroethylvinyl ether		2.0	
cis-1,3-Dichloropropene		1.0	
trans-1,3-Dichloropropene		1.0	
1,1,2-Trichloroethane		1.0	
Tetrachloroethene		1.2	
Dibromochloromethane		1.0	
Chlorobenzene		1.0	
Ethylbenzene		1.0	
Bromoform		1.0	
1,1,2,2-Tetrachloroethane		1.0	
1,3-Dichlorobenzene		1.0	
1,4-Dichlorobenzene		1.0	
1,2-Dichlorobenzene		1.0	
Sum of 624 Analytes		100.0	
608 Pesticides (2)	ug/L	ug/L	ug/L
alpha BHC	10.0		
beta BHC	20.0		
delta BHC	10.0		
gamma BHC	10.0		
Heptachlor	8.0		
Aldrin	8.0		
Heptachlor Epoxide	9.0		
4,4-DDE	20.0		
Methoxychlor	18.0		
Metals	mg/L		mg/L
Antimony	0.1	0.009	< 0.009
Boron	4.00	0.012	0.377
Chromium	5.33	0.005	< 0.005
Cyanide(T)	2.0	0.005	0.005
Other	mg/L	mg/L	mg/L
Total Phenolics	NA	0.005	< 0.005
TSS	300	4.000	5.600

**Legend:**

- (1) Permit limit @ 662 GPD with maximum daily discharged @ 2500 GPD
- (2) Discontinued per April 14, 1997 Letter from F. Narrone to PRP Group.
- (B) Detected in blank
- NA Not applicable


**WASTE STREAM TECHNOLOGY, INC.**

302 Grote Street  
Buffalo, NY 14207  
(716) 876-5290

**FILE COPY**

**Analytical Data Report**

Report Date : 06/19/00  
Group Number : 2001-1073



Prepared For :  
Mr. John Burns  
Olin Corporation  
P.O. Box 248  
1186 Lower River Road NW  
Charleston, TN 37310

Site : Frontier - Pendleton

**Field and Laboratory Information**

Client Id	WST Lab #	Matrix	Date Sampled	Date Received	Time
00F06705	WS65609	Aqueous	06/02/00	06/02/00	15:00
00F06706	WS65610	Aqueous	06/02/00	06/02/00	15:00
00F06707	WS65611	Aqueous	06/02/00	06/02/00	15:00
00F06708	WS65612	Aqueous	06/02/00	06/02/00	15:00

Sample Status Upon Receipt : No irregularities.

Analytical Parameters	Analytical Services Number of Samples	Turnaround Time
Total Metals	1	Standard
Cyanide	1	Standard
Phenol	1	Standard
Total Suspended Solids	1	Standard

Report Released By : Daniel W. Vollmer  
Daniel Vollmer, Laboratory QA QC Officer

**ENVIRONMENTAL LABORATORY ACCREDITATION CERTIFICATION NUMBERS**

**NYSDOH ELAP #11179 NJDEPE #73977**



## METHODOLOGIES

The specific methodologies employed in obtaining the analytical data reported are indicated on each of the result forms. The method numbers shown refer to the following U.S. Environmental Protection Agency Reference:

Methods for Chemical Analysis of Water and Wastes. EPA 600/4-79-020, March 1979, Revised 1983, U.S. Environmental Monitoring and Support Laboratory, Cincinnati, Ohio 45268.

Federal Register, 40 CFR Part 136: Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act. Revised July 1992.

Test Methods for Evaluating Solid Waste: Physical/Chemical Methods. Third Edition, Revised December 1996, U.S. EPA SW-846.

Annual Book of ASTM Standards, Volume II. ASTM, 100 Harbor Drive, West Conshohocken, PA 19428-2959.

Standard Methods for the Examination of Water and Wastewater. (20th Edition). American Public Health Association, 1105 18th Street, NW, Washington, D.C. 20036.

**Waste Stream Technology, Inc.**  
**Metals Analysis Result Report**

Site: Frontier - Pendleton  
Date Sampled: 06/02/00  
Date Received: 06/02/00

Group Number: 2001-1073  
Units: mg/L  
Matrix: Aqueous

WST ID: WS65609  
Client ID: 00F06705  
Digestion Date: 06/05/00

<b>Analyte</b>	<b>Detection Limit</b>	<b>Result</b>	<b>Date Analyzed</b>	<b>Analysis Method</b>
Antimony by GFAA	0.009	Not detected	06/16/00	EPA 200.9
Boron by ICP	0.012	0.377	06/07/00	EPA 200.7
Chromium by ICP	0.005	Not detected	06/07/00	EPA 200.7

# Waste Stream Technology, Inc.

## Cyanide in Water

EPA 335.2

Site: Frontier - Pendleton  
Date Sampled: 06/02/00  
Date Received: 06/02/00

Group Number: 2001-1073  
Matrix: Aqueous  
Units: mg/L

WST ID	Client ID	Detection Limit	Result	Date Analyzed
WS65610	00F06706	0.005	0.005	06/08/00

**Waste Stream Technology, Inc.**  
**Total Recoverable Phenol**  
**EPA 420.1**

Site: Frontier - Pendleton  
Date Sampled: 06/02/00  
Date Received: 06/02/00

Group Number: 2001-1073  
Matrix: Aqueous  
Units: mg/L

<b>WST ID</b>	<b>Client ID</b>	<b>Detection Limit</b>	<b>Result</b>	<b>Date Analyzed</b>
WS65611	00F06707	0.005	Not detected	06/15/00

**Waste Stream Technology, Inc.**  
**Total Suspended Solids**  
**EPA 160.2**

Site: Frontier - Pendleton  
Date Sampled: 06/02/00  
Date Received: 06/02/00

Group Number: 2001-1073  
Matrix: Aqueous  
Units: mg/L

<b>WST ID</b>	<b>Client ID</b>	<b>Detection Limit</b>	<b>Result</b>	<b>Date Analyzed</b>
WS65612	00F06708	4.0	5.6	06/06/00



**FRONTIER CHEMICAL PENDLETON PRP GROUP  
C/O OLIN CORPORATION  
1186 LOWER RIVER ROAD  
CHARLESTON, TN 37310**

**FILE COPY**

August 22, 2000

VIA AIRBORNE EXPRESS

Mr. Frank Nerone  
Chief Operator  
Niagara County Sewer District #1  
7346 Liberty Drive  
Niagara Falls, NY 14304

Subject: Analytical Sampling Results (7/6/2000 Monthly Sample)  
Groundwater Discharge Through Pre-Treatment System  
Pendleton (Frontier Chemical) Site

Dear Mr. Nerone:

Enclosed for your review are the analytical results from the July 6, 2000, sampling event for discharge of collected groundwater from the pre-treatment system at the Pendleton Site. Analytical results for this sampling event are compared against the Permit (#98-11) requirements on the attached Analytical Summary and Daily Flow sheets.

A review of the analytical and flow data shows that all permit parameters are significantly below the permit discharge requirements.

This data is being provided for your review and concurrence that all permit parameters are well within their limits. If, following review of the enclosed information, you are not in agreement with the above stated conclusion, please contact me at 423-336-4057 as soon as possible so we may discuss any future monitoring requirements.

Sincerely,



John M. Burns

For the Frontier Chemical - Pendleton Site PRP Group

Enclosures: as stated

David Cook, Esq.  
Nixon, Hargrave, Devans & Doyle  
900 Clinton Square  
P.O. Box 1051  
Rochester, NY 14604

Dave Moreira  
Waste Management – Closed Sites  
Department  
4 Liberty Lane West  
Hampton, New Jersey 03842

Bill Witt  
Radian  
304 West Wackerly St.  
Midland, MI 48640

David Paley  
Honeywell  
101 Columbia Road  
P.O. Box 1139  
Morristown, NJ 07962

Mark Piazza  
Elf AtoChem  
2000 Market Street  
Philadelphia, PA 19103

Colleen K. Sanson, Esq.  
Law Offices of Ted Hadzi-Antich  
Key Center  
Suite 1230  
50 Fountain Plaza  
Buffalo, NY 14202-2212

Dennis P. Harkowitz, Esq.  
Jaecekle, Fleishman & Mugal  
Fleet Bank Building  
Twelve Fountain Plaza  
Buffalo, NY 14202-2292

Tracy Goad Walter, Esq.  
Legal Department  
The Dow Chemical Company  
2030 Dow Center  
Midland, MI 48674

# July 2000 Analytical Summary for WS 001

## Permit # 98-11

Groundwater Discharge Point: D 002

408,324 Gallons Discharged Prior To 7/6/00  
5,893 Gallons Since Last Report  
173.3 Average Daily Flow Based on 34 days Between Samples

Parameters	Permit Limit GPD	Detection Limits	7/6/00 Sample Results GPD
<b>Treatment System Discharge</b>			
Discharge Rate (1)	662		
<b>624 Analytes</b>	ug/L	ug/L	ug/L
Toluene	10.0	1.0	
1,2-Dichloroethane	10.0	1.0	
4-Methyl-2-Pentanone	10.0	5.0	
Vinyl Chloride	10.0	2.0	
Methylene Chloride	10.0	2.8	
trans-1,2-Dichloroethene	10.0	1.0	
1,1,1-Trichloroethane	10.0	1.0	
Trichloroethene	10.0	1.0	
Benzene	10.0	1.0	
Chloromethane		2.0	
Bromomethane		2.0	
Chloroethane		2.0	
Chloroform		1.0	
Carbon Tetrachloride		1.0	
1,1-Dichloroethene		1.0	
Trichlorofluoromethane		2.0	
1,1-Dichloroethane		1.0	
1,2-Dichloropropane		1.0	
Bromodichloromethane		1.0	
2-Chloroethylvinyl ether		2.0	
cis-1,3-Dichloropropene		1.0	
trans-1,3-Dichloropropene		1.0	
1,1,2-Trichloroethane		1.0	
Tetrachloroethene		1.2	
Dibromochloromethane		1.0	
Chlorobenzene		1.0	
Ethylbenzene		1.0	
Bromoform		1.0	
1,1,2,2-Tetrachloroethane		1.0	
1,3-Dichlorobenzene		1.0	
1,4-Dichlorobezene		1.0	
1,2-Dichlorobenzene		1.0	
Sum of 624 Analytes		100.0	
<b>608 Pesticides (2)</b>	ug/L	ug/L	ug/L
alpha BHC	10.0		
beta BHC	20.0		
delta BHC	10.0		
gamme BHC	10.0		
Heptachlor	8.0		
Aldrin	8.0		
Heptachlor Epoxide	9.0		
4,4-DDE	20.0		
Methoxychlor	18.0		
<b>Metals</b>	mg/L		mg/L
Antimony	0.1	0.009	< 0.009
Boron	4.00	0.012	0.355
Chromium	5.33	0.005	< 0.005
Cyanide(T)	2.0	0.005	< 0.005
<b>Other</b>	mg/L	mg/L	mg/L
Total Phenolics	NA	0.005	< 0.005
TSS	300	4.000	< 4.000

**Legend:**

- (1) Permit limit @ 662 GPD with maximum daily discharged @ 2500 GPD
- (2) Discontinued per April 14, 1997 Letter from F. Narrone to PRP Group.
- (B) Detected in blank
- NA Not applicable

## DAILY FLOW DATA - PENDLETON SITE JULY 2000

DATE	TOTALIZER READING	DAILY FLOW	COMMENTS
7/1/00	399992	226.5	Average Flow
7/2/00		226.5	Average Flow
7/3/00		178.5	Average Flow
7/4/00	400349	178.5	Average Flow
7/5/00	400553	204.0	
7/6/00	400756	203.0	Sampling & Site Inspection
7/7/00		207.8	Average Flow
7/8/00		207.8	Average Flow
7/9/00		207.8	Average Flow
7/10/00	401587	207.8	Average Flow
7/11/00	401689	102.0	
7/12/00	401888	199.0	
7/13/00	402094	206.0	
7/14/00		242.3	Average Flow
7/15/00		242.3	Average Flow
7/16/00	402615	242.3	Average Flow
7/17/00	402825	210.0	
7/18/00	402983	158.0	
7/19/00	403197	214.0	
7/20/00	403353	156.0	
7/21/00		195.5	Average Flow
7/22/00	403744	195.5	Average Flow
7/23/00	403844	100.0	
7/24/00	404053	209.0	
7/25/00	404207	154.0	Site Inspection
7/26/00		154.5	Average Flow
7/27/00	404516	154.5	Average Flow
7/28/00		157.0	Average Flow
7/29/00		157.0	Average Flow
7/30/00	404987	157.0	Average Flow
7/31/00	405226	239.0	

AVERAGE DAILY FLOW IN GALLONS 190.1


	= DRY VAULT GROUNDWATER RELIEF	
		gallons

TOTAL GALLONS 0

avg =flow between data points divided by days of missing data

**WASTE STREAM TECHNOLOGY, INC.**

302 Grote Street  
Buffalo, NY 14207  
(716) 876-5290



**Analytical Data Report**

Report Date : 07/21/00  
Group Number : 2001-1360

Prepared For :  
Mr. John Burns  
Olin Corporation  
P.O. Box 248  
1186 Lower River Road NW  
Charleston, TN 37310

Site : Pendleton

<b>Analytical Parameters</b>	<b>Analytical Services Number of Samples</b>	<b>Turnaround Time</b>
Total Metals	1	Standard
Cyanide	1	Standard
Phenol	1	Standard
Total Suspended Solids	1	Standard

Report Released By : Daniel W. Vollmer  
Daniel Vollmer, Laboratory QA QC Officer

**ENVIRONMENTAL LABORATORY ACCREDITATION CERTIFICATION NUMBERS**  
NYSDOH ELAP #11179 NJDEPE #73977



**Waste Stream Technology, Inc.**

302 Grote Street  
Buffalo, NY 14207  
(716) 876-5290

**Analytical Data Report**

Group Number: 2001-1360

Site: Pendleton

**Field and Laboratory Information**

<b>WST ID</b>	<b>Client ID</b>	<b>Matrix</b>	<b>Date Sampled</b>	<b>Date Received</b>	<b>Time</b>
WS67369	00G07709	Aqueous	07/06/00	07/07/00	13:15
WS67370	00G07710	Aqueous	07/06/00	07/07/00	13:15
WS67371	00G07711	Aqueous	07/06/00	07/07/00	13:15
WS67372	00G07712	Aqueous	07/06/00	07/07/00	13:15

## METHODOLOGIES

The specific methodologies employed in obtaining the analytical data reported are indicated on each of the result forms. The method numbers shown refer to the following U.S. Environmental Protection Agency Reference:

Methods for Chemical Analysis of Water and Wastes. EPA 600/4-79-020, March 1979, Revised 1983, U.S. Environmental Monitoring and Support Laboratory, Cincinnati, Ohio 45268.

Federal Register, 40 CFR Part 136: Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act. Revised July 1992.

Test Methods for Evaluating Solid Waste: Physical/Chemical Methods. Third Edition, Revised December 1996, U.S. EPA SW-846.

Annual Book of ASTM Standards, Volume II. ASTM, 100 Harbor Drive, West Conshohocken, PA 19428-2959.

Standard Methods for the Examination of Water and Wastewater. (20th Edition). American Public Health Association, 1105 18th Street, NW, Washington, D.C. 20036.

**Waste Stream Technology, Inc.**  
**Metals Analysis Result Report**

Site: Pendleton  
Date Sampled: 07/06/00  
Date Received: 07/07/00

Group Number: 2001-1360  
Units: mg/L  
Matrix: Aqueous

WST ID: WS67369  
Client ID: 00G07709  
Digestion Date: 07/11/00

<b>Analyte</b>	<b>Detection Limit</b>	<b>Result</b>	<b>Date Analyzed</b>	<b>Analysis Method</b>
Antimony by GFAA	0.009	Not detected	07/21/00	EPA 200.9
Boron by ICP	0.012	0.355	07/11/00	EPA 200.7
Chromium by ICP	0.005	Not detected	07/11/00	EPA 200.7

**Waste Stream Technology, Inc.**  
**Wet Chemistry Analyses**

Site: Pendleton  
Date Sampled: 07/06/00  
Date Received: 07/07/00

Group Number: 2001-1360  
Matrix: Aqueous

WST ID: WS67370  
Client ID 00G07710

<b>Analysis</b>	<b>Method Reference</b>	<b>Detection Limit</b>	<b>Result</b>	<b>Units</b>	<b>Date Analyzed</b>
Cyanide in Water	EPA 335.2	0.005	Not detected	mg/L	07/20/00

**Waste Stream Technology, Inc.**  
**Wet Chemistry Analyses**

Site: Pendleton  
Date Sampled: 07/06/00  
Date Received: 07/07/00

Group Number: 2001-1360  
Matrix: Aqueous

WST ID: WS67371  
Client ID 00G07711

<b>Analysis</b>	<b>Method Reference</b>	<b>Detection Limit</b>	<b>Result</b>	<b>Units</b>	<b>Date Analyzed</b>
Total Recoverable Phenol	EPA 420.1	0.005	Not detected	mg/L	07/19/00

**Waste Stream Technology, Inc.**  
**Wet Chemistry Analyses**

Site: Pendleton  
Date Sampled: 07/06/00  
Date Received: 07/07/00

Group Number: 2001-1360  
Matrix: Aqueous

WST ID: WS67372  
Client ID 00G07712

<b>Analysis</b>	<b>Method Reference</b>	<b>Detection Limit</b>	<b>Result</b>	<b>Units</b>	<b>Date Analyzed</b>
Total Suspended Solids	EPA 160.2	4.0	Not detected	mg/L	07/12/00

**CHAIN OF CUSTODY**

REPORT TO: John Burras

**WASTE STREAM TECHNOLOGY**

TECHNOLOGY

Waste Stream Technology Inc.  
302 Grote Street, Buffalo, NY 14207  
(716) 876-5290 • FAX (716) 876-2412

OFFICE USE ONLY

GROUP # 2001-1360

DUE DATE

TURN AROUND TIME: 11:00

QUOTATION NUMBER:

PAGE 1 OF 1

ARE SPECIAL DETECTION LIMITS REQUIRED:  
YES  NO   
If yes please attach requirements.

Is a QC Package required:  
YES  NO   
If yes please attach requirements

DW DRINKING WATER  
GW GROUND WATER  
SW SURFACE WATER  
VW WASTE WATER  
O OIL

SL SLUDGE  
SO SOIL  
S SOLID  
W WIPE  
OTHER

ANALYSES TO BE PERFORMED

TOTAL NO. OF CONTAINERS

DATE SAMPLED  
TIME OF SAMPLING  
SAMPLE TYPE

SAMPLER SIGNATURE  
[Signature]

SAMPLE I.D.

TYPE OF CONTAINER/  
COMMENTS:

OFFICE USE ONLY  
WST. I.D.

NO.	DATE SAMPLED	TIME OF SAMPLING	SAMPLE TYPE	TOTAL NO. OF CONTAINERS	ANALYSES TO BE PERFORMED	TYPE OF CONTAINER/ COMMENTS:	OFFICE USE ONLY WST. I.D.
1	7/6/00	3:30	Comp	1	B.C. SB Cyanide Phenols TSS	1L (HNU3)	WSL07369
2	7/6/00	3:30	Comp	1		1L (NA011)	70
3	7/6/00	3:30	Comp	1		1L (H2S04)	71
4	7/6/00	3:30	Comp	1		500 ML (300C)	↓ 72
5							
6							
7							
8							
9							
10							

REMARKS:

RELINQUISHED BY: <u>W. Moore</u>	DATE: <u>7/7/00</u>	TIME: <u>11:30 AM</u>	RECEIVED BY: <u>[Signature]</u>	DATE: <u>7/7/00</u>	TIME: <u>11:30</u>
RELINQUISHED BY: <u>[Signature]</u>	DATE: <u>7/7/00</u>	TIME: <u>1:15</u>	RECEIVED BY: <u>[Signature]</u>	DATE: <u>7/7/00</u>	TIME: <u>1:15</u>

**FRONTIER CHEMICAL PENDLETON PRP GROUP  
C/O OLIN CORPORATION  
1186 LOWER RIVER ROAD  
CHARLESTON, TN 37310**

**FILE COPY**

September 10, 2000

**VIA AIRBORNE EXPRESS**

Mr. Frank Nerone  
Chief Operator  
Niagara County Sewer District #1  
7346 Liberty Drive  
Niagara Falls, NY 14304

Subject: Analytical Sampling Results (8/10/2000 Monthly Sample)  
Groundwater Discharge Through Pre-Treatment System  
Pendleton (Frontier Chemical) Site

Dear Mr. Nerone:

Enclosed for your review are the analytical results from the August 10, 2000, sampling event for discharge of collected groundwater from the pre-treatment system at the Pendleton Site. Analytical results for this sampling event are compared against the Permit (#98-11) requirements on the attached Analytical Summary and Daily Flow sheets.

A review of the analytical and flow data shows that all permit parameters are significantly below the permit discharge requirements.

This data is being provided for your review and concurrence that all permit parameters are well within their limits. If, following review of the enclosed information, you are not in agreement with the above stated conclusion, please contact me at 423-336-4057 as soon as possible so we may discuss any future monitoring requirements.

Sincerely,

  
John M. Burns

For the Frontier Chemical - Pendleton Site PRP Group

Enclosures: as stated

David Cook, Esq.  
Nixon, Hargrave, Devans & Doyle  
900 Clinton Square  
P.O. Box 1051  
Rochester, NY 14604

Dave Moreira  
Waste Management – Closed Sites  
Department  
4 Liberty Lane West  
Hampton, New Jersey 03842

David Paley  
Honeywell  
101 Columbia Road  
P.O. Box 1139  
Morristown, NJ 07962

Mark Piazza  
Elf AtoChem  
2000 Market Street  
Philadelphia, PA 19103

Colleen K. Sanson, Esq.  
Law Offices of Ted Hadzi-Antich  
Key Center  
Suite 1230  
50 Fountain Plaza  
Buffalo, NY 14202-2212

Dennis P. Harkowitz, Esq.  
Jaeckle, Fleishman & Mugel  
Fleet Bank Building  
Twelve Fountain Plaza  
Buffalo, NY 14202-2292

Tracy Goad Walter, Esq.  
Legal Department  
The Dow Chemical Company  
2030 Dow Center  
Midland, MI 48674

# August 2000 Analytical Summary for WS 001

## Permit # 98-11

Groundwater Discharge Point: D 002

412,126 Gallons Discharged Prior To 8/10/00  
3,802 Gallons Since Last Report  
180.2 Average Daily Flow Based on 35 days Between Samples

Parameters	Permit Limit GPD	Detection Limits	8/10/00 Sample Results GPD
Treatment System Discharge			
Discharge Rate (1)	662		
624 Analytes	ug/L	ug/L	ug/L
Toluene	10.0	1.0	
1,2-Dichloroethane	10.0	1.0	
4-Methyl-2-Pentanone	10.0	5.0	
Vinyl Chloride	10.0	2.0	
Methylene Chloride	10.0	2.8	
trans-1,2-Dichloroethene	10.0	1.0	
1,1,1-Trichloroethane	10.0	1.0	
Trichloroethene	10.0	1.0	
Benzene	10.0	1.0	
Chloromethane		2.0	
Bromomethane		2.0	
Chloroethane		2.0	
Chloroform		1.0	
Carbon Tetrachloride		1.0	
1,1-Dichloroethene		1.0	
Trichlorofluoromethane		2.0	
1,1-Dichloroethane		1.0	
1,2-Dichloropropane		1.0	
Bromodichloromethane		1.0	
2-Chloroethylvinyl ether		2.0	
cis-1,3-Dichloropropene		1.0	
trans-1,3-Dichloropropene		1.0	
1,1,2-Trichloroethane		1.0	
Tetrachloroethene		1.2	
Dibromochloromethane		1.0	
Chlorobenzene		1.0	
Ethylbenzene		1.0	
Bromoform		1.0	
1,1,2,2-Tetrachloroethane		1.0	
1,3-Dichlorobenzene		1.0	
1,4-Dichlorobezene		1.0	
1,2-Dichlorobenzene		1.0	
Sum of 624 Analytes		100.0	
608 Pesticides (2)	ug/L	ug/L	ug/L
alpha BHC	10.0		
beta BHC	20.0		
delta BHC	10.0		
gamme BHC	10.0		
Heptachlor	8.0		
Aldrin	8.0		
Heptachlor Epoxide	9.0		
4,4-DDE	20.0		
Methoxychlor	18.0		
Metals	mg/L		mg/L
Antimony	0.1	0.009	< 0.009
Boron	4.00	0.012	0.433
Chromium	5.33	0.005	< 0.005
Cyanide(T)	2.0	0.005	< 0.005
Other	mg/L	mg/L	mg/L
Total Phenolics	NA	0.005	< 0.005
TSS	300	4.000	< 4.000

**Legend:**

- (1) Permit limit @ 662 GPD with maximum daily discharged @ 2500 GPD
- (2) Discontinued per April 14, 1997 Letter from F. Narrone to PRP Group.
- (B) Detected in blank
- NA Not applicable

## DAILY FLOW DATA - PENDLETON SITE AUGUST 2000

DATE	TOTALIZER READING	DAILY FLOW	COMMENTS
8/1/00	405375	149.0	
8/2/00	405478	103.0	
8/3/00	405686	208.0	
8/4/00		154.7	Average Flow
8/5/00		154.7	Average Flow
8/6/00	406150	154.7	Sampling & Site Inspection
8/7/00	406359	209.0	Average Flow
8/8/00	406615	256.0	Average Flow
8/9/00	406964	349.0	Sampling & Average Flow
8/10/00		100.8	Average Flow
8/11/00		100.8	Average Flow
8/12/00		100.8	Average Flow
8/13/00	407367	100.8	Average Flow
8/14/00	407466	99.0	
8/15/00		105.5	Average Flow
8/16/00	407677	105.5	Average Flow
8/17/00	407776	99.0	
8/18/00	407876	100.0	
8/19/00		85.0	Average Flow
8/20/00		85.0	Average Flow
8/21/00		85.0	Average Flow
8/22/00	408226	85.0	Average Flow
8/23/00	408301	85.0	Filter Bag Change
8/24/00		99.8	Average Flow
8/25/00		99.8	Average Flow
8/26/00		99.8	Average Flow
8/27/00	408700	99.8	Average Flow
8/28/00	408750	50.0	Average Flow
8/29/00		92.7	Inspection & Average Flow
8/30/00		92.7	Average Flow
8/31/00	409028	92.7	Average Flow

AVERAGE DAILY FLOW IN GALLONS 122.7

	= DRY VAULT GROUNDWATER RELIEF	
		gallons
TOTAL GALLONS		<u>0</u>

avg = flow between data points divided by days of missing data

**WASTE STREAM TECHNOLOGY, INC.**

302 Grote Street  
Buffalo, NY 14207  
(716) 876-5290



**Analytical Data Report**  
Report Date : 08/28/00  
Group Number : 2001-1647

Prepared For :  
Mr. John Burns  
Olin Corporation  
P.O. Box 248  
1186 Lower River Road NW  
Charleston, TN 37310

Site : Frontier Pendleton

<b>Analytical Parameters</b>	<b>Analytical Services Number of Samples</b>	<b>Turnaround Time</b>
Total Metals	1	Standard
Cyanide	1	Standard
Phenol	1	Standard
Total Suspended Solids	1	Standard

Report Released By : Daniel W. Vollmer  
Daniel Vollmer, Laboratory QA QC Officer

**ENVIRONMENTAL LABORATORY ACCREDITATION CERTIFICATION NUMBERS**

**NYSDOH ELAP #11179 NJDEPE #73977**



**Waste Stream Technology, Inc.**

302 Grote Street  
Buffalo, NY 14207  
(716) 876-5290

**Analytical Data Report**

Group Number: 2001-1647

Site: Frontier Pendleton

**Field and Laboratory Information**

<b>WST ID</b>	<b>Client ID</b>	<b>Matrix</b>	<b>Date Sampled</b>	<b>Date Received</b>	<b>Time</b>
WS69381	00H08713	Aqueous	08/10/00	08/11/00	10:30
WS69382	00H08714	Aqueous	08/10/00	08/11/00	10:30
WS69383	00H08715	Aqueous	08/10/00	08/11/00	10:30
WS69384	00H08716	Aqueous	08/10/00	08/11/00	10:30

## **METHODOLOGIES**

The specific methodologies employed in obtaining the analytical data reported are indicated on each of the result forms. The method numbers shown refer to the following U.S. Environmental Protection Agency Reference:

Methods for Chemical Analysis of Water and Wastes. EPA 600/4-79-020, March 1979, Revised 1983, U.S. Environmental Monitoring and Support Laboratory, Cincinnati, Ohio 45268.

Federal Register, 40 CFR Part 136: Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act. Revised July 1992.

Test Methods for Evaluating Solid Waste: Physical/Chemical Methods. Third Edition, Revised December 1996, U.S. EPA SW-846.

Annual Book of ASTM Standards, Volume II. ASTM, 100 Harbor Drive, West Conshohocken, PA 19428-2959.

Standard Methods for the Examination of Water and Wastewater. (20th Edition). American Public Health Association, 1105 18th Street, NW, Washington, D.C. 20036.

**Waste Stream Technology, Inc.**  
**Metals Analysis Result Report**

Site: Frontier Pendleton  
Date Sampled: 08/10/00  
Date Received: 08/11/00

Group Number: 2001-1647  
Units: mg/L  
Matrix: Aqueous

WST ID: WS69381  
Client ID: 00H08713  
Digestion Date: 08/18/00

Analyte	Detection Limit	Result	Date Analyzed	Analysis Method
Antimony by GFAA	0.009	Not detected	08/23/00	EPA 200.9
Boron by ICP	0.012	0.433	08/21/00	EPA 200.7
Chromium by ICP	0.005	Not detected	08/21/00	EPA 200.7

**Waste Stream Technology, Inc.**  
**Wet Chemistry Analyses**

Site: Frontier Pendleton  
Date Sampled: 08/10/00  
Date Received: 08/11/00

Group Number: 2001-1647  
Matrix: Aqueous

WST ID: WS69382  
Client ID 00H08714

<b>Analysis</b>	<b>Method Reference</b>	<b>Detection Limit</b>	<b>Result</b>	<b>Units</b>	<b>Date Analyzed</b>
Cyanide in Water	EPA 335.2	0.005	Not detected	mg/L	08/22/00

**Waste Stream Technology, Inc.**  
**Wet Chemistry Analyses**

Site: Frontier Pendleton  
Date Sampled: 08/10/00  
Date Received: 08/11/00

Group Number: 2001-1647  
Matrix: Aqueous

WST ID: WS69383  
Client ID 00H08715

<b>Analysis</b>	<b>Method Reference</b>	<b>Detection Limit</b>	<b>Result</b>	<b>Units</b>	<b>Date Analyzed</b>
Total Recoverable Phenol	EPA 420.1	0.005	Not detected	mg/L	08/17/00

**Waste Stream Technology, Inc.**  
**Wet Chemistry Analyses**

Site: Frontier Pendleton  
Date Sampled: 08/10/00  
Date Received: 08/11/00

Group Number: 2001-1647  
Matrix: Aqueous

WST ID: WS69384  
Client ID 00H08716

<b>Analysis</b>	<b>Method Reference</b>	<b>Detection Limit</b>	<b>Result</b>	<b>Units</b>	<b>Date Analyzed</b>
Total Suspended Solids	EPA 160.2	4.0	Not detected	mg/L	08/15/00

# CHAIN OF CUSTODY

# WASTESIKREATH TECHNOLOGY

Waste Stream Technology Inc.  
302 Grote Street, Buffalo, NY 14207  
(716) 876-5290 • FAX (716) 876-2412

OFFICE USE ONLY  
GROUP # 20221-1647  
DUE DATE \_\_\_\_\_

TURN AROUND TIME  
10 BD  
QUOTATION NUMBER:  
\_\_\_\_\_

DW DRINKING WATER  
GW GROUND WATER  
SW SURFACE WATER  
VW WASTE WATER  
O OIL

SL SLUDGE  
SO SOIL  
S SOLID  
W WIPE  
OTHER \_\_\_\_\_

ARE SPECIAL DETECTION LIMITS REQUIRED:  
YES \_\_\_\_\_ NO \_\_\_\_\_  
If yes please attach requirements.

Is a QC Package required:  
YES \_\_\_\_\_ NO \_\_\_\_\_  
If yes please attach requirements

## ANALYSES TO BE PERFORMED

DATE SAMPLED  
TIME OF SAMPLING  
SAMPLE TYPE  
TOTAL NO. OF CONTAINERS

PO#	SAMPLE I.D.	DATE SAMPLED	TIME OF SAMPLING	SAMPLE TYPE	TOTAL NO. OF CONTAINERS	ANALYSES TO BE PERFORMED	TYPE OF CONTAINER/ COMMENTS:	OFFICE USE ONLY WST. I.D.
1	00H08713	8/10/00	730	Comp	1	B, Cr, Sb Cyanide Phenols TSS	1L 11ND3	WS69387
2	00H08714	8/10/00	730	Comp	1		1L NAOH	82
3	00H08715	8/10/00	730	Comp	1		1L H2SO4	83
4	00H08716	8/10/00	730	Comp	1		500ML 30C	84
5								
6								
7								
8								
9								
10								

REMARKS:

RELINQUISHED BY: [Signature] DATE: 8/11/00 TIME: 10:30 AM  
 RECEIVED BY: [Signature] DATE: 8/11/00 TIME: 10:30  
 RELINQUISHED BY: [Signature] DATE: 8/11/00 TIME: 1:45  
 RECEIVED BY: [Signature] DATE: 1/1 TIME: \_\_\_\_\_

## **B-2 Operation, Maintenance and Monitoring Activities**

## Operation, Maintenance, and Monitoring Activities

Table B-3

Date	Event	Action Taken
May 8, 2000	Pressure Problems	Changed filter bags

## **ATTACHMENT C – Groundwater Data**

- C-1 Frontier Chemical – Pendleton Site  
Semi-Annual Ground Water Monitoring Report  
O'Brien & Gere  
September 2000
  
- C-2 Frontier Chemical – Pendleton Site  
Town of Pendleton, Niagara County, NY Water Samples  
Volume 1 of 3  
O'Brien & Gere  
August 10 and 11, 2000

C-1 Frontier Chemical – Pendleton Site  
Semi-Annual Ground Water Monitoring Report  
O'Brien & Gere  
September 2000

C-2 Frontier Chemical – Pendleton Site  
Town of Pendleton, Niagara County, NY Water Samples  
Volume 1 of 2  
O'Brien & Gere  
August 10 and 11, 2000

## Attachment D – Site Maintenance Work Items and Field Observation Reports

D-1            Field Observation Reports

## Field Observation Reports

- February 7, 2000, Field Observation Report



a member of the GLYNN GROUP

# FIELD OBSERVATION REPORT (With attachments)

Civil • Structural • Geotechnical • Materials Testing • Consulting

PROJECT NO.: 94-1014-O REPORT NO.: 00-02 DATE: 08/10/00 PAGE: 1 OF 3  
 PROJECT: Pendleton – Frontier Chemical Site DAY: Thursday  
 SUBJECT: Semi-Annual Inspection PROJECT TIME: 7:30 am – 2:30 pm  
 CLIENT: Pendleton PRP Group SITE TIME: 8:00 am – 2:00 pm  
 WEATHER: Hazy, Warm (75°F) PHOTOS: YES X NO     

- Arrive at site for Semi-Annual site inspection. Meet Ben Brayley (Olin) and review ongoing operation of the pre-treatment system.
- In discussions with Ben B., note following items relative to pre-treatment system operation:
  - Earlier this morning, Ben B. operated the system manually and collected routine monthly discharge sample.
  - Filter bags are changed out at approx. 3 mo. intervals.
  - The waste container barrel in the vault is nearly full and Ben B. notes that waste sampling and disposal should be arranged.
  - The hydrostatic relief inlet piping in the vault sump has been replaced and the valve on the inlet piping is currently closed (just closed this am).
  - Ben B. reports that the battery operated flow meter on the hydrostatic relief inlet does not provide reliable totalized flow data and the PPRP is considering an alternate flow meter for measuring groundwater returned to MH #3.
  - Groundwater typically leaks into the pre-treatment vault from the horizontal joint between the upper and lower vault sections if hydrostatic pressure is allowed to build up on the vault exterior.
  - The pre-treatment system discharge rate is approx. 200 gpd.
  - Ben B. reports that system discharge rates and pressure differentials across the BF's and GAC's have remained consistent. There is no indication of scale build up or loss of flow area in the pre-treatment system piping based on the observed system discharge.

PERSONNEL ON SITE / CONTACTED:

Jim Young – PPRP  
Ben Brayley – Olin  
Abul Barkat – NYSDEC  
Jennifer Smith, Ron Chiarello – O'B&G  
Tim Prawel, Don Canastrari – O'B&G

Jesse E. Grossman, P.E., Project Manager

DISTRIBUTION:

Jim Young, John Burns – PPRP  
Ben Brayley – Olin  
Jennifer Smith, P.E. – O'Brien & Gere

DAILY MANHOURS: 7.0

Mark W. Glynn, P.E.

## GLYNN GEOTECHNICAL ENGINEERING

415 South Transit Street, Lockport, New York 14094

voice 716.625.6933 / fax 716.625.6983

www.glynneng.com

DOCFIELD:\C19BACKUP\C-19\Word Data\wordshare\Pendleton\FOR\8.10.00\FOR02.doc



a member of the GLYNN GROUP

# FIELD OBSERVATION REPORT (With attachments)

PROJECT NO.:	<u>94-1014-O</u>	REPORT NO.:	<u>00-02</u>	DATE:	<u>08/10/00</u>	PAGE:	<u>2</u> OF <u>3</u>
PROJECT:	<u>Pendleton – Frontier Chemical Site</u>			DAY:	<u>Thursday</u>		
SUBJECT:	<u>Semi-Annual Inspection</u>			PROJECT TIME:	<u>7:30 am – 2:30 pm</u>		
CLIENT:	<u>Pendleton PRP Group</u>			SITE TIME:	<u>8:00 am – 2:00 pm</u>		

- Ben B. reports that the air relief valve on the top of GAC #2 passes water when discharge stops and as the pressure drops. Ben suggests that the ARV's may need to be replaced.
- No leaks are noted in any of the pre-treatment system piping or vessel elements
- M.H. #3 (wet well) is essentially empty from earlier manual operation of the pre-treatment discharge system. With Ben B., use the "T" handle to fully close and reopen the pinch valve on the end of the leachate collection pipe at the inlet into M.H. #3. Note that inflow stops completely with the valve closed. The valve is returned to the full open position. The observed inflow into M.H.#3 from the collection pipe is at a "trickle" (est. @ say, 0.1 gpm). There is no visible build up of sediments in the M.H. #3 invert.
- With Jennifer Smith and Ron Chiarello (O'B&G) and later Jim Young (PPRP) perform semi-annual site inspection as outlined in Table 2-1 of the O&M Manual. The completed Inspection Checklist is attached. Some specific site inspection item notes follow:
  - The Quarry Lake water elevation is 578.07'.
  - The M.H. #1 inv. Is clean and dry.
  - There is some sediment M.H. #2 inv. (est. less than 2" in the pipe flow trough).
  - Areas of the low-permeability cover system that were repaired in April, 1998 are fully vegetated. There are no eroded or thinly vegetated areas on the cap.
- Ron Chiarello and Jennifer Smith (O'B&G) complete an inspection of the engineered wetlands including the wetlands on the north side of Quarry Lake, areas northeast and southeast of the pre-treatment vault, and south of the capped area. O'B&G will prepare a separate wetlands inspection and recommendations report.
- O'B&G sampling team on site for semi-annual groundwater sampling event. O'B&G will complete sampling tomorrow.

GLYNN GEOTECHNICAL ENGINEERING

415 South Transit Street, Lockport, New York 14094

voice 716.625.6933 / fax 716.625.6983

www.glynngroup.com

DOCFIELD:\C19BACKUP\C-19\Word Data\wordshare\Pendleton\FOR\8.10.00\FOR02.doc

Civil • Structural • Geotechnical • Materials Testing • Consulting



a member of the GLYNN GROUP

# FIELD OBSERVATION REPORT (With attachments)

PROJECT NO.: 94-1014-O REPORT NO.: 00-02 DATE: 08/10/00 PAGE: 3 OF 3  
 PROJECT: Pendleton – Frontier Chemical Site DAY: Thursday  
 SUBJECT: Semi-Annual Inspection PROJECT TIME: 7:30 am – 2:30 pm  
 CLIENT: Pendleton PRP Group SITE TIME: 8:00 am – 2:00 pm

- Abul Barkat (NYSDEC) on site in the am. Abul B. discusses wetlands inspection with O'B&G and observes areas of the perimeter berm, the overflow weir, the capped area, and the containment berm along the east side of Quarry Lake. Abul notes that a NYSDEC wetlands specialist may also perform a wetlands inspection. Abul notes that the site is in good condition and notes no deficiencies.
- With Jim Young, note that a pipeline Contractor is working in the Oxy brine line R.O.W. along the east side of the site. In discussions with an operator working in the R.O.W. determine that a new gas pipeline has been installed along the R.O.W. Operator notes that the 3" force main containment pipe from the pre-treatment system to the POTW MH-16 was located and was not damaged during pipeline installation. The new pipe crosses above the discharge piping to the POTW MH-16.
- The manhole covers are replaced and the pre-treatment system is locked upon leaving the site. O'B&G sampling team remains on site to continue sample collection.
- Attachments to this report include:
  - Site Inspection Checklist (3 pages).
  - Copy of the Pre-treatment System Operator's Log (2 pages) completed by B. Brayley.

GLYNN GEOTECHNICAL ENGINEERING

415 South Transit Street, Lockport, New York 14094

voice 716.625.6933 / fax 716.625.6983

www.glynn-group.com

DOCFILE:D:\C19BACKUP\C-19Word Data\wordshare\Pendleton\FOR\8.10.00FOR02.doc

Civil • Structural • Geotechnical • Materials Testing • Consulting

Table 2-1. Frontier Chemical - Pendleton Site - inspection checklist.

Date Performed: AUGUST 10, 2000 Weather: HAZY & WARM (75-80°F)  
 Site Name: PENDLETON - FRONTIER CHEMICAL Inspector Name: ESSE GROSSMAN (W/BB-JS, RCLJ)  
 Site Location: TOKYLINE RD., PENDLETON NY Inspector Signature: [Signature]

Item	Task	Response		Comments
		Yes	No	
Low-Permeability Cover	Visually inspect surface conditions.			
	1. Erosion problem?		X	
	2. Lack or thinning of vegetation?		X	COVER IN EXCELLENT CONDITION, THICK VEG. GROWTH 10" DEEP ±
	3. Mowing required?		X	
	4. Drainage problems?		X	
	5. Areas of settlement?		X	
	6. Areas of slope instability?		X	
Ground Water Collection and Conveyance System	7. Areas of damage?		X	
	Visually inspect manholes and cleanouts.			
	1. Buildup of solids/precipitates to the extent that the flow of ground water is affected?		X	
	2. Measure water levels in manholes and Quarry Lake. a. MH-1? DRY b. MH-2? ← 2" c. MH-3? 6" ± d. Quarry Lake? 578.07'			MH-1: CLEAN MH-2: SOME SEDIMENT IN PIPE FLOW TROUGH
	3. Closed and opened pinch valve?	X		FULLY CLOSED & RETURNED TO OPEN
	4. Leakage, degradation or corrosion of valves, pipes, or appurtenances?		X	
	5. Areas of damage?		X	

Table 2-1. Frontier Chemical - Pendleton Site - inspection checklist.

Date Performed: AUGUST 10, 2000 Weather: HAZY & WARM (75-80°F)  
 Site Name: PENDLETON - FRONTIER CHEMICAL Inspector Name: ESSE GIBBSMAN (10/28, 15, PG. 14)  
 Site Location: IRRAWADDIE RD, PENDLETON, NY Inspector Signature: [Signature]

Item	Task	Response		Comments
		Yes	No	
Ground Water Pre-Treatment System (including Dry Vault and Wet Well)	Perform inspection in accordance with Pre-Treatment System Operations Plan.	X		ALL SYSTEM WORKING PROPERLY • POSSIBLE FAULTY ARV @ GAC #2 • MID HT. CRACK IN VAULT WALL
	Visually inspect ditches and culverts.			
	1. Accumulation of debris?		X	DITCHES CLEAR
	2. Excessive scouring?		X	WELL VEGETATED
Surface Water Runoff Facilities	3. Areas of damage?		X	
	Visually inspect condition.			
	1. Erosion problems?		X	NO DEFICIENCIES NOTED
	2. Areas of settlement?		X	
	3. Areas of slope instability?		X	
Perimeter Berm, Containment Berm, and Outlet Weir	4. Areas of damage?		X	
	Visually inspect condition.			
	1. Casings secured and locked?		X	WELLS / PIEZOMETERS ACCESS FOR SAMPLING
	2. Areas of damage?		X	
Ground Water Monitoring Wells and Piezometers	Visually inspect condition.			
	2. Areas of damage?		X	

Table 2-1. . .ntier Chemical - Pendleton Site - inspection checklist.

Date Performed: AUGUST 10, 2002 Weather: HAZY & WARM (75° - 82° F)  
 Site Name: PENDLETON - FRONTIER CHEMICAL Inspector Name: JESSE GROSSMAN (W/BB, JS, REG, NY)  
 Site Location: TAWWLINE RD, PENDLETON, NY Inspector Signature: [Signature]

Item	Task	Response		Comments
		Yes	No	
Access Road	Visually inspect surface conditions of access roads.			
	1. Rutting?		X	NO DEFICIENCIES NOTED
	2. Potholes?		X	
	3. Settlement?		X	
4. Areas of damage?		X		
Physical Site Security	Visually inspect fences and gates.			
	1. Signs intact?	X		
	2. Fence breached?		X	
	3. Access gates locked?	X		GATES LOCKED BY SAMPLING TEAM.
	4. Areas of damage?		X	
Notes:				
• COINCIDENTAL SEMI-ANNUAL SAMPLING (O'B#6)				
• COINCIDENTAL PRE-TREATMENT SYSTEM DISCHARGE SAMPLING (O'IA)				
• COINCIDENTAL ENGINEERED WETLANDS INSPECTION (O'B#6)				

FRONTIER CHEMICAL - PENDLETON SITE  
 Pretreatment System Operator's Log

Date: 8/10/00

Time In: 7<sup>10</sup> AM  
 Time Out: 9<sup>40</sup> AM

Weather: Clear, cool

Precipitation: ∅

Temp: 62° f

Reason for Visit: Sampling + Inspection  
Assist Jesse Grossman w/ Semi-Annual Inspection

	Reading	Time
Flowmeter Totalization Reading (upon arrival)	<u>406354</u> gal	
Flowmeter Totalization Reading (upon departure)	<u>406502</u> gal	
Flow Rate	<u>8.12</u> gpm	
Pump Hour Meter Readings:	Pump #1	<u>441.2</u> hrs
	Pump #2	<u>346.0</u> hrs
Wet Well Water Level	<u>1.8</u> ft	
Pressure Sensor Reading (Bar Graph)	<u>31.20</u> psi	

	Influent Gauge	Effluent Gauge	Differential
BFI	<u>32</u>	<u>28</u>	<u>4</u>
BF2	<u>28</u>	<u>20</u>	<u>8</u>
GAC1	<u>14</u>	<u>4</u>	<u>10</u>
GAC2	<u>14</u>	<u>4</u>	<u>10</u>

Change Filter Bags (Circle One) YES NO TIME \_\_\_\_\_

Details: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Actions taken to correct problems NONE

Recommended actions to prevent future problems \_\_\_\_\_

Other relevant information Scheduling of filter bag replacement.

SYSTEM CHECK LIST	Arrival	Departure
#1 Vault Door	✓	✓
#2 Panel Door	✓	✓
#3 Vault Sump High	✓	/
#4 Containment Pipe Leak	✓	/
#5 High Wet Well Alarm	/	✓
#6 Pump #1 Fail	✓	/
#7 Pump #2 Fail	/	/
#8 Bag Filter Diff. Pressure High	✓	/
#9 Wet Well Level (Actual Measure Spoken)	1.7	0.5
#10 Flow Rate	0	0
#11 - #16: Reserved for future use		
<b>FOR CURRENT STATUS CALL: 716-743-1335</b>		

Operator Name: Bill Brayley

Signature: Bill Brayley

Attachment E – Wetland Inspections Report

E-1            Wetland Inspections Report

## Field Observation Reports

- February 7, 2000, Field Observation Report