

The electronic version of this file/report should have the file name:

Report.HW.932052.1998-11-09.EW-13-Installation-
Report.pdf

Type of document . Site Number . Year-Month . File Year-Year or Report name . pdf

File .pdf

example: letter . Year-Month . File Year-Year . pdf

.pdf

example: report . Site Number . Year-Month . Report Name . pdf

Project Site numbers will be proceeded by the following:

Municipal Brownfields - B


Superfund - HW

Spills - SP

ERP - E

VCP - V

BCP - C



Golder Associates Inc.

2221 Niagara Falls Boulevard, Suite 9
Niagara Falls, NY USA 14304
Telephone (716) 731-1560
Fax (716) 731-1652



REPORT ON

INSTALLATION OF EXTRACTION WELL EW-13 FOR
ON-SITE GROUNDWATER EXTRACTION SYSTEM
2221 NIAGARA FALLS BOULEVARD
WHEATFIELD, NEW YORK

Submitted to:

Textron Inc.
40 Westminster Street
Providence, RI 02903-2596

DISTRIBUTION:

8 Copies - Textron Inc.; Providence, Rhode Island
1 Copy - Golder Associates Inc.; Buffalo, New York

November 1998

983-9180

Golder Associates Inc.

2221 Niagara Falls Boulevard, Suite 9
Niagara Falls, NY USA 14304
Telephone (716) 731-1560
Fax (716) 731-1652



November 9, 1998

983-9180

Textron Inc.
40 Westminster Street
Providence, RI 02903-2596

Attention: Ms. Leslie Alden

RE: REPORT ON INSTALLATION OF EXTRACTION WELL EW-13 FOR
ON-SITE GROUNDWATER EXTRACTION SYSTEM
2221 NIAGARA FALLS BOULEVARD
WHEATFIELD, NEW YORK

Dear Ms. Alden:

Golder Associates Inc. (Golder Associates) is pleased to submit to Textron, Inc. (Textron) the above referenced report on the installation of extraction well EW-13 as an additional pumping well for the On-Site Groundwater Extraction System at the former Textron Realty Operations (Wheatfield) Inc. facility located at 2221 Niagara Falls Boulevard, Wheatfield, New York. Golder Associates provided design, construction management, and construction oversight services for the project. This report documents that the construction activities on the installation of the new extraction well were conducted in substantial compliance with the plans and specifications as presented in the Design Report entitled, "Final Design of Extraction Well EW-13, On-Site Groundwater Extraction System, Textron Realty Operations (Wheatfield), Inc. Facility, Wheatfield, New York (Revision 2)", Golder Associates, March 1998.

Golder Associates appreciates the opportunity to provide professional engineering services to Textron. If you have any questions regarding this report, please do not hesitate to call.

Very truly yours,

GOLDER ASSOCIATES INC.

David C. Wehn
Project Hydrogeologist

Anthony J. Grasso, P.G.
Associate

DCW/ALG:dml
F/N: FINAL/RECDOC.DOC

STATEMENT OF CERTIFICATION

Golder Associates Inc. (Golder Associates) certifies that the Construction Quality Assurance (CQA) program was conducted under the supervision of a Licensed New York State registered Professional Engineer (P.E.). Based on the CQA monitoring of the installation of Extraction Well EW-13 performed by Golder Associates and Wendel Engineers, P.C. (Wendel), Golder Associates certifies that Extraction Well EW-13 has been constructed in substantial compliance with the plans and specifications in the Final Design of Extraction Well EW-13 (Revision 2) dated March 1998 and approved design modifications and design clarifications. The limits and scope of the portion of Extraction Well EW-13 that Golder Associates is certifying are identified in the attached report. The letter of certification from Wendel accompanies this report. Design changes made during the construction are documented on the as-built drawings accompanying this report. It is the opinion of Golder Associates and Wendel that the changes are minor and did not change the intent of the design. This certification for the work completed by Golder Associates is issued under the seal of Mr. Richard F. Weimer, P.E., of Golder Associates Inc., with New York State License No. 53492.


Richard F. Weimer, P.E.

11/9/98
Date



TABLE OF CONTENTS

| | |
|----------------------------|----|
| Cover Letter | |
| Statement of Certification | i |
| Table of Contents | ii |

| <u>SECTION</u> | <u>PAGE</u> |
|---|-------------|
| 1. INTRODUCTION | 1 |
| 1.1 General..... | 1 |
| 1.2 Extraction Well EW-13 | 1 |
| 2. CONSTRUCTION SUMMARY | 3 |
| 2.1 General..... | 3 |
| 2.2 Subcontractors | 3 |
| 2.3 Construction Observation Summary..... | 4 |
| 2.3.1 Extraction Well Drilling | 4 |
| 2.3.2 Excavation and Piping..... | 5 |
| 3. SUMMARY | 8 |

In Order
Following
Page 8

FIGURE B-1 - Cover Sheet
 FIGURE B-2 - EW-13 Record Drawing Project Location
 FIGURE B-3 - EW-13 Record Drawing Mechanical Details Sheet 1 of 2
 FIGURE B-4 - EW-13 Record Drawing Mechanical Details Sheet 2 of 2
 FIGURE E-1 - EW-13 Record Drawing Electrical Plan (Wendel)
 FIGURE E-2 - EW-13 Record Drawing Electrical Details (Wendel)

APPENDIX A - Wendel's Electrical Certification Report
 APPENDIX B - Design Clarifications/Modifications
 APPENDIX C - Submittals
 APPENDIX D - Acknowledgment of Safety Briefing Sheets
 APPENDIX E - Well Drillhole and Installation Logs
 APPENDIX F - Drill Cuttings Sample Testing Results
 APPENDIX G - Air Monitoring Results
 APPENDIX H - Pipe Pressure Testing Certificates

1. INTRODUCTION

1.1 General

Golder Associates Inc. (Golder Associates) was retained by Textron, Inc. (Textron) to prepare design specifications and drawings for the construction of Extraction Well EW-13, an additional pumping well for the On-Site Groundwater Extraction System to be located approximately midway between existing wells EW-7 and EW-8 (See attached drawings B-1 through B-4 and E-1 and E-2 for details) at the former Textron Realty Operations (Wheatfield) Inc. (TRO) facility. This additional extraction well was requested by the New York State Department Of Environmental Conservation (NYSDEC) in order to provide a more robust hydraulic barrier to offsite migration of Zone 1 groundwater along the southern boundary of the former TRO facility. Golder Associates presented the final design package "Final Design of Extraction Well EW-13, On-Site Groundwater Extraction System, Textron Realty Operations (Wheatfield), Inc. Facility, Wheatfield, New York (Revision 2)", to Textron in March 1998, which was subsequently approved by the NYSDEC. Golder Associates also provided construction management services (including hiring the subcontractors) and full and part time Construction Quality Assurance (CQA) monitoring during construction. The design and CQA monitoring of electrical portions of the project were subcontracted to Wendel, of Buffalo, New York. Construction on the project began on April 6, 1998, with the drilling of the well and construction of the well was substantially complete (except for drying the pipe annulus) by August 8, 1998. Startup of the well occurred on September 25, 1998, once the leak detection cable was dry. The construction observation summary, final record drawings, and other pertinent project documentation are presented herein.

1.2 Extraction Well EW-13

This system consists of the operation of a submersible well pump in an 8-inch nominal diameter open-rock borehole located in the Lockport Dolomite. The borehole is located north of piezometer 96-01(1) (approximately midway between extraction wells EW-7 and EW-8) and approximately 10 feet north of the centerline of the existing On-Site

Groundwater Extraction System header pipe. The borehole was cased with 10-inch diameter High Density Polyethylene (HDPE) pipe through the overburden soil and approximately 3 feet into the top of the bedrock; the remainder of the borehole was uncased. The pump, controls, and associated piping and valving are housed in a 4-foot diameter by 4-foot tall HDPE vault buried nearly flush with the ground surface. The pump level sensors, consisting of high, low, and reference detectors, extend into the well bore through the well pump support plate. When the extraction well is operating, the water level is designed to be maintained between the high and low detector positions. The pump controls are connected to an existing signal from the treatment plant which deactivates the pump in the event of treatment plant shutdown. At the well vault panel, the pump can also be controlled by an automatic/off/hand selector switch. A pump overload signal is returned to the treatment plant in the event of pump overload and shutdown. The pump overload signal was combined with that from EW-7 such that a failure of either will be reported as "pump EW-7/EW-13 overload". The discharge from the pump is routed to a tie-in with the existing On-Site Groundwater Extraction System header pipe and delivered to the On-Site Groundwater Extraction System treatment plant.

2. CONSTRUCTION SUMMARY

2.1 General

This section presents a summary of the field observations performed by Golder Associates during the installation of EW-13. Field observations consist of field notes of construction progress, pipe pressure test data, air monitoring data, safety briefing documentation, photographic documentation, and survey data. Additionally, considering the construction activities were performed in areas potentially impacted by groundwater contamination, Golder Associates conducted air monitoring for volatile organic vapors and combustible gases during the well drilling and excavation process. As the vaults at EW-7 and EW-8, and the EW-13 excavation (when greater than 4-feet deep) were considered confined spaces, Golder Associates also conducted air monitoring for volatile organic vapors, combustible gases, and oxygen in these spaces prior to entry into them. Field observations of the electrical portions of the project were noted by Wendel and are included as Appendix A. The location of EW-13 is provided on Figure B-2. Specific details of as-built conditions for EW-13 are provided on Figures B-3 and B-4. The general electrical plan and details, as provided by Wendel, are located on Figures E-1 and E-2, respectively. Occasionally, design clarifications and modifications were necessary to allow for changing conditions; these are presented in Appendix B.

2.2 Subcontractors

Golder Associates retained Marcor Remediation, Inc. (Marcor) of Buffalo, New York, as the piping and excavation contractor. Marcor retained Cayuga Piping of Niagara Falls, New York, for portions of the extrusion welding of the containment piping. Weydman Electric, Inc. (Weydman) of Tonawanda, New York, was utilized by Golder Associates as the electrical contractor; Maxim Technologies Inc. of Hamburg, New York, was retained for drilling the extraction well and installing the overburden casing; and Klettke Land Surveyors, P.C. of Niagara Falls, New York, provided surveying. Friend Laboratory Inc. of Waverly, New York, was utilized as the analytical laboratory for the testing of soil-cuttings sample obtained from the soil cuttings generated during drilling of

EW-13. Wendel, of Buffalo New York, was subcontracted by Golder Associates to provide design and CQA services for the electrical portions of the project. Subcontractors' submittals are provided in Appendix C. Acknowledgment of Safety Briefing Sheets, indicating that contractor personnel were briefed on site safety issues, are provided in Appendix D.

2.3 Construction Observation Summary

2.3.1 Extraction Well Drilling

Maxim mobilized drilling equipment and materials to the site on April 6, 1998. Preparation for drilling the extraction well included: laying out the location of the well, clearing the location with the local utility companies and site personnel, and setting up traffic barriers.

The overburden soil material was drilled 0.8 feet into the bedrock surface (Zone 1) using auger (12-inch inside diameter (ID)) drilling techniques. Drilling continued by advancing the borehole 3 feet into bedrock with a 12-inch diameter drilling bit using appropriate air rotary drilling techniques. A 750 scfm air compressor, provided with an oil trap on the air line, was used for all air drilling operations. All drill cuttings and circulated fluids were contained and collected into 55-gallon drums. Ten-inch outside diameter (OD) SDR 11 HDPE overburden casing was installed through the augers into the borehole and pressure grouted in-place by the tremie method using a cement/bentonite grout mixture. Cement/bentonite grout was mixed in the appropriate proportions of:

- One 94-pound bag of Portland cement;
- Five gallons to six gallons water; and
- Five percent powdered bentonite by volume.

The grout was allowed to cure over a weekend. Subsequent drilling was completed by advancing through the inside of the casing and into the Zone 1 bedrock with a nominal 8-inch diameter bit using air rotary techniques to a depth of approximately 25 feet below ground surface. At this depth, drilling proceeded with an HQ-size air coring bit for 10 feet

(35 feet below ground surface), in order to secure a 10-foot long sample of bedrock which was provided to Richard Yager of the United States Geological Survey for sampling and research purposes. This interval was then reamed to a nominal 8-inch diameter, as above, to a depth of 35 feet below ground surface following collection of the core sample. A well installation log documenting the drilling of extraction well EW-13 is provided in Appendix E.

Following reaming of the borehole, it was developed by blowing air through the drill rods in a "pulsing" fashion until drill cuttings were removed and clear water was returned to the surface. Drilling was completed on April 8, 1998. Groundwater produced during drilling was transported by Maxim on April 9, 1998, to the On-Site Groundwater Extraction System treatment plant where it was treated prior to discharge. The empty, hose-washed drums were later removed by Maxim. Drill cuttings were containerized and representatively sampled by Golder Associates for Toxicity Characteristic Leaching Procedure (TCLP) Volatile Organic Compound (VOC) analysis. No analytical detections were noted. Sample results are presented in Appendix F.

Air monitoring conducted by Golder Associates during the well drilling operations did not indicate any detections of volatile organic compounds or combustible gases. Air monitoring results are presented in Appendix G.

2.3.2 Excavation and Piping

Marcor mobilized equipment and materials to the site on May 26, 1998, after delays in obtaining the requisite double-wall piping. Preparation for construction of EW-13 included laying out the limits of the excavation, locking out the power and valving off the 2-inch line to vaults EW-7 and EW-8, and setting up traffic barriers. Following these activities, Marcor initiated construction by saw-cutting the asphalt parking lot. After cutting of the parking lot asphalt, the vault excavation was completed with a tractor-mounted backhoe and the HDPE vault placed in position over a approximately 0.5 foot-thick layer of New York State Department of Transportation (NYSDOT) #1A stone.

Concurrently, the pump support plate, pump, riser, stilling well, and motor starter were removed from extraction well DW-9 and stored in plastic sheeting near DW-9 until they were needed for EW-13. The pump itself was cleaned prior to its use in EW-13 by the operation and maintenance personnel for the On-Site Groundwater Extraction System treatment plant (employees of CRA Services, formerly TreaTek-CRA, of Niagara Falls, New York). The 2-inch line leading into vault DW-9 was capped with a blind flange at the closest point possible to the interior vault wall. The 8-inch diameter well casing in DW-9 was closed with an expandable well plug to prevent debris from entering the well.

South of the vault for EW-13, the excavation was hand-dug (below a depth of approximately 4 feet below ground surface) to expose the existing conduits and header line running from EW-7 to EW-8. The excavation was shored on June 1, 1998 after its depth exceeded 4 feet.

Golder Associates performed air monitoring for organic vapors and combustible gases periodically during the excavation process and prior to entry of the excavation. Air monitoring results for organic vapors and combustible gases were not above background levels during construction. Air monitoring results are presented in Appendix G. The excavated soils were spread and seeded at an on-site location designated by site personnel, and approved by the NYSDEC.

On June 3, 1998, the existing header line was cut and the process of splicing in the "T" connection to EW-13 began. First, the 2-inch carrier pipe connections were made using electrofusion couplers. Next, the 6-inch containment connections were made using prefabricated HDPE couplers which were extrusion-welded at each end to the HDPE pipe. The leak detection cable was cut and spliced with cable connectors to enable it to pass through the horizontal section of the prefabricated "T". The leak detection cable was protected from the heat of extrusion welding the 6-inch containment pipe by passing the cable through lengths of 1-1/4 inch conduit in the areas of the welds.

On June 9, 1998, while Marcor was continuing to assemble the pipe connections, a representative of the Occupational Safety and Health Administration (OSHA) arrived and cited Marcor for deficiencies in the excavation shoring. These were corrected by June 12, 1998, and work resumed on the piping connections.

The 6-inch pipe annulus was sealed for leak-testing purposes by removing the leak detection cable fittings, pushing the cable into the pipe, and plugging the fitting holes with threaded plugs. The 2-inch pipe was sealed for leak-testing by removing piping inside vaults EW-7, EW-8 and EW-13 so blind flanges could be installed. The pre-backfill leak tests on both the 2-inch and 6-inch pipes from EW-7 to EW-13 to EW-8 were successfully completed by June 23, 1998. Pipe pressure testing certificates are presented in Appendix H. Once the tests were completed, the excavation was backfilled with NYSDOT #1A stone up to the level of the conduit. The pump and associated equipment from DW-9 were placed in EW-13 at this time.


Weydman began placing conduit and performing other electrical work on June 29, 1998, completed work in the excavation by July 7, 1998, and were essentially finished on July 21, 1998. The excavation was backfilled to the level of the asphalt on July 9, 1998, and post-backfill leak-testing was initiated. The 6-inch pipe failed its leak test on July 15, 1998. Due to a scheduling delay, Marcor could not re-mobilize to the site until August 3, 1998. The pipe was re-excavated and re-shored on August 3, 1998, and the leak in the west extrusion weld of the eastern lower coupling was repaired. The shoring was removed and the excavation was backfilled on August 8, 1998. Both pre-backfill and post-backfill leak tests were successfully completed by August 9, 1998. The system was tested on September 21, 1998, following drying of the leak detection cable between EW-7 and EW-8 with compressed air and nitrogen. Following adjustment of the water level sensor cables, the system was successfully started on September 25, 1998.

3. SUMMARY


Based on the results of field observations, it is Golder Associates' professional opinion that the installation of Extraction Well EW-13 was conducted in substantial compliance with the plans and specifications as presented in the Design Report entitled, "Final Design of Extraction Well EW-13, On-Site Groundwater Extraction System, Textron Realty Operations (Wheatfield), Inc. Facility, Wheatfield, New York (Revision 2)", Golder Associates, March, 1998.

Golder Associates appreciates the opportunity to provide professional engineering services to Textron. Should you have any questions regarding the content of this report, please call.

GOLDER ASSOCIATES INC.




David C. Wehn
Project Hydrogeologist



Anthony L. Grasso, P.G.
Associate

F/N: FINAL/RECDOC.DOC



**RECORD DRAWINGS - EXTRACTION WELL EW-13
ONSITE GROUNDWATER EXTRACTION SYSTEM
2221 NIAGARA FALLS BOULEVARD
WHEATFIELD, NEW YORK**


Provided by:



DRAWING LIST

| Drawing No. | Drawing Title |
|--------------------|---|
| B-1 | COVER SHEET |
| B-2 | EW-13 RECORD DRAWING PROJECT LOCATION |
| B-3 | EW-13 RECORD DRAWING MECHANICAL DETAILS (SHEET 1 OF 2) |
| B-4 | EW-13 RECORD DRAWING MECHANICAL DETAILS (SHEET 2 OF 2) |
| E-1 | EW-13 RECORD DRAWING ELECTRICAL PLAN |
| E-2 | EW-13 RECORD DRAWING ELECTRICAL DETAILS |

NOVEMBER 1998




LEGEND

- ⊕ 87-12(1) MONITORING WELL LOCATIONS
- ⊕ DW DNAPL WELL
- ⊕ EW EXTRACTION WELL
- EXTRACTION SYSTEM BURIED PIPELINE
- INDICATES DIRECTION OF FLOW
- W — WATER UTILITY
- F — FIRE PROTECTION UTILITY
- G — GAS UTILITY
- E — ELECTRICAL UTILITY
- SS — STORM SEWER UTILITY
- SAS — SANITARY SEWER UTILITY

NOTES


1. BASE TOPOGRAPHIC MAP PREPARED BY AERO-METRIC ENGINEERING, INC. ON 5/3/91.
2. THE UNDERGROUND UTILITIES SHOWN ARE BASED ON MAPS PROVIDED BY BELL AEROSPACE TEXTRON. THERE MAY BE ADDITIONAL UTILITIES NOT SHOWN. GOLDER ASSOCIATES IS NOT RESPONSIBLE FOR THE ACCURACY OR COMPLETENESS OF THE UTILITY MAPS PROVIDED BY BELL AEROSPACE TEXTRON. APPROXIMATE LOCATIONS OF UTILITIES ARE FOR SURVEYED LOCATIONS OF UTILITIES WHICH ARE CROSS EXTRACTION SYSTEM.




| | | | | | |
|--|--|-------------------------|----------|-------------|----------|
| CLIENT/PROJECT | | TEXTRON | | NOV 09 1993 | |
| | | NIAGARA FALLS, NEW YORK | | | |
| TITLE | | | | | |
| EW-13 RECORD DRAWING PROJECT LOCATION | | | | | |
| Buffalo, New York | | DRAWN | DEC | DATE | 9/30/93 |
| | | CHECKED | DCW | SCALE | AS SHOWN |
| | | REVIEWED | ALG | JOB NO. | 603-0100 |
| | | APPROVED | ALG | DWG. NO. | BELL-128 |
| | | FILE NO. | 073-0170 | FIGURE | E-2 |

| REV. | DATE | DESCRIPTION | DR. BY | APP. BY |
|------|------|-------------|--------|---------|
| | | | | |
| | | | | |







1
B-3
GENERAL LAYOUT - EXTRACTION WELL EW-13
CROSS SECTION VIEW
NOT TO SCALE




2
B-3
GENERAL LAYOUT
EXTRACTION WELL EW-13
PLAN VIEW
NOT TO SCALE



3
B-3
VAULT PENETRATION DETAIL
EXPLODED VIEW
NOT TO SCALE



4
B-3
VAULT AND PIPING DETAILS
NOT TO SCALE




PLAN VIEW


| REV. | DATE | DESCRIPTION | DR. BY | APP. BY |
|------|------|-------------|--------|---------|
| | | | | |

| | | | | | |
|----------------------|--|-------------------------|----------|-------------|--|
| CLIENT/PROJECT | | TEXTRON | | NOV 09 1999 | |
| TITLE | | NIAGARA FALLS, NEW YORK | | | |
| EW-13 RECORD DRAWING | | | | | |
| MECHANICAL DETAILS | | | | | |
| SHEET 1 OF 2 | | | | | |
| DRAWN | | REC | DATE | 9/30/98 | |
| CHECKED | | DCW | SCALE | AS SHOWN | |
| INVENTED | | ALG | JOB NO. | 893-0180 | |
| APPROVED | | ALG | FIG. NO. | BELL-126 | |
| FILE NO. | | 973-9170 | FIGURE | B-3 | |


Golden Associates






1
B-4 WELL BOTTOM DETAIL
NOT TO SCALE





2
B-4 PUMP SLEEVE DETAIL
NOT TO SCALE



3
B-4 HEADER TIE-IN PROCEDURE
NOT TO SCALE



4
B-4 HEADER TIE-IN COUPLING DETAILS/PROCEDURES
NOT TO SCALE



5
B-4 STAINLESS STEEL PLATE
NOT TO SCALE

CLIENT/PROJECT
TEXTRON
NIAGARA FALLS, NEW YORK

DATE: NOV 09 1998

TITLE
EW-13 RECORD DRAWING MECHANICAL DETAILS
SHEET 2 OF 2

Buffalo, New York


| | | | |
|----------|----------|----------|----------|
| DESIGNED | REC | DATE | 09/30/88 |
| CHECKED | DCW | SCALE | AS SHOWN |
| REVIEWED | ALG | JOB NO. | 083-0150 |
| APPROVED | ALG | DWG. NO. | BELL-127 |
| FILE NO. | 073-0170 | FIGURES | B-4 |

Golden Associates

| REV. | DATE | DESCRIPTION | DR. BY | APP. BY |
|------|------|-------------|--------|---------|
| | | | | |
| | | | | |

ON

FORMER BELL AEROSPACE TEXTRON WHEATFIELD PLANT




LEGEND

- 87-12(1) EXISTING MONITORING WELL LOCATIONS
- EW EXTRACTION WELL
- EXTRACTION SYSTEM BURIED PIPELINE
- INDICATES DIRECTION OF FLOW
- W WATER UTILITY
- F FIRE PROTECTION UTILITY
- G GAS UTILITY
- E ELECTRICAL UTILITY
- SS STORM SEWER UTILITY
- SAS SANITARY SEWER UTILITY


GENERAL NOTES:

1. THE DRAWINGS ARE DIAGRAMMATIC AND INDICATE GENERALLY THE LOCATIONS OF THE MATERIAL AND EQUIPMENT.

SITE PLAN
SCALE: 1"=60'




SECTION



PLAN


EXTRACTION WELL
NO SCALE



| | | | | | | | |
|--|-----|----------|--------------|------------------------------|--------------------------------------|----------------------|--------|
| REV | | DATE | | DESCRIPTION | | DR BY | RVW BY |
| SCALE: | | AS SHOWN | | PROJECT: | | TEXTRON NOV 09 1995 | |
| PROJECT No. | | 2847-13 | | PROJECT: | | WHEATFIELD, NEW YORK | |
| DES BY | JJR | 11/97 | SHEET TITLE: | | EW-13 RECORD DRAWING ELECTRICAL PLAN | | |
| DR BY | JJR | 11/97 | SHEET | | OF | | |
| CHK BY | | | FILE No. | | XXX | | |
| RVW BY | | | SHEET | | OF | | |
| WENDEL | | | | BUFFALO, N.Y. LOCKPORT, N.Y. | | | |
| ENGINEERING • ARCHITECTURE • SURVEY • CONSTRUCTION | | | | E-1 | | | |


NOTE: THIS DOCUMENT, AND THE IDEAS AND DESIGNS INCORPORATED HEREIN, AS AN INSTRUMENT OF PROFESSIONAL SERVICE, IS THE PROPERTY OF WENDEL ENGINEERS P.C. AND IS NOT TO BE USED, IN WHOLE OR IN PART, FOR ANY OTHER PROJECT WITHOUT THE WRITTEN AUTHORIZATION OF WENDEL ENGINEERS P.C.

NOTE: UNAUTHORIZED ALTERATION OR ADDITION TO ANY SURVEY DRAWING, DESIGN, SPECIFICATION, PLAN OR REPORT IS A VIOLATION OF SECTION 7200, PROVISION 2 OF THE NEW YORK STATE EDUCATION LAW.




VAULT CONTROL PANEL SCHEMATIC

- KEY
- - - - - INDICATES EXTERNAL PANEL WIRING
 - INDICATES INTERNAL PANEL WIRING
 - TERMINAL BLOCK LOCATED IN PANEL



VAULT CONTROL PANEL IS NEMA 4X STAINLESS STEEL WITH HINGED COVER HOFFMAN CAT. No. A-XXH2408SSLP

VAULT CONTROL PANEL
NO SCALE



MOTOR OVERLOAD WIRING

NOTE: THIS DOCUMENT, AND THE IDEAS AND DESIGNS INCORPORATED HEREIN, AS AN INSTRUMENT OF PROFESSIONAL SERVICE, IS THE PROPERTY OF WENDEL ENGINEERS P.C. AND IS NOT TO BE USED, IN WHOLE OR IN PART, FOR ANY OTHER PROJECT WITHOUT THE WRITTEN AUTHORIZATION OF WENDEL ENGINEERS P.C.

NOTE: UNAUTHORIZED ALTERATION OR ADDITION TO ANY SURVEY DRAWING, DESIGN, SPECIFICATION, PLAN OR REPORT IS A VIOLATION OF SECTION 2203, PROVISION 2 OF THE NEW YORK STATE EDUCATION LAW.

| REV | DATE | DESCRIPTION | DR BY | RW BY |
|--|-------|---|-------|-------|
| | | | | |
| | | | | |
| SCALE: AS SHOWN | | PROJECT: WHEATFIELD, NEW YORK | | |
| PROJECT No. 2847-13 | | NOV 09 1998 | | |
| DES BY: JJR | 11/97 | SHEET TITLE: EW-13 RECORD DRAWING VAULT PANEL | | |
| DR BY: JJR | 11/97 | | | |
| CHK BY: | | | | |
| REV BY: | | | | |
| WENDEL | | SHEET OF | | |
| BUFFALO, N.Y. LOCKPORT, N.Y. | | FILE No. XXX | | |
| ENGINEERING • ARCHITECTURE • SURVEY • CONSTRUCTION | | E-2 | | |

APPENDIX A

Wendel's Electrical Certification Report

WENDEL

SUITE 100
95 JOHN MUIR DRIVE
BUFFALO, NEW YORK 14228
716/688-0766 or 625-6867
FAX 716/625-6825
e-mail: wendel@wendel-design.com

October 20, 1998

Mr. Anthony Grasso, P.G., Associate
Golder Associates Inc.
2221 Niagara Falls Boulevard
L.P.O. Box 4069
Niagara Falls, New York 14304-4069

SUBJECT: CQA CERTIFICATION OF ELECTRICAL INSTALLATION
FOR CONSTRUCTION OF GROUND WATER EXTRACTION WELL - 13
TEXTRON REALTY OPERATIONS INC. FACILITY
WHEATFIELD, NEW YORK
WENDEL PROJECT NO. 2847-13
GOLDER PROJECT NO. 983-9180

Dear Mr. Grasso:


Wendel Engineers, P.C., provided site observation of the electrical components for the facility during the construction of the Ground Water Extraction Well - 13 at the former Textron Realty Operations Inc. Facility, Wheatfield, New York. Our site observations included the review of all visible and above ground electrical work involving instrumentation, control and power. Based on our site observations, Wendel certifies to the best of our knowledge that the electrical installation for the Ground Water Extraction Well - 13 has been constructed in substantial accordance with the permit drawings E1 and E2.


The certification for the work completed is issued for Wendel under the seal of Michael B. Turri, P.E., Principal of Wendel Engineers, P.C., with New York State License No. 54003.


If you have any questions with regard to the contents of this certification report, please contact the undersigned.

Very Truly Yours,

WENDEL


Michael B. Turri, P.E.
Principal




Robert J. McNamara, P.E.
Project Engineer

WENDEL
Field Report

PROJECT: Bell Aerospace Textron Extraction Well EW-13

FR NO: 1

PROJECT #: 284713

DATE: June 18, 1998

Owner: Textron Realty Operations

Engineer: Wendel

Observer: John Rauen

PERIOD: 10:00 am

Contractor: Weydman Electric

Observations and directives are as follows:

Looked in existing Extraction Wells for grounding conditions. Found ground wire running through side wall of EW-7. The remainder of the wells had grounds running through vault walls with conduit penetrations. Each vault panel was grounded.

WENDEL
Field Report

PROJECT: Bell Aerospace Textron Extraction Well EW-13

FR NO: 2

PROJECT #: 284713

DATE: June 30, 1998

Owner: Textron Realty Operations

Engineer: Wendel

Observer: John Rauen

PERIOD: 9:30 am

Contractor: Weydman Electric

Observations and directives are as follows:

Observed installation of conduit for new extraction well. Contractor cut existing conduits and attached a 45 deg bend, then ran straight into well. One conduit remains to be attached. Conduit entries into well vault must be sealed. Two ground rods were in place for grounding of panel in vault.

WENDEL

Field Report

PROJECT: Bell Aerospace Textron Extraction Well EW-13

FR NO: 3

PROJECT #: 284713

DATE: July 24, 1998

Owner: Textron Realty Operations

Engineer: Wendel

Observer: John Rauen

PERIOD: 9:00 am

Contractor: Weydman Electric

Observations and directives are as follows:

Observed installation of vault control panel in extraction well. Control panel was installed with components as shown on Drawings E1 and E2. Open items from FR2 were confirmed by Golder representative to have been completed.

Submitted by: WENDEL

PM-18

APPENDIX B

Design Clarifications/Modifications

SPECIFICATION / DESIGN MODIFICATION FORM

PROJECT NUMBER: 983-9180
OWNER: Textron Inc.
LOCATION: Textron Realty Operations
Wheatfield (Inc.) Facility, NY

PROJECT TITLE: Textron/EW-13 Eng. Serv./NY
CONSTR. MNGR. Golder Associates Inc.

FORM NUMBER 1

LOCATION / REFERENCE OF MODIFICATION: Drawing details 2/B-3 and 1/B-4, and relevant
portions of Specifications.

MODIFICATION MADE: Standard dimensional ratio (SDR) of HDPE overburden casing changed
from SDR 17.6 as specified to SDR 11 which has thicker walls. Reduced inside diameter of this pipe
(approximately 8 inches) necessitated reducing the rock borehole diameter from 9 inches to 8 inches
and shortening the stilling well from 6 inches above the bottom of the pump sleeve to 6 inches above
the top of the pump sleeve. The above borehole diameter and stilling well configuration are
consistent with the design of the Off-Site Groundwater Extraction System.

APPROVED BY DESIGNER: David Wehn Golder Associates Inc. 4/9/98
NAME COMPANY DATE

OWNER NOTIFIED OF MODIFICATION: YES
 NO

Leslie Alden Textron Inc. 4/9/98
NAME COMPANY DATE

REMARKS: SDR of pipe changed to accommodate pipe availability relative to project schedule.

ATTACHMENTS:
None.

DISTRIBUTION:
Leslie Alden - Textron Inc. Robert McNamara - Wendel
Kevin Thompson - Marcor Remediation Inc. Golder Associates Inc.
Robert Hobba - Weydman Electric Inc.

SPECIFICATION / DESIGN MODIFICATION FORM

PROJECT NUMBER: 983-9180
OWNER: Textron Inc.
LOCATION: Textron Realty Operations
Wheatfield (Inc.) New York Facility

PROJECT TITLE: Textron/EW-13 Eng. Serv./NY
CONTRACTOR: Golder Associates Inc.

FORM NUMBER 2

LOCATION / REFERENCE OF MODIFICATION: Drawing detail 2/B-3, and relevant portions
of Specifications.

MODIFICATION MADE: Butt-Fusion weld joining vault penetration piping to exterior piping
replaced by coupler weld as in detail 4/B-4.

APPROVED BY DESIGNER: Anthony Grasso Golder Associates Inc. 5/29/98
NAME COMPANY DATE

OWNER NOTIFIED OF MODIFICATION: YES
 NO

Leslie Alden Textron Inc. 5/29/98
NAME COMPANY DATE

REMARKS: _____

ATTACHMENTS: None.

DISTRIBUTION:
Leslie Alden - Textron Inc. Robert McNamara - Wendel
Kevin Thompson - Marcor Remediation Inc.
Robert Hobba - Weydman Electric Inc.

SPECIFICATION / DESIGN MODIFICATION FORM

PROJECT NUMBER: 983-9180
OWNER: Textron Inc.
LOCATION: Textron Realty Operations
Wheatfield (Inc.) New York Facility

PROJECT TITLE: Textron/EW-13 Eng. Serv./NY
CONTRACTOR: Golder Associates Inc.

FORM NUMBER 3

LOCATION / REFERENCE OF MODIFICATION: Drawing detail 2/B-3 and relevant portions of
Specifications.

MODIFICATION MADE: NYSDOT #1A stone replaced by flowable (flyash) fill from approximately
one foot below the bottom of the 6-inch containment pipe to approximately 4-inches above the top of the pipe.
Modification applies only to the lower portion of the pipe, not that connecting EW-13 to the "T".

APPROVED BY DESIGNER: Anthony Grasso Golder Associates Inc. 8/6/98
NAME COMPANY DATE

OWNER NOTIFIED OF MODIFICATION: YES
 NO

Leslie Alden Textron Inc.
NAME COMPANY DATE

REMARKS: Modification made to better support pipe during backfill operations.

ATTACHMENTS: See attached design data.

DISTRIBUTION:
Leslie Alden - Textron Inc. Robert McNamara - Wendel
Kevin Thompson - Marcor Remediation Inc.
Robert Hobba - Weydman Electric Inc.



**Contract
Drilling
and
Testing**

1951-1 Hamburg Turnpike
Buffalo, NY 14218

Phone: (716) 821-5911
Fax: (716) 821-0163

55 Oliver Street
Canoes, New York 12047

Phone: (518) 238-1145
Fax: (518) 238-1249

P.O. Box 416 • 208 Le Fevre Road
Stockertown, PA 18083

Phone: (610) 748-2870
Fax: (610) 748-2669

TOLL FREE: 1-800-821-5911

May 9, 1997

Pina Hill Concrete
2255 Bailey Avenue
Buffalo, New York 14211-1798
Ph: 894-2255/Fax: 894-6572

Attention: *Brian Kirchmeyer*

Reference: *Flowable Fill*

Gentlemen,

As requested, SJB SERVICES performed a series of Laboratory Tests on 6" x 12" cylinder specimens which were fabricated using flowable fill. A copy of the Laboratory Test Results are attached for your review.

Based on this data and our experience with flowable fill, we expect that a bearing value of 2000 PSF could be assigned to a material with these properties. These properties are typical for most flowable fill supplied in the Western New York area.

Flowable fill being a mixture of sand, flyash and cement mixed with water, when properly placed, should consolidate in place to 95% of its maximum unit weight.


If you have any further questions, please contact the undersigned.

Respectfully Submitted.

SJB SERVICES INC.

Stanley J. Blas
Stanley J. Blas
President

vah
Attachment



"QUALITY & SERVICE THE WAY IT USED TO BE"



Sent by: MARCOR REMEDIATION
Received Aug-06-98 02:02pm
AUG-08-98 THU 02:10 PM

AUG-06-98 02:13PM


from 7164478799@7166915189

Page 3

from CCITT G3 -> MARCOR REMEDIATION

page 2

P. 02/08



DATE: _____
PROJECT: _____
TO: _____

SUBJECT: FLOWABLE FILL SUGGESTED DESIGN MIX

WE SUBMIT FOR REVIEW THE USE OF THE FOLLOWING MATERIALS AND PROPORTIONS PER CUBIC YARD TO SUPPLY FLOWABLE FILL TO THE ABOVE REFERENCED PROJECT.

QUALITATIVE DATA

PINE HILL MIX NO. 300001 / 199
SPECIFIED STRENGTH MINIMUM 100 psi @ 28 Days
ASTM - C33 AGG. SIZE --
AREAS OF USE Fill Materials

MATERIALS: SOURCE QUANTITIES/CU. YD. (S.S.D.)

CEMENTITIOUS:
CEMENT TYPE: LAFARGE CEMENT 100 #

FINE AGGREGATE:
COAL FLY ASH NMPC HUNTLEY STATION 2373 #

BATCHED WATER IN #: CITY 417 #

ADMIXTURES: NONE

PLASTIC PROPERTIES:
W/C RATIO: 4.20 lb./lb.
AIR CONTENT RANGE: 2% - Entrapped Only
SLUMP RANGE: 8 to 10 inches
UNIT WEIGHT: 103.1 lb./cu.ft.

The Flyash used from Niagara Mohawk meets the requirements of 711-10 identified in the New York State specification (Item 17502.95) for Flowable Fly Ash Material. The finished product as well is certified to meet the requirements of Item 17203.80 - Controlled Low Strength Material (CLSM).

RESPECTFULLY SUBMITTED:



**Contract
Drilling
and
Testing**

1951-1 Hamburg Turnpike
Buffalo, NY 14218

Phone: (716) 821-5911
Fax: (716) 821-0183

55 Oliver Street
Cohoes, New York 12047

Phone: (518) 238-1145
Fax: (518) 238-1249

P.O. Box 416 • 208 Le Fevre Road
Stockertown, PA 18083

Phone: (610) 746-2670
Fax: (610) 746-2669

TOLL FREE: 1-800-821-5911

Laboratory Test Report

PROJECT : MATERIAL TESTING : PINE HILL CONCRETE

CLIENT : PINE HILL CONCRETE

DATE : MAY 8, 1997

PROJECT NO.: SJB-T691

REPORT NO.: LTR-8

SAMPLE INFORMATION :

Sample No. 97-218 and 97-219 were collected by the client and received at SJB Services, Inc. on May 7, 1997. Samples are described as two (2) 6"x12" flowable fill cylinders representing Mix 99 of the Easy Fill material placed on April 23, 1997.

Unconfined Compressive Strength Utilizing a Pocket Penetrometer

| Sample Number | Penetrometer Reading |
|---------------|--|
| 97-218 | Exceeded the limits of the gauge (4.5 tons per square foot) |
| 97-219 | Exceeded the limits of the gauge (4.5 tons per square foot) |

Unit Weight of the Flowable Fill Cylinders

| Sample Number | Unit Weight |
|---------------|----------------------------|
| 97-218 | 95.82 lbs./ft ³ |
| 97-219 | 94.99 lbs./ft ³ |

ASTM C-39: Compressive Strength of Cylindrical Concrete Specimens

| Sample Number | Maximum Load lbs. | Diameter in. | Area in. ² | Compressive Strength PSI |
|---------------|-------------------|--------------|-----------------------|--------------------------|
| 97-218 | 2880 | 5.955 | 27.852 | 103.4 |
| 97-219 | 3430 | 5.958 | 27.880 | 123.0 |

SJB Services, Inc.

Paul Gregorczyk
Paul Gregorczyk
Laboratory Manager


Ray J. Kron
Ray J. Kron
Testing Services Manager



"QUALITY & SERVICE THE WAY IT USED TO BE"



New York State Department of Environmental Conservation
60 Wolf Road, Albany, New York 12233



Thomas C. Jerling
Commissioner

JUL 22 1991

Mr. James F. Sullivan
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, NY 13202

CEIVL

JUL 26 1991

URL SUPPLY
SYRACUSE

Dear Mr. Sullivan:


Re: Beneficial Use Determination
Coal Ash Utilization
(BUD #076-7-34)

This is in response to your July 3, 1991 petition for a beneficial use determination (BUD) regarding the use of fly ash from Niagara Mohawk Power Corporation's (NMPC) coal-fired units in Dunkirk and North Tonawanda, New York, as a flowable fill in construction projects.

We have reviewed the metal analyses of the raw fly ash leachate based on the USEPA Toxic Characteristic Leaching Potential (TCLP) and the Monofilled Waste Extraction Procedure, USEPA Technical Resource Document SW-924; and the arsenic analyses of leachate from a stabilized NMPC fly ash flowable fill cylinder based on the SW-924 protocol. Our review indicates that in this stabilized form the 6 NYCRR Section 703.6 groundwater discharge standards for TCLP metals will not be exceeded.

Accordingly, the use of NMPC fly ash as a stabilized (flowable fill) product is approved in accordance with 6 NYCRR Paragraph 300-1.2(u)(5), with the following conditions:

- For each project location, NMPC must notify the project sponsor in writing, in advance, that the flowable fill contains coal combustion fly ash.
- Any contractual arrangements that are made between NMPC and the user of the fly ash, must indicate that the user has the necessary equipment to perform the work; will only use the fly ash as an ingredient for flowable fill; and will incorporate the fly ash directly into the flowable fill production process.
- All flowable fill mixes must be properly formulated. NMPC will be responsible to conduct, and keep appropriate records on, all testing necessary to ensure finished product quality.
- A semiannual report on the amount of fly ash which is being utilized in this manner must be submitted to the Bureau of Resource Recovery, Division of Solid Waste, NYSDEC, so that we may keep track of the amount of material beneficially reused throughout the State. This report should include the location, amount used at each location, and type of use.





Niagara Mohawk Power Corporation
Ash Utilization Group
3500 River Road
Tonawanda, NY 14150

FLOWABLE FILL COAL COMBUSTION FLY ASH

| <u>Major Constituents in Coal Fly Ash</u> | <u>Huntlev %</u> | <u>Dunkirk %</u> |
|--|------------------|------------------|
| Silicon Dioxide (SiO ₂) | 47.35 | 40.24 |
| Iron Oxide (Fe ₂ O ₃) | 19.28 | 17.36 |
| Aluminum Oxide (Al ₂ O ₃) | 13.48 | 18.17 |
| Calcium Oxide CaO | 3.58 | 3.81 |
| Magnesium Oxide (MgO) | 0.52 | 0.48 |
| Potassium Oxide (K ₂ O) | 2.39 | 1.81 |
| Sodium Oxide (Na ₂ O) | 0.77 | 0.76 |
| Titanium Oxide (TiO ₂) | 1.22 | 1.17 |
| Manganese Dioxide (MnO ₂) | 0.02 | 0.02 |
| Sulfur Trioxide (SO ₃) | 0.95 | 1.31 |
| Loss-On-Ignition (unburned carbon) * | 10.46 | 16.87 |
| | Total 100.00 | 100.00 |

*varies on average from 8-17%

Mix Design CE100

Specifications:

Strength: Minimum 100 psi @ 28 Days
Slump: 8" to 10"
Cement: Type I/II Amount: 100 lbs./cu.yd.
W/C Ratio: 4.2 lb./lb.
Aggregates: Coal Fly Ash
Admixtures: None

Design Mix Per Cubic Yard:

Cement: 100 lbs.
Conditioned Fly Ash: 2273 lbs.
Aggregates: None
Water: 417 lbs.
Fresh Unit Weight: 103 lbs./cu.ft.

Compressive Strength Tests (psi):

3 days - 85; 7 days - 85; 14 days - 150; 21 days - 160; 28 days - 175

Shrink and Swell Potential

ASTM D 2218-82 Moisture Content
ASTM D 4318-84 (Method A) Liquid and Plastic Limits
ASTM D 427-83 Shrinkage Limit
Swell Potential: After testing for 12 days, no volume change was measured




CEMENT MILL TEST REPORT

Period Represented: DECEMBER 1996
Plant: BATH
Cement Type: II

| PHYSICAL DATA | | CHEMICAL DATA | Percent |
|---|------|------------------------------|---------|
| Specific Surface (Blaine) (sq.m./ kg.) | 361 | Silicon Dioxide (SiO2) | 22.1 |
| Percent Passing 325 Mesh | 97.9 | Aluminum Oxide (Al2O3) | 4.3 |
| Compressive Strength (psi) | | Ferric Oxide (Fe2O3) | 3.1 |
| Mortar Cubes | | Calcium Oxide (CaO) | 63.5 |
| 1 day... | NA | Magnesium Oxide (MgO) | 2.17 |
| 3 day... | 3340 | Sulphur Trioxide (SO3) | 2.7 |
| 7 day... | 4360 | Loss on Ignition | 1.2 |
| 28 day... | 6000 | Insoluble Residue | 0.20 |
| Vicat Time Of Set (min.) | 109 | Free Lime | 1.2 |
| Air Content (%) | 6 | Tricalcium Silicate (C3S) | 48 |
| Autoclave Expansion (%) | 0.01 | Tricalcium Aluminate (C3A) | 7.0 |
| | | Total Alkali as Sodium Oxide | 0.64 |

CERTIFIED BY:


Quality Control Supervisor

We hereby certify that this cement complies with current ASTM C-150 specifications using applicable ASTM standard test procedures. This mill test represents a monthly average.

Sent by: MARCOR REMEDIATION
Received Aug-06-98 02:02pm
AUG-08-98 THU 02:11 PM

Aug-06-98 02:32pm

from 7164470799@7166915109

Page 8 / 8

from CCITT G3 -> MARCOR REMEDIATION

page 6

P. 08/08


Mr. James F. Sullivan

2.

- A representative sample of the fly ash must be obtained annually on or about September 30 of each year to form a flowable fill cylinder. This cylinder should be analyzed in accordance with SW-924 for all TCLP metals and the results reported in writing, to Mr. Jeffrey Schmitt, Bureau of Resource Recovery, Division of Solid Waste, NYSDEC.
- The Department reserves the right to rescind this approval at any time, should conditions warrant. Further, this approval does not exempt this activity from any other federal, State, and local requirements.

If you have any questions regarding this matter, please contact Mr. Schmitt, of my staff, at 518-457-7336. We look forward to the receipt of your "Fly Ash Testing and Utilization Options Report," which should greatly enhance the potential opportunities for beneficial uses of coal combustion ash.

Sincerely,



Norman H. Nosenchuck, P.E.
Director
Division of Solid Waste

SPECIFICATION / DESIGN MODIFICATION FORM

PROJECT NUMBER: 983-9180
OWNER: Textron Inc.
LOCATION: Textron Realty Operations
Wheatfield (Inc.) New York Facility

PROJECT TITLE: Textron/EW-13 Eng. Serv./NY
CONTRACTOR: Golder Associates Inc.

FORM NUMBER

| |
|---|
| 4 |
|---|

LOCATION / REFERENCE OF MODIFICATION: Drawing E-2

MODIFICATION MADE: Warrick controller specified, No. 2D1F4-2Z1, is incorrect; correct catalog number is 2G1F4-2Z1

APPROVED BY DESIGNER: David Wehn Golder Associates Inc. 6/24/98
NAME COMPANY DATE

OWNER NOTIFIED OF MODIFICATION: YES
 NO

Leslie Alden Textron Inc. 6/24/98
NAME COMPANY DATE

REMARKS: None.

ATTACHMENTS: None.

DISTRIBUTION:
Leslie Alden - Textron Inc. Robert McNamara - Wendel
Kevin Thompson - Marcor Remediation Inc.
Robert Hobba - Weydman Electric Inc.

SPECIFICATION / DESIGN CLARIFICATION FORM

PROJECT NUMBER: 983-9180
OWNER: Textron Inc.
LOCATION: Textron Realty Operations
Wheatfield (Inc.) New York Facility

PROJECT TITLE: Textron/EW-13 Eng. Serv./NY
CONTRACTOR: Golder Associates Inc.

FORM NUMBER 1

LOCATION / REFERENCE OF CLARIFICATION: Detail 4/B-4.

CLARIFICATION MADE: Fiberglass-reinforced heat shrink sleeve not required by pipe manufacturer; omit.

APPROVED BY DESIGNER: Anthony Grasso Golder Associates Inc. 6/4/98
NAME COMPANY DATE

OWNER NOTIFIED OF CLARIFICATION: YES
 NO

Leslie Alden Textron Inc. 6/4/98
NAME COMPANY DATE

REMARKS: _____

ATTACHMENTS: None.

DISTRIBUTION:
Leslie Alden - Textron Inc. Robert McNamara - Wendel
Kevin Thompson - Marcor Remediation Inc.
Robert Hobba - Weydman Electric Inc.

SPECIFICATION / DESIGN CLARIFICATION FORM

PROJECT NUMBER: 983-9180
OWNER: Textron Inc.
LOCATION: Textron Realty Operations
Wheatfield (Inc.) New York Facility

PROJECT TITLE: Textron/EW-13 Eng. Serv./NY
CONTRACTOR: Golder Associates Inc.

FORM NUMBER 2

LOCATION / REFERENCE OF CLARIFICATION: Section 4.2 of Specifications (Revision 2).

CLARIFICATION MADE: Elevation settings for the pump start and stop points shall be as follows:
Pump ON point to be six feet above top of pump sleeve, or approximately 22.3 feet below top of HDPE well casing.
Pump OFF point to be two feet above top of pump sleeve, or approximately 26.3 feet below top of HDPE well casing.

| | | | |
|-----------------------|-----------------------|-------------------------------|---------------|
| APPROVED BY DESIGNER: | <u>Anthony Grasso</u> | <u>Golder Associates Inc.</u> | <u>7/2/98</u> |
| | NAME | COMPANY | DATE |

OWNER NOTIFIED OF CLARIFICATION: YES
 NO

| | | | |
|--|---------------------|---------------------|---------------|
| | <u>Leslie Alden</u> | <u>Textron Inc.</u> | <u>7/2/98</u> |
| | NAME | COMPANY | DATE |

REMARKS: None.

ATTACHMENTS: None.

DISTRIBUTION:

| | |
|---|---------------------------------|
| <u>Leslie Alden - Textron Inc.</u> | <u>Robert McNamara - Wendel</u> |
| <u>Kevin Thompson - Marcor Remediation Inc.</u> | |
| <u>Robert Hobba - Weydman Electric Inc.</u> | |

APPENDIX C

Submittals

CHECK VALVES

INTRODUCTION

| |
|--------------|
| Introduction |
| Discussion |
| Warranty |
| Liabilities |

Introduction

For over 15 years Asahi/America has been at the forefront of thermoplastic valve technology. The Asahi/America line is now the broadest in the industry in terms of size range, valve types, materials, features, and options. Advanced molding techniques, rigid engineering standards, and a wide choice of corrosion resistant thermoplastic and elastomeric materials insure the highest level of reliability for all Asahi/America valves, even in the most severe corrosive applications.

- APPROVED
- APPROVED AS NOTED
- REVISE AND RESUBMIT

The valves in this catalog represent one segment of the Asahi/America line. Other valves are grouped according to type or special function in separate catalogs. On the back cover of this brochure you will find a brief representation of the complete product line as an aid to requesting additional information.

BY D. Wehn DATE 4/8/98
GOLDER ASSOCIATES INC.

If, however, you have a requirement for a valve with features not contained in any of our literature, please contact our engineering department to discuss our custom fabrication capability. Chances are we have already encountered a similar request and can accommodate your special needs with a minimum of effort.

THESE DOCUMENTS HAVE BEEN REVIEWED FOR COMPLIANCE WITH THE PLANS AND SPECIFICATIONS. WE MAKE NO GUARANTEE FOR PERFORMANCE AND ASSUME NO LIABILITY FOR INSTALLATION METHODS.

Check Valves: Discussion

Check valves are self-contained, automatic valves which are used to prevent reversal of flow in a line. When open and under flow pressure; the checking mechanism will move freely in the media, offering very little resistance and minimal pressure drop. Asahi/America provides two basic types of check valves: Swing Check Valves and Ball Check Valves. Swing Check Valves utilize a swinging disc which requires only minimal back pressure to close the valve. This valve can also be modified with a lever and weight or spring to assist valve in seating faster to eliminate shock. Asahi/America's Ball Check Valve employs a free-moving ball which unseats to permit flow in one direction but seals against a seat to prevent backflow. Both types of valves may be installed either vertically or horizontally.

Warranty and Liabilities

To the best of our knowledge the information contained herein is accurate. However, neither Asahi/America, Inc. nor any of its affiliates assumes any liability whatsoever for the accuracy or completeness of the information contained herein. Final determination of the suitability of any information or material for the use contemplated, or the manner of use, is the sole responsibility of the user.

Due to our policy of continuous product improvement, we reserve the right to change or modify design without incurring any obligation to furnish or install such changes or modifications on products previously or subsequently sold.

WARRANTY

THE SALE BY ASAHI/AMERICA, INC. OF ITS PRODUCTS IS EXPRESSLY CONDITIONED UPON AND SUBJECT TO ALL TERMS AND CONDITIONS SET FORTH ON THE BACK COVER OF THIS CATALOG.

CHECK VALVES continued

Thermoplastic Materials

Elastomeric Materials

Note

Thermoplastic Materials

PVC (POLYVINYL CHLORIDE) TYPE 1, GRADE 1 Asahi/America uses an unplasticized PVC polymer in all of its PVC valves. This material has excellent chemical resistance, strength, rigidity, and modulus of elasticity. It resists attack by most acids and strong alkalis, as well as gasoline, kerosene, aliphatic alcohols and hydrocarbons, and salt solutions. Aromatics, chlorinated organic compounds, and lacquer solvents do have effect upon PVC's chemical properties. Its temperature range is 140° F. PVC's low cost and overall balance of properties make it the material best suited to the widest number of corrosive applications.

CPVC (CHLORINATED POLYVINYL CHLORIDE) TYPE 4, GRADE 1 The properties of CPVC and its advantages are very similar to those of PVC; however, its working temperature range is higher (200°F.) than that of PVC. It should be specified in some instances where hot corrosive liquids are being handled and an extra margin of safety is required.

PP (POLYPROPYLENE) TYPE 1 Polypropylene, a member of the polyolefin family, is one of the lightest plastics known. It is highly crystalline, thus is strong and hard. It possesses excellent chemical resistance to many acids, alkalies and organic solvents. PP is not recommended for use with chlorinated hydrocarbons and aromatics. Its upper temperature limit is slightly lower than that of CPVC.

PVDF (POLYVINYLIDENE FLUORIDE) PVDF is a high molecular weight fluorocarbon that has superior abrasion resistance, chemical resistance, dielectric properties, and mechanical strength. The remarkable fact is that it maintains these characteristics over a temperature range of -40°F. to 250°F. PVDF is highly resistant to wet or dry chlorine, bromine and other halogens, most strong acids and bases, aliphatics, aromatics, alcohols, and chlorinated solvents. It is not, however, recommended for ketones or esters. Asahi/America's PVDF resin conforms with FDA No. 177.2510 requirements for contact with food.

Elastomeric Materials

TEFLON® (TFE FLUOROCARBONS) This fluorocarbon is almost totally insoluble and chemically inert. Teflon® in application on bearing surfaces exhibits a natural lubricity that makes lubrication completely unnecessary. It has a very high thermal stability, is nonflammable, and exhibits a very low dielectric constant.

VITON® Viton® is a fluoroelastomer which is used as an "O" ring material in many Asahi/America valves. It resists a wide range of chemicals, including mineral acids, salts, and chlorinated hydrocarbons. The maximum temperature is 250° F.

EPDM (ETHYLENE PROPYLENE TERPOLYMER) This elastomer is particularly suited to diaphragms, valve seats, and "O" rings. It can stand up to a variety of acids, bases, alcohols, and oxidizing chemicals. The maximum temperature is 212° F.


Note

Caution: Asahi/America valves are not recommended for use in compressed air service. When testing, only hydrostatic pressure testing is recommended with a gradual increase in pressure.

Copyright © 1987 Asahi/America, Inc. All rights reserved. This catalog may not be reproduced in whole or in part without express written permission by Asahi/America, Inc.

SWING CHECK

- Features
- Options
- Sample Specifications
- Cv Values
- Pressure Tables



FEATURES

- Minimum resistance to flow.
- May be installed in horizontal or in vertical lines.
- Disc seats tightly with minimum back pressure.
- Top entry valve facilitates cleaning without removing from line.
- EPDM seat and seal.
- All sizes rated for vacuum service.

OPTIONS

- External lever and weight to assist the disc in closing faster.
- External spring to assist disc in closing faster.
- Teflon® or Viton® seat and seals.

DCW


SPECIFICATIONS

SIZES: 1/4" - 8"
MODELS: Flanged
BODIES: PVC, PP, PVDF

DCW

SAMPLE SPECIFICATIONS

All swing check valves shall be of a solid thermoplastic construction having no metal to media contact. Valves must incorporate a single disc design suitable for either horizontal or vertical installations as manufactured by Asahi/America.



Cv VALUES

| Size | Cv |
|--------|------|
| 1/4" | 1.0 |
| 1" | 2.0 |
| 1 1/2" | 3.0 |
| 2" | 4.0 |
| 2 1/2" | 5.0 |
| 3" | 6.0 |
| 4" | 8.0 |
| 5" | 10.0 |
| 6" | 12.0 |
| 8" | 16.0 |

MINIMUM BACK PRESSURE REQUIRED TO CLOSE VALVE (PSI)


| Seat | 1/4" | 1/2" | 1" | 2" | 2 1/2" | 3" | 4" | 6" | 8" |
|--------|------|------|-----|-----|--------|-----|-----|------|------|
| EPDM | 2.5 | 3.0 | 4.0 | 5.0 | 6.0 | 7.0 | 8.0 | 10.0 | 12.0 |
| Teflon | 3.0 | 3.5 | 4.5 | 5.5 | 6.5 | 7.5 | 8.5 | 10.5 | 12.5 |

OPERATING PRESSURE VS. TEMPERATURE (PRESSURE IN PSI, WATER NON SHOCK)

| Size | PVC | | | | PP | | | | PVDF | | | | |
|--------|--------|-------|-------|--------------|---------------|-------|-------|---------------|---------------|-------|-------|---------|-------|
| | Rubber | | | Teflon® | Rubber | | | Teflon® | Rubber | | | Teflon® | |
| | 70°F | 105°F | 120°F | 30° 120°F | -5°F 105°F | 140°F | 175°F | -5°F 175°F | -5°F 140°F | 175°F | 190°F | 210°F | 210°F |
| 1/4" | 150 | 150 | 100 | 40 | 150 | 100 | 80 | 40 | 150 | 120 | 100 | 85 | 85 |
| 1" | 150 | 150 | 100 | 40 | 150 | 100 | 90 | 40 | 150 | 120 | 100 | 85 | 85 |
| 1 1/2" | 150 | 150 | 100 | 40 | 150 | 100 | 90 | 40 | 150 | 120 | 100 | 85 | 85 |
| 2" | 150 | 150 | 100 | 40 | 150 | 100 | 80 | 40 | 150 | 120 | 100 | 85 | 85 |
| 2 1/2" | 150 | 100 | 100 | 40 | 100 | 85 | 70 | 40 | 150 | 100 | 80 | 55 | 85 |
| 3" | 150 | 100 | 100 | 30 | 100 | 70 | 60 | 30 | 150 | 100 | 80 | 40 | 70 |
| 4" | 100 | 70 | 70 | 30 | 70 | 65 | 40 | 30 | 100 | 85 | 60 | 40 | 70 |
| 5" | 100 | 70 | 70 | 30 | 70 | 60 | 35 | 30 | 100 | 85 | 60 | 30 | 60 |
| 6" | 100 | 70 | 60 | 20 | 70 | 40 | 30 | 20 | 100 | 70 | 60 | 30 | 40 |
| 8" | 70 | 40 | 40 | 20 | 40 | 40 | 30 | 20 | 70 | 60 | 40 | 30 | 40 |

SWING CHECK continued

| |
|------------|
| Parts |
| Dimensions |
| |
| |
| |



PARTS

| No. | Parts | Pcs. | Materials |
|-----|-------------------|------|------------------------|
| 1 | Body | 1 | PP, PVC, PVDF |
| 2 | Bonnet | 1 | PP, PVC, PVDF |
| 3 | Disc | 1 | PP, PVC, PVDF |
| 4 | Seat Holder | 1 | PP, PVC, PVDF |
| 5 | Swing Arm | 1 | PP, PVC, PVDF |
| 6 | Seat | 1 | EPDM, PTFE, Viton |
| 7 | Sheet Gasket Seal | 1 | EPDM, PVC, PVDF, Viton |
| 8 | Shaft | 1 | PP, PVC, PVDF |
| 9 | Nut | 1 | PP, PVC, PVDF |
| 10 | Washer | 1 | PP, PVC, PVDF |
| 11 | Bolt and Nut | Set | PVC (SS) |
| 12 | Washer | Set | Stainless Steel |
| 13 | Sheet Gasket | 1 | EPDM or PTFE |
| 14 | Bolt | 1 | PP, PVC, PVDF |
| 15 | Bolt | Set | PP, PVC, PVDF |
| 16 | Set Pin | 1 | PP, PVC, PVDF |

DCW

PARTS—LEVER AND WEIGHT

| No. | Parts | Pcs. | Materials |
|-----|---------|------|---------------|
| 1 | Fitting | 1 | PP, PVC, PVDF |
| 2 | O' Ring | 1 | PTFE |
| 3 | Weight | 1 | PP, PVC, PVDF |
| 4 | Arm | 1 | PP, PVC, PVDF |

LEVER & WEIGHT DIMENSIONS

| Size | D1 | H3 |
|--------|------|------|
| 3/4" | 4.0 | 1.18 |
| 1" | 4.5 | 1.57 |
| 1 1/2" | 5.0 | 1.77 |
| 2" | 5.5 | 2.17 |
| 2 1/2" | 6.0 | 2.56 |
| 3" | 6.5 | 2.76 |
| 4" | 7.0 | 3.34 |
| 5" | 7.5 | 3.93 |
| 6" | 8.0 | 4.51 |
| 8" | 10.0 | 6.09 |

LEVER & WEIGHT OPTION

DIMENSIONS (IN INCHES UNLESS OTHERWISE NOTED.)

| Size | Weight (lbs.) | D1 | D2 | e | n | D3 | L | T | H |
|--------|---------------|------|-------|------|---|-------|-------|------|-------|
| 3/4" | 1.6 | 0.79 | 2.76 | 0.63 | 4 | 3.39 | 5.51 | 0.69 | 3.64 |
| 1" | 3.0 | 0.98 | 3.13 | 0.63 | 4 | 5.12 | 6.30 | 0.63 | 4.72 |
| 1 1/2" | 6.0 | 1.57 | 3.88 | 0.63 | 4 | 6.71 | 7.09 | 0.74 | 5.43 |
| 2" | 8.9 | 1.97 | 4.74 | 0.75 | 4 | 7.09 | 7.87 | 0.78 | 6.16 |
| 2 1/2" | 11.3 | 2.56 | 5.49 | 0.75 | 4 | 7.87 | 9.45 | 0.87 | 6.81 |
| 3" | 12.2 | 3.15 | 6.00 | 0.75 | 4 | 8.07 | 10.24 | 0.87 | 6.73 |
| 4" | 21.0 | 3.94 | 7.50 | 0.75 | 8 | 10.43 | 11.81 | 0.94 | 8.39 |
| 5" | 36.4 | 4.92 | 8.60 | 0.87 | 8 | 12.99 | 13.78 | 0.94 | 8.76 |
| 6" | 48.0 | 5.91 | 9.51 | 0.87 | 8 | 14.57 | 15.75 | 0.98 | 11.11 |
| 8" | 76.2 | 7.87 | 11.75 | 0.87 | 8 | 18.73 | 19.89 | 1.18 | 13.23 |

DCW →

BUTTERFLY VALVES

INTRODUCTION

| |
|--------------|
| Introduction |
| Discussion |
| Warranty |
| |
| |

Introduction

For over 15 years Asahi/America has been at the forefront of thermoplastic valve technology. The Asahi/America line is now the broadest in the industry in terms of size, range, valve types, materials, features, and options. Advanced molding techniques, rigid engineering standards, and a wide choice of corrosion resistant thermoplastic and elastomeric materials insure the highest level of reliability for all Asahi/America valves, even in the most severe corrosive applications.

The valves in this catalog represent one segment of the Asahi/America line. Other valves are grouped according to type or special function in separate catalogs. On the back cover of this brochure you will find a brief representation of the complete product line as an aid to requesting additional information.

If, however, you have a requirement for a valve with features not contained in any of our literature, please contact our engineering department to discuss our custom fabrication capability. Chances are we have already encountered a similar request and can accommodate your special needs with a minimum of effort.

Butterfly Valves: Discussion

The name of this valve comes from the wing-like action of the flow-controlling disc which operates at right angles to the flow. The disc has about the same diameter as the connecting pipe and the flow is straight-through with a low pressure drop. Maintenance is easy because of the minimum number of moving parts. The butterfly valve can be used either as an "ON/OFF" type of valve, wherein the seating of the disc against an elastomeric seal is important, or it can be used as a control valve, wherein seating materials are unnecessary.

Asahi/America butterfly valves with seats are self-gasketing, eliminating the need for flange gaskets. These valves can be operated manually, electrically or pneumatically.

Asahi/America thermoplastic valves provide a dependable and economical way to handle corrosive chemicals like sulfuric and hydrofluoric acid, nitric acid, and other oxidizing chemicals, as well as caustics, solvents, halogens and other problem materials, at temperatures to 250° F, pressures to 150 PSI and flows up to 18,500 gpm.

When we speak of corrosion resistance, we refer to the ability of a material to withstand physical and chemical deterioration when it reacts with its environment, and particularly with oxygen. Corrosion, itself, has become a term which applies mostly to metals because the process is primarily an electrochemical one. There is ionization or corrosion at the surface due to electrical potentials that are created between positive and negative poles formed when unlike metals are joined in the same electrically conductive medium or when fluids that surround the metals have different ionic concentrations. Because thermoplastics are dielectric, meaning that they cannot easily support a charge, they are practically immune from corrosion in the conventional sense. There are some chemicals that can cause thermoplastics to deteriorate. For this reason, we have a thermoplastic chemical resistance chart, which we will be happy to send you upon request.

To the best of our knowledge the information contained herein is accurate. However, neither Asahi/America, Inc. nor any of its affiliates assumes any liability whatsoever for the accuracy or completeness of the information contained herein. Final determination of the suitability of any information or material for the use contemplated, or the manner of use, is the sole responsibility of the user.

Due to our policy of continuous product improvement, we reserve the right to change or modify design without incurring any obligation to furnish or install such changes or modifications on products previously or subsequently sold.

WARRANTY—THE SALE BY ASAHI/AMERICA, INC. OF ITS PRODUCTS IS EXPRESSLY CONDITIONED UPON AND SUBJECT TO ALL TERMS AND CONDITIONS SET FORTH ON THE BACK COVER OF THIS CATALOG.

Copyright ©1989 Asahi/America, Inc. All rights reserved. This catalog may not be reproduced in whole or in part without express written permission by Asahi/America, Inc.

ASAHI/AMERICA

APPROVED
APPROVED AS NOTED
REVISE AND RESUBMIT

(X)
()

DATE 4/8/98
BY WJH
GOLDEN ASSOCIATES INC.

THESE DOCUMENTS HAVE BEEN REVIEWED FOR COMPLIANCE WITH THE PLANS AND SPECIFICATIONS. WE MAKE NO GUARANTEE FOR PERFORMANCE AND ASSUME NO LIABILITY FOR INSTALLATION METHODS.

Warranty and Liabilities

BUTTERFLY VALVES continued

| |
|-------------------------|
| Thermoplastic Materials |
| Elastomeric Materials |
| Sample Specification |
| Note |

Thermoplastic Materials

PVC (POLYVINYL CHLORIDE) TYPE 1, GRADE 1 Asahi/America uses an unplasticized PVC polymer in all of its PVC valves. This material has excellent chemical resistance, strength, rigidity, and modulus of elasticity. It resists attack by most acids and strong alkalis, as well as gasoline, kerosine, aliphatic alcohols and hydrocarbons, and salt solutions. Aromatics, chlorinated organic compounds, and lacquer solvents do have effect upon PVC's chemical properties. Its temperature range is 140° F. PVC's low cost and overall balance of properties make it the material best suited to the widest number of corrosive applications.

PP (POLYPROPYLENE) TYPE 1 Polypropylene, a member of the polyolefin family, is one of the lightest plastics known. It is highly crystalline, thus is strong and hard. It possesses excellent chemical resistance to many acids, alkalis and organic solvents. PP is not recommended for use with chlorinated hydrocarbons and aromatics. Its upper temperature limit is slightly lower than that of CPVC.

PVDF-KYNAR® (POLYVINYLIDENE FLUORIDE) PVDF is a high molecular weight fluoro-carbon that has superior abrasion resistance, chemical resistance, dielectric properties, and mechanical strength. The remarkable fact is that it maintains these characteristics over a temperature range of -40° F. to 250° F. PVDF is highly resistant to wet or dry chlorine, bromine and other halogens, most strong acids and bases, aliphatics, aromatics, alcohols, and chlorinated solvents. It is not, however, recommended for ketones or esters.

FRP (FIBERGLASS WRAPPED POLYESTER) Unsaturated polyester thermoset resins are manufactured from glycols, dibasic acids and monomers. Inhibitors are used to control gel and curing during the cross linking process. An initiator is added at the final fabrication process to achieve cure. Working temperature range is 210° F. Chemical and corrosion resistance is excellent for acids, bases and some organics.

Elastomeric Materials

NITRILE (BUNA N) Nitrile rubber is a copolymer of butadiene and acrylonitrile. In addition to its good elastomeric properties, it is resistant to aliphatic hydrocarbons and aromatic solvents.

BUTYL Butyl rubber is a copolymer of isobutylene and isoprene, vulcanized in the same manner as natural rubber. Butyl has good resistance to most acids.

HYPALON® Hypalon® is DuPont's name for its elastomer of chlorosulfonated polyethylene used for diaphragms and valve seals.

EPDM (ETHYLENE PROPYLENE TERPOLYMER) This elastomer is particularly suited for diaphragms, valve seals, and "O"-rings. It can stand up to a variety of acids, bases, alcohols, and oxidizing chemicals.

NEOPRENE Neoprene is a chlorinated synthetic rubber which is used primarily as a diaphragm or sealing material in Asahi/America valves. Its use should be limited to lower temperature applications.

NATURAL RUBBER Natural rubber is a high molecular weight polymer of isoprene derived from the Hevea tree. It is used as a diaphragm and sealing material because of its excellent elastomeric properties and resistance to abrasion.

Sample Specification

All solid thermoplastic butterfly valves shall be of the lined body design and seal bubble tight with only the liner and disc as wetted parts. The disc shall have double "O" ring seals on top and bottom trunnions, of the same material as the valve liner. Line shall be molded and formed around the body, functioning as a gasket on each side of valve. Stem shall be of stainless steel and have engagement over the full length of the disc. Butterfly valves shall be wafer style, as manufactured by Asahi/America, 425 Riverside Avenue, Medford, MA 02155.

Note

Caution: Asahi/America Butterfly Valves are not recommended for use in compressed gas services. When testing, only hydrostatic pressure testing is recommended, with a gradual increase in pressure.

Teflon®, Viton® and Hypalon® are registered trademarks of DuPont.
Kynar® is a registered trademark of Pennwalt.

TYPE 75 BUTTERFLY VALVES LEVER AND GEAR

- Specifications, Features
- Pressure Loss, Options
- Pressure Vs. Temperature
- Vacuum Service, Cv Values
- Flow Characteristics

SPECIFICATIONS


Handwritten: PVC, PVDF, PP

SIZES: 1½"-24" Lever: 1½"-8" Gear: 8"-24"
 MODELS: Water style (for ANSI flanges)
 OPERATIONS: Lever (Gear)
 BODIES: PVC, PVDF
 DISCS: PP, PVDF, PVC (optional)
 SEATS: EPDM, Viton®, Nitrile (Buna N)
 Butyl, Hypalon, Natural Rubber, Neoprene,
 Chlorinated Polyethylene (CPE)
 SEALS: Same as seating material
 ACTUATORS: Electric, Pneumatic

FEATURES

- Standard model has PVC body and polypropylene disc for better chemical and abrasion resistance at temperatures higher than can be achieved with PVC.
- Can be fitted with a variety of elastomeric seat materials to provide bubble-tight seating for a wide range of chemicals.
- Stainless steel shaft has full engagement with disc and is a non-wetted part isolated from the media by double "O" ring seals on top and bottom trunnions of disc.
- EDPM and Viton® are standard seat materials. Others are available as options.
- Only disc and liner are wetted parts.

PRESSURE LOSS



OPTIONS

- Stem Extensions.
- Other seat materials available on special order.
- Gear operators for all sizes.
- Sprocket and chain wheel: all sizes.
- Teflon® or PVDF stem coatings.
- Handle locking devices.
- 2" square operating nut.
- Stem of any commercially available metal.
- Lug style butterfly valves.
- Lever handle on 8".
- Tandem arrangements (patented).
- Disc and/or body in PVDF for better temperature range or chemical resistance.

PRESSURE VS. TEMPERATURE (PSI, WATER, NON-SHOCK)

| Size (Inches) | PVC Body with PP Disc and appropriate elastomer | | | | PVDF Body with PVDF Disc and appropriate elastomer | | | |
|---------------|---|--------|--------|--------|--|--------|--------|--------|
| | 90° F | 120° F | 140° F | 160° F | 140° F | 175° F | 210° F | 250° F |
| 1½" | 150 | 100 | 70 | 30 | 150 | 100 | 85 | 70 |
| 2" | 150 | 100 | 45 | 30 | 150 | 100 | 85 | 70 |
| 2½" | 180 | 100 | 40 | 20 | 150 | 85 | 70 | 60 |
| 3" | 150 | 100 | 30 | 15 | 150 | 85 | 70 | 60 |
| 4" | 100 | 60 | 30 | 15 | 100 | 60 | 40 | 20 |
| 6" | 100 | 60 | 30 | 7 | 100 | 40 | 30 | 15 |
| 8" | 85 | 60 | 30 | 7 | 85 | 40 | 30 | 15 |
| 10" | 70 | 30 | 20 | 7 | 70 | 40 | 30 | 15 |
| 12-24" | 50 | 30 | 20 | 7 | 50 | 30 | 20 | 15 |

*Maximum allowable temperature of Viton is 250° F. All other elastomers have a limit of 210° F.

VACUUM SERVICE


(UNIT: INCHES OF MERCURY)

| Size | 10" | 12" | 14" | 16" | 18" | 20" | 24" |
|------|--------|--------|-----|-----|-----|-----|-----|
| 1½" | -29.92 | -27.66 | | | | | |
| 2" | -29.92 | -23.62 | | | | | |
| 2½" | -29.92 | -23.62 | | | | | |
| 3" | -29.92 | -23.62 | | | | | |
| 4" | -29.92 | -19.69 | | | | | |
| 5" | -29.92 | -19.69 | | | | | |
| 6" | -27.56 | -19.69 | | | | | |
| 8" | -27.56 | | | | | | |

Cv VALUES

| Size | 10° | 20° | 30° | 40° | 50° | 60° | 70° | 80° | 90° |
|------|-------|--------|--------|--------|--------|--------|---------|---------|---------|
| 1½" | 0 | 0.8 | 2.6 | 5.4 | 11.0 | 22.0 | 38.0 | 58.0 | 75.0 |
| 2" | 0 | 1.9 | 5.2 | 9.5 | 25.0 | 46.8 | 79.0 | 91.0 | 102.0 |
| 2½" | 0 | 4.0 | 9.0 | 18.2 | 35.7 | 59.7 | 106.0 | 239.0 | 260.0 |
| 3" | 0 | 7.5 | 17.7 | 31.8 | 58.0 | 101.0 | 251.0 | 366.0 | 387.0 |
| 4" | 0.7 | 10.8 | 25.3 | 45.3 | 85.8 | 156.2 | 308.0 | 466.0 | 504.0 |
| 5" | 2.7 | 21.8 | 46.3 | 82.0 | 140.0 | 271.0 | 501.0 | 710.0 | 772.0 |
| 6" | 15.3 | 42.6 | 80.5 | 142.0 | 220.0 | 402.0 | 784.0 | 1085.0 | 1183.0 |
| 8" | 33.0 | 82.0 | 147.0 | 300.0 | 387.0 | 816.0 | 1390.0 | 1880.0 | 2040.0 |
| 10" | 61.0 | 151.0 | 270.0 | 540.0 | 720.0 | 1478.0 | 2490.0 | 3320.0 | 3600.0 |
| 12" | 88.0 | 239.0 | 408.0 | 778.0 | 1070.0 | 2140.0 | 3680.0 | 4760.0 | 5160.0 |
| 14" | 129.0 | 328.0 | 535.0 | 1030.0 | 1609.0 | 2770.0 | 4580.0 | 5890.0 | 6440.0 |
| 16" | 175.0 | 458.0 | 780.0 | 1418.0 | 2170.0 | 3760.0 | 6000.0 | 7860.0 | 8340.0 |
| 18" | 252.0 | 622.0 | 1100.0 | 1960.0 | 2940.0 | 5020.0 | 7980.0 | 10020.0 | 10880.0 |
| 20" | 337.0 | 845.0 | 1448.0 | 2873.0 | 3940.0 | 6820.0 | 10400.0 | 12820.0 | 14060.0 |
| 24" | 483.0 | 1148.0 | 2130.0 | 3700.0 | 5550.0 | 9180.0 | 13900.0 | 17000.0 | 18500.0 |


FLOW CHARACTERISTICS



ASAHI/AMERICA

TYPE 75 BUTTERFLY VALVES LEVER



*TO BE GEAR
OPERATED, NOT
LEVER OPERATED
AS SHOWN
Q10*



| |
|-------------------|
| Parts, Lever |
| Dimensions, Lever |
| |
| |
| |

PARTS—LEVER 1½"-8"

| No. | Parts | Pcs. | Materials |
|-----|-----------------------|------|---|
| 1 | Body | 1 | PVC, PP, PVDF |
| 2 | Disc | 1 | PP, PVDF |
| 3 | Seat | 1 | EPDM, Viton®, Nitrile (Buna N), Neoprene®, Hypalon®, Butyl, Natural Rubber |
| 4 | Stem | 1 | Stainless Steel |
| 5 | Stem Seal "O" Ring | 1 | Same material as seat |
| 6 | Disc Seal "O" Ring | 4 | Same material as seat |
| 7 | Stem Retainer | 1 | Stainless Steel |
| 8 | Retaining Nut | 1 | PVC |
| 9 | Handle | 1 | PP |
| 10 | Trigger | 1 | Stainless Steel |
| 11 | Cap Nut | 1 | PVC covered |
| 12 | Gauge Plate | 1 | Stainless Steel |
| 13 | Machine Screw | 3 | Stainless Steel |



DIMENSIONS—LEVER (IN INCHES—BODY BOLT HOLES ANSI)

| Size | Weight (lbs.) | D ₁ | C | n | e | L | H ₁ | H ₂ | H ₃ | D ₂ |
|------|------------------|----------------|-------|------|---|------|----------------|----------------|----------------|----------------|
| 1½" | 2.00 | 1.99 | 3.88 | 0.63 | 4 | 1.54 | 2.98 | 3.74 | 2.76 | 7.87 |
| 2" | 2.65 | 2.22 | 4.75 | 0.75 | 4 | 1.65 | 3.25 | 3.82 | 2.76 | 7.87 |
| 2½" | 3.32 | 2.78 | 5.50 | 0.75 | 4 | 1.81 | 3.66 | 4.33 | 2.76 | 7.87 |
| 3" | 3.76 | 3.11 | 6.00 | 0.75 | 4 | 1.81 | 3.94 | 4.53 | 2.76 | 7.87 |
| 4" | 5.08 | 4.08 | 7.50 | 0.75 | 8 | 2.20 | 4.63 | 5.31 | 2.76 | 9.06 |
| 5" | 10.39 | 5.12 | 8.50 | 0.87 | 8 | 2.60 | 5.00 | 6.30 | 4.02 | 11.81 |
| 6" | 12.18 | 5.94 | 9.50 | 0.87 | 8 | 2.80 | 5.63 | 7.01 | 4.02 | 11.81 |
| 8" | 22.00 | 7.99 | 11.75 | 0.87 | 8 | 3.43 | 8.70 | 8.27 | 4.02 | 15.75 |

ASAHI/AMERICA

PERMA-PIPE®

1310 Quarles Drive, Lebanon, TN 37087 Telephone: 615-444-4910

Ship-To: JONES DRILLING
S-5167 SOUTH PARK AVE
HAMBURG, NY 14075

Customer Contact:

Telephone Number:

Fax Number

Date: Tuesday, March 31, 1998

Date Shipped : Tuesday, March 31, 1998

PACKING LIST

Page Number: 1

| Packaging | Part Number | Assembly/Part Description | Qty Required | Qty Shipped | Piece Weight |
|-----------|-------------|---------------------------|--------------|-------------|--------------|
| | 8004329 | PIPE, PE 250 SDR 11 | 40 | 40 FT | 448.00 |

APPROVED
APPROVED AS NOTED
REVISE AND RESUBMIT
By D. Wolk DATE 4/9/98
GOLDER ASSOCIATES, INC.

THESE DOCUMENTS HAVE BEEN REVIEWED FOR
CONFORMANCE WITH ALL APPLICABLE
SPECIFICATIONS AND STANDARDS AND
INSTALLATION METHODS.

10" Well Casing

Shipment Number: 7595

Job Number: GL-8083

Carrier Name: CONWAY SOUTHERN

Pro Number: 539 223053

Trailer Number: MR8558

Truck: 0

Shipment Weight: 175.00

ELECTRICAL SUBMITTAL

ITEM Level Control System

SPECIFICATION SECTION 16000

MANUFACTURER Warrick

PROJECT EW-13 Installation, Textron Realty Operations Inc. Facility

LOCATION Wheatfield, New York

ARCHITECT _____ CHECKED BY _____

ENGINEER Golder Associates CHECKED BY _____

ELECTRICAL CONTRACTOR Weydman Electric, Inc. CHECKED BY KA
OWNER

~~SM~~ CONTRACTOR Textron Realty CHECKED BY _____

ELECTRICAL CONTRACTOR (fill out)

- 1. Lighting Fixtures
 - a. Voltage _____
 - b. Ballast Type _____
 - c. Lens Type _____
 - d. Mounting _____
 - e. Options _____
- 2. Equipment
 - a. Voltage _____
 - b. Load _____
 - c. Motor Power Factor _____
 - d. Starter(s) _____
 - e. Disconnect(s) By _____
- 3. _____
- 4. _____
- 5. _____

I hereby certify that the item submitted herein complies in every respect with the Contract Drawings and Specifications.

SIGNED [Signature]
POSITION Robert E. Hobba, Vice President

DATE 5/1/98

ENGINEER (fill out)

- No Exception Taken
- Make Corrections Noted
(Resubmission Not Required)
- Revise and Resubmit
- Rejected

Checking is only for conformance with the design concept of the project and general compliance with the information given in the Contract Documents. Contractor is responsible for dimensions to be confirmed and correlated at the job site, for information that pertains solely to the fabrication processed or to techniques of construction, and for coordination of the work of all trades.

SIGNED [Signature]

DATE 5/8/98

COMMENTS _____

- Quantities Not Checked
- Color(s) As Selected By Architect
- Verify Exact Ceiling Type
- Submit To Power Company For Approval



RL Stone company inc

630 Cleveland Dr., Buffalo, NY 14225-1098 • Tel: 716-834-2525 • Fax: 716-834-4082



Est. 1923
Representatives & Distributors

SUBMITTAL FOR APPROVAL

PROJECT : BELL AEROSPACE TEXTRON
WHEATFIELD NY

ENGINEER : GOLDER ASSOCIATES

CONTRACTOR : WEYDMAN ELECTRIC

P.O. # : 9804

SETS SUBMITTED : 5 SETS

DATE : 4/22/98

SUBMITTAL FOR APPROVAL
BELL AEROSPACE TEXTRON
WHEATFIELD NY
4/22/98

BILL OF MATERIAL

WARRICK

SPEC. 973-9170 REV. 2

EW 13

REFERENCE

1 EA. WARRICK LEVEL CONTROL SYSTEM
CONSISTS OF:

B3003D, B3032D
173A

- (1) 2D1F4-2Z1E RELAY MOUNTED IN NEMA 4 ENCLOSURE,
10,000 SENSITIVITY *Bor C only Dew*
- (1) 3E3A [ⓐ]THREE POSITION ELECTRODE HOLDER
- (3) 3W2 ELECTRODE 304 SS.
- (3) 3Z1A SUSPENSION CABLE 50'
- (3) 3Z1B ADAPTERS

PLEASE RETURN ONE SET MARKED APPROVED.

Jim Heisler / Chuck Dilullo
JIM HEISLER / CHUCK DILULLO
R.L. STONE CO., INC.

Bw


Controls. (continued)

Solid state—high amperage contact rating.




Series 2. The controls have low probe voltage and are U.L. listed. Two or three pole electromechanical relays are available with 16A current ratings, double break bridge type contacts. Sensitivity up to 100,000 OHM-centimeter specific resistance. Sensitivity and mode of operation are field adjustable.

*NOTE: Series 2 control not recommended for interfacing to microprocessor-based systems.



SINGLE LEVEL SERVICE



DIFFERENTIAL SERVICE




Table 16-1

| Design | Contact Design | Contact Rating at 110 VAC | Mode of Operation | Sensitivity | Primary Voltage VAC | Secondary Voltage VAC | Listing | Connections | Options and Accessories | Ordering Information (Page) |
|----------|--------------------------------|---|-------------------------|--------------------------|---------------------|-----------------------|------------|----------------------|-------------------------|-----------------------------|
| Series 2 | Electro-mechanical/solid state | 2 Pole 3 Pole single thr. elec-mech relay | 16 AMP Resistive 1 H.P. | 0-100,000 OHM field adj. | 115 | 10V | UL Type 50 | All screw type conn. | | 25 |

Series 2 Controls

ORDER BY COMPONENT NUMBER----- 2XXXX-2Z1X

| 2ND PLACE SYMBOL | | |
|------------------|-----------------------|------|
| ↓ | Contact Configuration | |
| | N.O. | N.C. |
| C | 2 | 0 |
| D | 1 | 1 |
| E | 0 | 2 |
| F | 3 | 0 |
| G | 2 | 1 |
| H | 1 | 2 |
| J | 0 | 3 |

| 3RD PLACE SYMBOL | |
|------------------|----------------------------------|
| ↓ | A.C. Line Volts & Freq. 50/60 HZ |
| 1 | 115V |
| 2 | 230V |
| 4 | 460V |
| 5 | 575V |

| 4TH PLACE SYMBOL | |
|------------------|--|
| ↓ | Maximum Sensitivity Capability in Ohms |
| F | 100,000 |


| 5TH PLACE SYMBOL | |
|------------------|---------------------|
| ↓ | Nema Type Enclosure |
| 0 | Open |
| 1 | 1 |
| 4 | 3, 4, 5 |
| 7 | 7, 9, |
| 12 | 12 |

| 9TH PLACE SYMBOL | | | |
|------------------|--------------------|-----|---------|
| ↓ | Sensitivity - Ohms | | |
| | A | 470 | E |
| B | 1,000 | F | 22,000 |
| C | 2,200 | G | 47,000 |
| D | 4,700 | H | 100,000 |




**WEATHERPROOF, NEMA-3
WATERTIGHT, NEMA-4
DUST TIGHT, NEMA-5**

This multipurpose enclosure is fabricated from diecast aluminum and provided with a blue, fused epoxy coat. A rubber gasket, retained in a groove in the cover, insures a tight seal between the cover and box. The cover is secured to the box with four captivated screws located at the corners of the cover.



TYPICAL SERIES 3 ELECTRODE FITTING



The type 3Z1B adapter kit facilitates the use of wire suspended electrodes with electrode fittings which possess 1/4-20 tapped electrode couplings. One kit is required per wire suspended electrode.

Each kit consists of four parts. These are the adapter, terminal screw, terminal lug and heatshrink tubing. Proceed as follows to perform the installation of the adapter kit.

Mate the threaded end of the adapter with the tapping in the hexagonal coupling of the electrode fitting. Hold the coupling with a small wrench and use a second wrench to tighten the adapter in the coupling. Strip the insulation from the suspension wire a distance of 1/4 inch from the end of the wire. Crimp the terminal lug on the wire. Slip the heatshrink tubing over the terminal lug and on to the wire a short distance. Place the terminal lug on the adapter, oriented so the barrel of the terminal lug is in line with the semi-circular cross section portion of the adapter. Secure the terminal lug to the adapter with the terminal screw. Push the heatshrink tubing up over the assembled parts until the upper end of the tubing reaches the lower end of the coupling. Heat the tubing until it shrinks tightly on to the adapter and insulation of the suspension wire. A heat gun, cigarette lighter or even matches may be used for this purpose.

| REQ'D | 3W1 | 3W2 | 3Z1A | 3Z1B | TAG |
|-------|----------------|-----|------|------|-----|
| 3 | | ✓ | ✓ | ✓ | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |


The wire suspended electrode consists of seven parts. These are illustrated in the diagram which shows the unassembled electrode. With the exception of the lower O-ring and electrode bar, none of the parts are preassembled by the manufacturer. Assembly is performed in the field incident to installation of the electrode on the suspension wire.

Assemble as shown in the diagram. Slip the bushing, upper O-ring and shield over the end of the wire in that order before the terminal lug is crimped onto the stripped end of the wire. Otherwise it will be necessary to pull the entire length of wire through those parts after the terminal lug has been fastened to the electrode bar.

NOTE: The suspension wire must have an outside diameter between 0.155 and 0.187 inch, preferably on the high side. If it is less than 0.155 inch the tubing may not clasp the wire tightly after the shrink operation has been completed. This requirement is satisfied by type 3Z1A suspension wire.

| | | |
|--|--------------|--|
| A. C. LINE: | SCALE: NONE | TITLE: SERIES 3WX ELECTRODES & ACCESSORIES |
| DATE: MAR 87 | DRAWN BY: JL | |
| SHEET NO: 1 | CHKD BY: | |
| WARRICK CONTROLS, INC., ROYAL OAK, MI. | | DWG NO: B3032D |

| BILL OF MATERIAL | |
|------------------|---|
| 1 | BODY: CAST IRON P/N 3P126 RED BRASS P/N 3P127 316 SS P/N 3P128 |
| 2 | ELECTRODE FITTING: SERIES 3B3A ON CAST IRON & RED BRASS, SERIES 3B1B ON 316 SS |
| 3 | GASKET P/N 3P108 |
| 4 | HOUSING P/N 3P102 |
| 5 | SCREW P/N 3P113 |
| 6 | GASKET P/N 3P111 |
| 7 | LID P/N 3P105 |
| 8 | SCREW P/N 3P115 |



Bar-C
SERIES 3E3 A ELECTRODE FITTING

BODY MATERIAL

~~A-CAST IRON~~

B-RED BRASS ← *OR*

C-316 SS ← *OR*

DeW

| | | | |
|---|-------------------|----------|----------------------------------|
| A. C. LINE: | SCALE: NONE | TITLE: | SERIES 3E3X ELECTRODE FITTING |
| DATE: 31 May 1988 | DRWN BY: <i>R</i> | | |
| SHEET NO: 1 | CHKD BY: | | |
| WARRICK CONTROLS, INC. 4337 NORMANDY CT, ROYAL OAK MI 48073-2264 | | DRWG NO: | B3003D |



**WARRICK
CONTROLS**

FORM 173A



RECOMMENDED ELECTRODE FITTING GROUNDING METHODS

GENERAL:

- 1) Always follow good N.E.C. (C.E.C.) grounding and bonding wiring procedures.
- 2) Use 'approved' insulated ring terminals for all wiring connections.
- 3) Use # 14 or # 16 AWG, type MTW or THHN copper wire only.
- 4) Wiring must be rated higher than nominal voltage and temperature values anticipated in installation.

INSTALLATION:

- 1) During installation orient the fitting so the tapped hub on the terminal housing faces the most favorable direction for receiving the conduit from the control box.
- 2) After conduit has been installed and conductors pulled through same, fasten the incoming ground conductor(s) as shown below; the ground connection should be facilitated by securing that end of the system ground wire to one of the four screws provided which hold the terminal housing to the body of the electrode fitting.




*FOR ADDITIONAL INFORMATION, SEE RESPECTIVE LEVEL CONTROLS INSTALLATION INSTRUCTIONS.

DOUBLE-PIPE GENERAL NOTES



- 1.0 2" PRODUCT PIPE SHALL BE STRESS RELIEVED POLYPROPYLENE SDR 11 (PN-10) AND SHALL MEET THE SPECIFICATIONS OF TYPE 1 HOMOPOLYMER AS DETAILED IN ASTM STANDARD SPECIFICATION F-4101.
- 2.0 PRODUCT PIPE AND CONTAINMENT PIPE FITTINGS SHALL BE UNITIZED, AND FACTORY MANUFACTURED. UNITIZED FITTING ASSEMBLIES SHALL BE BUTT FUSED IN THE FIELD TO STRAIGHT LENGTHS OF PIPE. CARRIER AND CONTAINMENT PIPE FITTINGS SHALL MATCH ADJACENT PIPE. ALL FITTINGS SHALL BE DOUBLE RESTRAINED.
- 3.0 6" CONTAINMENT PIPE SHALL BE SDR 32.5, HIGH DENSITY POLYETHYLENE PE3408 IN ACCORDANCE WITH ASTM D3350, AND SHALL MEET THE SPECIFICATIONS OF TYPE 1 HOMOPOLYMER AS DETAILED IN ASTM STANDARD SPECIFICATION F-4101.
- 4.0 ALL SUPPORTS SHALL BE CIRCULAR WELDED TO THE CARRIER PIPE. THE SUPPORTS AT BOTH ENDS OF EVERY STRAIGHT LENGTH SHALL BE FACTORY WELDED TO BOTH THE CARRIER AND CONTAINMENT PIPES. SUPPORTS SHALL FACILITATE THE DRAINAGE OF THE CONTAINMENT PIPE.
- 5.0 END SEALS SHALL BE FACTORY FABRICATED TO PREVENT THE INGRESS OF MOISTURE INTO THE SYSTEM. FACTORY FABRICATED END SEALS SHALL ALLOW FOR COMPLETE DRAINAGE OF THE SYSTEM.
- 6.0 PRODUCT LINE DESIGN TEMPERATURE SHALL BE 70 DEG F. PRODUCT LINE DESIGN PRESSURE SHALL BE 25 PSIG
- 7.0 FIELD JOINTS SHALL BE ACCOMPLISHED BY SIMULTANEOUSLY WELDING THE CARRIER AND CONTAINMENT PIPES.
- 8.0 CONNECTIONS TO TANKS AND EQUIPMENT, INCLUDING UNCONTAINED OR EXISTING PIPING, PLUS ALL WALL SLEEVES AND SEALS SHALL BE BY THE INSTALLING CONTRACTOR.
- 9.0 CONTAINMENT PIPE SHALL BE EQUIPPED WITH PROVISIONS FOR A CABLE LEAK DETECTION SYSTEM. LEAK DETECTION SYSTEM SHALL BE CONNECTED TO THE EXISTING LEAK DETECTION SYSTEM SUPPLIED UNDER A PREVIOUS CONTRACT.
- 10.0 CABLE AND CABLE CONNECTORS SHALL BE INSTALLED IN ACCORDANCE WITH THE PAL-AT INSTALLATION MANUAL
- 11.0 CARE MUST BE TAKEN TO STORE ALL PAL-AT COMPONENTS IN A DRY AND PROTECTED AREA AT ALL TIMES. ELECTRONIC ALARM/LOCATOR UNITS AND SENSING CABLE SHOULD BE WRAPPED AND SEALED WITH PLASTIC.
- 12.0 THE DOUBLE-PIPE SYSTEM MUST BE KEPT DRY DURING INSTALLATION. IF IT BECOMES WET, THE CONTRACTOR MUST DRY THE OUTER PIPE BEFORE ACTIVATING THE LEAK DETECTION SYSTEM.
16. THE LEAK DETECTION SYSTEM SHALL INCLUDE THE FOLLOWING MATERIALS.

| QTY | DESCRIPTION |
|--------|--------------------------|
| 5 FEET | ACW LEAK DETECTION CABLE |
| 2 | ACW CONNECTORS |




| NOMINAL PIPE SIZE | SDR 11 | | SDR 32.5 | | r | Z |
|-------------------|----------|----------|----------|----------|------|------|
| | D1 (IN.) | t1 (IN.) | D2 (IN.) | t2 (IN.) | | |
| 2 | 6 | 2.48 | .23 | 6.30 | .197 | 3.74 |

DOUBLE-QUIK POLYPROPYLENE 90° ELBOW






| NOMINAL PIPE SIZE | SDR 11 | | SDR 32.5 | | S | L |
|-------------------|----------|----------|----------|----------|------|---|
| | D1 (IN.) | t1 (IN.) | D2 (IN.) | t2 (IN.) | | |
| 2 | 6 | 2.48 | .23 | 6.30 | .197 | 5 |

DOUBLE-QUIK POLYPROPYLENE STRAIGHT ASSEMBLY



| NOMINAL PIPE SIZE | SDR 11 | | SDR 32.5 | | Z | X |
|-------------------|----------|----------|----------|----------|------|------|
| | D1 (IN.) | t1 (IN.) | D2 (IN.) | t2 (IN.) | | |
| 2 | 6 | 2.48 | .23 | 6.30 | .197 | 6.50 |

DOUBLE-QUIK POLYPROPYLENE TEE



THESE SUBMITTALS DO NOT CONSTITUTE ACCEPTANCE OF YOUR ORDER. A FORMAL ACKNOWLEDGEMENT WILL BE FORWARDED AT TIME OF ACCEPTANCE.
PermaAlert A SUBSIDIARY OF PERMA-PIPE, INC.

APPROVED
 APPROVED AS NOTED
 REVISE AND RESUBMIT

D. Wick DATE _____
 CONTRACTOR SIGNATURE

THESE SUBMITTALS ARE REVIEWED FOR CONFORMANCE WITH PERMA-PIPE SPECIFICATIONS AND STANDARDS. PERMA-PIPE SHALL NOT BE RESPONSIBLE FOR ANY ERRORS OR OMISSIONS THAT MAY OCCUR DUE TO INADEQUATE INFORMATION PROVIDED BY THE SUBMITTER.

1/8"=1'

| | |
|-------------|--------|
| DRAWN BY | KL |
| APPROVED BY | JC |
| DATE | 5-7-98 |

| NOTICE | | | |
|--|------|----------|----|
| THIS DRAWING, AND THE INFORMATION CONTAINED AND/OR ILLUSTRATED THEREIN, IS THE PROPERTY OF PERMA-PIPE, INC. OF 7720 NORTH LEHIGH AVENUE, NILES, ILLINOIS 60714, AND IS SUBMITTED AND FURNISHED IN CONFIDENCE WITH THE UNDERSTANDING THAT THE RECIPIENT SHALL NOT REPRODUCE, COPY, LOAN, DISPOSE OF, OR DISCLOSE TO ANYONE OUTSIDE RECIPIENT'S ORGANIZATION, DIRECTLY OR INDIRECTLY, OR USE FOR ANY PURPOSE OTHER THAN THAT FOR WHICH IT IS FURNISHED AND SUBMITTED, AND THAT RECIPIENT SHALL RETURN THE SAME TO PERMA-PIPE WHEN REQUESTED. | | | |
| REV | DATE | REVISION | BY |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

PermaAlert
 ENVIRONMENTAL SPECIALTY PRODUCTS INC.
 A SUBSIDIARY OF PERMA-PIPE INC.
 7720 LEHIGH AVE. NILES ILLINOIS
 647-966-2190

FOR
BELL / TEXTRON AEROSPACE

JOB NUMBER: PQA3811 DRAWING NO.: 98-230-B
 SCALE: NONE SHEET 1 OF 1

CUSTOMER: MARCOR REMEDIATION, INC.

APPENDIX D

Acknowledgment of Safety Briefing Sheets

Job No. 983-980

Short Title: EW-13 SERVICES

ACKNOWLEDGEMENT OF SAFETY BRIEFING

I hereby acknowledge that I have been given a safety briefing on the work I am to do at the above-referenced site. I understand that the site may contain materials classified by EPA or others as potentially hazardous. I have read and understand the safety plans for this project and will adhere to the procedures contained therein. I have been instructed in and understand the use of the safety equipment for this project. I understand that failure to follow the safety plan may result in dismissal from employment.

Employee

DATE 4/6/98

PRINT NAME PHILIP BENCE

SIGNED Philip P. Bence

Project Manager or Representative

DATE 4/6/98

PRINT NAME David Wehn

SIGNED David Wehn

- Original - Job File
- 1 Copy - Personnel File
- 1 Copy - Safety File

Job No. 983-9180

Short Title: EW-13 ENGINEERING SERVICES

ACKNOWLEDGEMENT OF SAFETY BRIEFING

I hereby acknowledge that I have been given a safety briefing on the work I am to do at the above-referenced site. I understand that the site may contain materials classified by EPA or others as potentially hazardous. I have read and understand the safety plans for this project and will adhere to the procedures contained therein. I have been instructed in and understand the use of the safety equipment for this project. I understand that failure to follow the safety plan may result in dismissal from employment.

Employee

DATE 4-6-98


PRINT NAME MICHAEL J. GUZIEC

SIGNED 

Project Manager or Representative

DATE 4/6/98

PRINT NAME David Wahn

SIGNED 

Original - Job File

1 Copy - Personnel File

1 Copy - Safety File

Job No.

985-9/80

Short Title:

TEETON/EU-13/N4

ACKNOWLEDGEMENT OF SAFETY BRIEFING

I hereby acknowledge that I have been given a safety briefing on the work I am to do at the above-referenced site. I understand that the site may contain materials classified by EPA or others as potentially hazardous. I have read and understand the safety plans for this project and will adhere to the procedures contained therein. I have been instructed in and understand the use of the safety equipment for this project. I understand that failure to follow the safety plan may result in dismissal from employment.

Employee


DATE

5/26/98

PRINT NAME

Rob Jager

SIGNED



Project Manager or Representative


DATE

5/26/98

PRINT NAME

David Wahn

SIGNED



Original - Job File

1 Copy - Personnel File

1 Copy - Safety File

Job No.

983-9180

Short Title:

TEKTRON / EW-13 / NY

ACKNOWLEDGEMENT OF SAFETY BRIEFING

I hereby acknowledge that I have been given a safety briefing on the work I am to do at the above-referenced site. I understand that the site may contain materials classified by EPA or others as potentially hazardous. I have read and understand the safety plans for this project and will adhere to the procedures contained therein. I have been instructed in and understand the use of the safety equipment for this project. I understand that failure to follow the safety plan may result in dismissal from employment.

Employee

DATE 26 May 98

PRINT NAME Lee Blount

SIGNED 

Project Manager or Representative

DATE 5/26/98

PRINT NAME David Wehr

SIGNED 

Original - Job File

1 Copy - Personnel File

1 Copy - Safety File

Job No.

983-980

Short Title:

TEXTRON/EW-13/14

ACKNOWLEDGEMENT OF SAFETY BRIEFING

I hereby acknowledge that I have been given a safety briefing on the work I am to do at the above-referenced site. I understand that the site may contain materials classified by EPA or others as potentially hazardous. I have read and understand the safety plans for this project and will adhere to the procedures contained therein. I have been instructed in and understand the use of the safety equipment for this project. I understand that failure to follow the safety plan may result in dismissal from employment.

Employee

DATE 26 May 98

PRINT NAME FRED BOH

SIGNED Fred Boh

Project Manager or Representative

DATE 5/26/98

PRINT NAME David Wehn

SIGNED David Wehn

Original - Job File

1 Copy - Personnel File

1 Copy - Safety File

Job No.

983-9180

Short Title:

TEXTRON / EU-13

ACKNOWLEDGEMENT OF SAFETY BRIEFING

I hereby acknowledge that I have been given a safety briefing on the work I am to do at the above-referenced site. I understand that the site may contain materials classified by EPA or others as potentially hazardous. I have read and understand the safety plans for this project and will adhere to the procedures contained therein. I have been instructed in and understand the use of the safety equipment for this project. I understand that failure to follow the safety plan may result in dismissal from employment.

Employee

DATE

8-3-98

PRINT NAME

Christopher Bath

SIGNED

Christopher Bath

Project Manager or Representative

DATE

8/3/98

PRINT NAME

David Wohn

SIGNED

David Wohn

Original - Job File

1 Copy - Personnel File

1 Copy - Safety File

Job No.

983-9180

Short Title:

Tertan / EW-13 / NY

ACKNOWLEDGEMENT OF SAFETY BRIEFING

I hereby acknowledge that I have been given a safety briefing on the work I am to do at the above-referenced site. I understand that the site may contain materials classified by EPA or others as potentially hazardous. I have read and understand the safety plans for this project and will adhere to the procedures contained therein. I have been instructed in and understand the use of the safety equipment for this project. I understand that failure to follow the safety plan may result in dismissal from employment.

Employee

DATE 8/3/98
PRINT NAME DAVE PANEK
SIGNED David Panek

Project Manager or Representative

DATE 8/3/98
PRINT NAME David Wehr
SIGNED D Wehr

Original - Job File

1 Copy - Personnel File

1 Copy - Safety File

Job No.

983-9180

Short Title:

TEXTRON / EW-13 / NY

ACKNOWLEDGEMENT OF SAFETY BRIEFING

I hereby acknowledge that I have been given a safety briefing on the work I am to do at the above-referenced site. I understand that the site may contain materials classified by EPA or others as potentially hazardous. I have read and understand the safety plans for this project and will adhere to the procedures contained therein. I have been instructed in and understand the use of the safety equipment for this project. I understand that failure to follow the safety plan may result in dismissal from employment.

Employee

DATE

8/3/98

PRINT NAME

Lonnie Hines

SIGNED

[Signature]

Project Manager or Representative

DATE

8/3/98

PRINT NAME

Daniel Wehr

SIGNED

[Signature]

Original - Job File

1 Copy - Personnel File

1 Copy - Safety File

APPENDIX E

Well Drillhole and Installation Logs

MONITORING WELL INSTALLATION LOG

| | | | |
|-------------------------|---|-------------------------|---|
| Job No. <u>983-9180</u> | Project <u>TEXTRON / EW-13 ENG. SERVICES / NV</u> | Well No. <u>EW-13</u> | Sheet <u>1</u> of <u>1</u> |
| GA Insp. <u>D. WEHN</u> | Drilling Method <u>SEE NOTES</u> | Ground Elev. <u>NA</u> | Water Depth <u>N/A</u> |
| Weather <u>RAIN</u> | Drilling Company <u>MAXIM TECHNOLOGIES INC.</u> | Collar Elev. <u>NA</u> | Date/Time <u>N/A</u> |
| Temp. <u>50°F</u> | Drill Rig <u>FALLING F-10</u> | Driller <u>P. BENCE</u> | Started <u>13:30 4/6/98</u> Completed <u>14:35 4/8/98</u> |

MATERIALS INVENTORY

| | | |
|--|--------------------------------------|---------------------------------|
| Well Casing <u>10</u> in. dia. | I.F. Well Screen <u>N/A</u> in. dia. | I.F. Bentonite Seal <u>NONE</u> |
| Casing Type <u>HDPE SDR 11</u> | Screen Type <u>NONE</u> | Installation Method <u>N/A</u> |
| Joint Type <u>NONE</u> | Slot Size <u>N/A</u> | Filter Pack Qty. <u>N/A</u> |
| Grout Quantity <u>100 Gal.</u> | Centralizers <u>NONE</u> | Filter Pack Type <u>NONE</u> |
| Grout Type <u>97% BENTONITE / 95% CEMENT</u> | Drilling Mud Type <u>N/A</u> | Installation Method <u>N/A</u> |

| Elev./Depth | Soil/Rock Description | WELL SKETCH | Installation Notes |
|-------------|--|-----------------|---|
| | GROUND SURFACE | | |
| 0.0 | OVERBURDEN | | Augered to 15.0 ft bgs. with 12 1/4 inch ID augers. Top of rock noted at 14.2 ft bgs. |
| 2 | See Field Boring Log for monitoring well 96-C(1) for soil description. | Bottom of vault | No split spoon soil samples collected due to proximity of monitoring well 96-C(1) |
| 4 | | 2" | Switched to 12-inch tri-cone bit using air to cut HDPE casing socket from 15.0 to 17.2 ft bgs. Once casing was set and grouted, borehole was drilled with 8-inch tri-cone carbide button bit to 25 ft bgs with air. |
| 6 | | | HW wireline core was collected from 25 to 35 ft bgs and taken by USGS. Borehole reamed with air from 25 to 35 ft bgs with same roller bit as before. |
| 8 | | | |
| 10 | | | |
| 12 | | | |
| 14 | 14.2 | 16.0 - | |
| 16 | LOCKPORT DOLOMITE | 17.2 - | |
| 18 | See Record of Drillhole for rock core description. | | |
| 20 | | | |
| 22 | | | |
| 24 | | | |
| 26 | | | |
| 28 | | | |
| 30 | | | |
| 32 | | | |
| 34 | 35.0 | 35.0 - | |
| 36 | END OF BOREHOLE | | |
| 38 | | | |
| 40 | | | |
| 42 | | | |

RECORD OF DRILLHOLE

Sheet 1 of 1

PROJECT: *TECTONIC ENG. SERVICES* DRILLING DATE: *4/8/98*
 PROJECT NO.: *983-9180*
 LOCATION: *WHEATFIELD, NY*

DATUM: *MSL* COLLAR ELEV.: *N/A*
 COORDINATES: *N: 1129549.0 E: 407711.9*
 AZIMUTH: *N/A* INCLINATION: *90°*

DRILL RIG: *FAILING F-10*

| DEPTH SCALE (FEET) | ROCK TYPE | | DISCONTINUITY DATA | | | | | | | | | | Axial Diameter | | NOTES WATER LEVELS INSTRUMENTATION | | | | | | |
|---------------------------------------|-----------------|------------------|--------------------|-----------------------|------------------------------|--------------|------------|---------|---------------|-------------|------------------|----------------|------------------------|----|--|----|----|----|--|--|---|
| | DESCRIPTION | GRAPHIC LOG | J-Joint | | PL-Planar | | P-Polished | | K-Sickensided | | WEATHERING INDEX | STRENGTH INDEX | POINT LOAD INDEX (psi) | | | | | | | | |
| | | | F-Fault | S-Shear | C-Curved | U-Undulating | S-Smooth | R-Rough | VR-V. Rough | | | | | | | | | | | | |
| ELEV DEPTH (FT) | RUN NO. | CORE RECOVERY | ROD | FRACTURES PER FOOT | TYPE AND SURFACE DESCRIPTION | | | | | GRAPHIC LOG | SW | FR | RW | RW | RW | RW | RW | RW | | | |
| 5 10 15 20 25 30 35 | NO CORE | | | | | | | | | | | | | | | | | | | | |
| | 25.0 | <i>51.84</i> | | <i>Estimated 60%</i> | <i>Estimated 3/ft</i> | | | | | | | | | | | | | | | | Core removed for USGS immediately after retrieval for biologic study. No precise logging possible |
| | 30.1 | | | | | | | | | | | | | | | | | | | | |
| | END OF COREHOLE | | | | | | | | | | | | | | | | | | | | |

DEPTH SCALE: SEE ABOVE
 DRILLING CONTRACTOR: *MAKIM*
 DRILLER: *P. BENCE*

LOGGED: *D. WEHN*
 CHECKED:
 DATE: *4/8/98*

Golder Associates

APPENDIX F

Drill Cuttings Sample Testing Results



ONE RESEARCH CIRCLE WAVERLY, NY 14892-1532
TELEPHONE (607) 565-3500 FAX (607) 565-4083

DATE : Apr 24, 1998

LAB SAMPLE ID : 77084

Golder Associates, Inc.
David Wehn
2221 Niagara Falls Blvd.
PO Box 4069
Niagara Falls NY 14304-4069

| | |
|---------------|------------------|
| SAMPLE SOURCE | TEXTRON 983-9180 |
| ORIGIN | SOIL |
| DESCRIPTION | COMPOSITE |
| SAMPLED ON | 04/14/98 |
| DATE RECEIVED | 04/15/98 |
| P.O. NO. | by CLIENT |

| Analysis Performed | Result | Units | Date Analyzed | Method | Notebook Reference | Analyst |
|--------------------|--------|-------|---------------|----------|--------------------|---------|
| ZHE Extraction | 77085 | | 04/17/98 | EPA 1311 | 95-167-47 | KAL |

For questions regarding this report, please call Customer Services.

cc :

QC QC SW NY 10252 NJ 73168 PA 68180 EPA NY 00033

Approved by: 

Lab Director

KEY: ND or U = None Detected < = less than ug/L = micrograms per liter (equivalent to parts per billion)
 mg/L = milligrams per liter (equivalent to parts per million) mg/kg = milligrams per kilogram (equivalent to parts per million)
 B = analyte was detected in the method or trip blank J = result estimated below the quantitation limit

The information in this report is accurate to the best of our knowledge and ability. In no event shall our liability exceed the cost of these services. Your samples will be discarded after 14 days unless we are advised otherwise.

"Our family, caring about your analytical needs . . . Since 1963."



ONE RESEARCH CIRCLE WAVERLY, NY 14892-1532
TELEPHONE (607) 565-3500 FAX (607) 565-4083

DATE : Apr 24, 1998

LAB SAMPLE ID : 77084

Golder Associates, Inc.
David Wehn
2221 Niagara Falls Blvd.
PO Box 4069
Niagara Falls NY 14304-4069

| | |
|---------------|--------------------|
| SAMPLE SOURCE | TEXTRON 983-9180 |
| ORIGIN | SOIL |
| DESCRIPTION | COMPOSITE |
| SAMPLED ON | 04/14/98 by CLIENT |
| DATE RECEIVED | 04/15/98 |
| P.O. NO. | |

| Analysis Performed | Result | Units | Date Analyzed | Method | Notebook Reference | Analyst |
|--------------------|--------|-------|---------------|----------|--------------------|---------|
| ZHE Extraction | 77085 | | 04/17/98 | EPA 1311 | 95-167-47 | KAL |

For questions regarding this report, please call Customer Services.

cc :

QC SW NY 10252 NJ 73168 PA 68180 EPA NY 00033

Approved by: 

Lab Director

KEY: ND or U = None Detected < = less than ug/L = micrograms per liter (equivalent to parts per billion)
 mg/L = milligrams per liter (equivalent to parts per million) mg/kg = milligrams per kilogram (equivalent to parts per million)
 B = analyte was detected in the method or trip blank J = result estimated below the quantitation limit

The information in this report is accurate to the best of our knowledge and ability. In no event shall our liability exceed the cost of these services. Your samples will be discarded after 14 days unless we are advised otherwise.

"Our family, caring about your analytical needs . . . Since 1963."



Volatiles

ONE RESEARCH CIRCLE WAVERLY, NY 14892-1532
TELEPHONE (607) 565-3500 FAX (607) 565-4083

DATE Apr 28, 1998

LAB SAMPLE ID : 77085

Golder Associates, Inc.
David Wehn
2221 Niagara Falls Blvd.
PO Box 4069
Niagara Falls NY 14304-4069

| | |
|---------------|--------------------|
| SAMPLE SOURCE | TEXTRON 983-9180 |
| ORIGIN | 77084 |
| DESCRIPTION | ZHE EXTRACT |
| SAMPLED ON: | 04/14/98 by CLIENT |
| DATE RECEIVED | 04/15/98 |
| P.O. NO. | |

| | | |
|--------------------------|---------------|----------------------------------|
| Method : SW846/8260/5030 | Analyst : SMB | Notebook Reference : 98-035-1520 |
| Compounds Detected | Units : MG/L | Date Analyzed : 04/24/98 |
| ----- | Results | ----- |
| Vinyl Chloride | ND<0.025 | 0.2 |
| 1,1-Dichloroethene | ND<0.025 | 0.7 |
| Methyl Ethyl Ketone | ND<0.25 | 200.0 |
| Chloroform | ND<0.025 | 6.0 |
| Carbon Tetrachloride | ND<0.025 | 0.5 |
| Benzene | ND<0.025 | 0.5 |
| 1,2-Dichloroethane | ND<0.025 | 0.5 |
| Trichloroethene | ND<0.025 | 0.5 |
| Tetrachloroethene | ND<0.025 | 0.7 |
| Chlorobenzene | ND<0.025 | 100.0 |
| 1,4-Dichlorobenzene | ND<0.025 | 7.5 |
| Surrogate Recovery (%) | | |
| Dibromofluoromethane | 97 | |
| Toluene-d8 | 98 | |
| Bromofluorobenzene | 94 | |

For questions regarding this report, please call and ask for Customer Services.

CC :

QC NY 10252 NJ 73168 PA 68180 EPA NY 00033

Approved by: Lab Director

KEY: ND or U = None Detected < = less than ug/L = micrograms per liter (equivalent to parts per billion)
mg/L = milligrams per liter (equivalent to parts per million) mg/kg = milligrams per kilogram (equivalent to parts per million)
B = analyte was detected in the method or trip blank J = result estimated below the quantitation limit

The information in this report is accurate to the best of our knowledge and ability.. In no event shall our liability exceed the cost of these services. Your samples will be discarded after 14 days unless we are advised otherwise.

"Our family, caring about your analytical needs . . . Since 1963."

APPENDIX G

Air Monitoring Results

GOLDER ASSOCIATES INC.

Air Monitoring During Drilling

Sheet 1 of 1

PROJECT NAME TEXTRON / EW-3 ENG. SERVO. / NY BORING NUMBER EW-13
 PROJECT NUMBER 983-9180 AMBIENT TEMPERATURE 50°F
 INSTRUMENT USED AND ID NO. Mini RAE 00084 / Badarach 4HT WIND SPEED 5-10 mph
 CALIBRATION NUMBER _____ WIND DIRECTION SE

| DATE | TIME | DEPTH OF AUGER* | INSTRUMENT READING | |
|--------|-------|-----------------|--------------------|--------|
| 4/6/98 | 13:45 | 2 FT BGS | 0.0 ppm | 0% LEL |
| | 13:50 | 5 FT | 0.0 ppm | 0% LEL |
| | 14:02 | 7.5 FT | 0.0 ppm | 0% LEL |
| | 14:05 | 10 FT | 0.0 ppm | 0% LEL |
| | 14:20 | 12.5 FT | 0.0 ppm | 0% LEL |
| | 14:23 | 14.2 FT | 0.0 ppm | 0% LEL |
| | 15:50 | 15 FT | 0.0 ppm | 0% LEL |
| | 16:05 | 15.5 FT | 0.0 ppm | 0% LEL |
| | 16:15 | 16 FT | 0.0 ppm | 0% LEL |
| | 16:22 | 16.5 FT | 0.0 ppm | 0% LEL |
| 16:30 | 17 FT | 0.0 ppm | 0% LEL | |
| 4/8/98 | 9:25 | 15 FT | 0.0 ppm | 0% LEL |
| | 9:45 | 18 FT | 0.0 ppm | 0% LEL |
| | 10:05 | 22 FT | 0.0 ppm | 0% LEL |
| | 10:20 | 25 FT | 0.0 ppm | 0% LEL |
| | 11:10 | 26 FT | 0.0 ppm | 0% LEL |
| | 11:30 | 28 FT | 0.0 ppm | 0% LEL |
| | 12:10 | 30 FT | 0.0 ppm | 0% LEL |
| | 13:30 | 34 FT | 0.0 ppm | 0% LEL |
| | 14:10 | 32 FT | 0.0 ppm | 0% LEL |
| | 14:30 | 35 FT | 0.0 ppm | 0% LEL |

* 12" TRICONE BIT AFTER 14.2 FT BGS
 8" TRICONE BIT AFTER 17.2 FT BGS
 (OR CORE BARREL)



Date 5/26/98 Sheet 1 of 1

Job Name TEXTRON / EW-13 ENG. SERV. / NY Job Number 983-9180

Location NIAGARA FALLS, NY

Time In _____ Time Out _____ Weather Sun Temp. 70°F Wind 0 SE V0-5

Instrument Type Sentinel 44T Multi-Gas / Mine RAE PID Serial No. N/A

Calibration Gas 30% LEL / 100 ppm Iso. Instrument Reading 27% / 98 ppm Span/Gain/RF Setting 100

and Concentration * If more than one instrument is used, document calibration procedures and results for each additional instrument in recommendations section below and indicate the instrument used (eg. OVA, 361, OVM, etc.) for each observation.

| Time | Station | Instr. * | Reading | Procedure/Observations/Comments | |
|-------|---------|------------|-----------------|---------------------------------|------------|
| | | | | Vault | Excavation |
| 9:20 | Vault | 44T PID | 0% LEL 0 ppm | Vault | Excavation |
| 9:35 | Vault | 44T PID | 0% LEL 0 ppm | | |
| 9:50 | Vault | 44T PID | 0% LEL 0 ppm | | |
| 10:10 | Vault | 44T PID | 0% LEL 0 ppm | | |
| 11:00 | Vault | 44T PID | 0% LEL 0 ppm | | |
| 13:30 | Vault | 44T PID | 0% LEL 0 ppm | | |

Recommendations

David Wehn
Printed Name

David Wehn
Signature



Date 6/1/98 Sheet 1 of 1

Job Name TRITON / EW-13 ENG SERV. / NY Job Number 983-980

Location NIAGARA FALLS, NY

Time In _____ Time Out _____ Weather SUN Temp. 60°F Wind D. NE V 0-15

Instrument Type Sentinel 44T Multi-Gas / Mini RAE PID Serial No. N/A

Calibration Gas 30% LEL / 100ppm Iso Instrument Reading 27% / 9ppm Scarv/Gain/VF Setting 100

and Concentration * If more than one instrument is used, document calibration procedures and results for each additional instrument in recommendations section below and indicate the instrument used (eg. OVA, 351, OVM, etc.) for each observation.

| Time | Station | Instr. * | Reading | Procedure/Observations/Comments |
|-------|---------|------------|----------------|--|
| 8:30 | Vault | 44T PID | 0% LEL 0ppm | EW-13 Excavation |
| 13:10 | Vault | 44T PID | 0% LEL 0ppm | 6/2/98 - EW-8 vault EW-13 Excavation |
| | | 44T PID | 0% LEL 0ppm | EW-13 Excavation |
| 10:30 | | 44T PID | 0% LEL 0ppm | EW-13 Excavation 6/3/98 NE WINDS 55°F |
| 14:00 | | 44T PID | 0% LEL 0ppm | EW-7 vault |
| 14:00 | | 44T PID | 0% LEL 0ppm | EW-8 vault |

Recommendations

David Wehn
Printed Name

David Wehn
Signature



Date 6/4/98 Sheet 1 of

Job Name TRITON / EW-13 ENG SERU. / NY Job Number 983-9180

Location NIAGARA FALLS, NY

Time In Time Out Weather SUN Temp 60°F Wind D. E V 0-5

Instrument Type Sentinel 44T Multi-Gas / Mini RAE PID Serial No. N/A

Calibration Gas 30% LEL / 100ppm Iso Instrument Reading 27% / 9ppm Scarv/Gain/VRF Setting 100

and Concentration * If more than one instrument is used, document calibration procedures and results for each additional instrument in recommendations section below and indicate the instrument used (eg. OVA, 361, OVM, etc.) for each observation.

| Time | Station | Instr. * | Reading | Procedure/Observations/Comments |
|------|---------|----------|---------|---------------------------------|
| 8:10 | | 44T | 0% LEL | EW-13 Excavation |
| | | PID | 0 ppm | |
| | | 44T | 0% LEL | EW-8 |
| | | PID | 0 ppm | |
| | | 44T | 0% LEL | EW-7 |
| | | PID | 0 ppm | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Recommendations

David Weber
 Printed Name

David Weber
 Signature



Date 6/9/98 Sheet 1 of 1

Job Name TR-12W-13 ENG SERV. NY Job Number 983-9180

Location NIAGARA FALLS, NY

Time In _____ Time Out _____ Weather SUNNY Temp. 55°C Wind D. SW V 0-5

Instrument Type Sentinel 44T Multi-Gas / Mini RAE PID Serial No. N/A

Calibration Gas 30% LEL / 100 ppm Iso Instrument Reading 27% / 9 ppm Span/Gain/RF Setting 100

and Concentration * If more than one instrument is used, document calibration procedures and results for each additional instrument in recommendations section below and indicate the instrument used (eg. OVA, 361, OVM, etc.) for each observation.

| Time | Station | Instr. * | Reading | Procedure/Observations/Comments |
|-------------|---------|------------|---------------|---------------------------------|
| <u>0755</u> | | <u>44T</u> | <u>0% LEL</u> | <u>FW-13 Excavation</u> |
| | | <u>PID</u> | <u>0 ppm</u> | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Recommendations

JONATHAN P. RIZZO
Printed Name

[Signature]
Signature



Date 6/12/98 Sheet 1 of 1

Job Name TEETREN / EW-13 ENG SERV. / NY Job Number 983-980

Location NIAGARA FALLS, NY

Time In _____ Time Out _____ Weather INTERMITTENT RAIN Temp. 70°F Wind D. SW V 5-15 MPH

Instrument Type Sentinel 44T Multi-Gas / Mini RAE PID Serial No. N/A

Calibration Gas 30% LEL / 100 ppm Iso. Instrument Reading 27% / 18 ppm Scarv/Gain/RF Setting 100

and Concentration • If more than one instrument is used, document calibration procedures and results for each additional instrument in recommendations section below and indicate the instrument used (eg. OVA, 351, OVM, etc.) for each observation.

| Time | Station | Instr. • | Reading | Procedure/Observations/Comments |
|-------|---------|----------|----------|---------------------------------|
| 10:30 | | 44T | 0% LEL | EW-13 FIVE AU-4T SW |
| | | 44T | 20.4% O2 | |
| 10:35 | | 44T | 0% LEL | EW-07 VAULT |
| | | 44T | 20.4% O2 | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Recommendations

J. P. Russo
Printed Name

[Signature]
Signature



Date 6/15/98 Sheet 1 of 1

Job Name TECTREX / EW-13 ENG SERV. / NY Job Number 983-980

Location NIAGARA FALLS, NY

Time In _____ Time Out _____ Weather OVERCAST Temp. 65°F Wind D. SW V. 0-5 mph

Instrument Type Sentinel 44T Multi-Gas / Mini RAE PID Serial No. X/A

Calibration Gas 30% LEL / 100 ppm Iso Instrument Reading 27% Span/Gain/VRF Setting 100

and Concentration • If more than one instrument is used, document calibration procedures and results for each additional instrument in recommendations section below and indicate the instrument used (eg. OVA, 35T, OVM, etc.) for each observation.

| Time | Station | Instr. * | Reading | Procedure/Observations/Comments |
|-------|---------|----------|---------------------|---------------------------------|
| 08:30 | | 44T | 0.0 LEL | EW-13 EXCAVATION |
| | | | 20.4 O ₂ | |
| 08:35 | | 44T | 0.0 LEL | EW-07 VAULT |
| | | 44T | 20.4 O ₂ | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Recommendations

William P. Rizzo
Printed Name

[Signature]
Signature



Date 6/16/98 Sheet 1 of 1

Job Name TELECOM / EW-13 ENG SERV. / NY Job Number 983-980

Location NIAGARA FALLS, NY

Time In _____ Time Out _____ Weather PARTLY SUNNY Temp. 65° Wind D. SW V 5-10 MPH

Instrument Type Sentinel 44T Multi-Gas / Mini RAE PID Serial No. _____ x/A

Calibration Gas 30% LEL / 100ppm Isc Instrument Reading 27% / 9ppm Span/Gain/RF Setting 100

and Concentration • If more than one instrument is used, document calibration procedures and results for each additional instrument in recommendations section below and indicate the instrument used (eg. OVA, 361, OVM, etc.) for each observation.

| Time | Station | Instr. • | Reading | Procedure/Observations/Comments |
|-------|---------|----------|---------------------------------|---------------------------------|
| 08:05 | | 44T | 20.4% O ₂ 0.0 LEL | EW-13 EVACUATION |
| 08:10 | | 44T | 20.4% O ₂ 0.0 LEL | EW-7 VAULT |
| 08:15 | | 44T | 20.4% O ₂ 0.0 LEL | EW-8 VAULT |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Recommendations

Jonathan P. Rizzo
Printed Name

Signature



Date 6/17/90 Sheet 1 of 1

Job Name TEETRON / EW-13 ENG SERV. / NY Job Number 983-9180

Location NIAGARA FALLS, NY

Time In _____ Time Out _____ Weather 65°F Partly Sunny Temp. 65°F Wind D. NW V 0-5 mph

Instrument Type Sentinel 44T Multi-Gas / Mini RAE PID Serial No. N/A

Calibration Gas 30% LEL / 100 ppm Iso Instrument Reading 27% / 98 ppm Scan/Gain/RF Setting 100

and Concentration * If more than one instrument is used, document calibration procedures and results for each additional instrument in recommendations section below and indicate the instrument used (eg. OVA, 361, OVM, etc.) for each observation.

| Time | Station | Instr. * | Reading | Procedure/Observations/Comments |
|------|---------|----------|---------------------------------|---------------------------------|
| 0800 | | 44T | 20.4% O ₂ 0.0 LEL | EW-13 EXCAVATION |
| 0805 | | 44T | 20.4% O ₂ 0.0 LEL | EW-7 EXCAVATION |
| 0808 | | 44T | 20.4% O ₂ 0.0 LEL | EW-8 EXCAVATION |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Recommendations

JONATHAN P. Rizzo
Printed Name

[Signature]
Signature



Date 6/18/98 Sheet 1 of 1

Job Name TEKTROL EW-13 ENG SERVO. NY Job Number 983-9180

Location NIAGARA FALLS, NY

Time In _____ Time Out _____ Weather PARTLY SUNNY Temp. 68°F Wind D. SW V 0-5mph

Instrument Type Sentinel 44T Multi-Gas / Mini RAE PID Serial No. N/A

Calibration Gas 30% LEL / 100ppm Iso Instrument Reading 27% Span/Gain/VF Setting 100

and Concentration *If more than one instrument is used, document calibration procedures and results for each additional instrument in recommendations section below and indicate the instrument used (eg. OVA, 361, OVM, etc.) for each observation.

| Time | Station | Instr. * | Reading | Procedure/Observations/Comments |
|-------------|---------|------------|-----------------------------------|---------------------------------|
| <u>0805</u> | | <u>44T</u> | <u>20.4% O2</u> <u>0.0 LEL</u> | <u>EW-13 EXHAUSTION</u> |
| <u>0810</u> | | <u>44T</u> | <u>20.4% O2</u> <u>0.0 LEL</u> | <u>EW-7 VAULT</u> |
| <u>0815</u> | | <u>44T</u> | <u>20.7% O2</u> <u>0.0 LEL</u> | <u>EW-8 VAULT</u> |
| <u>1410</u> | | <u>44T</u> | <u>20.4% O2</u> <u>0.0 LEL</u> | <u>EW-9 VAULT</u> |

Recommendations

Jonathan P. Rizzo
Printed Name

[Signature]
Signature



Date 6/19/98 Sheet 1 of 1

Job Name TECTREX / EW-13 ENG SERV. / NY Job Number 983-980

Location NIAGARA FALLS, NY

Time In _____ Time Out _____ Weather SUNNY Temp. 75°F Wind D. S V 0-5 MPH

Instrument Type Sentinel 44T Multi-Gas / Mini RAE PID Serial No. N/A

Calibration Gas 30% LEL / 100ppm Iso Instrument Reading 27% / 9ppm Span/Gain/RF Setting 100

and Concentration - If more than one instrument is used, document calibration procedures and results for each additional instrument in recommendations section below and indicate the instrument used (eg. OVA, 361, OVM, etc.) for each observation.

| Time | Station | Instr. * | Reading | Procedure/Observations/Comments |
|-------------|---------|------------|--|---------------------------------|
| <u>0815</u> | | <u>44T</u> | <u>20.4% O₂</u> <u>0.0 LEL</u> | <u>EW-13 EXCAVATION</u> |
| <u>0820</u> | | <u>44T</u> | <u>20.4% O₂</u> <u>0.0 LEL</u> | <u>EW-7 VAULT</u> |
| <u>0825</u> | | <u>44T</u> | <u>20.4% O₂</u> <u>0.0 LEL</u> | <u>EW-8 VAULT</u> |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Recommendations

JONATHAN P. DIZZO
Printed Name

[Signature]
Signature



Date 1/23/98 Sheet 1 of 1

Job Name TELECOM / EW-13 ENG SERV. / NY Job Number 983-980

Location NIAGARA FALLS, NY

Time In _____ Time Out _____ Weather Overcast Temp. 80°F Wind D. E V 0-5

Instrument Type Sentinel 44T Multi-Gas / Mini RAE PID Serial No. _____ x/A

Calibration Gas 30% LEL / 100ppm Isc Instrument Reading 27% / 90ppm Span/Gain/RF Setting 100

and Concentration • If more than one instrument is used, document calibration procedures and results for each additional instrument in recommendations section below and indicate the instrument used (eg. OVA, 361, OVM, etc.) for each observation.

| Time | Station | Instr. • | Reading | Procedure/Observations/Comments |
|--------------|---------|------------|---------------|---------------------------------|
| <u>10:10</u> | | <u>44T</u> | <u>0% LEL</u> | <u>EW-13 Excavation</u> |
| | | <u>PID</u> | <u>0 ppm</u> | |
| | | <u>44T</u> | <u>0% LEL</u> | <u>EW-7 Vault</u> |
| | | <u>PID</u> | <u>0 ppm</u> | |
| | | <u>44T</u> | <u>0% LEL</u> | <u>EW-8 Vault</u> |
| | | <u>PID</u> | <u>0 ppm</u> | |

Recommendations

David Wehn
Printed Name

[Signature]
Signature



Date 6/29/98 Sheet 1 of 1

Job Name TREXLOW / EW-13 ENG SERV. / NY Job Number 983-9180

Location NIAGARA FALLS, NY

Time In _____ Time Out _____ Weather 80° P. Sunny Temp. 80°F Wind D. E VO-5

Instrument Type Sentinel 44T Multi-Gas / Mini RAE PID Serial No. N/A

Calibration Gas 30% LEL / 100ppm Iso Instrument Reading 27% / 8ppm Span/Gain/VRF Setting 100

and Concentration * If more than one instrument is used, document calibration procedures and results for each additional instrument in recommendations section below and indicate the instrument used (eg. OVA, 361, OVM, etc.) for each observation.

| Time | Station | Instr. | Reading | Procedure/Observations/Comments |
|------|---------|------------|-------------------------------------|---------------------------------|
| 9:00 | | 44T PID | 0% LEL 20.8% O ₂ 0ppm | EW-13 Excavation |
| | | 44T PID | 0% LEL 20.8% O ₂ 0ppm | EW-8 |
| | | 44T PID | 0% LEL 20.7% O ₂ 0ppm | EW-7 |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Recommendations

David Wehr
Printed Name

David Wehr
Signature



Date 7/2/98 Sheet 1 of 1

Job Name TR & TRAIL / EW-13 ENG SERV. / NY Job Number 983-9180

Location NIAGARA FALLS, NY

Time In _____ Time Out _____ Weather Sunny Temp. 70°F Wind D. V 0

Instrument Type Sentinel 44T Multi-Gas / Mini RAE PID Serial No. N/A

Calibration Gas 30% LEL / 100ppm Isc Instrument Reading 27% / 9ppm Span/Gain/RF Setting 100

and Concentration • If more than one instrument is used, document calibration procedures and results for each additional instrument in recommendations section below and indicate the instrument used (eg. OVA, 361, OVM, etc.) for each observation.

| Time | Station | Instr. • | Reading | Procedure/Observations/Comments |
|--------------|---------|------------|----------------------------|---------------------------------|
| <u>7:50</u> | | <u>44T</u> | <u>0% LEL</u> | <u>EW-8</u> |
| | | <u>44T</u> | <u>20.9% O₂</u> | |
| | | <u>PID</u> | <u>0ppm</u> | |
| | | <u>44T</u> | <u>0% LEL</u> | <u>Excavation (EW-13)</u> |
| | | <u>44T</u> | <u>20.9% O₂</u> | |
| | | <u>PID</u> | <u>0ppm</u> | |
| <u>14:00</u> | | <u>44T</u> | <u>0% LEL</u> | <u>EW-7</u> |
| | | <u>44T</u> | <u>20.9% O₂</u> | |
| | | <u>PID</u> | <u>0ppm</u> | |

Recommendations

David Wehn
Printed Name

[Signature]
Signature



Date 8/3/98 Sheet 1 of 1

Job Name TREX / EW-13 ENG SERV. / NY Job Number 983-9180

Location NIAGARA FALLS, NY

Time In _____ Time Out _____ Weather Sun Temp. 75°F Wind D. E V 0-5

Instrument Type Sentinel 44T Multi-Gas / Mini RAE PID Serial No. N/A

Calibration Gas 30% LEL / 100ppm Iso Instrument Reading 27% / 75ppm Scarv/Gain/RF Setting 100
and Concentration * If more than one instrument is used, document calibration procedures and results for each additional instrument in recommendations section below and indicate the instrument used (eg. OVA, 361, OVM, etc.) for each observation.

| Time | Station | Instr. * | Reading | Procedure/Observations/Comments |
|-------|------------|------------|--------------------------|---------------------------------|
| 8:00 | EW-7 Vault | 44T PID | 0% LEL 20.9% O2 0 ppm | |
| 8:00 | EW-8 Vault | 44T PID | 0% LEL 20.8% O2 0 ppm | |
| 13:00 | Excavation | 44T PID | 0% LEL 20.9% O2 0 ppm | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Recommendations

David Weber
Printed Name

David Weber
Signature



Date 8/4/98 Sheet 1 of 1

Job Name TEETROW / EW-13 ENG SERV. / NY Job Number 983-9180

Location NIAGARA FALLS, NY

Time In _____ Time Out _____ Weather Cloudy Temp. 75°F Wind D. E V 0-5

Instrument Type Sentinel 44T Multi-Gas / Mini RAE PID Serial No. N/A

Calibration Gas 30% LEL / 100ppm Iso Instrument Reading 27% / 8ppm Span/Gain/RF Setting 100

and Concentration * If more than one instrument is used, document calibration procedures and results for each additional instrument in recommendations section below and indicate the instrument used (eg. OVA, 361, OVM, etc.) for each observation.

| Time | Station | Instr. * | Reading | Procedure/Observations/Comments |
|------|------------|----------|----------------------------|---------------------------------|
| 8:00 | EW-7 Vault | 44T | 0% LEL 20.9 O ₂ | |
| | | PID | 0 ppm | |
| 8:00 | EW-8 Vault | 44T | 0% LEL 20.9 O ₂ | |
| | | PID | 0 ppm | |
| 8:00 | Excavation | 44T | 0% LEL 20.9 O ₂ | |
| | | PID | 0 ppm | |

Recommendations

David Wehn
Printed Name

David Wehn
Signature



Date 8/5/98 Sheet of 1

Job Name TE & TRAIL / EW-13 ENG SERV. / NY Job Number 983-980

Location NIAGARA FALLS, NY

Time In Time Out Weather Overcast Temp. 80°F Wind D. E V 0-5

Instrument Type Sentinel 44T Multi-Gas / Mini RAE PID Serial No. X/A

Calibration Gas 30% LEL / 100ppm Iso Instrument Reading 27% / 98ppm Span/Gain/VRF Setting 100

and Concentration • If more than one instrument is used, document calibration procedures and results for each additional instrument in recommendations section below and indicate the instrument used (eg. OVA, 361, OVM, etc.) for each observation.

| Time | Station | Instr. | Reading | Procedure/Observations/Comments |
|-------|------------|--------|-----------------------------|---------------------------------|
| 10:00 | EW-7 Vault | 44T | 0% LEL 20.9% O ₂ | |
| | | PID | 0 ppm | |
| | EW-8 Vault | 44T | 0% LEL 20.9% O ₂ | |
| | | PID | 0 ppm | |
| | Excavation | 44T | 0% LEL 20.9% O ₂ | |
| | | PID | 0 ppm | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Recommendations

David Weber
Printed Name

David Weber
Signature



Golder Associates Inc.

AIR MONITORING DATA SHEET

Date 8/6/98 Sheet 1 of 1

Job Name TR & TRON / EW-13 ENG SERV. / NY Job Number 983-9180

Location NIAGARA FALLS, NY

Time In _____ Time Out _____ Weather Overcast Temp 80°F Wind D. E V 0-5

Instrument Type Sentinel 44T Multi-Gas / Mini RAE PID Serial No. N/A

Calibration Gas 30% LEL / 100ppm Iso Instrument Reading 272 / 8ppm Span/Gain/RF Setting 100

and Concentration * If more than one instrument is used, document calibration procedures and results for each additional instrument in recommendations section below and indicate the instrument used (eg. OVA, 361, OVM, etc.) for each observation.

| Time | Station | Instr. * | Reading | Procedure/Observations/Comments |
|------|------------|----------|-----------------------------|---------------------------------|
| 8:30 | EW-7 Vault | 44T | 0% LEL 20.9% O ₂ | |
| | | PID | 0 ppm | |
| | EW-8 Vault | 44T | 0% LEL 20.8% O ₂ | |
| | | PID | 0 ppm | |
| | Excavation | 44T | 0% LEL 20.9% O ₂ | |
| | | PID | 0 ppm | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Recommendations

David Wehn
 Printed Name

David Wehn
 Signature



Date 8/7/98 Sheet 1 of 1

Job Name TELECOM 1 EW-13 ENG SERV. NY Job Number 983-9180

Location NIAGARA FALLS, NY

Time In _____ Time Out _____ Weather Overcast Temp. 85°F Wind D. E V 0-10

Instrument Type Sentinel 44T Multi-Gas / Mini RAE PID Serial No. _____ N/A

Calibration Gas 30% LEL / 100ppm Iso Instrument Reading 27% / 95ppm Span/Gain/RF Setting 100

and Concentration • If more than one instrument is used, document calibration procedures and results for each additional instrument in recommendations section below and indicate the instrument used (eg. OVA, 351, OVM, etc.) for each observation.

| Time | Station | Instr. • | Reading | Procedure/Observations/Comments |
|------|---------------|----------|---------|---------------------------------|
| 8:30 | EW-7 Vault | 44T | 0% LEL | 20.9% O ₂ |
| | | PID | 0 ppm | |
| | EW-8 Vault | 44T | 0% LEL | 20.9% O ₂ |
| | | PID | 0 ppm | |
| | F. Excavation | 44T | 0% LEL | 20.9% O ₂ |
| | | PID | 0 ppm | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Recommendations

David Wehr
Printed Name

D. Wehr
Signature



Date 8/10/98 Sheet 1 of 1

Job Name TEETREN / EW-13 ENG SERV. / NY Job Number 983-9180

Location NIAGARA FALLS, NY

Time In _____ Time Out _____ Weather _____ Temp. 75°F Wind D. 0 V 0

Instrument Type Sentinel 44T Multi-Gas / Mini RAE PID Serial No. N/A

Calibration Gas 30% LEL / 100ppm Iso Instrument Reading 27% / 9ppm Scan/Gain/VRF Setting 100

and Concentration • If more than one instrument is used, document calibration procedures and results for each additional instrument in recommendations section below and indicate the instrument used (eg. OVA, 361, OVM, etc.) for each observation.

| Time | Station | Instr. • | Reading | Procedure/Observations/Comments |
|------|------------|----------|-----------------------------|---------------------------------|
| 9:00 | EW-7 Vault | 44T | 0% LEL 20.9% O ₂ | |
| | | PID | 0 ppm | |
| | EW-8 Vault | 44T | 0% LEL 20.9% O ₂ | |
| | | PID | 0 ppm | |
| | EW-8 Vault | 44T | 0% LEL 20.9% O ₂ | |
| | | PID | 0 ppm | |

Recommendations

David Woh
Printed Name

David Woh
Signature



Date 8/11/98 Sheet 1 of 1

Job Name TEETREN / EW-13 ENG SERV. / NY Job Number 983-980

Location NIAGARA FALLS, NY

Time In _____ Time Out _____ Weather overcast Temp. 80°F Wind D. E V.O.S _____

Instrument Type Sentinel 44T Multi-Gas / Mini RAE PID Serial No. _____ x/A

Calibration Gas 30% LEL / 100ppm Iso Instrument Reading 27% / 9ppm Span/Gain/RF Setting 100

and Concentration • If more than one instrument is used, document calibration procedures and results for each additional instrument in recommendations section below and indicate the instrument used (eg. OVA, 361, OVM, etc.) for each observation.

| Time | Station | Instr. • | Reading | Procedure/Observations/Comments |
|------|---------|----------|----------------------|---------------------------------|
| 7:40 | EW-8 | 44T | 8% O ₂ | 0% LEL <u>LOW</u> <u>On</u> |
| | | PID | 0 ppm | |
| 7:45 | EW-8 | 44T | 20.9% O ₂ | ← <u>Open vault + air out</u> |
| 7:45 | EW-7 | 44T | 20.8% O ₂ | 0% LEL. |
| | | PID | 0 ppm | |

Recommendations

Vault EW-8 should be closed + locked when receiving N₂ from EW-7 while line drying.

David Wahn
Printed Name

D. Wahn
Signature



Date 8/12/98 Sheet 1 of 1

Job Name TELECOM EW-13 ENG SERV. / NY Job Number 983-980

Location NIAGARA FALLS, NY

Time In _____ Time Out _____ Weather Sun Temp. 75°F Wind D. N V 0-5

Instrument Type Sentinel 44T Multi-Gas / Mini RAE PID Serial No. X/A

Calibration Gas 30% LEL / 100ppm Iso Instrument Reading 27% / 95ppm Span/Gain/VRF Setting 100
and Concentration • If more than one instrument is used, document calibration procedures and results for each additional instrument in recommendations section below and indicate the instrument used (eg. OVA, 361, OVM, etc.) for each observation.

| Time | Station | Instr. * | Reading | Procedure/Observations/Comments |
|-------------|-------------|------------|-----------------|---------------------------------|
| <u>8:00</u> | <u>Ew-7</u> | <u>44T</u> | <u>20.9% O2</u> | <u>0% LEL</u> |
| | | <u>PID</u> | <u>0 ppm</u> | |
| | <u>Ew-8</u> | <u>44T</u> | <u>20.9% O2</u> | <u>0% LEL</u> |
| | | <u>PID</u> | <u>0 ppm</u> | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Recommendations

David Wahn
Printed Name

[Signature]
Signature



Date 8/13/98 Sheet 1 of 1

Job Name TREX / EW-13 ENG SERV. / NY Job Number 983-980

Location NIAGARA FALLS, NY

Time In Time Out Weather Sun Temp. 75°F Wind D. N V 0-5

Instrument Type Sentinel 44T Multi-Gas / Mini RAE PID Serial No. X/A

Calibration Gas 30% LEL / 100ppm Iso Instrument Reading 27% / 85ppm Span/Gain/VRF Setting 100

and Concentration • If more than one instrument is used, document calibration procedures and results for each additional instrument in recommendations section below and indicate the instrument used (eg. OVA, 361, OVM, etc.) for each observation.

| Time | Station | Instr. * | Reading | Procedure/Observations/Comments |
|------|---------|------------|-----------------|---------------------------------|
| 8:00 | EW-7 | 44T PID | 0% LEL 0 ppm | 20.9% O ₂ |
| | | | | |
| | EW-8 | 44T PID | 0% LEL 0 ppm | 20.9% O ₂ |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Recommendations

David Wehr
 Printed Name

David Wehr
 Signature

APPENDIX H

Pipe Pressure Testing Certificates

PIPE TEST CERTIFICATE

| | <u>Initial Test Status</u> | <u>Interim Test Status</u> | <u>Interim Test Status</u> | <u>Final Test Status</u> | <u>Duration</u> |
|------------------------|--|---|------------------------------------|----------------------------------|-----------------------------|
| Date/Time: | <u>6/12/98 1400</u> | <u>6/12/98 1800</u> | <u> </u> | <u>6/13/98 1400</u> | <u>24 HRS.</u> |
| Temperature (Ambient): | <u>70°F</u> | <u>70°F</u> | <u> </u> | <u>68°F</u> | <u> </u> |
| Test Pressure (psig): | <u>30</u> | <u>30</u> | <u> </u> | <u>30</u> | <u> </u> |
| Test Medium: | <input type="checkbox"/> Water | <input checked="" type="checkbox"/> Air | <input type="checkbox"/> Nitrogen | <input type="checkbox"/> _____ | |
| Test Specification: | <u>TEST WITH AIR TO 30 PSI FOR PERIOD OF 24 HOURS</u> <u>(PRE - BACKFILL)</u> | | | | |

DESCRIPTION OF PIPELINE(S) TESTED

Location: 2" POLY PROPYLENE CARTRIDGE LINE BETWEEN EW-07 AND EW-08 INCLUDING EW-13




Line Numbers: N/A

Portion of Line Tested: All, or _____

Remarks: None

Test Results: Pass Fail

I certify that the above information is correct and that the pipeline described above was prepared and tested in my presence in accordance with the Specification indicated above.

| | | | |
|-------------------|--|---|----------------|
| Signed by | <u></u> | <u></u> | <u>6/12/98</u> |
| | Contractor's Representative | Company | Date |
| Test Witnessed by | <u></u> | <u>GOLDER ASSOCIATES INC.</u> | <u>6/12/98</u> |
| | Owner's Representative | Company | Date |

PIPE TEST CERTIFICATE

| | <u>Initial Test Status</u> | <u>Interim Test Status</u> | <u>Interim Test Status</u> | <u>Final Test Status</u> | <u>Duration</u> |
|------------------------|--|------------------------------------|------------------------------------|----------------------------------|-------------------|
| Date/Time: | <u>6/23/98 16:25</u> | <u>17:25</u> | <u> </u> | <u>18:25</u> | <u>2 Hrs.</u> |
| Temperature (Ambient): | <u>75°F</u> | <u>75°F</u> | <u> </u> | <u>75°F</u> | <u> </u> |
| Test Pressure (psig): | <u>5</u> | <u>5</u> | <u> </u> | <u>5</u> | <u> </u> |
| Test Medium: | <u>() Water (X) Air () Nitrogen () _____</u> | | | | |
| Test Specification: | <u>Test with air to 5 psi for min. of 2 hours -</u> <u>bubble check for leaks. PRE-Backfill</u> | | | | |

DESCRIPTION OF PIPELINE(S) TESTED

Location: Annulus of 6" HDPE Containment pipe between EW-7, EW-8,
Line Numbers: n/a including EW-13.
Portion of Line Tested: (X) All, or () _____
Remarks: None

Test Results: Pass ✓ Fail

I certify that the above information is correct and that the pipeline described above was prepared and tested in my presence in accordance with the Specification indicated above.

| | | | |
|-------------------|-----------------------------|--------------------------|----------------|
| Signed by | <u>[Signature]</u> | <u>Marcor</u> | <u>6/23/98</u> |
| | Contractor's Representative | Company | Date |
| Test Witnessed by | <u>[Signature]</u> | <u>Golder Associates</u> | <u>6/23/98</u> |
| | Owner's Representative | Company | Date |

PIPE TEST CERTIFICATE

| | <u>Initial Test Status</u> | <u>Interim Test Status</u> | <u>Interim Test Status</u> | <u>Final Test Status</u> | <u>Duration</u> |
|------------------------|--|------------------------------------|------------------------------------|----------------------------------|-----------------|
| Date/Time: | <u>7-14-97/1500</u> | _____ | _____ | <u>7-14-97/1700</u> | <u>2 HRS</u> |
| Temperature (Ambient): | <u>88°F</u> | _____ | _____ | <u>88°F</u> | _____ |
| Test Pressure (psig): | <u>75 PSI</u> | _____ | _____ | <u>75 PSI</u> | _____ |
| Test Medium: | <input checked="" type="checkbox"/> Water | <input type="checkbox"/> Air | <input type="checkbox"/> Nitrogen | <input type="checkbox"/> _____ | |
| Test Specification: | <u>PRESSURIZED TO 75 PSI - WATER PUMPED INTO 2" CARRIER</u> <u>PIPE AND PRESSURIZED - FOR 2 HOURS</u> <u>(POST-BACKFILL)</u> | | | | |

DESCRIPTION OF PIPELINE(S) TESTED

Location: 2" CARRIER PIPE FROM EW-7 TO EW-8 INCLUDING LINE TO EW-13

Line Numbers: EW-13 FROM EW-7 TO EW-8

Portion of Line Tested: All, or _____

Remarks: _____

Test Results: Pass Fail _____

I certify that the above information is correct and that the pipeline described above was prepared and tested in my presence in accordance with the Specification indicated above.

| | | | |
|-------------------|-----------------------------|--------------------------|----------------|
| Signed by | <u>[Signature]</u> | <u>Malcor</u> | <u>7/11/98</u> |
| | Contractor's Representative | Company | Date |
| Test Witnessed by | <u>[Signature]</u> | <u>Golder Associates</u> | <u>7/14/98</u> |
| | Owner's Representative | Company | Date |

PIPE TEST CERTIFICATE

| | <u>Initial Test Status</u> | <u>Interim Test Status</u> | <u>Interim Test Status</u> | <u>Final Test Status</u> | <u>Duration</u> |
|------------------------|--|------------------------------------|------------------------------------|----------------------------------|-----------------|
| Date/Time: | 7/14/98 - 1700 | _____ | _____ | _____ | 7/15/98 |
| Temperature (Ambient): | 88°F | _____ | _____ | _____ | _____ |
| Test Pressure (psig): | 5 PSI | _____ | _____ | 1.5 PSI | 24 HRS |
| Test Medium: | () Water | (X) Air | () Nitrogen | () _____ | |
| Test Specification: | PRESSURIZE TO 5 PSI AIR - 6" CONTAINMENT FOR 24 HOURS - (POST-BACKFILL) | | | | |

DESCRIPTION OF PIPELINE(S) TESTED

Location: ANNULUS OF 6" HDPE CONTAINMENT PIPE BETWEEN EW-7, EW-8, AND EW-13

Line Numbers: N/A

Portion of Line Tested: (X) All, or () _____

Remarks: None

Test Results: Pass _____ Fail X

I certify that the above information is correct and that the pipeline described above was prepared and tested in my presence in accordance with the Specification indicated above.

Signed by [Signature] GOLDER ASSOCIATES 7/15/98
Contractor's Representative Company Date

Test Witnessed by _____ 7/15/98
Owner's Representative Company Date

FN: PIPETEST.WK1

PIPE TEST CERTIFICATE

| | <u>Initial Test Status</u> | <u>Interim Test Status</u> | <u>Interim Test Status</u> | <u>Final Test Status</u> | <u>Duration</u> |
|------------------------|---|------------------------------------|------------------------------------|----------------------------------|-----------------|
| Date/Time: | <u>8/16/98 12:05</u> | <u>14:15</u> | <u>8/17/98 8:52</u> | <u>12:05</u> | <u>24 H</u> |
| Temperature (Ambient): | <u>80°F</u> | <u>80°F</u> | <u>70°F</u> | <u>70°F</u> | |
| Test Pressure (psig): | <u>5</u> | <u>5</u> | <u>5</u> | <u>5</u> | |
| Test Medium: | <input type="checkbox"/> Water <input checked="" type="checkbox"/> Air <input type="checkbox"/> Nitrogen <input type="checkbox"/> _____ | | | | |
| Test Specification: | <u>Pre-backfill Test (same spec. as post-backfill test)</u> <u>Test with air to 5 psi for 24 hours.</u> <u>No allowable drop.</u> | | | | |

DESCRIPTION OF PIPELINE(S) TESTED

Location: Annulus of 6" HDPE containment pipe between EW-7, EW-8, and EW-13

Line Numbers: N/A

Portion of Line Tested: All, or _____

Remarks: Retest of line after repairs due to failing previous post-backfill test.

Test Results: Pass Fail _____

I certify that the above information is correct and that the pipeline described above was prepared and tested in my presence in accordance with the Specification indicated above.

| | | | |
|-------------------|-----------------------------|----------------------|----------------|
| Signed by | <u>[Signature]</u> | <u>Maccor</u> | <u>8/17/98</u> |
| | Contractor's Representative | Company | Date |
| Test Witnessed by | <u>[Signature]</u> | <u>Golder Assoc.</u> | <u>8/17/98</u> |
| | Owner's Representative | Company | Date |

PIPE TEST CERTIFICATE

| | <u>Initial Test Status</u> | <u>Interim Test Status</u> | <u>Interim Test Status</u> | <u>Final Test Status</u> | <u>Duration</u> |
|------------------------|---|------------------------------------|------------------------------------|----------------------------------|-----------------|
| Date/Time: | 8/8/98 11:00 | 8/9/98 11:08 | | | 24 H |
| Temperature (Ambient): | 75°F | 75°-80°F | } | | |
| Test Pressure (psig): | 5 | 5 | } | | |
| Test Medium: | () Water | (X) Air | () Nitrogen | () _____ | |
| Test Specification: | <u>Post-backfill test</u> <u>Test with air to 5 psi for 24 hours.</u> <u>No allowable drop.</u> | | | | |

DESCRIPTION OF PIPELINE(S) TESTED

Location: Annulus of 6" HDPE containment pipe between EW-7, EW-8, and EW-13.

Line Numbers: N/A

Portion of Line Tested: (X) All, or () _____

Remarks: Retest of line after repairs due to failing previous post-backfill test.

Test Results: Pass Fail

I certify that the above information is correct and that the pipeline described above was prepared and tested in my presence in accordance with the Specification indicated above.

| | | | |
|-------------------|-----------------------------|----------------------|----------------|
| Signed by | <u>[Signature]</u> | <u>Marcor</u> | <u>8/10/98</u> |
| | Contractor's Representative | Company | Date |
| Test Witnessed by | <u>[Signature]</u> | <u>Golder Assoc.</u> | <u>8/10/98</u> |
| | Owner's Representative | Company | Date |

RECEIVED

NOV 13 1998

NYSDEC - REG. 9

REL UNREL

