



| | | |
|--|--|-------------------------|
|  | Daily Activity Report | |
| | 820 East 182nd Street | |
| | Bronx, NY | |
| BCP Site No. C203149 | | |
| General Site Information | | |
| Date: | Monday, February 27, 2023 | |
| Weather: | Sunny, 35° F | |
| Wind Direction/Speed: | Coming from North @ 4 mph | |
| AKRF Personnel on Site: | Jack Kelleher-Ferguson | |
| AKRF Equipment on Site: | Mini RAE 3000 Photoionization Detectors [(PID) x3] and DustTrak Aerosol Monitors (x3) | |
| Visitors: | Adrianna Bosco, AKRF | |
| Contractor Information | | |
| Subcontractor | | Service |
| Island Pump & Tank Corp. (IPT) East Northport, NY | | Tank removal contractor |
| Description and Location of Work Activities Performed | | |
| <p>IPT mobilized their equipment to the Site and marked out all belowgrade utilities prior to the start of work. IPT began to remove the concrete cap over the tank vault in the northwestern corner. The pump island piping and electrical lines were disconnected in preparation of future demoltion activities.</p> | | |
| CAMP Air Monitoring Results | | |
| CAMP Station | UPWIND | DOWNWIND |
| Odors: | None | None |
| VOC Action Level Exceedance(s): | None | None |
| Particulate Action Level Exceedance(s): | 1 | 1 |
| Maximum VOC Level (ppm) 15-min avg: | 0.2674 | 0.206 |
| Maximum Particulate Level (mg/m³) 15-min avg: | 0.1665 | 0.3640 |
| <p>CAMP Response Actions: Particulate exceedances occurred immediately after both the upwind and downwind stations were assembled and connected to the telemetry system. AKRF determined that the elevated levels were not caused by work activities, but from the stations being setup at the beginning of the workday.</p> | | |
| Additional Information | | |
| Planned Work Activity for Next Day/Week: | Removal of gasoline and waste oil USTs, associated piping, and any grossly contaminated fill/soil. | |
| Comments: | None | |



© 2022 AKRF. W:\Projects\210138 - 820 East 182nd Street\Technical\GIS and Graphics\Hazmat\RMWP\210138 Fig 2 Site Plan.mxd 4/25/2022 10:53:39 AM iszaus



440 Park Avenue South, New York, NY 10016

820 East 182nd Street
Bronx, New York

SITE PLAN

DATE

4/25/2022

PROJECT NO.

210138

FIGURE

2

Upwind CAMP Station Data

02/27/2023 0:00:10 – 02/28/2023 0:00:00
(GMT-05:00) Eastern Time (US & Canada)



Mass Conc. Total mg/m³ AVG 15m
mg/m³
DustTrak-8530
RS232(C)

| MIN | AVG | MAX |
|--------|--------|--------|
| 0.0101 | 0.0321 | 0.1665 |

VOC ppm AVG 15m ppm
miniRAE 3000
RS232(B)


| MIN | AVG | MAX |
|-------|--------|--------|
| 0.011 | 0.1836 | 0.2674 |

Name 182 st UW
S/N 0B120565
Description FA02973
Location Southern Blvd/E 182 St,
The Bronx, NY 10460,
USA

© Netronix 2022

Downwind CAMP Station Data

02/27/2023 0:00:30 – 02/28/2023 0:00:00
(GMT-05:00) Eastern Time (US & Canada)



Mass Conc. Total mg/m³ AVG 15m
mg/m³
DustTrak-8530
RS232(C)

| MIN | AVG | MAX |
|--------|--------|--------|
| 0.0115 | 0.0308 | 0.3638 |

VOC ppm AVG 15m ppm
miniRAE 3000
RS232(A)

| MIN | AVG | MAX |
|-------|--------|--------|
| 0.023 | 0.1337 | 0.2062 |

Name 182 St DW
S/N 0B352750
Description FA04956
Location Southern Blvd/E 182 St,
The Bronx, NY 10460,
USA

© Netronix 2022

Site Photographs

Photograph 1 - IPT removing concrete over the tank vault to gain access to the tanks.



Photograph 2 - IPT checking the depth of the waste oil tank and for any residual oil.



Photograph 3 - Marking out belowgrade utilities at the Site.

