

## SITE OBSERVATION REPORT

<b>PROJECT No.:</b> 170747001  <b>PROJECT:</b> C224398 – 1709 Surf Avenue  <b>LOCATION:</b> 1709 Surf Avenue, Brooklyn, New York	<b>CLIENT:</b> Coney Island Associates Phase 3 LLC c/o BFC Partners	<b>DATE:</b> Thu, May 29, 2025  <b>WEATHER:</b> Cloudy, 55-68°F Wind: NNE at 1-9 mph  <b>TIME:</b> 6:50am to 3:45pm
<b>CONTRACTOR'S EQUIPMENT:</b> Doosan DL 300 Loader Doosan DX300LC Excavator Bobcat S590 Skid Steer Bobcat E45 Mini Excavator CAT 345C Excavator CAT 350L Excavator	<b>PRESENT AT SITE:</b> <b>RAWP Implementation Day 51</b> Environmental (Langan) – Michael Pinnella General Contractor (BFC Construction) Foundation Contractor (Precise Contracting [Precise]) Deep Foundation Contractor (RYC Turbos Corp.)	
<b>OBSERVATIONS, DISCUSSIONS, TEST RESULTS, ETC.:</b>  Langan was present to oversee implementation of the November 20, 2024 Remedial Action Work Plan (RAWP) for Brownfield Cleanup Program (BCP) Site No. C224398 at 1709 Surf Avenue. Observed activities were as follows:  <b>Site Activities</b> <ul style="list-style-type: none"> <li>Precise excavated an about 30-foot-long by 30-foot-wide by 6-foot-deep area and an about 15-foot-long by 40-foot-wide by 1-foot-deep area in the southern part of the site. Excavated material consisted of non-hazardous fill/soil and was screened for staining, odors, and instrumental evidence of contamination using a handheld photoionization detector (PID); staining, a petroleum-like odor, and a maximum PID reading of 415.6 parts per million (ppm) was observed in the 1-foot-deep excavation, and a petroleum-like odor and a maximum PID reading of 3.5 ppm was observed in the 6-foot-deep excavation. Non-hazardous soil/fill was stockpiled in the southern part of the site for future offsite disposal. The stockpiles were covered with polyethylene sheeting at the end</li> <li>Precise loaded previously excavated soil/fill into permitted triaxle trucks from stockpiles in the southern part of the site for offsite disposal at Clean Earth of Carteret in Carteret, New Jersey.</li> <li>Precise backfilled an about 10-foot-long by 10-foot-wide area from 6 feet bgs to grade in the eastern part of the site with newly imported Pipe Sand from Braen Stone of Sparta located in Sparta, New Jersey.</li> <li>Precise continued dewatering through the temporary dewatering system, consisting of shallow wells and carbon filter pre-treatment, in accordance with the Wastewater Discharge State Pollutant Discharge Elimination System (SPDES) Permit Equivalent and Long Island Well Permit Equivalence to facilitate remedial excavation. Groundwater was pumped into the settling tank and continued through the two carbon pre-treatment tanks within the system. Groundwater was discharged into the sanitary-sewer along W17<sup>th</sup> Street in accordance with the New York City Department of Environmental Protection (NYCDEP) permit C003671447. 4 of the workday.</li> <li>Precise imported unapproved NJDOT #4 (1.5-inch) stone from Braen Stone of Sparta located in Sparta, New Jersey. The stone was temporarily backfilled in an about 30-foot-long by 30-foot wide by 2-foot-deep area in the southern part of the site as part of construction of a dewatering sump. Langan notified the contractor that</li> </ul>		
<b>Cc:</b> B. Gochenaur, K. Semon, M. Aronica (Langan)	<b>By:</b> Michael Pinnella  <b>LANGAN</b>	

## SITE OBSERVATION REPORT

documentation supporting stone approval must be submitted or the stone will need to be removed from the site. Receipt of documentation is pending.

### **Sampling**

- No samples were collected.

### **CAMP Activities**

- Langan performed community air monitoring at the perimeter of the site at two locations (one downwind and one upwind) and included air monitoring for particulate matter for particulates less than 10 µm in diameter (PM10) and volatile organic compounds (VOC). Particulate and VOC concentrations did not exceed the action levels established in the site Community Air Monitoring Program (CAMP). Fugitive dust or odors associated with intrusive activities were not observed.

### **Anticipated Activities**

- Precise will continue site wide excavation and offsite disposal of non-hazardous fill/soil.
- Precise will continue to import approved backfill.
- Langan will continue to collect endpoint and sidewall samples from remedial subgrade across the site.

Cc:	B. Gochenaur, K. Semon, M. Aronica (Langan)	By:	Michael Pinnella
			LANGAN

## SITE OBSERVATION REPORT

### Material Tracking

- Three truckloads of pipe sand were imported from Braen Stone of Sparta located in Sparta, New Jersey
- One truckload of NJDOT #4 (1.5-inch) stone was imported from Braen Stone of Sparta located in Sparta, New Jersey.
- Fifteen truckloads of non-hazardous soil/fill were exported to Clean Earth of Carteret in Carteret, New Jersey

#### MATERIALS EXPORT SUMMARY

Facility Name	Clean Earth Carteret		Clean Earth Carteret		Clean Earth New Castle	
Location	Carteret, New Jersey		Carteret, New Jersey		New Castle, Delaware	
Type of Material	Non-hazardous fill/soil - Standard		Non-hazardous fill/soil - Elevated		Non-hazardous fill/soil	
Today	Number of Loads	Approx. Volume (CY)	Number of Loads	Approx. Volume (CY)	Number of Loads	Approx. Volume (CY)
	15	300	0	0	0	0
Total	Number of Loads	Approx. Volume (CY)	Number of Loads	Approx. Volume (CY)	Number of Loads	Approx. Volume (CY)
	278	5,560	26	520	73	1,460

#### MATERIALS IMPORT SUMMARY

Facility Name	Braen Aggregates, LLC					
Location	Franklin, New Jersey			Sparta, New Jersey		
Type of Material	NJDOT #3 (2.5-inch) stone		Pipe Sand		Unapproved NJDOT #4 (1.5-inch) stone	
Today	Number of Loads	Approx. Volume (Tons)	Number of Loads	Approx. Volume (Tons)	Number of Loads	Approx. Volume (Tons)
	0	0	3	52.57	1	18.65
Total	Number of Loads	Approx. Volume (Tons)	Number of Loads	Approx. Volume (Tons)	Number of Loads	Approx. Volume (Tons)
	2	37.84	7	122.86	1	18.65
NYSDEC Approval Quantity (CY)		500	4,300		N/A	


Cc: B. Gochenaur, K. Semon, M. Aronica (Langan)

By: Michael Pinnella

**LANGAN**

SITE OBSERVATION REPORT

FIGURE 1: SITE PLAN



Cc:	B. Gochenaur, K. Semon, M. Aronica (Langan)	By:	Michael Pinnella
			LANGAN

SITE OBSERVATION REPORT

FIGURE 2: ENDPOINT/SIDEWALL SAMPLE LOCATION MAP



- Legend**
- Approximate Site Boundary
  - Excavation to about 2 feet bgs
  - Excavation to about 3 feet bgs
  - Excavation to about 4 feet bgs
  - Excavation to about 5 feet bgs
  - Excavation to about 6 feet bgs
  - Excavation to about 16 feet bgs to Remove Petroleum Impacts
  - Proposed Endpoint Sample Location
  - Proposed Sidewall Sample Location
- Endpoint/Sidewall Sample(s) Collected Since Last Report
- Previously Collected Endpoint/Sidewall Samples
- Endpoint/Sidewall Sample(s) Re-collected Since Last Report

Cc:	B. Gochenaur, K. Semon, M. Aronica (Langan)	By:	Michael Pinnella
			LANGAN

SITE OBSERVATION REPORT

SITE PHOTOGRAPHS



**Photo 1:** Precise loading non-hazardous fill/soil for offsite disposal in the southern part of the site (facing northeast).

Cc:	B. Gochenaur, K. Semon, M. Aronica (Langan)	By:	Michael Pinnella
			LANGAN